

5099

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Barrier Reef		BOWEN TAFE CAMPUS	BOWEN TAFE CAMPUS		32621003	WORKSHOP	WORKSHOP	Internal	Ground Floor	POWER BOARD	BACKING BOARD TO SWITCHBOARD, SAMPLE WS:1334	Insulation/Fill	Polymer Based	CHR - Chrysotile	4	Confirmed	25	-	
Barrier Reef		BOWEN TAFE CAMPUS	BOWEN TAFE CAMPUS		32621003	WORKSHOP	WORKSHOP	Internal	Ground Floor	LOFT STORE	WALL SHEETING, SIMILAR TO SAMPLE WS:1335 (MIX)	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		BOWEN TAFE CAMPUS	BOWEN TAFE CAMPUS		32621003	WORKSHOP	WORKSHOP	Internal	Ground Floor	LOFT STORE	CEILING SHEETING TO LOFT INCLUDING UNDERSIDE OF LOFT, SAMPLE WS:1335	Ceiling	Cement Based	Mixed	4	Confirmed	18	-	
Barrier Reef		BOWEN TAFE CAMPUS	BOWEN TAFE CAMPUS		32621003	WORKSHOP	WORKSHOP	External	Various levels External	WORKSHOP EXTERNAL	AC VENT PIPE	Drains/Pipes/Floor	Cement Based		4	Presumed	18	-	
Barrier Reef		BOWEN TAFE CAMPUS	BOWEN TAFE CAMPUS		32621004	OFFICE BLOCK	OFFICE BLOCK	Internal	Ground Floor	INTERNAL	CEILING SHEETS TO THE OFFICE BLOCK	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BOWEN TAFE CAMPUS	BOWEN TAFE CAMPUS		32621006	STORE SHED	STORE SHED	External	Various levels External	GABLE ENDS	GABLE ENDS TO STORE SHED, SAMPLE WS:1332	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Barrier Reef		BOWEN TAFE CAMPUS	BOWEN TAFE CAMPUS		32621006	TOILETS	TOILETS	External	Various levels External	TOILETS EXTERNAL	VENT PIPE, SIM SAMPLE WS:1333 (CHR C)	Drains/Pipes/Floor	Cement Based		4	Presumed	18	-	
Barrier Reef		BOWEN TAFE CAMPUS	BOWEN TAFE CAMPUS		32621006	TOILETS	TOILETS	External	Various levels External	EXTERNAL	EXTERNAL WALL SHEET SAMPLE WS:1333	Wall	Cement Based	Mixed	4	Confirmed	18	-	
Barrier Reef		BOWEN TAFE CAMPUS	BOWEN TAFE CAMPUS	UBO	32621000	SITE	SITE	External	Site / Grounds	EXTERNAL	LOOSE DEBRIS OUTSIDE THE ENTRY TO THE SITE OFFICE (STEP TREADS)	Debris	Cement Based	Mixed	3	Confirmed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE		24932001	COVERED WALKWAYS	COVERED WALKWAYS	External	Ground Floor	COVERED WALKWAY	NO ASBESTOS DETECTED IN THIS STRUCTURE	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBA	24932000	" Site Grounds	" Site Grounds										-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBA02		Flammable Store	Flammable Store										-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBA03		Plant	Plant										-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBA04		Carport	Carport										-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBA05		Store	Store										-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAAA		A Block	A Block	External	Ground Floor	WALKWAY	SHEETING TO CEILING OF WALKWAY BETWEEN MALE & FEMALE TOILETS	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAAA		A Block	A Block	Internal	Ground Floor	AC PLANT ROOM SOUTH	SHEET INFILL PANEL TO DUCT WORK GOING THROUGH BLOCK WALL IN AC PLANT ROOM SOUTH SIDE (ADMINISTRATION)	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAAA		A Block	A Block	Internal	Ground Floor	MALE/FEMALE STAFF TOILETS	VILLABOARD SHEETING TO CEILING IN MALE AND FEMALE STAFF TOILETS (ADMINISTRATION)	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAAA		A Block	A Block	Internal	Ground Floor	MALE & FEMALE TOILETS	SHEETING TO CEILING THROUGHOUT MALE AND FEMALE TOILET BLOCKS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAAA		A Block	A Block	Internal	Ground Floor	INTERNAL	SHEETING TO DUCT WORK IN CANTEN	Insulation/Fill	Cement Based		4	Presumed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAAA		A Block	A Block	Internal	Ground Floor	INT. WINDOW SILLS	COMPRESSED SHEET WINDOW SILLS THROUGHOUT (ADMINISTRATION)	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAAA		A Block	A Block	Internal	Ground Floor	INT. INFILL PANELS	SHEET INFILL PANELS ABOVE BLOCK WALLS	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAAA		A Block	A Block	Internal	Ground Floor	HALLWAY (LIBRARY TO ADMIN)	SHEETING TO PARTITION WALLS IN HALLWAY FROM LIBRARY TO ADMIN OFFICES	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAAA		A Block	A Block	Internal	Ground Floor	CANTEEN KITCHEN & CLEANER'S ROOM	VILLABOARD SHEETING TO CEILING OF CANTEN KITCHEN AND CLEANER'S ROOM	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAAA		A Block	A Block	External	Ground Floor	SOFFITS	SHEETING TO SOFFITS AND BREEZEWAY CEILING ALL ROUND (ADMINISTRATION)	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAAA		A Block	A Block	External	Ground Floor	SOFFITS	SHEETING TO SOFFITS	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAAA		A Block	A Block	External	Ground Floor	SIGNS	COMPRESSED SHEET BUILDING AND ROOM ID SIGNS (ADMINISTRATION)	Sign	Cement Based		4	Removed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAAA		A Block	A Block	External	Ground Floor	OPEN AREA	SHEETING TO CEILING OF OPEN AREA BETWEEN CANTEN AND TOILETS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAAA		A Block	A Block	External	Ground Floor	FASCIA	SHEETING TO FASCIA ALL ROUND SIM SAMPLE 3760	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAAA		A Block	A Block	External	Ground Floor	FASCIA	SHEETING TO FASCIA	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAAA		A Block	A Block	External	Ground Floor	EXTERNAL	COMPRESSED SHEET DOWNPIPES AND RAIN HEADS (ADMINISTRATION)	Drains/Pipes/Floor	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAAA		A Block	A Block	Internal	Ground Floor	AC PLANT ROOM SOUTH	VILLABOARD SHEETING TO CEILING IN AC PLANT ROOM SOUTH SIDE (ADMINISTRATION)	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBABB	24932008	B Block	B Block	External	Ground Floor	SOFFITS	SHEETING TO SOFFITS	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBABB	24932008	B Block	B Block	Internal	Ground Floor	THROUGHOUT	SPRAYED MATERIAL TO CEILING THROUGHOUT	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBABB	24932008	B Block	B Block	Internal	Ground Floor	ROOM B1 2.3 & MALE TOILETS	SHEETING TO INTERNAL WALLS OF SKYLIGHTS IN ROOMS NO. B.1 2.3 AND MALE TOILETS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBABB	24932008	B Block	B Block	Internal	Ground Floor	ROOM B1 2.3 & MALE TOILETS	SHEETING TO CEILINGS OF SKYLIGHTS IN ROOMS B.1 2.3 AND MALE TOILETS	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBABB	24932008	B Block	B Block	Internal	Ground Floor	OLD DARK ROOM	VILLABOARD SHEETING TO CEILING OF OLD DARK ROOM USED AS STORE ROOM	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBABB	24932008	B Block	B Block	External	Ground Floor	INT. WINDOW SILLS	COMPRESSED SHEET WINDOW SILLS THROUGHOUT	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBABB	24932008	B Block	B Block	External	Ground Floor	SIGNS	COMPRESSED SHEET BLOCK AND ROOM ID SIGNS SIMILAR TO SAMPLE 3721 (CHR)	Sign	Cement Based		4	Removed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBABB	24932008	B Block	B Block	External	Ground Floor	EXTERNAL	COMPRESSED SHEET DOWNPIPES AND RAIN HEADS	Drains/Pipes/Floor	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBABB	24932008	B Block	B Block	Internal	Ground Floor	MALE & FEMALE TOILETS	VILLABOARD SHEETING TO CEILING OF MALE AND FEMALE TOILETS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBACC	24932007	C Block	C Block	Internal	Ground Floor	KILN AREA	SHEETING TO WALLS OF WARD KILN IN KILN AREA	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBACC	24932007	C Block	C Block	Internal	Ground Floor	WORK BENCHES	COMPRESSED SHEET TO TOP AND SHELF OF WORK BENCHES	Furniture	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBACC	24932007	C Block	C Block	External	Ground Floor	KILN ROOM NORTHERN SIDE	SHEETING TO WALLS OF KILN IN EXTERIOR KILN ROOM NORTH SIDE OF BUILDING	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBACC	24932007	C Block	C Block	External	Ground Floor	SIGNS	COMPRESSED SHEET BLOCK AND ROOM ID SIGNS	Sign	Cement Based		4	Removed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBACC	24932007	C Block	C Block	External	Ground Floor	SOFFITS	SHEETING TO SOFFITS	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBACC	24932007	C Block	C Block	Internal	Ground Floor	INT. WINDOW SILLS	COMPRESSED SHEET TO WINDOW SILLS THROUGHOUT	Wall	Cement Based		4	Presumed	18	-	

TAFES from BEMIR-TAFES

Current as at 10-May-11

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBACC	24932007	C Block	C Block	Inter nal	Ground Floor	KILN ROOM	SHEETING TO CEILING ABOVE ROLLER DOOR IN KILN ROOM	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBACC	24932007	C Block	C Block	Inter nal	Ground Floor	THROUGHOUT	SHEET TO WALLS ABOVE BLOCK WALLS AND PERFORATED WALL SHEETING THROUGHOUT	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBACC	24932007	C Block	C Block	Inter nal	Ground Floor	CLASSROOMS EAST & WEST	SPRAYED MATERIAL TO CEILINGS IN CLASS ROOMS EAST & WEST ENDS OF BUILDING	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBADD	24932006	D Block	D Block	Exter nal	Ground Floor	OFFICE IN DEPOT STORE	SHEETING TO INTERNAL AND EXTERNAL WALLS OF OFFICE IN DEPOT STORE	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBADD	24932006	D Block	D Block	Exter nal	Ground Floor	SIGNS	COMPRESSED SHEET BLOCK AND ROOM ID SIGNS	Sign	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBADD	24932006	D Block	D Block	Exter nal	Ground Floor	SIGNS	DUPICATE ENTRY - COMPRESSED SHEET BLOCK AND ROOM ID SIGNS SIMILAR TO SAMPLE 3737 (CHR)	Sign	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBADD	24932006	D Block	D Block	Exter nal	Ground Floor	SOFFITS	SHEETING TO SOFFITS	Gable/Soffit/F ascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBADD	24932006	D Block	D Block	Inter nal	Ground Floor	COMMON & MAINT ROOMS	VILLABOARD SHEETING TO CEILING IN COMMON ROOM AND MAINTENANCE ROOM	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBADD	24932006	D Block	D Block	Inter nal	Ground Floor	INT. INFILL PANELS	SHEET INFILL PANELS ABOVE BLOCK WALLS THROUGHOUT	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBADD	24932006	D Block	D Block	Inter nal	Ground Floor	OFFICE D1.05	SHEETING TO THE CEILING OF THE DEPOT OFFICE D1.05	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBADD	24932006	D Block	D Block	Inter nal	Ground Floor	OFFICE IN DEPOT STORE	SHEETING TO CEILING OF OFFICE IN DEPOT STORE SIMILAR TO SAMPLE 3736 (CHR)	Ceiling	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBADD	24932006	D Block	D Block	Inter nal	Ground Floor	ROOM D1.03	CEILING SHEETING TO THE COMMON ROOM AND MAINTENANCE ROOM D1.03	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBADD	24932006	D Block	D Block	Inter nal	Ground Floor	ROOM D1.03	COMPRESSED SHEET TO BENCH TOPS AND SHELVES IN MAINTENANCE ROOM D1.03	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAEE	24932005	E Block	E Block	Inter nal	Ground Floor	FLAM LIQUID STR	NO ASBESTOS DETECTED IN THIS BUILDING	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAEE	24932005	E Block	E Block	Exter nal	Ground Floor	EXTERNAL	COMPRESSED SHEET DOWNPIPES AND RAIN WATER HEADS	Drains/Pipes/F lues	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAEE	24932005	E Block	E Block	Exter nal	Ground Floor	SOFFIT	SHEETING TO SOFFIT AND ENTRY WALKWAY CEILINGS	Gable/Soffit/F ascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAEE	24932005	E Block	E Block	Inter nal	Ground Floor	INT. WINDOW SILLS	COMPRESSED SHEET WINDOW SILLS THROUGHOUT	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAEE	24932005	E Block	E Block	Inter nal	Ground Floor	MAINT. SHOP	SHEETING STORED ON SHELVES IN OPEN STORAGE AREA ADJACENT TO MAINT/FITTER WORKSHOP	Stored Material	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAEE	24932005	E Block	E Block	Inter nal	Ground Floor	MAINT. SHOP	SHEETING TO CEILING THROUGHOUT MAINTENANCE FITTERS WORKSHOP & COMPRESSOR ROOM	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAEE	24932005	E Block	E Block	Inter nal	Ground Floor	ROOM E108 WORKSHOP	COMPRESSED SHEET BENCH TOPS TO WORKSHOP WEST END OF BUILDING ROOM NO. E108	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAEE	24932005	E Block	E Block	Inter nal	Ground Floor	ROOMS E102, E103 & E107	SPRAYED MATERIAL TO CEILING OF CLASS ROOMS E102, E103 E106 AND E107	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAEE	24932005	E Block	E Block	Inter nal	Ground Floor	THROUGHOUT	SHEETING TO WALLS ABOVE BLOCK WALLS AND PERFORATED	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAEE	24932005	E Block	E Block	Inter nal	Ground Floor	WELDING BAY CUB	COMPRESSED SHEET TO WELDING BAY CUBICLES	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAEE	24932005	E Block	E Block	Inter nal	Ground Floor	MAINT. SHOP	PIECES OF C.S. STORED ON SHELVING IN OPEN STORAGE AREA ADJ MAINT/FITTER WORKSHOP	Stored Material	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAEE	24932005	E Block	E Block	Exter nal	Ground Floor	SIGNS	COMPRESSED SHEET BUILDING ID SIGN SIMILAR TO SAMPLE 3748	Sign	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAFF	24932004	F Block	F Block	Exter nal	Ground Floor	EXTERNAL	COMPRESSED SHEET DOWNPIPES AND RAIN HEADS	Drains/Pipes/F lues	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAFF	24932004	F Block	F Block	Inter nal	Ground Floor	VARIOUS ROOMS	SHEETING TO CEILING IN FIRST AID ROOM COMMON ROOM & CLEANERS ROOM	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAFF	24932004	F Block	F Block	Inter nal	Ground Floor	SWITCH & TRANSFORMER ROOMS	SPRAYED MATERIAL TO CEILINGS IN MAIN SWITCH ROOM AND TRANSFORMER ROOM	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAFF	24932004	F Block	F Block	Inter nal	Ground Floor	STOREROOMS	VILLABOARD SHEETING TO CEILING OF STORE ROOMS BETWEEN CLASS ROOMS	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAFF	24932004	F Block	F Block	Exter nal	Ground Floor	SOFFITS	SHEETING TO SOFFITS AND ENTRANCE TO CLASS ROOMS	Gable/Soffit/F ascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Barrier Reef		BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	BURDEKIN TAFE CAMPUS - 28 SIXTH AVENUE	UBAFF	24932004	F Block	F Block	Inter nal	Ground Floor	INT. WINDOW SILLS	COMPRESSED SHEET WINDOW SILLS THROUGHOUT	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Barrier Reef		CANNONVALE TAFE CAMPUS	CANNONVALE TAFE CAMPUS	29782000		SITE	SITE	Exter nal	Ground Floor	SITE	BUILT AFTER 1990	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Barrier Reef		CANNONVALE TAFE CAMPUS	CANNONVALE TAFE CAMPUS	29782006		Covered Way - Joins Blks A & E	Covered Way - Joins Blks A & E	Exter nal	Ground Floor	Covered Way - Joins Blks A & E	BUILT AFTER 1990	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Barrier Reef		CANNONVALE TAFE CAMPUS	CANNONVALE TAFE CAMPUS	29782007		Covered Way - Joins Blks A & B	Covered Way - Joins Blks A & B	Exter nal	Ground Floor	Covered Way - Joins Blks A & B	BUILT AFTER 1990	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Barrier Reef		CANNONVALE TAFE CAMPUS	CANNONVALE TAFE CAMPUS	29782008		Covered Way - Joins Blks B & C	Covered Way - Joins Blks B & C	Exter nal	Ground Floor	Covered Way - Joins Blks B & C	BUILT AFTER 1990	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Barrier Reef		CANNONVALE TAFE CAMPUS	CANNONVALE TAFE CAMPUS	29782009		Covered Way - Adjacent Blk B (1)	Covered Way - Adjacent Blk B (1)	Exter nal	Ground Floor	Covered Way - Adjacent Blk B (1)	BUILT AFTER 1990	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Barrier Reef		CANNONVALE TAFE CAMPUS	CANNONVALE TAFE CAMPUS	29782010		Covered Way - Adjacent Blk B (2)	Covered Way - Adjacent Blk B (2)	Exter nal	Ground Floor	Covered Way - Adjacent Blk B (2)	BUILT AFTER 1990	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Barrier Reef		CANNONVALE TAFE CAMPUS	CANNONVALE TAFE CAMPUS	29782011		Covered Way - Joins Blks A, E, D, C & B	Covered Way - Joins Blks A, E, D, C & B	Exter nal	Ground Floor	Covered Way - Joins Blks A, E, D, C & B	BUILT AFTER 1990	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Barrier Reef		CANNONVALE TAFE CAMPUS	CANNONVALE TAFE CAMPUS	29782012		Covered Way - Joins Blks C & D	Covered Way - Joins Blks C & D	Exter nal	Ground Floor	Covered Way - Joins Blks C & D	BUILT AFTER 1990	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Barrier Reef		CANNONVALE TAFE CAMPUS	CANNONVALE TAFE CAMPUS	29782013		Covered Way - Joins Blks D & E	Covered Way - Joins Blks D & E	Exter nal	Ground Floor	Covered Way - Joins Blks D & E	BUILT AFTER 1990	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Barrier Reef		CANNONVALE TAFE CAMPUS	CANNONVALE TAFE CAMPUS	29782014		Kiln Shed	Kiln Shed	Exter nal	Ground Floor	Kiln Shed	BUILT AFTER 1990	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Barrier Reef		CANNONVALE TAFE CAMPUS	CANNONVALE TAFE CAMPUS	UCVAA	29782001	A Block	A Block	Exter nal	Ground Floor	Block A - Administration & Teaching	BUILT AFTER 1990	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Barrier Reef		CANNONVALE TAFE CAMPUS	CANNONVALE TAFE CAMPUS	UCVBB	29782002	B Block	B Block	Exter nal	Ground Floor	Block B - Hospitality Building	BUILT AFTER 1990	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Barrier Reef		CANNONVALE TAFE CAMPUS	CANNONVALE TAFE CAMPUS	UCVBB	29782002	B Block	B Block	Inter nal	Ground Floor	Restaurant	INSULATION - BAKERS OVEN	Insulation/Fill	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	

TAFEs from BEMIR-TAFEs

Current as at 10-May-11

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Barrier Reef		CANNONVALE TAFE CAMPUS	CANNONVALE TAFE CAMPUS	UCVCC	29782003	C Block	C Block	External	Ground Floor	Block C - College Store / Student Dining	BUILT AFTER 1990	Baffles/Lining	Other (refer to description)		3	Presumed		-	
Barrier Reef		CANNONVALE TAFE CAMPUS	CANNONVALE TAFE CAMPUS	UCVDD	29782004	D Block	D Block	External	Ground Floor	Block D - Toilet Block	BUILT AFTER 1980	Baffles/Lining	Other (refer to description)		3	Presumed		-	
Barrier Reef		CANNONVALE TAFE CAMPUS	CANNONVALE TAFE CAMPUS	UCVEE	29782005	E Block	E Block	External	Ground Floor	Block E - Voids Linq	BUILT AFTER 1990	Baffles/Lining	Other (refer to description)		3	Presumed		-	
Barrier Reef		CHARTERS TOWERS TAFE CAMPUS	CHARTERS TOWERS TAFE CAMPUS	29562000	29562000	** Site Grounds	** Site Grounds											-	
Barrier Reef		INGHAM TAFE CAMPUS - 74 TOWNSVILLE ROAD	INGHAM TAFE CAMPUS - 74 TOWNSVILLE ROAD	UIN	37267000	** Site - Grounds	** Site - Grounds											-	
Barrier Reef		INGHAM TAFE CAMPUS - 74 TOWNSVILLE ROAD	INGHAM TAFE CAMPUS - 74 TOWNSVILLE ROAD	UINAA	37267001	A Block	A Block	External	Ground Floor	THROUGHOUT	BUILT AFTER 1990	Baffles/Lining	Other (refer to description)		3	Presumed		-	
Barrier Reef		PALM ISLAND TAFE CAMPUS	PALM ISLAND TAFE CAMPUS	UPI	44084000	** Site Grounds	** Site Grounds											-	
Barrier Reef		PALM ISLAND TAFE CAMPUS	PALM ISLAND TAFE CAMPUS	UPI01		Store	Store	External	Ground Floor	STORE	STORE	Wall	Cement Based		3	Presumed	18	-	
Barrier Reef		PALM ISLAND TAFE CAMPUS	PALM ISLAND TAFE CAMPUS	UPIAA		A Block	A Block	External	Ground Floor	A BLOCK	A BLOCK	Wall	Cement Based		3	Presumed	18	-	
Barrier Reef		PALM ISLAND TAFE CAMPUS	PALM ISLAND TAFE CAMPUS	UPIBB		B Block	B Block	External	Ground Floor	B BLOCK	B BLOCK	Wall	Cement Based		3	Presumed	18	-	
Barrier Reef		PALM ISLAND TAFE CAMPUS	PALM ISLAND TAFE CAMPUS	UPINN		N Block	N Block	External	Ground Floor	N BLOCK	N BLOCK	Wall	Cement Based		3	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UPHOUSE	29919008	Caretakers Residence	Caretakers Residence											-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTP	29919000	SITE/GROUNDS	SITE/GROUNDS	Internal	Ground Floor	OFFICE	ALL WALLS OF THIS OFFICE	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTP05		Groundsmans Shed	Groundsmans Shed											-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTP06		Fuel Store	Fuel Store											-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTP07		Store	Store											-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTP08	29918007	Brick Laying	Brick Laying	Internal	Ground Floor	Substation								-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTP12	29919002	Roof Laying	Roof Laying											-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTP13		Roof Laying	Roof Laying											-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTP14		Fuel Store	Fuel Store											-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTP16		Fuel Store	Fuel Store											-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTP17		Greenhouse	Greenhouse											-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTP18		Greenhouse	Greenhouse											-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTP19		Greenhouse	Greenhouse											-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPAA	29919005	BLOCK A	A Block	External	Ground Floor	VERANDAH	ALL VERANDAH WALLS ARE SUSPECTED AC SHEETING	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPAA	29919005	BLOCK A	A Block	External	Level 1	VERANDAH	EXTERIOR WALLS OF THE 1ST FLOOR VERANDAH	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPAA	29919005	BLOCK A	A Block	Internal	Ground Floor	MAIL ROOM	MAIL ROOM CEILING	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPAA	29919005	BLOCK A	A Block	Internal	Ground Floor	ROOM 1.01	CEILING OF ROOM 1.01	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPAA	29919005	BLOCK A	A Block	Internal	Ground Floor	ROOM A 1.04	CEILING OF ROOM A 1.04	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPAA	29919005	BLOCK A	A Block	Internal	Ground Floor	ROOM A 1.05	CEILING OF ROOM A 1.05	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPAA	29919005	BLOCK A	A Block	Internal	Ground Floor	ROOM A1.04	FLOOR TILES IN THIS ROOM MAY CONTAIN ASBESTOS FURTHER TESTING IS REQUIRED	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	2	Not Present(Not Tested)	24	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPAA	29919005	BLOCK A	A Block	Internal	Ground Floor	TOILETS M & F	CEILING OF BOTH MAIL AND FEMALE TOILETS	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPAA	29919005	BLOCK A	A Block	Internal	Level 1	ROOM A 2.08	CEILING OF ROOM A 2.08	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPAA	29919005	BLOCK A	A Block	Internal	Level 1	ROOM A 2.09	CEILING OF ROOM A 2.09	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPAA	29919005	BLOCK A	A Block	Internal	Level 1	ROOM A2.01	ALL WALLS OF ROOM A2.01	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPBB	29919010	BLOCK B	B Block	Internal	Ground Floor	ROOM B1.04	WALL OF ROOM B1.04 ARE SUSPECTED OF BEING AC	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPBB	29919010	BLOCK B	B Block	Internal	Level 1	ROOM B2.17 COPIER ROOM	FLOOR TILES IN COPIER ROOM MAY CONTAIN ASBESTOS TESTING IS REQUIRED TO CONFIRM	Floor Finish/Covering	Vinyl Tiles		3	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPBB	29919010	BLOCK B	B Block	Internal	Ground Floor	ROOM B1.07	WALL OF ROOM B1.07 ARE SUSPECTED OF BEING AC	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPBB	29919010	BLOCK B	B Block	Internal	Ground Floor	ROOM B1.09	FLOOR TILES IN ROOM B1.09 MAY CONTAIN ASBESTOS ADDITIONAL SAMPLING REQUIRED TO CONFIRM	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPCC	29919004	BLOCK C	C Block	Internal	Ground Floor	ROOM C1.05	ALL WALLS OF THIS ROOM	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPCC	29919004	BLOCK C	C Block	Internal	Ground Floor	ROOM C1.05	VINYL TILES THROUGHOUT ROOM C1.05	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPCC	29919004	BLOCK C	C Block	Internal	Level 1	ROOM C2.08	VINYL TILES THROUGHOUT ROOM C2.08	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPCC	29919004	BLOCK C	C Block	Internal	Level 1	ROOM C2.09	VINYL TILES THROUGHOUT ROOM C2.09	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPCC	29919004	BLOCK C	C Block	Internal	Level 1	ROOM C2.11	FLOOR TILES IN THIS ROOM MAY CONTAIN ASBESTOS FURTHER TESTING IS REQUIRED	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPDC	29919029	Child Care	Child Care											-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPDD	29919006	BLOCK D	D Block	Internal	Level 1	TOILETS M & F	CLEVELAND BAR TOILET WALLS BOTH MALE AND FEMALE	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPDD	29919006	BLOCK D	D Block	Internal	Level 3	PLANT ROOM	PLANT ROOM FIRE DOORS	Fire Door	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPDD	29919006	BLOCK D	D Block	External	Various levels	SOFFITS	ALL SOFFITS OF THIS BUILDING ARE SUSPECTED OF BEING AC SHEET	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPDD	29919006	BLOCK D	D Block	Internal	Level 1	FIRE STAIRS	FIRE DOORS TO FIRE ESCAPE STAIRS ON LEVEL 1	Fire Door	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPDD	29919006	BLOCK D	D Block	Internal	Level 1	KITCHEN	OVEN INSPECTION PORTS (4) REFER SAMPLE NO.1. (NAD)	Furniture	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPDD	29919006	BLOCK D	D Block	Internal	Level 1	ROOM 3.03	ALL WALLS OF ROOM 3.03	Wall	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPDO	29919006	BLOCK D	D Block	Internal	Level 1	TOILET M & F	GEORGE COATES ROOM SHEETING TO TOILET WALLS BOTH MALE AND FEMALE	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPEE	29919005	BLOCK E	E Block	External	Ground Floor	VERANDAH	ALL THE VERANDAH WALLS. THIS WORK WAS DONE IN 1985	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPFF	29918001	BLOCK F	F Block											-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPHH		H Block	H Block											-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPJJ	29918016	BLOCK J	J Block	External	Roof Level 1	CERAMICS BLDG	CORRUGATED ROOF TO CERAMICS BUILDING	Roof Sheeting	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPJJ	29919016	BLOCK J	J Block	Internal	Ground Floor	SCULPTURE ROOM	ALL WALLS THROUGHOUT SCULPTURE ROOM ARE SUSPECTED OF BEING AC	Wall	Cement Based		4	Presumed	18	-	

TAFEs from BEMIR-TAFEs

Current as at 10-May-11

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPJJ	29919015	BLOCK J	J Block	Internal	Ground Floor	KILN ROOM	ALL WALLS THROUGHOUT KILN ROOM ARE SUSPECTED OF BEING AC	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPJJ	29919016	BLOCK J	J Block	Internal	Ground Floor	PAINTING ROOM	ALL WALLS THROUGHOUT PAINTING ROOM ARE SUSPECTED OF BEING AC	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPLL	29919014	BLOCK L	L Block	Internal	Ground Floor	NO.4 DONGA (NOT ON EQUIP. LIST) IS SITUATED BEHIND BLOCK L. WALLS ARE SUSPECTED AC		Wall	Cement Based		2	Presumed	34	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPLI	29919014	BLOCK L	L Block	Internal	Ground Floor	ROOM L1.03	FLOOR TILE IN ROOM L1.03 CONTAIN ASBESTOS REFER SAMPLE NO.4	Floor Finish/Covering	CHR - Chrysotile		4	Confirmed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPLL	29919014	BLOCK L	L Block	Internal	Ground Floor	ROOM L1.04	FLOOR TILES IN ROOM L1.04 MAY CONTAIN ASBESTOS. FURTHER TESTING IS REQUIRED	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPLL	29919014	BLOCK L	L Block	Internal	Ground Floor	ROOM L1.02	CEILING OF ROOM L1.02 IS SUSPECTED OF BEING AC	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPLL	29919014	BLOCK L	L Block	Internal	Ground Floor	ROOM L1.01	CEILING OF ROOM L1.01 IS SUSPECTED OF BEING AC	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPLL	29919014	BLOCK L	L Block	Internal	Ground Floor	ROOM L1.03	CEILING OF ROOM L1.03 IS SUSPECTED OF BEING AC	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPRR		BLOCK R	R Block												
Barrier Reef		PIMLICO TAFE CAMPUS	PIMLICO TAFE CAMPUS	UTPSS	29919015	BLOCK S	S Block	Internal	Ground Floor	CANTEEN	ALL WALLS THROUGHOUT CANTEEN ARE SUSPECTED OF BEING AC	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070000	** Site - Grounds	** Site - Grounds												
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070005	A Block	A Block	Internal	Level 1	STAIRCASE	AC SHEET TO CEILING OF INTERNAL STAIRCASE LEADING TO BALCONY IN CONFERENCE ROOM	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070005	A Block	A Block	Internal	Level 1	UNDER BALCONY/CONF RM	AC SHEET TO CEILING UNDER BALCONY IN CONFERENCE ROOM	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070005	A Block	A Block	Internal	Level 1	LECTURE ROOMS 6 & 7	SHEET TO BOTH SIDES OF ROOF SUPPORT BEAM IN LECTURE ROOMS 6 & 7	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070005	A Block	A Block	Internal	Level 1	ENCLOSED VERANDAH	AC SHEETING TO CEILING OF ENCLOSED VERANDAH OUTSIDE LECTURE RM 7	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070005	A Block	A Block	Internal	Ground Floor	REST ROOM	F.C. SHEETING TO CEILING OF REST ROOM SOUTHERN END OF BLOCK A	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070005	A Block	A Block	Internal	Ground Floor	CLEANERS ROOM	F.C. SHEETING TO CEILING IN CLEANER'S ROOM BESIDE MALE STAFF TOILET	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070005	A Block	A Block	External	Level 1	TOILETS WEST END 5TH SIDE	AC VENT PIPE TO TOILETS WEST END 5TH SIDE OF BLOCK A	Drains/Pipes/Fittings	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070005	A Block	A Block	External	Ground Floor	REST ROOM/SOUTHERN END	F.C. SHEETING INFILL PANELS ABOVE DOORWAY TO REST ROOM SOUTHERN END OF BLOCK A	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070005	A Block	A Block	External	Ground Floor	MALE STAFF TOILET & CLEANER'S ROOM	F.C. SHEETING INFILL PANELS ABOVE DOORWAYS OF MALE STAFF TOILET & CLEANER'S ROOM	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070005	A Block	A Block	Internal	Ground Floor	MALE STAFF TOILET	F.C. SHEET TO CEILING IN MALE STAFF TOILET	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070005	A Block	A Block	Internal	Level 1	VARIOUS ROOMS	AC SHEET TO CEILINGS OF ALL ROOMS THROUGHOUT LEVEL 01	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070004	B Block	B Block	External	Roof Level 1	EASTERN END	WATERPROOF MEMBRANE TO BOX GUTTER EAST END OF BLDG REFER SAMPLE 44	Roof Sheeting	Polymer Bound	CHR - Chrysotile	4	Confirmed	25	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070003	C Block	C Block	External	Level 2	FASCIA	AC SHEETING TO EXT & INT LINING OF FASCIA'S OUTSIDE WINDOWS NTH & WEST SIDES (BUSINESS STUDIES)	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070003	C Block	C Block	External	Level 1	SOFFIT	SHEET TO SOFFIT LINING OUTSIDE WINDOWS NTH & WEST SIDES	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070003	C Block	C Block	External	Level 1	INFILL PANELS	AC SHEET TO INFILL PANELS BELOW WINDOWS THROUGHOUT (BUSINESS STUDIES)	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070003	C Block	C Block	External	Ground Floor	SOFFIT	SHEET TO SOFFIT LINING OUTSIDE WINDOWS (BUSINESS STUDIES)	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070003	C Block	C Block	External	Ground Floor	REC AREAS ADJ CANTEEN	SHEET TO BULKHEAD OF REC AREA ADJ CANTEEN NTH SIDE (BUSINESS STUDIES)	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070003	C Block	C Block	External	Ground Floor	CANTEEN AREA	AC SHEET INFILL PANELS ABOVE GLASS DOORS & PANELS AROUND CANTEEN AREA (TEACHING BLOCK)	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070003	C Block	C Block	External	Level 2	NTH STH & WEST SIDES	AC SHEETING TO PANELS BELOW WINDOWS NTH STHN & WEST SIDES (BUSINESS STUDIES)	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070003	C Block	C Block	External	Level 1	NTH STH & WEST SIDES	SHEET TO LINING OF BULKHEAD ABOVE WINDOWS & SUSPENDED CEILING NTH STHN & WEST SIDES (BUSINESS STUDIES)	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070003	C Block	C Block	External	Ground Floor	FASCIA	SHEET TO EXT & INT LININGS OF FASCIA'S OUTSIDE WINDOWS - SAMPLE 40 (NAD) (BUSINESS STUDIES)	Gable/Soffit/ascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070003	C Block	C Block	Internal	Level 2	VARIOUS AREAS	AC SHEET LINING TO BULKHEAD ABOVE WINDOWS & ABOVE SUSPENDED CEILING N S&W SIDES.(SM.38NAD) (BUSINESS STUDIES)	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070003	C Block	C Block	External	Level 1	FASCIA	SHEET TO EXT & INT LININGS OF FASCIA'S OUTSIDE WINDOWS NTH STHN & WEST SIDES (BUSINESS STUDIES)	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070003	C Block	C Block	External	Level 2	SOFFIT	SHEET TO SOFFIT LINING OUTSIDE WINDOWS NTH STHN & WEST SIDES (BUSINESS STUDIES)	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070003	C Block	C Block	Internal	Level 2	VARIOUS ROOMS	AC SHEETING CEILING TILES IN CLEANER'S ROOM 3.02 & STOREROOMS 3.04 & 3.20 (BUSINESS STUDIES)	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070003	C Block	C Block	Internal	Level 1	VARIOUS ROOMS	AC SHEET TO CEILING TILES IN CLEANER'S ROOM 2.02 & STOREROOMS 2.04 & 2.20 (BUSINESS STUDIES)	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070003	C Block	C Block	Internal	Ground Floor	VARIOUS AREAS	INSULATION SPRAYED TO WALLS & UNDERSIDE OF STAIRWELL EAST & WEST ENDS REFER SAMPLE 38	Wall	Sprayed Coating	CHR - Chrysotile	4	Confirmed	64	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070003	C Block	C Block	Internal	Ground Floor	ROOM 1.21 CLEANERS	AC SHEET TO LINING OF DUCT TO PIPWORK CLEANER'S ROOM 1.21 - SAMPLE 42 (NAD) (BUSINESS STUDIES)	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070003	C Block	C Block	Internal	Ground Floor	ROOM 1.21 CLEANERS	AC SHEET TO CEILING TILES IN CLEANER'S ROOM NO 1.21 SAMPLE 41 (NAD) (BUSINESS STUDIES)	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070003	C Block	C Block	External	Roof Level 1	BLOCK C	AC SHEET TO INT LINING OF PLANT COMPRESSOR ROOM ON ROOF WEST END SAMPLE 43 (NAD) (BUSINESS STUDIES)	Roof Sheeting	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070002	D Block	D Block	Internal	Level 1	VARIOUS	OLD AC SHEETING CEILING ABOVE NEW SUSPENDED CEILING OF LOCKER ROOM INDUSTRIAL SEW ROOMS & STAFFROOM (TEACHING BLOCK)	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070002	D Block	D Block	External	Ground Floor	WALKWAY	FC SHEET TO CEILING OF WALKWAY LEADING TO UPPER LEVEL VIA CONCRETE STAIRS STHN END (TEACHING BLOCK)	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070002	D Block	D Block	Internal	Ground Floor	BLOCK D	TEXTILE COVERED WIRING TO THERMOSTAT OF USCINSKI HEATER BOILER IN FASHION CRAFTS ROOM (TEACHING BLOCK)	Plant, Equipment & Machinery	Woven Textile		4	Presumed	64	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070002	D Block	D Block	Internal	Ground Floor	VARIOUS	FC SHEET TO VARIOUS PARTITIONS THROUGHOUT BLDG AS BLDG WAS RENOVATED IN 1993 (TEACHING BLOCK)	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070002	D Block	D Block	Internal	Level 1	VARIOUS	AC SHEET TO CEILING OF CAMPUS STOREROOM NO 215 & STOREROOMS 2.13 & 2.13 STAIRS STHN END (TEACHING BLOCK)	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070002	D Block	D Block	External	Ground Floor	VERANDAH BENCH SEATS	COMPRESSED SHEET BENCH SEATS EAST SIDE NTH END OF BLDG ON VERANDAH (TEACHING BLOCK)	Furniture	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070001	E Block	E Block	Internal	Level 1	MALE TOILETS	COMPRESSED SHEETING TO TOILET CUBICLES/MALE TOILETS (TEACHING & GARAGE)	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070001	E Block	E Block	Internal	Level 1	STOREROOM NEAR MALE TOILETS	AC SHEETING TO PARTITION WALL OF STOREROOM NEAR MALE TOILETS (TEACHING & GARAGE)	Wall	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070001	E Block	E Block	External	Level 1	FASCIA	COMPRESSED SHEET TO FASCIA'S ON STHN EAST & WEST SIDES (TEACHING & GARAGE)	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070001	E Block	E Block	External	Level 1	SOFFIT	SHEET TO SOFFIT ON WESTSIDE (TEACHING & GARAGE)	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTC	26070001	E Block	E Block	External	Ground Floor	SWITCHBOARD ROOM	AC SHEET TO INFILL PANEL ABOVE BLOCK WORK OF SWITCHBOARD ROOM EAST & WEST SIDES (TEACHING & GARAGE)	Wall	Cement Based		4	Presumed	18	-	

TAFEs from BEMIR-TAFEs

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTCEE	26070001	E Block	E Block	External	Ground Floor	EASTERN SEATING	COMPRESSED SHEET TO THE BACK & SEAT AREAS OF SEATING ON EAST SIDE (TEACHING & GARAGE)	Furniture	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTCEE	26070001	E Block	E Block	Internal	Level 1	WALKWAY	F.C. SHEETING TO CEILING OF WALKWAY ADJ BLOCKS E & D (TEACHING & GARAGE)	Ceiling	Cement Based		4	Presumed	18	-	
Barrier Reef		TOWNSVILLE TAFE CAMPUS	TOWNSVILLE TAFE CAMPUS	UTCEE	26070001	E Block	E Block	External	Ground Floor	SOFFITS	SHEET TO SOFFITS ON EAST WEST & STHN SIDES ON SWITCHBOARD ROOM STHN SIDE (TEACHING & GARAGE)	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	23543012		CAR WASHING PLANT	CAR WASHING PLANT	External	Ground Floor	CAR WASHING PLANT	ALL METAL STRUCTURE	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	23543013		WASTE WATER SHED	WASTE WATER SHED	External	Ground Floor	WASTE WATER SHED	ALL METAL CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	23543000	23543000	** Site - Grounds	** Site - Grounds	External	Site / Grounds	GROUNDS	PHOTOGRAPH NO. 1 - PHOTO OF BRACKEN RIDGE B.N.P.I. TAFE	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	23543000	23543000	** Site - Grounds	** Site - Grounds	External	Ground Floor	TELECOMMUNICATION PIT	TELECOM COMMUNICATION PIT OFF THE NORTHERN SIDE OF BLOCK B	Drains/Pipes/F	Cement Based	Mixed	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	23543000	23543000	** Site - Grounds	** Site - Grounds	External	Ground Floor	EXTERNAL	TWO 6" PIPES CARRYING PRIMARY POWER CABLES THROUGH SERVICE TUNNELS OF BLOCK C. 1000 Lm OF CONDUIT	Drains/Pipes/F	Cement Based	Mixed	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	23543000	23543000	** Site - Grounds	** Site - Grounds	Internal	Lower Ground 1	SERVICE TUNNEL	100mm & 200mm WATER SUPPLY PIPES IN THE SERVICE TUNNEL UNDER THE COMPLEX	Drains/Pipes/F	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	23543001	23543001	COVERED LINKS	COVERED LINKS	External	Site / Grounds	COVERED WALKWAY	8 COLUMNS SUPPORTING STEEL RSJS TO WALKWAY FRONT OF RMC	Drains/Pipes/F	Cement Based		4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	23543006	23543006	CONCRETE TOWER	CONCRETE TOWER	External	Ground Floor	CONCRETE TOWER	NO ASBESTOS CONTAINING MATERIALS DETECTED IN CONCRETE TOWER	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	23543010	23543010	TRACTOR SHED	TRACTOR SHED	External	Ground Floor	TRACTOR SHED	NO ASBESTOS CONTAINING MATERIALS DETECTED IN TRACTOR SHED	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBR01	23543009	GROUNDSMANS SHED	GROUNDSMANS SHED	External	Ground Floor	GROUNDSMAN'S SHED	NO ASBESTOS CONTAINING MATERIALS DETECTED IN GROUNDSMAN'S SHED	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 1	ROOM B1-26	4 X BRAKE SHOES STORED IN THE TIMBER CUPBOARD OFF ROOM B1-26	Stored Material	Polymer Bound	CHR - Chrysotile	3	Confirmed	25	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	ROOM B1-52	STORED BRAKE PADS AND CLUTCH PLATES ON THE BROWN BUILT SHELVEING	Stored Material	Polymer Bound	CHR - Chrysotile	3	Confirmed	25	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	ROOM B1-53	BENCH TOPS TO FUME CUPBOARDS IN ACID ROOM - PREVOCAONAL PLUMBING	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	ROOM B1-53	VARIOUS BRAKE PADS & CLUTCH PLATES STORED IN TWO BROWN BUILT CUPBOARDS	Stored Material	Polymer Bound	CHR - Chrysotile	3	Confirmed	25	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	ROOM B1-58	BACKING TO LIGHT GREY VINYL SHEET TO AUTO TRANSMISSION WORKSHOP	Floor Backing/Under lay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	ROOM B1-58	BACKING TO SHEET VINYL FLOOR COVERING TO ROOM B1-58	Floor Backing/Under lay	Vinyl Sheeting (includes backing)	CHR - Chrysotile	2	Removed	65	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	ROOM B1-58	FIRE DOOR TO THE EASTERN ENTRY OF ROOM B1-58	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	ROOMS B1-23 & B1-21	TOILET AND SHOWER CUBICLE WALLS TO MALE & FEMALE TOILETS	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 1	ROOM B1-10	STORED BRAKE ASSEMBLIES IN ROOM B1-10	Stored Material	Polymer Bound	CHR - Chrysotile	3	Confirmed	25	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 1	ROOM B1-11	GASKET MATERIALS STORED IN THE BROWN BUILT SHELVEING	Stored Material	Polymer Bound	CHR - Chrysotile	3	Confirmed	25	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 1	ROOM B1-11	MILLBOARD GASKETS HANGING ON A YELLOW BOARD (PORTABLE)	Stored Material	Millboard	CHR - Chrysotile	2	Removed	69	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	ROOM B1-38 CAMPUS STORE TOILET	BACKING MATERIAL TO LIGHT GREY SHEET VINYL FLOOR TO CAMPUS STORE TOILET B1-38	Floor Backing/Under lay	Vinyl Sheeting (includes backing)	CHR - Chrysotile	3	Confirmed	62	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 1	ROOM B1-26	BACKING TO SHEET VINYL ON THE FLOOR	Floor Backing/Under lay	Vinyl Sheeting (includes backing)	CHR - Chrysotile	3	Confirmed	62	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 1	ROOM B1-3	STORED GASKET MATERIALS IN THE BROWN BUILT SHELVEING IN ROOM B1-3	Stored Material	Polymer Bound	CHR - Chrysotile	3	Confirmed	25	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 1	ROOM B1-66	GASKETS STORED IN 3 PLAN PRESSES IN ROOM B1-66	Stored Material	Polymer Bound	CHR - Chrysotile	2	Removed	39	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 1	ROOM B1-66	GASKETS STORED IN BROWN BUILT SHELVEING IN ROOM B1-66	Stored Material	Polymer Bound	CHR - Chrysotile	2	Removed	39	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 1	ROOM B1-66	MANIFOLD GASKET MATERIAL STORED IN THE PLAN PRESS	Stored Material	Polymer Bound	CHR - Chrysotile	4	Confirmed	25	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 1	ROOM B1-70	SHEETING STORED BEHIND A LOCKER IN ROOM B1-70	Stored Material	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 1	ROOM B1-11	GASKETS IN A SET OF DRAWS (PORTABLE)	Stored Material	Polymer Bound	CHR - Chrysotile	3	Confirmed	25	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	MAIN STAIRWELL	BEIGE COLOURED VINYL TILES TO MAIN STAIRS LEADING TO LEVEL 2	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Mezzanine 1	ROOM B1-64 EXHAUST DUCT	TEXTILE FLEXIBLE JOINT TO THE EXHAUST DUCT	Insulation/Fill	Woven Textile	CHR - Chrysotile	2	Confirmed	69	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Mezzanine 1	ROOM B1-7	TEXTILE MATERIAL TO EXHAUST MANIFOLD NO. 6 (ABOVE SMALL ENGINE AREA)	Plant, Equipment & Machinery	Woven Textile		3	Presumed	64	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 1	LPG INSTALLATION	BACKING TO THE SHEET VINYL IN THE LPG INSTALLATION ROOM	Floor Backing/Under lay	Vinyl Sheeting (includes backing)	CHR - Chrysotile	3	Confirmed	62	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Mezzanine 1	ROOM B1-62	LAGGING INSTALLED TO EXHAUST MANIFOLD ABOVE DOOR OF ROOM B1-62	Pipe Insulation	Lagging		3	Presumed	64	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 1	SERVICE DUCT	3 X PIPE COLLARS IN THE CONCRETE FLOOR OF THE SERVICE DUCT BETWEEN ROOMS B1-21 & B1-22	Drains/Pipes/F	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	External	Ground Floor	SOFFIT	SOFFIT INSTALLED TO AUTO BUILDING PERIMETER	Gable/Soffit/ascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	External	Level 1	SOFFIT	SOFFIT SHEETING TO THE EASTERN END OF THE SAW TOOTH ROOF (APPROX 7.0M)	Gable/Soffit/ascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	ROOM B1-50 CLASSROOM	VARIOUS CLUTCH PLATES STORED ON WORK BENCHES IN THE CLASS ROOM B1-50	Stored Material	Polymer Bound	CHR - Chrysotile	2	Removed	39	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	B1-54 PLANT ROOM	INSULATION TO 2 HEATER BANKS IN AC DUCTWORK IN PLANT ROOM OF WORKSHOP B1-54	Stored Material	Heater Bank Insulation	CHR - Chrysotile	2	Removed	69	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	ROOM B1-52	MILLBOARD GASKET MATERIAL STORED ON TOP OF BROWN BUILT SHELVEING	Stored Material	Millboard	CHR - Chrysotile	2	Removed	69	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	MAIN STAIRWELL	SHEETING UNDER VINYL TILES OF MAIN STAIRS LEADING TO LEVEL 2	Floor Finish/Covering	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	PURCHASING	WALL PANELS TO PURCHASING OFFICE	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	ROOM B1-1 MALE TOILET	WALL PARTITIONS TO MALE TOILET CUBICLES	Wall	Cement Based		4	Presumed	18	-	

TAFEs from BEMIR-TAFEs

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	ROOM B1-31 STOREROOM	BACKING MATERIAL TO LIGHT GREY SHEET VINYL FLOORING TO STOREROOM B1-31	Floor Backing/Underlay	Vinyl Sheeting (includes backing)		3	Presumed	62	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	ROOM B1-32 CLASSROOM	BACKING MATERIAL TO LIGHT GREY SHEET VINYL FLOORING TO CLASSROOM B1-32	Floor Backing/Underlay	Vinyl Sheeting (includes backing)		3	Presumed	62	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	ROOM B1-37 SUB-STATION	BACKING BOARD TO ELECTRICAL METER IN ELECTRICAL SUB-STATION (DOOR INSPECTION FOUND REMOVED)	Insulation/Fill	Polymer Bound		4	Presumed	25	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Mezzanine 1	ROOM B1-64	1 ROLL OF PAYEN OIL JOINTING GASKET MATERIAL STORED ON THE MEZZANINE LEVEL	Stored Material	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	ROOM B1-39 STORE MANAGERS OFFICE	BACKING MATERIAL TO LIGHT GREY SHEET VINYL TO STORE MANAGERS OFFICE	Floor Backing/Underlay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	External	Roof Level 1	MASTIC JOINTING	GREY MASTIC TO ROOF JOINTS	Membrane	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Mezzanine 1	ROOM B1-10 ABOVE BRAKES AREA	TEXTILE MATERIAL INSTALLED TO EXHAUST MANIFOLD NO. 4 (ABOVE BRAKES AREA)	Plant, Equipment & Machinery	Woven Textile		3	Presumed	64	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Ground Floor	ROOM B1-67 STORE ROOM	PAYEN OIL JOINTING PAPER - ROLLS OF GASKET PAPER STORED ON FLOOR OF STORE ROOM B1-67	Stored Material	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Mezzanine 1	ROOM B1-58	GASKET JOINT ON EXHAUST MUFFLER	Gasket	Polymer Bound	CHR - Chrysotile	3	Confirmed	25	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Mezzanine 1	PLANT ROOM	TEXTILE FLEXIBLE JOINTS TO THE EXHAUST DUCT ABOVE ROOM B1-02	Insulation/Fill	Woven Textile	CHR - Chrysotile	2	Confirmed	69	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Mezzanine 1	AUTO WORKSHOP	TEXTILE MATERIAL INSTALLED TO EXHAUST MANIFOLD 1 & 2	Plant, Equipment & Machinery	Woven Textile		3	Presumed	64	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Mezzanine 1	ABOVE ACID TANK	TEXTILE MATERIAL INSTALLED TO EXHAUST MANIFOLD LOCATED ABOVE ACID TANKS B1-16	Plant, Equipment & Machinery	Woven Textile	CHR - Chrysotile	3	Confirmed	64	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 2	STAIRWELL EXIT	INTERNAL CORE TO FIRE DOOR X2 AT WEST STAIRWELL EXIT	Fire Door	Millboard		4	Presumed	64	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 2	ROOM B2-9 KITCHEN	BACKING MATERIAL TO LIGHT GREY SHEET VINYL FLOOR OF KITCHEN AREA	Floor Backing/Underlay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 2	ROOM B2-6 CLEANERS ROOM	BACKING MATERIAL TO LIGHT GREY SHEET VINYL FLOOR OF CLEANERS ROOM	Floor Backing/Underlay	Vinyl Sheeting (includes backing)		3	Presumed	62	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 2	ROOM B2-7 KITCHEN	BACKING TO THE SHEET VINYL IN THE KITCHEN AREA	Floor Backing/Underlay	Vinyl Sheeting (includes backing)	CHR - Chrysotile	3	Confirmed	62	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 2	ROOM B2-5 MALE TOILETSHOWER	WALLS TO TOILET CUBICLES AND SHOWERS IN MALE TOILET	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 2	ROOM B2-10 STORE ROOM	BACKING MATERIAL TO LIGHT GREY SHEET VINYL FLOOR OF STORE ROOM	Floor Backing/Underlay	Vinyl Sheeting (includes backing)		3	Presumed	62	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 1	SMALL ENGINE ROOM	VARIOUS GASKET PACKETS STORED IN THE SHELVING (APPROX 50 SETS)	Stored Material	Polymer Bound	CHR - Chrysotile	3	Confirmed	25	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 1	SMALL ENGINE ROOM	MILLBOARD GASKETS STORED ON THE YELLOW PEGBOARD NEAR THE ENTRY DOOR	Stored Material	Millboard	CHR - Chrysotile	3	Confirmed	64	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRBB	23543004	AUTO SECTION BLK B	AUTO SECTION BLK B	Internal	Level 2	ROOM B2-4 FEMALE TOILET/SHOWER	WALL TO TOILET AND SHOWER CUBICLES OF FEMALE TOILET	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	External	Level 4	SOFFIT	SOFFIT SHEETING TO ALL SIDES OF C BLOCK	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	CORRIDORS	CEILING COATING TO CORRIDORS THROUGHOUT LEVEL 1	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	CORRIDOR	FIRE DOORS IN CORRIDOR OPP. COMPUTER AIDED DRAFTING ROOM C1-24	Fire Door	Millboard		4	Presumed	64	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	CLASSROOM	BACKING TO SHEET VINYL FLOOR TO CLASSROOM NEXT TO C1-11 & OPP. C1-17	Floor Backing/Underlay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ARC WELDING 2	WALL AND CEILING LININGS TO 16 WELDING BOOTHS TO ARC WELDING MIG & TIG AREA 2	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ARC WELDING 1	COMPRESSED SHEET BENEATH METAL SHEET OF TABLE TO EACH OF 16 WELDING BOOTHS	Furniture	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Ground Floor	ROOM C1 - 19	TEXTILE SEAL TO ELECTRODE OVEN OUTSIDE ROOM C1 - 19	Plant, Equipment & Machinery	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	GAS BOTTLE STORE	11 X ACETYLENE BOTTLES STORED IN THE WESTERN GAS BOTTLE STORE ROOM POSSIBLE ASBESTOS INSIDE BOTTLES	Stored Material	Cement Based		4	Presumed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	External	Roof Level 1	FASCIA	FASCIA BOARD TO PERIMETER OF BUILDING & AROUND COURTYARD AREA AT ROOF LEVEL	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	OLD FURNACE ROOM C1.23	ORANGE FURNACE TOP LOADING. MILLBOARD GASKETS SERIAL No 53 (PORTABLE ITEM)	Gasket	Millboard	CHR - Chrysotile	2	Removed	69	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	External	Level 3	SOFFIT	SOFFIT SHEETING TO THE PERIMETER OF LEVEL 3	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	External	Level 3	PLANT ROOM	NO ASBESTOS CONTAINING MATERIALS DETECTED IN PLANT ROOM ABOVE C1-38	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 4	DISABLED TOILET	FIRE DOOR TO SERVICE DUCT IN THE DISABLED TOILET	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	External	Level 2	SOFFIT	SOFFIT INSTALLED TO EXTERNAL PERIMETER OF BLDG	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ROOM C1.27	FIRE DOOR TO THE SERVICE AREA ADJACENT TO THE URINALS	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	External	Roof Level 1	PLANT ROOM SOUTH	NO ASBESTOS CONTAINING MATERIALS DETECTED IN PLANT ROOM (SOUTH)	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	External	Level 2	BALCONY	FLOOR LINING TO EXTERNAL BALCONY AREA RUNNING AROUND PERIMETER OF BUILDING	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Various levels Internal	STAIRWELLS	WORMALD 1 HR FIRE DOORS INSTALLED TO EACH OF THREE STAIRWELLS ON FL 1-4	Fire Door	Millboard	Mixed	4	Confirmed	64	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Roof Level 1	PLANT ROOM NORTH	NO ASBESTOS MATERIALS DETECTED IN PLANT ROOM NORTH	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ROOM C1.12	FIRE DOOR TO THE SERVICE AREA OFF THE MALE STAFF TOILET	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 5	LIFT PLANT ROOM	BRAKE PADS TO THE LIFT MOTOR IN THE PLANT ROOM	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEIR Score	Attention Required	Comments
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ROOM C1.01	ELECTRICAL TEST BENCH LINED WITH AC	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	OLD FURNACE ROOM C1.23	BLUE FURNACE MILLBOARD GASKETS TO GAS PORTS. SERIAL No 487551 (PORTABLE ITEM)	Gasket	Millboard	CHR - Chrysotile	2	Removed	69	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 4	FEMALE TOILETS	FIRE DOOR IN THE AIR LOCK AREA OF THE FEMALE TOILETS	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ROOM C1.01	1 X 32 VOLT TRANSFORMER SITTING ON THE BENCH IN ROOM C1.01 (PORTABLE ITEM)	Furniture	Polymer Based	CHR - Chrysotile	4	Confirmed	25	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 4	FEMALE TOILET	1 X FIRE DOOR IN THE SHOWER OF THE FEMALE TOILET	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	External	Level 1	CENTRAL COURTYARD	SIX STORMWATER PIPES IN CENTRAL COURTYARD AREA	Stormwater Plumbing	Cement Based		4	Presumed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 4	ALL ROOMS	VERMICULITE DECORATIVE COATING TO CEILINGS OF CLASSROOMS AND CORRIDORS & CUPBOARDS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ROOM 1.09 FABRICATION WORKSHOP	FIRE DOOR ON THE EASTERN SIDE OF THE FABRICATION WORKSHOP C.1.09	Fire Door	Cement Based	Mixed	3	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	OLD FURNACE ROOM C1.23	RED FURNACE MILLBOARD GASKETS TO GAS PORTS SERIAL No 487552 (PORTABLE ITEM)	Gasket	Millboard	CHR - Chrysotile	2	Removed	69	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	OLD FURNACE ROOM C1.23	COMPRESSED SHEET TO THE BENCH TOPS	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ROOM C1.01	16 COVER PANELS LEANING ON THE COLUMN IN ROOM C1.01 (PORTABLE ITEMS)	Stored Material	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ROOM C1-120	CEILING COATING TO WELDING WSHOP CORRIDOR STORE & ARC WELDING MIG & TIG AREA2	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 2	ROOM C2.11.1 MOTOR CONTROL ROOM	FIRE DOOR TO THE SERVICE DUCT IN ROOM C2.11.1 MOTOR CONTROL ROOM	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 2	FOYER ENTRY	2 COLUMNS NEXT TO DOOR RELEASE BUTTON IN FRONT OF ADMIN RECEPTION AREA- MAIN FOYER ENTRY	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 2	CORRIDORS & CUPBOARDS	VERMICULITE DECORATIVE COATING TO CEILINGS OF CORRIDORS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 2	CORRIDOR	WORKM.D 1 HR FIRE RATED DOORS N & S OF ELEVATOR IN CORRIDOR	Fire Door	Millboard		4	Presumed	84	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	TELECOM RISER	FIRE RATED DOOR TO TELECOM RISER OPPOSITE ROOM C1-22	Fire Door	Millboard		4	Presumed	64	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ROOM C1-32 CLASSROOM	BACKING MATERIAL TO GREY SHEET VINYL FLOORING TO CLASSROOM C1-32	Floor Backing/Underlay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ROOM C1-18 & C1-20 ARC WELDING ROOMS	WALL AND CEILING LININGS -J2 WELDING BOOTHS TO ARC WELDING MIG & TIG AREA 1	Wall	Cement Based		3	Presumed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 2	ROOM C2.33	FIRE DOOR THAT ACCESSES DUCTS BESIDE THE URINALS	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ROOM C1-15 CLASSROOM	BACKING TO SHEET VINYL FLOOR TO CLASSROOM C1-15	Floor Backing/Underlay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ROOM C1-11 CLASSROOM	BACKING MATERIAL TO GREY SHEET VINYL FLOOR TO CLASSROOM C1-11	Floor Backing/Underlay	Vinyl Sheeting (includes backing)		4	Presumed	82	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ROOM C1.27	FIRE DOOR TO THE CISTERN SERVICE AREA	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	External	Level 2	SOFFIT	SOFFIT SHEETING TO THE PERIMETER OF LEVEL 2	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ROOM C1-01 ELECTRICAL SECTION	BACKING BOARD TO ELECTRICAL MOTOR IN ELECTRICAL SECTION C1-01	Insulation/Fill	Polymer Based	CHR - Chrysotile	3	Confirmed	25	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ROOM C1.27	FIRE DOOR TO THE SERVICE AREA BESIDE THE URINALS	Fire Door	Cement Based	Mixed	2	Removed	34	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ROOM C1.14 CLASSROOM	ACETYLENE BOTTLE CUT IN HALF AT THE FRONT OF THE CLASSROOM (PORTABLE ITEM)	Stored Material	Cement Based	CHR - Chrysotile	2	Removed	34	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ROOM C1.15	ACETYLENE BOTTLE CUT IN HALF IN TEACHING ROOM C1.15	Stored Material	Cement Based	CHR - Chrysotile	2	Removed	34	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ROOM C1.23	BAG OF FIRE CLAY STORED UNDER THE RED FURNACE	Stored Material	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 1	ROOM C1-18 & C1-20 ARC WELDING ROOMS	BENCH TOPS TO EACH OF THE WELDING BOOTHS IN ARC WELDING MIG & TIG 2	Furniture	Cement Based		4	Presumed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 3	ROOM C3-8C AC PLANT	INTERNAL LINING TO DUCTWORK AROUND HEATING ELEMENT - DEBRIS ALSO EVIDENT IN DUCTWORK	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 2	ROOM C2.33	MALE TOILET CUBICLE WALL	Wall	Cement Based	No asbestos detected (NAD)	2	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 3	DISABLED TOILET	FIRE DOOR TO THE SERVICE DUCT IN THE TOILET	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 3	FEMALE STAFF TOILET	FIRE DOOR TO SERVICE DUCT IN THE FEMALE STAFF TOILET	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 3	MALE STAFF TOILET	FIRE DOOR TO THE SERVICE DUCT IN THE MALE STAFF TOILET	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 3	MALE TOILETS	FIRE DOOR TO THE SERVICE DUCT BEHIND THE URINALS	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 3	MALE TOILETS	FIRE DOOR TO THE SERVICE DUCT IN FRONT OF THE SHOWERS	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 3	ROOM C3-8B LECTURE ROOM	VERMICULITE COATING TO CEILING OF LECTURE ROOM C3-8B	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRCC	23543005	PRE-VOCATIONAL/COM	PRE-VOCATIONAL/COM	Internal	Level 2	ROOM C2.33	FIRE DOOR THAT ACCESSES THE URINAL CISTERN SERVICE AREA	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRDD	23543002	LIBRARY/ADMIN BLK D	LIBRARY/ADMIN BLK D	External	Roof Level 1	ROOF	CORRUGATED ROOF SHEETING TO THE THREE ATRIUM ROOF'S	Roof Sheeting	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRDD	23543002	LIBRARY/ADMIN BLK D	LIBRARY/ADMIN BLK D	External	Roof Level 1	ATRIUM	WALL SHEETING TO THE GABLE END OF THE ATRIUM	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRDD	23543002	LIBRARY/ADMIN BLK D	LIBRARY/ADMIN BLK D	External	Roof Level 1	ATRIUM	FASCIA BARGE ON THE SOUTHERN SIDE OF ALL THREE ATRIUMS	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRDD	23543002	LIBRARY/ADMIN BLK D	LIBRARY/ADMIN BLK D	External	Roof Level 1	SEMINAR ROOM	INSULATION TO 11 HEATER BANKS IN CEILING SPACE ABOVE SEMINAR ROOM	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRDD	23543002	LIBRARY/ADMIN BLK D	LIBRARY/ADMIN BLK D	External	Roof Level 1	SOFFIT & GABLES	SOFFIT SHEETING TO THE SOUTHERN SIDE OF ALL THREE ATRIUMS	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HBRDD	23543002	LIBRARY/ADMIN BLK D	LIBRARY/ADMIN BLK D	External	Various levels External	EXTERNAL	THREE DOWNPIPES & RAIN WATER HEADS WESTERN END OF BUILDING	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No.	Other Ref No.	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description Of ACM	Name of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BSMR Score	Attention Required	Comments
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRDD	23543002	LIBRARY/ADMIN BLK D	LIBRARY/ADMIN BLK D	External	Roof Level 1	ROOF MEMBRANE	BITUMEN MEMBRANE TO UPPER & LOWER ROOF PERIMETERS	Membrane	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRDD	23543002	LIBRARY/ADMIN BLK D	LIBRARY/ADMIN BLK D	Internal	Ground Floor	STORE	GREEN VINYL TILES TO STORE BEHIND MAIN LIBRARY CHECK OUT DESK	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRDD	23543002	LIBRARY/ADMIN BLK D	LIBRARY/ADMIN BLK D	External	Ground Floor	SUN HOODS	SHADE AWNINGS TO WINDOWS ON THE NORTHERN & SOUTHERN SIDES OF THE ORIGINAL BUILDING	Sun Hood	Cerment Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRDD	23543002	LIBRARY/ADMIN BLK D	LIBRARY/ADMIN BLK D	Internal	Ground Floor	ROOM D1-04 & STUDIO	BACKING MATERIAL TO BROWN COLOUR SHEET VINYL FLOOR TO D1-04 AND STUDIO	Floor Backing/Underlay	Vinyl Sheeting (includes backing)	CHR - Chrysotile	4	Confirmed	62	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	External	Level 2	SUN LOUVRES	FIBRE CEMENT SUN LOUVRES - SIMILAR LOUVRES SEEN ON ROOF (ROOF NOT ACCESSED)	Sun Hood	Cerment Based	Mixed	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	Internal	Level 2	MOTEL STORE RM	FLOOR TILES TO MOTEL STORE ROOM	Floor Finish/Covering	Vinyl Tiles	4	Presumed	18	-		
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	External	Various levels External	EXTERNAL	RAIN WATER HEADS ON NORTH & SOUTH SIDES OF BUILDING	Drains/Pipes/Floors	Cerment Based	4	Presumed	18	-		
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	Internal	Level 2	ROOM E2-13	MOTTLED GREEN VINYL FLOOR TILES TO ROOM E2-13	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	Internal	Level 2	ROOM E2-14 LABORATORY	MOTTLED LIGHT BROWN VINYL FLOOR TILES TO LABORATORY AND STORE ROOMS OFF LABORATORY	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	Internal	Level 2	ROOM E2-14 LABORATORY	SHELVING IN APPARATUS STORE, CHEMICAL STORE & CORROSIVE STORE OFF LABORATORY	Furniture	Cerment Based	CHR - Chrysotile	3	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	Internal	Level 1	TRAINING KITCHEN	TEXTILE SEALS TO A NUMBER OF A/C DUCT ACCESS PANELS IN CEILING SPACE	Ceiling	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	Internal	Level 1	ENROLMENT/INFO.	BACKING TO VINYL FLOOR - ALSO APPEARS TO BE UNDER CARPETED RECEPTION AREA	Floor Backing/Underlay	Vinyl Sheeting (includes backing)	CHR - Chrysotile	4	Confirmed	62	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	Internal	Level 2	THE STUDIO BAR CEILING SPACE	FIBRE CEMENT SHEET INFILL PANEL & CEILING ACCESS HOLE COVER IN CEILING SPACE ABOVE COLD STORE	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	Internal	Level 2	THE STUDIO BAR	FLOOR TILES TO WINE/GLASS STORE ROOM	Floor Finish/Covering	Vinyl Tiles	4	Presumed	18	-		
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	Internal	Level 1	FAN ROOM	TEXTILE SEALS TO A NUMBER OF A/C DUCT ACCESS PANELS	Plant, Equipment & Machinery	Woven Textile	2	Removed	69	-		
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	Internal	Level 1	LIFT MOTOR ROOM	NO ACCESS TO LIFT MOTOR ROOM	Wall	Other (refer to description)	3	Presumed	-	-		
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	External	Roof Level 1	ROOF	ROOF SHEETING HAS A THICK LAYER OF SOME SORT OF UNKNOWN COATING	Roof Sheeting	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	Internal	Level 1	MAIN SWITCHBOARD ROOM	FIRE DOOR TO THE MAIN SWITCHBOARD ROOM OPPOSITE ROOM B1-31	Fire Door	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	External	Roof Level 1	EXTERNAL	END GABLE WALL SHEETING TO SEVEN (7) ROOFS (ATRIUMS)	Wall	Cerment Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	Internal	Level 1	CLEANERS STORE	DISCARDED SECTION FIBRE CEMENT SHEET IN SERVICE DUCT SW/ CNR OF CLEANERS STORE	Drains/Pipes/Floors	Cerment Based	3	Presumed	18	-		
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	Internal	Level 1	CANTEEN/DINING	BACKING TO VINYL FLOOR SHEET TO CANTEEN DINING AREA	Floor Backing/Underlay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	Internal	Level 1	CANTEEN KITCHEN CEILING	TEXTILE SEALS TO A NUMBER OF A/C DUCT ACCESS PANELS ABOVE KITCHEN CEILING	Ceiling	Woven Textile	2	Removed	69	-		
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	Internal	Level 1	CANTEEN KITCHEN	SECTION OF WALL AT S END OF PARTITION WALL BETWEEN KITCHEN& SERVERY AREA OF CANTEEN	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	Internal	Level 1	BATTERY ROOM	NO ACCESS TO BATTERY ROOM OPPOSITE CANTEEN ENTRY	Wall	Other (refer to description)	3	Presumed	-	-		
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	External	Various levels External	EAVES/AWNINGS	FIBRE CEMENT SHEET LINING TO EAVES/AWNINGS AROUND BUILDING EXTERIOR	Gables/Soffit/ascle	Cerment Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	Internal	Level 2	ROOM E2-15 TRAINING AREA	FLOOR TILES TO TRAINING AREA E2-15	Floor Finish/Covering	Vinyl Tiles	4	Presumed	18	-		
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRREE	23543003	INFORMATION CTR BLK E	INFORMATION CTR BLK E	External	Roof Level 1	ROOF	CORRUGATED ROOF SHEETING TO SEVEN (7) ROOF ATRIUMS	Roof Sheeting	Cerment Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		BRACKEN RIDGE TAFE CAMPUS	BRACKEN RIDGE TAFE CAMPUS	HRBF	23543011	BUILT ENVIRONMENT BLK F	BUILT ENVIRONMENT BLK F	External	Ground Floor	CARPENTRY MASONRY WORKSHOP	NO ASBESTOS CONTAINING MATERIALS WERE DETECTED IN CARPENTRY MASONRY WORKSHOP BUILT POST 1990	Baffles/Lining	Other (refer to description)	3	Not Present(Not Tested)	-	-		
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS		23741003	RSTRNT/SALON/LIBRY	RSTRNT/SALON/LIBRY	External	Ground Floor	RSTRNT/SALON/LIBRY	RSTRNT/SALON/LIBRARY	Baffles/Lining	Other (refer to description)	3	Presumed	-	-		
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS		23741008	SHADE HOUSE	SHADE HOUSE	External	Ground Floor	SHADE HOUSE	SHADE HOUSE	Baffles/Lining	Other (refer to description)	3	Presumed	-	-		
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS		23741013	ODDOOR DINING AREA	ODDOOR DINING AREA	External	Ground Floor	OUTDOOR DINING AREA	OUTDOOR DINING AREA	Baffles/Lining	Other (refer to description)	3	Presumed	-	-		
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	23741016	23741016	SHADE STRUCTURE	SHADE STRUCTURE	External	Whole Building (asbestos free)	CAR STORE SHED	BUILDING CONSTRUCTED POST 1990 OCG PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	NA	Not Present(Not Tested)	-	-	Building built post 1990	
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	23741018	23741018	BLOCK H QUT BUILDING	BLOCK H QUT BUILDING	External	Whole Building (asbestos free)	BLOCK H QUT BUILDING	BUILDING CONSTRUCTED POST 1990 OCG PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	NA	Not Present(Not Tested)	-	-	Building built post 1990	
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	23741019	23741019	BLOCK K QUT BUILDING	BLOCK K QUT BUILDING	External	Whole Building (asbestos free)	BLOCK K QUT BUILDING	BUILDING CONSTRUCTED POST 1990 OCG PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)	NA	Not Present(Not Tested)	-	-	Building built post 1990	
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	HCA	23741000	** Site - Grounds	** Site - Grounds	-	-	-	-	-	-	-	-	-	-	-	
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	HCA01	23741011	Fuel Store	Fuel Store	External	Ground Floor	FUEL STORE	FUEL STORE	Baffles/Lining	Other (refer to description)	3	Presumed	-	-		
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	HCA02	-	Mist House 1	Mist House 1	-	-	-	-	-	-	-	-	-	-	-	
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	HCA03	-	Mist House 2	Mist House 2	-	-	-	-	-	-	-	-	-	-	-	
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	HCA04	23741007	Machinery Shed	Machinery Shed	-	-	-	-	-	-	-	-	-	-	-	
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	HCA05	-	Tractor Shed	Tractor Shed	-	-	-	-	-	-	-	-	-	-	-	
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	HCA06	23741010	Hothouse	Hothouse	-	-	-	-	-	-	-	-	-	-	-	
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	HCA07	-	Shed	Shed	-	-	-	-	-	-	-	-	-	-	-	
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	HCAAA	23741002	A Block	A Block	-	-	-	-	-	-	-	-	-	-	-	
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	HCAAB	-	B Block	B Block	-	-	-	-	-	-	-	-	-	-	-	
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	HCACC	23741004	C Block	C Block	External	Ground Floor	GENERAL TEACHING	GENERAL TEACHING	Baffles/Lining	Other (refer to description)	3	Presumed	-	-		
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	HCACH	31498001	Childcare Centre	Childcare Centre	-	-	-	-	-	-	-	-	-	-	-	
										TAFEs from BEMIR-TAFEs									Current as at 10-May-11

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEIMR Score	Attention Required	Comments
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	HCADD	23741005	D Block	D Block	External	Ground Floor	CAMPUS/MAINT WSHOP	CAMPUS/MAINT WSHOP	Baffles/Lining	Other (refer to description)		3	Presumed		-	
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	HCAEE	23741006	E Block	E Block	External	Ground Floor	HORTICULTURAL	HORTICULTURAL	Baffles/Lining	Other (refer to description)		3	Presumed		-	
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	HCAGG	23741012	G Block	G Block	Internal	Ground Floor	TOILET	TOILET	Baffles/Lining	Other (refer to description)		3	Presumed		-	
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	HCAHH		H Block (Demountable)	H Block (Demountable)											-	
Brisbane North		CABOOLTURE TAFE CAMPUS	CABOOLTURE TAFE CAMPUS	HCAJJ		J Block	J Block											-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS		23801002	RETAIL SALES BLOCK	RETAIL SALES BLOCK	External	Ground Floor	THROUGHOUT	BUILDING CONSTRUCTED POST 1990 ASBESTOS FREE	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS		23801006	SHADE HOUSE	SHADE HOUSE	External	Ground Floor	SHADE HOUSE	BUILDING CONSTRUCTED OF STEEL ASBESTOS FREE	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS		23801009	G Block Chemical/Fuel	G Block Chemical/Fuel	External	Roof Level 1	EXTERNAL	4 X VENT PIPES	Drains/Pipes/Furniture	Cement Based		4	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS		23801009	G Block Chemical/Fuel	G Block Chemical/Fuel	Internal	Ground Floor	WORK BENCHES	COMPRESSED SHEETING TO WORK BENCHES	Furniture	Cement Based		4	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS		23801009	G Block Chemical/Fuel	G Block Chemical/Fuel	External	Roof Level 1	ROOF	SHEETING TO ROOF FLASHINGS & GUTTERS	Roof Sheeting	Cement Based		4	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS		23801009	G Block Chemical/Fuel	G Block Chemical/Fuel	Internal	Ground Floor	INTERNAL	4 X VENT PIPES	Drains/Pipes/Furniture	Cement Based		4	Presumed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS		23801010	FOG HOUSE	FOG HOUSE	Internal	Ground Floor	FOG HOUSE	24 X PIPE SUPPORTS FOR TABLES	Drains/Pipes/Furniture	Cement Based	Mixed	4	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS		23801010	FOG HOUSE	FOG HOUSE	Internal	Ground Floor	FOG HOUSE	COMPRESSED SHEETING TO ROOFLINE OF WALKWAY	Roof Sheeting	Cement Based		3	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS		23801010	FOG HOUSE	FOG HOUSE	Internal	Ground Floor	INTERNAL	COMPRESSED SHEETING TO WORK BENCHES	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS		23801010	FOG HOUSE	FOG HOUSE	Internal	Ground Floor	INTERNAL	LINING TO HEATER BANK	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS		23801010	FOG HOUSE	FOG HOUSE	Internal	Ground Floor	SPLASHBACK/BENCH TOP	SHEETING TO SPLASHBACK BENCH TOPS WESTERN SIDE	Furniture	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS		23801016	COVERED WALKWAYS	COVERED WALKWAYS	External	Ground Floor	FOG HOUSE AND CS	COMPRESSED ROOF SHEETING TO DOOR ENTRANCES	Roof Sheeting	Cement Based		4	Presumed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS		23801018	FERTILIZER SHED	FERTILIZER SHED	External	Ground Floor	FERTILIZER SHED	BUILDING CONSTRUCTED POST 1990 ASBESTOS FREE	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS		23801019	GARDENERS SHED	GARDENERS SHED	External	Ground Floor	GARDENERS SHED	BUILDING CONSTRUCTED POST 1990 ASBESTOS FREE	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS		23801020	U Block Orchard Site	U Block Orchard Site	Internal	Ground Floor	BOILER AREA - BLOCK C	SEALED UNIT TO BOILER	Plant, Equipment & Machinery	Cement Based		4	Presumed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS		23801020	U Block Orchard Site	U Block Orchard Site	Internal	Ground Floor	BONSAI COLLECTION	SHEETING TO CEILING	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS		23801022	STORAGE SHED	STORAGE SHED	External	Ground Floor	STORAGE SHED	BUILDING NOT ACCESSED	Baffles/Lining	Other (refer to description)		3	Presumed		-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGR	23801000	SITE	SITE	External	Site / Grounds	SWITCHBOARD	BACKING TO SWITCHBOARD BETWEEN BOWLING & GOLF GREENS	Insulation/Fill	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGR	23801000	SITE	SITE	External	Site / Grounds	EXTERNAL	1 X TELECOMMUNICATIONS PIT ON WEST SIDE OF BLOCK D	Drains/Pipes/Furniture	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGR	23801000	SITE	SITE	External	Site / Grounds	EXTERNAL RETAILS SALES AREA	1 X WORKBENCH STORED IN RETAIL SALES AREA	Stored Material	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGR01		Shade House	Shade House											-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGR02	23801011	Propagation House	Propagation House	Internal	Ground Floor	BENCH TOPS	FIBROUS SHEET TOPS TO BENCHES	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGR02	23801011	Propagation House	Propagation House	External	Ground Floor	PROPAGATION ROOM	BUILDING CONSTRUCTED OF ALUMINIUM. ASBESTOS FREE	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGR03		Glasshouse	Glasshouse											-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGR04	23801012	Hydroponics	Hydroponics	Internal	Ground Floor	HYDROPONICS	BUILDING CONSTRUCTED POST 1990 ASBESTOS FREE	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGR05	23801021	Fuel Store	Fuel Store	External	Ground Floor	FUEL STORAGE	BUILDING NOT ACCESSED	Wall	Other (refer to description)		3	Presumed		-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGR06		Shed 1	Shed 1											-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGR07		Shed 2	Shed 2											-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGR08		Shade House	Shade House											-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGR09		Amenities	Amenities											-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGR10		Shed 3	Shed 3											-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGR11	23801003	Machinery Shed	Machinery Shed	External	Ground Floor	MACHINERY SHED	BUILDING CONSTRUCTED OF STEEL ASBESTOS FREE	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGR12		Shed 4	Shed 4											-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	Internal	Ground Floor	ROOM A7 A5 & A4 & LIBRARY	PERFORATED SHEETS TO CEILING TO ROOMS A7 A5 A4 AND 'QUIET AREA' IN LIBRARY	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	Internal	Ground Floor	CORRIDORS	VINYL FLOORINGS TO THE CORRIDORS	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	Internal	Ground Floor	CANTEEN	INSULATION BLOCK & WASHERS TO LARGE SANDWICH MAKER WOODSOM BRAND - PORTABLE ITEM	Plant, Equipment & Machinery	Millboard	CHR - Chrysotile	2	Removed	69	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	External	Roof Level 1	ROOF	SUPER SIX ROOFING TO ADMIN	Roof Sheeting	Cement Based	CHR - Chrysotile	3	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	External	Roof Level 1	GABLE END AT SOUTHERN ELEVATION	GABLE END AT SOUTHERN ELEVATION	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	External	Roof Level 1	ATRIUM	SHEETING TO SUN HOODS OVER ATRIUM	Sun Hood	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	External	Ground Floor	FASCIA	FASCIA BARGE BOARD ABOVE MAIN ENTRY DOOR	Gable/Soffit/Fascia	Cement Based		4	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	External	Ground Floor	EXTERNAL	SHEETING TO ENTRY CEILINGS 2 X EASTERN ENTRY & 1 S	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	External	Ground Floor	ENTRY DOORS & SUNHOODS	FLAT WALL SHEETING ABOVE WINDOWS ENTRY DOORS & BEHIND SUNHOODS	Wall	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	Internal	Ground Floor	ENTRY AREA	SHEETING TO THE ENTRY CEILINGS 2 X EASTERN ENTRY & 1 S.	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	External	Ground Floor	SUN HOODS	CURVED COMPRESSED SHEETING TO SUN HOODS	Sun Hood	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	Internal	Ground Floor	LIBRARY	11.25KW HEATER ELEMENT LOCATED ABOVE THE SECOND LIGHT FITTING OF THE EASTERN WALL IN LIBRARY STAFF A	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	Internal	Ground Floor	LIBRARY	11.25KW HEATER ELEMENT LOCATED ABOVE THE SECOND LIGHT FITTING OF THE EASTERN WALL IN LIBRARY STAFF A	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	Internal	Ground Floor	LIBRARY	3.75KW HEATER ELEMENT - LOCATED ABOVE THE SECOND LIGHT FITTING OFF THE EASTERN WALL IN LIBRARY STAFF	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	Internal	Ground Floor	LIBRARY	5.25 KM ELEMENT LOCATED ABOVE THE LIGHT FITTING AGAINST EASTERN WALL IN LIBRARY STAFF AREA APPROX 3M	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	Internal	Ground Floor	LIBRARY	5.25 KM ELEMENT LOCATED ABOVE THE LIGHT FITTING AGAINST EASTERN WALL IN LIBRARY STAFF AREA APPROX 3M	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	Internal	Ground Floor	LIBRARY CEILING SPACE	3 HEATER BANKS ABOVE THE LIBRARY CEILING	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	Internal	Ground Floor	PLANT ROOM	1 X HEATER BANK IN CEILING SPACE ABOVE PLANT ROOM	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	Internal	Ground Floor	ROOM A7	POSSIBLE STORED MATERIAL IN CUPBOARDS - PORTABLE ITEM	Stored Material	Cement Based		4	Presumed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	Internal	Ground Floor	RECEPTION	SHEETING TO RECEPTION COUNTER CEILINGS	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRAA	23801001	A Block	A Block	Internal	Ground Floor	ENTRY AREA	SHEETING TO THE RECEPTION COUNTER CEILING	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRBB	23801004	B Block	B Block	External		PLANT AREA	GUTTERS TO SOUTHERN FACE TO PLANT AREA ON ROOF	Drains/Pipes/Floors	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRBB	23801004	B Block	B Block	Internal	Lower Ground 1	STAFF ROOM	ASBESTOS UNDERLAY TO SHEET VINYL	Floor Backing/Underlay	Vinyl Sheeting (includes backing)	CHR - Chrysotile	4	Removed	62	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRBB	23801004	B Block	B Block	Internal	Level 1	DUCT WORK	MASTIS TO A/C DUCTS	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRBB	23801004	B Block	B Block	External	Roof Level 1	ROOF	SUPER SIX SHEETING TO ROOF	Roof Sheeting	Cement Based		4	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRBB	23801004	B Block	B Block	External	Level 1	SUN HOOD	SHEETING TO SUN HOOD - EASTERN SIDE	Sun Hood	Cement Based		4	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRBB	23801004	B Block	B Block	External	Ground Floor	TOILETS/STAFFROOM	SHEETING TO CEILINGS OF STAFFROOM & TOILETS	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRBB	23801004	B Block	B Block	External	Level 1	MEMBRANE	BITUMEN MEMBRANE TO THE OPEN AREA	Roof Sheeting	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRCC	23801013	C Block	C Block	Internal	Ground Floor	STAFF ROOM	BACKING TO SHEET VINYL IN THE STAFF ROOM	Floor Backing/Underlay	Vinyl Sheeting (includes backing)	CHR - Chrysotile	4	Removed	62	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRCC	23801013	C Block	C Block	External	Roof Level 1	BOTTOM OF GUTTERS	LOOSE DEBRIS IN BOTTOM OF GUTTERS	Debris	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRCC	23801013	C Block	C Block	External	Roof Level 1	ROOF	FLASHINGS GUTTERS & ROOF TO BLOCK G	Roof Sheeting	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRCC	23801013	C Block	C Block	Internal	Ground Floor	SPLASHBACK/BENCH TOP	COMPRESSED SHEETING TO BENCH TOPS AND SPLASHBACKS	Furniture	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRDD	23801007	D Block	D Block	Internal	Ground Floor	OPEN AREA	1 WORKBENCH STORED ON THE NORTHERN WALL	Stored Material	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRDD	23801007	D Block	D Block	Internal	Ground Floor	MACHINERY WORKSHOP	CLUTCH PLATES & BRAKE PADS	Stored Material	Polymer Based		4	Presumed	25	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRDD	23801007	D Block	D Block	External	Roof Level 1	ROOF	SUPER SIX ROOFING GUTTERS & FLASHINGS	Roof Sheeting	Cement Based		4	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGREE	23801005	E Block	E Block	Internal	Ground Floor	ROOM E2 CLASSROOM	VERMICULITE COATING TO CLASSROOM (4 SAMPLES TAKEN) - REFER SAMPLE 11863	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGREE	23801005	E Block	E Block	Internal	Ground Floor	ROOM E2 CLASSROOM	VERMICULITE COATING TO CLASSROOM (4 SAMPLES TAKEN) - REFER SAMPLE 11864	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGREE	23801005	E Block	E Block	Internal	Ground Floor	ROOM E2 CLASSROOM	VERMICULITE COATING TO CLASSROOM (4 SAMPLES TAKEN) - REFER SAMPLE 11862	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGREE	23801005	E Block	E Block	Internal	Ground Floor	ROOM E1 CLASSROOM	VERMICULITE COATING TO CLASSROOM (4 SAMPLES TAKEN) - REFER SAMPLE 11861	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGREE	23801005	E Block	E Block	Internal	Ground Floor	ROOM E1 CLASSROOM	VERMICULITE COATING TO CLASSROOM (4 SAMPLES TAKEN) - REFER SAMPLE 11860	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGREE	23801005	E Block	E Block	Internal	Ground Floor	ROOM E1 CLASSROOM	VERMICULITE COATING TO CLASSROOM (4 SAMPLES TAKEN) - REFER SAMPLE 11859	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGREE	23801005	E Block	E Block	Internal	Ground Floor	ROOM E1 CLASSROOM	VERMICULITE COATING TO CLASSROOM (4 SAMPLES TAKEN) - REFER SAMPLE 11858	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGREE	23801005	E Block	E Block	External	Roof Level 1	ROOF	SUPER SIX ROOFING & GUTTERING	Roof Sheeting	Cement Based		4	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGREE	23801005	E Block	E Block	External	Ground Floor	SUN HOODS	COMPRESSED SHEETING TO SUN HOOD	Sun Hood	Cement Based		4	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGREE	23801005	E Block	E Block	Internal	Ground Floor	ROOM E2 CLASSROOM	VERMICULITE COATING TO CLASSROOM (4 SAMPLES TAKEN) - REFER SAMPLE 11865	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRFF	23801008	F Block	F Block	External	Ground Floor	GABLE - DISPATCH ROLLER DOOR	COMPRESSED SHEETING TO GABLE END ABOVE DISPATCH ROLLER DOOR	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRFF	23801008	F Block	F Block	External	Ground Floor	ROLLER & ENTRY DOOR	FLAT SHEETING AROUND ROLLER DOOR & ENTRY DOOR - NORTHERN & SOUTH FACES	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRFF	23801008	F Block	F Block	External	Ground Floor	ROLLER DOORS/STORE	FLAT SHEETING TO GABLES ABOVE ROLLER DOORS & TO STOREROOM	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRFF	23801008	F Block	F Block	External	Roof Level 1	ROOF	SUPER SIX ROOFING GUTTERS & FLASHINGS	Roof Sheeting	Cement Based		4	Removed	18	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRFF	23801008	F Block	F Block	Internal	Ground Floor	STORE ROOM	LINING TO SHEET VINYL IN THE STORE ROOM	Floor Finish/Covering	Vinyl Sheeting (includes backing)	CHR - Chrysotile	4	Removed	62	-	
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRPP		P Block	P Block												
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRSS	23801015	S Block	S Block	External	Ground Floor	STUDENT SERVICES BLOCK	BUILDING CONSTRUCTED POST 1980 ASBESTOS FREE	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)	-		
Brisbane North		GROVELY TAFE CAMPUS	GROVELY TAFE CAMPUS	HGRTT	23801014	T Block	T Block	Internal	Ground Floor	AF MODULAR BLOCK	NO ACCESS GAINED TO ROOM	Wall	Other (refer to description)		3	Presumed	-		
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS		24574001	OPEN STORAGE SHED	OPEN STORAGE SHED	External	Roof Level 2	OPEN STORAGE SHED	METAL FRAME METAL CLAD	Baffles/Lining	Other (refer to description)		3	Presumed	-		
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS		24574002	GARAGE/TOILET	GARAGE/TOILET	External	Roof Level 1	EXTERNAL	VENT PIPE PENETRATING THROUGH ROOF AT SOUTH EASTERN CORNER	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS		24574002	GARAGE/TOILET	GARAGE/TOILET	External	Ground Floor	TOILETS	AC SOFFIT TO PERIMETER OF BUILDING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS		24574002	GARAGE/TOILET	GARAGE/TOILET	External	Roof Level 1	EXTERNAL	FASCIA BARGE TO PERIMETER OF BUILDING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS		24574002	GARAGE/TOILET	GARAGE/TOILET	External	Roof Level 1	EXTERNAL	WALL SHEETING TO EASTERN SIDE OF BUILDING	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS		24574002	GARAGE/TOILET	GARAGE/TOILET	Internal	Roof Level 1	INTERNAL	CEILING TILES THROUGHOUT TOILETS AND LARGE ROOM ADJACENT	Ceiling	Cement Based		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEHIR Score	Attention Required	Comments
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS		24574043	COVERED AREA/STORE	COVERED AREA/STORE	External	Ground Floor	COVERED AREA/STORE ROOM	METAL FRAME AND ROOF	Baffles/Lining	Other (refer to description)		3	Presumed		-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS		24574045	Covered Area	Covered Area	External	Ground Floor	COVERED AREA	TIMBER FRAME IRON ROOF CLADDING	Baffles/Lining	Other (refer to description)		3	Presumed		-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS		24574046	LUNCH SHELTER 2	LUNCH SHELTER 2	External	Ground Floor	LUNCH SHELTER 2	IRON ROOF & TIMBER SUPPORTS	Baffles/Lining	Other (refer to description)		3	Presumed		-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT	24574000	SITE GROUNDS	SITE GROUNDS	External	Site / Grounds	GARDEN	VENT PIPE NEAR POWER POLE IN GARDEN NORTH SIDE OF BLOCK 12	Drains/Pipes/F	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT	24574000	SITE GROUNDS	SITE GROUNDS	External	Site / Grounds	TELECOMMUNICATION PIT	TELECOM PIT NORTH CORNER OF BLOCK 8 ON PATHWAY	Drains/Pipes/F	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT	24574000	SITE GROUNDS	SITE GROUNDS	External	Site / Grounds	TELECOMMUNICATION PIT	3 X TELECOMMUNICATIONS PITS ON THE EASTERN SIDE OF BLOCK 9 (028) GARDEN & PATHWAY	Drains/Pipes/F	Cement Based		3	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT	24574000	SITE GROUNDS	SITE GROUNDS	External	Site / Grounds	TELECOMMUNICATION PIT	1 X TELECOMMUNICATION PIT USED AS AN ASHTRAY EASTERN SIDE NEAR ENTRY DOOR TO BLOCK 6 (027)	Drains/Pipes/F	Cement Based	Mixed	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT	24574000	SITE GROUNDS	SITE GROUNDS	External	Site / Grounds	TELECOMMUNICATION PIT	1 X TELECOM PIT EASTERN SIDE NEAR ENTRY DOOR (ADJACENT TO ASHTRAY)	Drains/Pipes/F	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT	24574000	SITE GROUNDS	SITE GROUNDS	External	Site / Grounds	EXTERNAL FENCE	GALBESTOS FENCE NORTHERN SIDE OF BLOCK 12 (007)	Fencing	Cement Based	CHR - Chrysotile	2	Removed	34	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT	24574000	SITE GROUNDS	SITE GROUNDS	External	Site / Grounds	EXTERNAL FENCE	CORRUGATED FENCE NORTHERN SIDE OF BLOCK 12 (007)	Fencing	Cement Based	Mixed	2	Removed	34	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT	24574000	SITE GROUNDS	SITE GROUNDS	External	Site / Grounds	BBQ	UNDERSIDE OF BBQ OUTSIDE OF THE RENEWABLE ENERGY BUILDING	Furniture	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT	24574000	SITE GROUNDS	SITE GROUNDS	External	Ground Floor	EXTERNAL FENCE	CORRUGATED FENCING ON WEST SIDE OF WOOD WORK BLOCK & WOOD MACHINING SHOP	Fencing	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT	24574000	SITE GROUNDS	SITE GROUNDS	External	Site / Grounds	TELECOMMUNICATION PIT	1 X TELECOMMUNICATION PIT SOUTH EASTERN CORNER OF 027 UNDER GATE D SIGN	Drains/Pipes/F	Cement Based	Mixed	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT01	24574044	Amenities	Amenities	External	Level 1	SOFFITS	SOFFITS TO NORTH AND SOUTHERN SIDES	Gable/Soffit/F	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT02	24574005	Propagation Shed	Propagation Shed	External	Roof Level 1	EXTERNAL	3 X DISCONNECTOR TRAP (DT) SURROUNDS 1 X EASTERN SIDE 2 X WESTERN SIDE	Drains/Pipes/F	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT02	24574005	Propagation Shed	Propagation Shed	Internal	Roof Level 1	INTERNAL	COMPRESSED SHEET TO 2 WORK BENCHES ON SOUTHERN SIDE	Furniture	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT02	24574005	Propagation Shed	Propagation Shed	Internal	Roof Level 1	INTERNAL	EDGING OF SEEDLING BEDS X 6	Furniture	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT02	24574005	Propagation Shed	Propagation Shed	Internal	Roof Level 1	INTERNAL	SHEETING TO PARTITION WALL	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT04		Hort - Shed	Hort - Shed											-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT05	24574009	Flammable Store	Flammable Store	External	Roof Level 1	EXTERNAL	AC D.T. SURROUND ON NIE CORNER OF BUILDING	Drains/Pipes/F	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT05	24574009	Flammable Store	Flammable Store	External	Ground Floor	EXTERNAL	SMALL AC SOFFIT ON NORTH & SOUTH SIDE OF BUILDING	Gable/Soffit/F	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT05	24574009	Flammable Store	Flammable Store	External	Ground Floor	EXTERNAL	AC FASCIA ON ALL SIDES TO THE FLAMMABLE LIQUID STORE	Gable/Soffit/F	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT11	24574029	Truck Shed	Truck Shed	External	Level 1	FASCIA	PART SOFFIT SHEETING TO THE UNDER SIDE OF THE FASCIA	Gable/Soffit/F	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HIT11	24574029	Truck Shed	Truck Shed	External	Level 1	FASCIA	FASCIA BARGE SHEETING TO PART PERIMETER OF BUILDING	Gable/Soffit/F	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	Internal	Level 1	VARIOUS ROOMS	AC CEILING TILES THROUGHOUT	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	External	Level 1	AWNINGS	AC CEILING UNDER 3 ONLY AWNINGS ON NTHN SIDE OF BLOCK CENTRE AWNING HAS BEEN REMOVED (RESIDUE REMAIN)	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	External	Level 1	INFIL PANELS	FIBRE CEMENT INFILL PANELS ADJACENT TO GDT1	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	Internal	Various levels	STAIRWELLS	VINYL FLOOR TILES ON LANDINGS & STAIRS TO EAST & WEST STAIRWELLS	Floor Finish/Coverin	Vinyl Tiles		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	External	Level 1	ROOM 1GT	EXTERNAL CLADDING ON NORTH & SOUTH END OF ROOM 1GT	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	External	Level 1	SOUTH WALL	AC D.T. SURROUNDS - 12 ONLY ON SOUTH WALL	Drains/Pipes/F	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	External	Level 3	VERANDAH/FOYER	VINYL FLOOR TILES ON VERANDAH ALONG NORTHERN SIDE OF BLOCK	Floor Finish/Coverin	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	External	Roof Level 1	ROOF	COATING TO ROOF SHEETING (POSSIBLY GALBESTOS) SAMPLE 1078X CONFIRMS CHR	Roof Sheeting	Polymer Bound	CHR - Chrysotile	3	Removed	25	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	External	Various levels	INFILL PANELS	COMPRESSED FIBRO INFILL PANELS BETWEEN & ADJ. HOPPER & LOUVRE WINDOWS ON S SIDE	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	External	Various levels	ROOF	COATING TO ROOF SHEETING (LEVEL 3) (POSSIBLY GALBESTOS) UNABLE TO SAMPLE. NO ACCESS TO ROOF	Roof Sheeting	Polymer Bound		3	Removed	25	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	Internal	Level 1	SWITCH BOARDS	SWITCH BOARD LIFT EQUIPMENT	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	Internal	Various levels	LIFT	POSSIBLE ASBESTOS CONTAINING MATERIAL IN BRAKE LINING TO LIFT AT WEST END OF BUILDING	Plant, Equipment & Machinery	Polymer Bound		4	Presumed	25	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	Internal	Level 1	CABINET MAKING	FLOOR TO THE CABINET MAKING ROOM	Floor Finish/Coverin	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	Internal	Various levels	STAIRWELL	COMPRESSED SHEETING TO STAIRWELL EASTERN SIDE	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	Internal	Level 1	VARIOUS ROOMS	VINYL FLOOR TILES IN VERANDAH AREA WORKSHOP 1 MALE TOILETS	Floor Finish/Coverin	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	Internal	Level 3	VARIOUS ROOMS	VINYL FLOOR TILES IN DISPLAY AREA WORKSHOP 4 RESOURCE AREA MACHINE ROOM 3 & WORKSHOP 5	Floor Finish/Coverin	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	Internal	Level 3	VARIOUS ROOMS	AC CEILING TILES IN ALL ROOMS ON TOP LEVEL OF WOOD WORK BLOCK	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	Internal	Level 3	ROOM 12 S	AC WALL JUST BELOW CEILING IN FRONT OF SPRAY BOOTH	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	Internal	Level 3	ROOM 12 S	AC CEILING IN ROOM 12 S	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	Internal	Level 3	ROOM 12 L MACHINE ROOM	AC SPLASHBACK TO SINK UNIT IN MACHINE ROOM ON SOUTH EAST CORNER	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	Internal	Level 2	VARIOUS ROOMS	VINYL FLOOR TILES IN VERANDAH WORKSHOP 2 MACHINERY ROOM 2 & RESOURCE ROOM	Floor Finish/Coverin	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITAA	24574014	A Block (Block 1)	A Block (Block 1)	Internal	Level 2	VARIOUS ROOMS	AC CEILING TILES THROUGHOUT	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITBB	24574015	B Block (Block 2)	B Block (Block 2)	Internal	Various levels	VARIOUS ROOMS	VINYL FLOOR TILES TO STAIRS, LANDINGS, TOILET AIR LOCK AND CUPBOARD ROOM 227 AND PASSAGEWAY	Floor Finish/Coverin	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITBB	24574015	B Block (Block 2)	B Block (Block 2)	Internal	Level 3	ROOM 22C	UNDERSIDE OF BULKHEAD	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITBB	24574015	B Block (Block 2)	B Block (Block 2)	Internal	Level 3	ROOM 22C	AC SHEETING ON BOTH SIDE OF DIVIDING WALL	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	

TAFEs from BEHIR-TAFEs

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Est	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEIR Score	Attention Required	Comments
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITBB	24574015	B Block (Block 2)	B Block (Block 2)	Internal	Level 3	NORTHERN & SOUTHERN SIDES	WALL PANEL ADJACENT TO BULKHEADS (NORTHERN & SOUTHERN SIDES)	Wall	Cement Based	Mixed	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITBB	24574015	B Block (Block 2)	B Block (Block 2)	Internal	Level 3	FOYER & ROOM 22A	AC CEILING IN ROOM 22A & IN FOYER AREA OUTSIDE INCLUDING LINING IN 2 SKYLIGHTS	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITBB	24574015	B Block (Block 2)	B Block (Block 2)	Internal	Level 2	ROOM 228	SHEET VINYL FLOORING UNDER EXISTING VINYL FLOOR	Floor Finish/Covering	Vinyl Sheetting (includes backing)	CHR - Chrysotile	4	Confirmed	62	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITBB	24574015	B Block (Block 2)	B Block (Block 2)	Internal	Level 1	ROOM 112 MAIN POWERBOARD ROOM	MAIN POWER BOARD ROOM HAS STORED SHEETING (5 PIECES)	Stored Material	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITBB	24574015	B Block (Block 2)	B Block (Block 2)	External	Level 1	JOINTING COMPOUND	BITUMEN JOINTS TO CONCRETE SLAB	Membrane	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITBB	24574015	B Block (Block 2)	B Block (Block 2)	Internal	Level 1	CLEANER'S ROOM 213	VINYL FLOOR TILES IN CLEANER'S ROOM ON EAST SIDE OF BUILDING	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITBB	24574015	B Block (Block 2)	B Block (Block 2)	External	Various levels External	INFILL PANELS	COMPRESSED FIBRO INFILL PANELS IN BETWEEN WINDOWS ON EAST & WEST SIDE OF BUILDING	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITBB	24574015	B Block (Block 2)	B Block (Block 2)	External	Level 3	NORTH EASTERN CORNER	AC VENT PIPE ON N/E CORNER OF BUILDING	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITBB	24574015	B Block (Block 2)	B Block (Block 2)	External	Level 1	SOUTH & EAST SIDE	DT SURROUNDS - 1 ON SOUTH SIDE 4 ON EAST SIDE	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITBB	24574015	B Block (Block 2)	B Block (Block 2)	Internal	Level 1	ELECTRICAL BOARD	BACKING BOARD TO THE DISTRIBUTION BOARD CABINET	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITBB	24574015	B Block (Block 2)	B Block (Block 2)	External	Level 1	INFILL PANELS	INFILL PANEL TO DOOR WESTERN SIDE	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITCC	24574016	C Block (Block 3)	C Block (Block 3)	External	Level 1	WORKSHOP GABLES	POSSIBLE GALBESTOS TO SOUTH CLADDING & ABOVE ROLLER DOOR ON WESTERN SIDE OF WORKSHOP	Wall	Polymer Bond		3	Presumed	25	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITCC	24574016	C Block (Block 3)	C Block (Block 3)	External	Roof Level 1	ROOF	AC TILES & AC BULL NOSE COVERED WITH WATERPROOF MEMBRANE - LOWER SECTION OF ROOF ON STYN SIDE OF BLDG	Roof Sheetting	Polymer Bond	CHR - Chrysotile	3	Removed	25	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITCC	24574016	C Block (Block 3)	C Block (Block 3)	External	Roof Level 1	ROOF	GALBESTOS ROOF SHEETING TO WOOD MACHINING BLOCK, SAMPLE 19803 CONFIRMS CHR	Roof Sheetting	Polymer Bond	CHR - Chrysotile	2	Removed	38	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITCC	24574016	C Block (Block 3)	C Block (Block 3)	Internal	Ground Floor	SHEETING ABOVE AND BESIDE DOORWAY ROOM 3109	SHEETING ABOVE AND BESIDE DOOR WAY ROOM 3109	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITCC	24574016	C Block (Block 3)	C Block (Block 3)	Internal	Level 1	COMPRESSOR ROOM	AC CEILING IN COMPRESSOR ROOM ON S/E CORNER OF BUILDING	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITCC	24574016	C Block (Block 3)	C Block (Block 3)	External	Level 1	WORKSHOP GABLES	GABLES TO SOUTHERN WALL CLADDING ABOVE ROLLER DOORS ON EASTERN SIDE OF WORKSHOP	Wall	Cement Based		3	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITCC	24574016	C Block (Block 3)	C Block (Block 3)	Internal	Level 1	VARIOUS ROOMS	VINYL FLOOR TILES IN ROOMS 317 317 315 314 3114 STOREROOM FOYER ON SOUTHERN SIDE	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITCC	24574016	C Block (Block 3)	C Block (Block 3)	Internal	Ground Floor	ENTRY	VINYL TILES TO ENTRY	Floor Finish/Covering	Vinyl Tiles		2	Removed	34	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITCC	24574016	C Block (Block 3)	C Block (Block 3)	Internal	Level 1	INTERNAL	AC CEILING TILES IN STAFF TOILET MEN'S TOILET & IN ROOMS 318 317 315 & 314	Ceiling	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITCC	24574016	C Block (Block 3)	C Block (Block 3)	External	Level 1	OUTSIDE	COMPRESSED FIBRO FASCIA TO LOW SECTION OF ROOF FROM MAIN ENTRANCE TO COMPRESSOR ROOM	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITCC	24574016	C Block (Block 3)	C Block (Block 3)	External	Level 1	OUTSIDE	AC VENT PIPE PENETRATING ROOF IN COMPRESSOR ROOM S/E CORNER OF BUILDING	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITCC	24574016	C Block (Block 3)	C Block (Block 3)	External	Level 1	NORTH, SOUTH & EAST	DT SURROUNDS - 1 ON EASTSIDE 2 ON NORTH SIDE 6 ON SOUTH SIDE OF BUILDING	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITCC	24574016	C Block (Block 3)	C Block (Block 3)	External	Level 1	INFILL PANELS	SMALL COMPRESSED FIBRO INFILL PANELS BETWEEN WINDOWS LOCATED ABOVE & BELOW HOOD ON NORTH WALL	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITCC	24574016	C Block (Block 3)	C Block (Block 3)	External	Level 1	FASCIA	COMPRESSED FIBRO FASCIA TO LOWER SECTION OF ROOF ALONG NORTH SIDE OF BLOCK	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITCC	24574016	C Block (Block 3)	C Block (Block 3)	External	Level 1	EXTERNAL	1 X COMMUNICATION PIT ON SOUTHERN SIDE NEAR ROLLER DOOR	Drains/Pipes/Floors	Cement Based	Mixed	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITCC	24574016	C Block (Block 3)	C Block (Block 3)	External	Ground Floor	SHEETING TO FASCIA OF GROUND FLOOR SOUTHERN SIDE	SHEETING TO FASCIA OF GROUND FLOOR SOUTHERN SIDE	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITCC	24574016	C Block (Block 3)	C Block (Block 3)	External	Level 1	WEST END	COMPRESSED FIBRO WALL SHEETS ABOVE DOUBLE DOORS ON WEST END OF BLOCK	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITCC	24574016	C Block (Block 3)	C Block (Block 3)	Internal	Level 1	ABOVE ROLL-A-DOORS X3	GALBESTOS SHEETING ABOVE 3 ROLL-A-DOOR	Wall	Sprayed Coating	CHR - Chrysotile	2	Removed	69	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITDD	24574021	D Block (Block 4)	D Block (Block 4)	External	Level 1	EAST, NORTH & SOUTHERN WALLS	AC SHEETING ON EAST NORTH & SOUTH WALLS TO UPPER LEVEL OF BUILDING	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITDD	24574021	D Block (Block 4)	D Block (Block 4)	Internal	Level 1	STORE/OFFICE	AC SHEETING FIXED TO CEILING IN STORE ROOM (LARGER ROOM) IN UPPER LEVEL	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITDD	24574021	D Block (Block 4)	D Block (Block 4)	Internal	Level 1	STORE/OFFICE	AC CEILING IN SMALLER ROOM IN UPPER LEVEL OF BUILDING	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITDD	24574021	D Block (Block 4)	D Block (Block 4)	Internal	Ground Floor	ROOM 413	WALL LINING TO ROOM 413	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITDD	24574021	D Block (Block 4)	D Block (Block 4)	Internal	Ground Floor	INTERNAL	CEILING LINING TO CLASS ROOMS & ROOM 413	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITDD	24574021	D Block (Block 4)	D Block (Block 4)	External	Level 1	UPPER ROOMS	AC EXTERNAL CLADDING ON WESTERN WALL TO UPPER ROOMS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITDD	24574021	D Block (Block 4)	D Block (Block 4)	External	Level 1	FASCIA	AC FASCIA ON EAST WALL ADJACENT TO GLASS SLIDING DOORS LEADING TO OFFICE ON UPPER LEVEL	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITDD	24574021	D Block (Block 4)	D Block (Block 4)	External	Ground Floor	NORTHERN SIDE	WALL LINING TO NORTHERN SIDE ABOVE GLASS ENTRY DOORS & WINDOWS	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITDD	24574021	D Block (Block 4)	D Block (Block 4)	External	Ground Floor	NORTHERN & WESTERN ENDS	CEILING LINING TO NORTHERN & WESTERN ENDS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITDD	24574021	D Block (Block 4)	D Block (Block 4)	External	Level 1	SOFFIT	AC SOFFIT AROUND ALL SIDES OF UPPER LEVEL OF BUILDING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITEE	24574038	E Block (Block 5)	E Block (Block 5)	External	Ground Floor	BLOCK 5 FAC/TEACHING	ASBESTOS FREE - BUILT POST 1990	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITFF	24574025	F Block (Block 6)	F Block (Block 6)	Internal	Level 1	VARIOUS ROOMS	PERFORATED AC CEILING TILES IN CLEANER'S ROOM STAFF FEMALE & MALE TOILETS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITFF	24574025	F Block (Block 6)	F Block (Block 6)	Internal	Level 1	VARIOUS ROOMS	PERFORATED CEILING TILES IN STORE ADULT ED. & SMALL ROOMS ADJ. ADULT ED	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITFF	24574025	F Block (Block 6)	F Block (Block 6)	Internal	Level 1	VARIOUS ROOMS	VINYL FLOOR TILES UNDER CARPET IN STORE & SMALL ROOMS ADJ. TO ADULT ED	Floor Backing/Underlay	Vinyl Tiles		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITFF	24574025	F Block (Block 6)	F Block (Block 6)	Internal	Level 2	VARIOUS ROOMS	PERFORATED AC CEILING TILES IN VARIOUS OFFICES TOILETS & FOYER CLEANER'S ROOM & ON UPPER FLOOR	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITFF	24574025	F Block (Block 6)	F Block (Block 6)	Internal	Level 1	VARIOUS ROOMS	PERFORATED AC CEILING TILES IN SMALL OFFICE BETWEEN FEMALE STAFF TOILET & STAIRS WEST END	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITFF	24574025	F Block (Block 6)	F Block (Block 6)	Internal	Level 1	VARIOUS ROOMS	PERFORATED AC CEILING TILES IN OPEN SPACE ON SOUTH SIDE OF GENERAL OFFICE	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITFF	24574025	F Block (Block 6)	F Block (Block 6)	Internal	Level 1	VARIOUS ROOMS	PERFORATED AC CEILING TILES IN GENERAL OFFICE & MEETING ROOM	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITFF	24574025	F Block (Block 6)	F Block (Block 6)	Internal	Level 2	ROOM 6.2.11 CEILING TILES	CEILING TILES	Ceiling	Cement Based	No asbestos detected (NAD)	2	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITFF	24574025	F Block (Block 6)	F Block (Block 6)	Internal	Level 1	ROOM 216 PLANT ROOM	VINYL FLOOR TILES IN PLANT ROOM 215 ON S/E CORNER OF BLOCK	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEIRIR Score	Attention Required	Comments
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITFF	24574025	F Block (Block 6)	F Block (Block 6)	External	Ground Floor	SOUTH SIDE	DISCONNECTOR TRAP (DT) SURROUND SOUTHERN SIDE OF BUILDING	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITFF	24574025	F Block (Block 6)	F Block (Block 6)	External	Level 1	NORTH SIDE	DT SURROUNDS - 2 ON NORTH SIDE ONLY	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITFF	24574026	F Block (Block 6)	F Block (Block 6)	Internal	Level 1	CLEANERS ROOM	VINYL FLOOR TILES IN CLEANER'S ROOM	Floor Finish/Coverings	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITFF	24574026	F Block (Block 6)	F Block (Block 6)	Internal	Level 1	GENERAL OFFICE	VINYL FLOOR TILES UNDER CARPET IN GENERAL OFFICE & OPEN AREA ON SOUTH SIDE OF GENERAL OFFICE	Floor Backing/Underlay	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITFF	24574026	F Block (Block 6)	F Block (Block 6)	Internal	Level 1	OPEN AREA	SAMPLE TAKEN FROM CEILING TILES IN OPEN AREA ADJ TO ROOM 6.2.11 ON LEVEL 1	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	VARIOUS ROOMS	VINYL FLOOR TILES IN ROOMS 711M POSSIBLY UNDER CARPET IN 711L PO & 71V	Floor Finish/Coverings	Vinyl Tiles		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 2	VARIOUS ROOMS	AC WALL SHEETING ON OUTSIDE OF ROOMS THROUGHOUT	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 2	TOILETS	AC SHEETS ON WALLS FEMALE & MALE STAFF TOILETS MALE TOILETS RM 71K AT SOUTH END OF BLOCK	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 2	HALLWAY	AC WALL LINING ON BOTH SIDE OF HALLWAY ALONG EAST SIDE OF BLOCK	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 2	ROOM 71AB HOT WATER SYSTEM ROOM	AC VENT PIPE PENETRATING THROUGH ROOF IN HOT WATER SYSTEM ROOM LOCATED INSIDE 71AB	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 2	ROOM 71AC	AC SHEETING ON EAST & WEST WALLS IN ROOM 71AC	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 2	ROOM 722	1 X AC VENT PIPE GOING FROM ROOM 722 THROUGH TO ROOF	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 2	ROOMS 71AC & 71AE	AC SHEETING ON WALL OUTSIDE ROOMS 71AC & 71AE ON SOUTHERN SIDE	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 2	TOILETS	AC CEILING IN MALE STAFF FEMALE STAFF TOILETS & ROOM 71K AT SOUTHERN END OF BLOCK	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 2	HALLWAY	AC CEILING TO HALLWAY ALONG EASTERN SIDE OF BUILDING UP TO ROOM 71P	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 2	TOILETS	AC VENT PIPE IN FEMALE STAFF TOILET AT SOUTHERN END OF BLOCK	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	VARIOUS ROOMS	VINYL FLOOR TILES IN FIRST AID ROOM & IN ROOM 7GI 7116 & 7117	Floor Finish/Coverings	Vinyl Tiles		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 2	VARIOUS ROOMS	AC CEILING IN ROOMS 71L & CLASSROOM 71O	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	STORE	VINYL FLOOR TILES IN STORE BETWEEN BOAT BLDG. & MOTOR BODY BLDG. TRADE	Floor Finish/Coverings	Vinyl Tiles		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 2	VARIOUS ROOMS	AC WALLS IN ROOMS 71L M O P R U V. NOTE-SOME WALLS ARE PLY & GYPPOCK	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 2	VARIOUS ROOMS	COMPRESSED FIBRO LINING ON TOILET/SHOWER PARTITIONS IN ROOMS 71AA & MALE STAFF TOILET	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 2	VARIOUS ROOMS	VINYL FLOOR TILES IN VARIOUS ROOMS	Floor Finish/Coverings	Vinyl Tiles		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Mezzanine 1	AUTOMOTIVE	SAMPLE SWITCHBOARD	Plant, Equipment & Machinery	Polymer Bonded	CHR - Chrysotile	4	Confirmed	25	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Mezzanine 1	INTERNAL	WALL LINING TO MEZZANINE LEVEL	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Mezzanine 1	SWITCHBOARD	ZELEMIT BACKING TO SWITCHBOARD BEHIND THE ESCUTCHEON PANEL	Insulation/Fill	Polymer Bonded		4	Presumed	25	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Mezzanine 1	UPHOLSTER,TRADE	AC WALL LINING IN CLEANER'S DIRECTOR'S ROOM SPRAY BOOT & ROOM 71E ON NORTH SIDE OF ROOM	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Mezzanine 1	UPHOLSTER,TRADE	VINYL FLOOR TILES THROUGHOUT UPHOLSTERY SECTION	Floor Finish/Coverings	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 2	TOILETS	COMPRESSED FIBRO TOILET & SHOWER PARTITIONS IN MALE & FEMALE TOILETS (SOUTH)	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	PANEL BEATING ROOM	COMPRESSED FIBRO SHEETS ON WELDING BAYS ON NORTH SIDE OF PANEL BEATING ROOM	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 2	VARIOUS ROOMS	AC SHEETING ON WALLS TO ROOMS 71AA AB AE AF W X Y Z & MALE STAFF TOILET	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Various levels Internal	EAST STAIRS	INFILL PANELS TO BALUSTRADE EASTERN STAIRS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	External	Level 1	EXTERNAL	COMPRESSED FIBRO MOULDED CURVE SECTIONS ON VARIOUS CORNERS OF BLOCK AND DOORWAYS	Wall	Cement Based		3	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	External	Level 1	NORTH, EAST & WEST	AC D.T. SURROUNDS - 4 ON EAST 2 ON NORTH & 3 ON WEST SIDE OF BLOCK	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	External	Level 1	ROOM 7114	WALL LINING TO EXTERNAL OFFICE ROOM 7114	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	External	Various levels External	SUN HOODS	COMPRESSED SHEETS ON SUN HOODS ON N E WALL (ABOVE GAS BOTTLES) SIDE OF BLOCK	Sun Hood	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	AUTOMOTIVE	SAMPLE SWCHBOARD EAST	Plant, Equipment & Machinery	Polymer Bonded	CHR - Chrysotile	4	Confirmed	25	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	AUTOMOTIVE	SAMPLE SWCHBOARD WEST	Plant, Equipment & Machinery	Polymer Bonded	CHR - Chrysotile	4	Confirmed	25	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	BODY BLDG. WKSHOP	AC PANELS ABOVE DOUBLE DOORS TO S/E ENTRANCE TO MOTOR BODY BUILDING WORKSHOP	Wall	Cement Based	Mixed	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	SWITCHBOARD	POSSIBLE ZELEMITE BACKING TO SWITCHBOARD BEHIND THE ESCUTCHEON PANEL	Insulation/Fill	Polymer Bonded		4	Presumed	25	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	FOYER	VINYL FLOOR TILES IN FOYER ON RIGHT OF INTERNAL GATES LEADING TO UPHOLS	Floor Finish/Coverings	Vinyl Tiles		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	VARIOUS ROOMS	AC WALL SHEETING BEHIND METAL PERFORATED SHEETS ON WALLS OUTSIDE ROOMS 7GI GM GO GR G8 & G9	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	ROOM 7115 MOTOR TRIMMING WORKSHOP	CURVED COLUMN PROTECTORS TO LARGE TILT DOORS WESTERN SIDE OF MOTOR TRIMMING WORKSHOP	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	ROOM 7121 PANEL BEATING WORKSHOP	CURVED COLUMN PROTECTORS TO LARGE TILT DOORS WESTERN SIDE OF PANEL BEATING WORKSHOP	Wall	Cement Based	Mixed	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	ROOM 7128 PAINT STORE ROOM	1 SET OF DOUBLE LEAF FIRE DOORS TO PAINT STORE ROOM 7128	Fire Door	Loose Fill	Mixed	3	Confirmed	64	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	ROOM 7GW	COMPRESSED FIBRO WALL PANELS IN WELDING BAYS IN ROOM 7GW	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	ROOMS 7GR & 7GQ	SPRAYED COATING TO CEILING IN ROOM 7GR & 7GQ	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	ROOMS 7GR & 7GQ	SPRAYED COATING TO CEILING IN ROOM 7GR & 7GQ	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	STORE	AC PANELS ABOVE DOUBLE DOORS & DOORS TO STOREROOM BETWEEN BOAT BLDG & MOTOR BODY BLDG & ROOM 7110	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	SWITCHBOARD	POSSIBLE ZELEMITE BACKING TO SWITCHBOARD 7 DBC	Insulation/Fill	Polymer Bonded		4	Presumed	25	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	VARIOUS ROOMS	AC SHEETS ON WALLS IN ROOM 7G9 & IN ADJACENT STORE (IE. ROOM 7G8)	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	

TAFEs from BEIRIR-TAFEs

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 1	FIRST AID ROOM	AC SHEETING ON SOUTHERN WALL INCLUDING ABOVE DOOR IN FIRST AID ROOM	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITGG	24574026	G Block (Block 7A)	G Block (Block 7A)	Internal	Level 2	VARIOUS ROOMS	AC CEILING IN ROOMS 71AA AB Y & MALE STAFF TOILETS	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITHH	24574030	H Block (Block 7B)	H Block (Block 7B)	External	Level 1	PANEL BEAT	STEEL PORTALS AND IRON CLADDING	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 2	ROOMS 20 21 22	SHEET VINYL FLOOR TO ROOMS 20 21 AND 22	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 2	PASSAGEWAY	1 X SET DOUBLE DOOR TO ELECT CUPBOARD 8-1-2	Fire Door	Cement Based	Mixed	2	Removed	34	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 2	PASSAGEWAY	SET DOUBLE FIRE DOORS TO ELECT CUPBOARD RM 8-1-11	Fire Door	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 2	PLANT ROOM	AC WALL SHEETS ON NORTH WALL IN PLANT ROOM ADJACENT 8.2.9	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 2	PLANT ROOM	LOOSE FILL INSIDE OLD RHEEM H/WATER UNIT ROOM 8.29	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 2	PLANT ROOM PIPEWORK	TEXTILE TO PIPE SADDLE FROM OLD DISUSED HOT WATER UNIT IN PLANT ROOM APPROX 6 SADDLES	Insulation/Fill	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 2	FIRE ESCAPE WESTERN SIDE	FIRE DOOR WESTERN SIDE LEVEL 1 WITH GLASS PANEL	Fire Door	Cement Based	Mixed	2	Removed	34	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 2	ROOM 828 TO PLANT ROOM	1 X DOUBLE LEAF FIRE DOOR FROM ROOM 828 TO THE PLANT ROOM	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 2	PLANT ROOM	POSSIBLE ACM IN HOT WATER SYSTEM & HEATING EQUIPMENT USED IN SPRAY PAINTING BOOTHS	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 2	SPRAY BOOTH 3	WALL LINING TO WESTERN WING NEAR EXTRACTION UNIT TO SPRAY BOOTH 3	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 2	SWITCHBOARD ROOM	FIRE PROOF LINING TO CORE OF DOUBLE DOORS TO SWITCHBOARD E & W END OF VERANDAH (SAMPLED NAD 200405)	Fire Door	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 2	TEA ROOM	VINYL FLOOR TILES IN TEA ROOM SITUATED INSIDE ROOM 81Z	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 2	TOILETS	AC CEILING IN MALE TOILETS ON EAST END & IN FEMALE TOILETS ON WEST END OF SPRAY PAINT BLDG	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 2	VARIOUS ROOMS	PERFORATED CEILING TILES IN ROOMS 8.2.10 8.2.9 8.2.17 8.2.20 8.2.21 & 8.2.22	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Various levels Internal	STAIRWELLS	FIRE PROOF LINING INSIDE CORE OF FIRE DOORS TO STAIRWELLS ON WEST & EAST END OF BLOCK	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 2	ROOM 14	SAMPLE TAKEN FROM CEILING OF ROOM 14 SAME CEILING CONTINUES THROUGH ROOMS 15 & 16	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	External	Various levels External	SOFFIT	AC SOFFIT ON N & S SIDE OF BLDG UNDER HOODS ON S SIDE & ABOVE N/E ENTRANCE	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 2	PLANT ROOM PIPEWORK	TEXTILE WRAPPED ON HOT WATER PIPE ON EVERY SADDLE JOINT ON LEVEL 2 APPROX 50. CHK ALL 75MM HT WATER SADDLES	Drains/Pipes/Fittings	Woven Textile		2	Removed	69	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	External	Level 1	EXTERNAL	VARIOUS COMPRESSED WALL PANELS ABOVE WINDOWS & DOORS AROUND BUILDING	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 2	FIRE ESCAPE EASTERN SIDE	FIRE DOOR EASTERN SIDE ON LEVEL 1 DOOR 8-1-1	Fire Door	Cement Based	Mixed	2	Removed	34	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 1	BOX DUCTING	FIRE CEMENT WALL AND BOX DUCTING LINING	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 1	CHEMICAL STORE	MATERIAL IN CORE OF FIRE DOOR TO CHEMICAL STORE	Fire Door	Cement Based	Mixed	2	Removed	34	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 1	FIRE ESCAPE EASTERN SIDE	FIRE DOOR EASTERN SIDE FIRE ESCAPE 1 X GLASS PANEL	Fire Door	Cement Based	Mixed	2	Removed	34	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 1	FIRE ESCAPE WESTERN SIDE	FIRE DOOR WESTERN END NO 860 (WITH PYREX VIEW PANE)	Fire Door	Cement Based	Mixed	2	Removed	34	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 1	GUN WASH ROOM	MATERIALS IN FIRE DOOR WITH A PYREX VIEW PANEL	Fire Door	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 1	PASSAGEWAY	MATERIALS S/BOARD C/BOARD DOORS BESIDE ROOM 8.64	Fire Door	Cement Based	Mixed	2	Removed	34	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	External	Level 1	LOUVRE PANELS Various Levels	FIBRE CEMENT LOUVRE PANELS OUTSIDE THE WINDOWS	Wall	Cement Based	Mixed	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 1	PLANT ROOM PIPEWORK	TEXTILE ON EVERY SADDLE TO HOT WATER PIPE (APPROX 120) ON LEVEL 1. CHK ALL 100MM PIPE SADDLES	Insulation/Fill	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 1	SAND BLASTING	MATERIAL TO COMP AIR PIPE SADDLE CABINET STN WEST	Drains/Pipes/Fittings	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 1	TOILETS	AC CEILING IN MALE & FEMALE STAFF TOILET AT EASTERN END OF SPRAY PAINTING BUILDING	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	External	Various levels External	FASCIA	FASCIA ON N & S SIDE OF BLDG INCLUDING ON HOODS ABOVE N/E ENTRANCE & ROLLER DOORS S SIDE	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITI	24574027	I Block (Block 8)	I Block (Block 8)	Internal	Level 1	PASSAGEWAY	MATERIAL S/BOARD C/BOARD BESIDE EASTERN EXIT DOOR	Fire Door	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITJJ	24574028	J Block (Block 9)	J Block (Block 9)	Internal	Level 1	VARIOUS ROOMS	AC SHEETING ON ALL INTERNAL WALLS IN ADMINISTRATION AREA AT EASTERN END OF BLOCK	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITJJ	24574028	J Block (Block 9)	J Block (Block 9)	External	Ground Floor	FASCIA	AC FASCIA ALONG N & S SIDE OF BLDG & ON E & W SIDE OF COVERED LINK BETWEEN BLOCK 8 & BLOCK 9	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITJJ	24574028	J Block (Block 9)	J Block (Block 9)	Internal	Ground Floor	ROOM 12	SHEET VINYL FLOOR TO ROOM 12	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITKK	24574040	K Block (Block 10)	K Block (Block 10)	Internal	Level 2	PARTITIONS & UNDER WINDOWS	WALL SHEETING TO ALL PARTITIONS AND UNDER THE LOUVRE	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITKK	24574040	K Block (Block 10)	K Block (Block 10)	External	Level 2	INFILL PANELS	INFILL PANELS BETWEEN THE SOFFIT AND WALLS	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITKK	24574040	K Block (Block 10)	K Block (Block 10)	Internal	Level 2	INTERNAL	CEILING SHEETS THROUGHOUT LEVEL 2	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITLL	24574008	L Block (Block 11)	L Block (Block 11)	External	Roof Level 2	EXTERNAL NORTH	AC CEILING ABOVE STAIRS TO MAIN ENTRANCE ON NORTH SIDE	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITLL	24574008	L Block (Block 11)	L Block (Block 11)	Internal	Roof Level 1	ROOM 11.1.5	NO ACCESS TO ROOM	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITLL	24574008	L Block (Block 11)	L Block (Block 11)	Internal	Roof Level 2	VARIOUS ROOMS	VINYL FLOOR TILES UNDER CARPET IN CONFERENCE RM OFFICE RECEPTION & ADJOINING STOREROOM & SVC CPBRD	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITLL	24574008	L Block (Block 11)	L Block (Block 11)	Internal	Roof Level 2	VARIOUS ROOMS	VINYL FLOOR TILES UNDER CARPET IN ANIMAL VET.SERV. OFFICES & HORTICULT.OFF	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITLL	24574008	L Block (Block 11)	L Block (Block 11)	Internal	Roof Level 2	VARIOUS ROOMS	VINYL FLOOR TILES IN HALLWAYS MALE FEMALE STAFF & UNISEX DISABLED TOILETS	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITLL	24574008	L Block (Block 11)	L Block (Block 11)	Internal	Roof Level 2	STAFF LUNCH RM	VINYL FLOOR TILES UNDER CARPET & IN FRONT OF SINK IN STAFF LUNCH RM	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	

TAFES from BEMIR-TAFES

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other	Int. Est.	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITLL	24574008	L Block (Block 11)	L Block (Block 11)	Internal	Roof Level 2	SERVICE CUPBOARD	24 X 225X225 VINYL FLOOR TILES STORED ON THE AIR HANDLING UNIT INSIDE THE SERVICE CUPBOARD	Stored Material	Vinyl Tiles	CHR - Chrysotile	3	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITLL	24574008	L Block (Block 11)	L Block (Block 11)	Internal	Roof Level 1	ROOM 11.1.8	NO ACCESS TO ROOM	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITLL	24574008	L Block (Block 11)	L Block (Block 11)	Internal	Roof Level 1	ROOM 11.1.6	NO ACCESS TO ROOM	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITLL	24574008	L Block (Block 11)	L Block (Block 11)	Internal	Roof Level 1	ANIMAL CHECK-IN	FLOOR TO THE ANIMAL CHECK IN ROOM	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITLL	24574008	L Block (Block 11)	L Block (Block 11)	Internal	Ground Floor	LAB CLASSROOM	AC SHEETING ON WALL TO ALL INTERNAL PARTITIONS IN ALL ROOMS UNDER BLOCK	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITLL	24574008	L Block (Block 11)	L Block (Block 11)	External	Roof Level 2	EXTERNAL	COMPRESSED FIBRO WALL INFILL PANELS UNDER WINDOW ON NORTH EAST & SOUTH WALLS	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITLL	24574008	L Block (Block 11)	L Block (Block 11)	External	Roof Level 2	EXTERNAL	AC SOFFIT ALONG NORTH & SOUTH SIDE OF BUILDING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITLL	24574008	L Block (Block 11)	L Block (Block 11)	External	Roof Level 2	EXTERNAL	AC FASCIA AROUND ENTIRE BUILDING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITLL	24574008	L Block (Block 11)	L Block (Block 11)	External	Roof Level 1	DOG WASH	TILUX WALL SHEETING TO THE DOG WASHER AREA UNDER THE BATH TUB	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITLL	24574008	L Block (Block 11)	L Block (Block 11)	External	Roof Level 1	DOG WASH	1 X DISCONNECTOR (DT) SURROUND IN THE DOG WASH BAY AREA	Drains/Pipes/Fittings	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITLL	24574008	L Block (Block 11)	L Block (Block 11)	Internal	Roof Level 1	ROOM 11.1.1 & 11.1.4	EASTERN WALL OF ROOM 11.1.1 & 11.1.4 IS SUSPECTED TO BE AC SHEETED	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITMM	24574007	M Block (Block 12)	M Block (Block 12)	External	Roof Level 1	EXTERNAL	AIRCORN UNIT EASTERN SIDE OF BLOCK 12 MAY HAVE HEATER BANS (NO ACCESS)	Hoister Bank Insulation	Milboard		4	Presumed	64	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITMM	24574007	M Block (Block 12)	M Block (Block 12)	Internal	Roof Level 1	VARIOUS ROOMS	INFILL PANELS ABOVE ALL PARTITIONS AND WALLS IN RM 12.10 ON E WALL IN 2 STAFF RMS & RMS 12.9 12.11	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITMM	24574007	M Block (Block 12)	M Block (Block 12)	Internal	Roof Level 1	VARIOUS ROOMS	AC CEILING IN ROOMS 12.4 12.5 12.6 12.7 12.8 12.9 12.10 12.11 & HALLWAY	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITMM	24574007	M Block (Block 12)	M Block (Block 12)	Internal	Roof Level 1	ROOM 12-7	SHEET VINYL FLOOR TO ROOM 12 - 7	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITMM	24574007	M Block (Block 12)	M Block (Block 12)	Internal	Roof Level 1	HALLWAY	AC WALL SHEETS IN HALLWAY	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITMM	24574007	M Block (Block 12)	M Block (Block 12)	External	Roof Level 1	VERANDAH S/W CNR	SHEETING TO CEILING OF VERANDAH ON SOUTH WEST CORNER OF BUILDING	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITMM	24574007	M Block (Block 12)	M Block (Block 12)	External	Roof Level 1	VERANDAH S/W CNR	AC SHEETING ON WALL BEHIND A/C UNIT ON VERANDAH ON S/W CORNER OF BUILDING	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITMM	24574007	M Block (Block 12)	M Block (Block 12)	External	Roof Level 1	EXTERNAL	COMPRESSED FIBRO PANEL UNDER WINDOWS ON ALL SIDES OF BLD	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITMM	24574007	M Block (Block 12)	M Block (Block 12)	External	Roof Level 1	EXTERNAL	AC SHEETING ON WEST SIDE OF GABLE END WALLS OF SAW TOOTH ROOF	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITMM	24574007	M Block (Block 12)	M Block (Block 12)	External	Roof Level 1	EXTERNAL	INFILL PANEL ABOVE MAIN ENTRY WESTERN SIDE OF BLOCK 12	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITNN	24574006	N Block (Block 13)	N Block (Block 13)	External	Roof Level 2	EXTERNAL	SHEETING TO GABLE END NORTHERN SIDE	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITNN	24574006	N Block (Block 13)	N Block (Block 13)	Internal	Roof Level 2	VARIOUS ROOMS	AC CEILING THROUGHOUT UPPER LEVEL OF HOUSE INCLUDING VERANDAH CEILING	Ceiling	Cement Based	Mixed	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITNN	24574006	N Block (Block 13)	N Block (Block 13)	Internal	Roof Level 2	KITCHEN	SHEET VINYL ON FLOOR IN KITCHEN	Floor Finish/Covering	Vinyl Sheeting (includes backing)	CHR - Chrysotile	3	Confirmed	62	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITNN	24574006	N Block (Block 13)	N Block (Block 13)	Internal	Roof Level 2	VARIOUS ROOMS	AC SHEETS ON ALL WALLS IN BATHROOM INCL. SHOWER CUBICLE & ON WALLS AROUND STOVE IN KITCHEN	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITNN	24574006	N Block (Block 13)	N Block (Block 13)	External	Roof Level 2	EXTERNAL	AC WALL SHEETS ADJ. FRONT ENTRANCE DOOR & ABOVE/BELOW WINDOWS OUTSIDE VERANDAH	Wall	Cement Based		3	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITNN	24574006	N Block (Block 13)	N Block (Block 13)	External	Roof Level 1	EXTERNAL	SHADOWLINE WALL SHEETING ENCLOSING GARAGE AREA ON ALL WALLS AROUND HOUSE	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITNN	24574006	N Block (Block 13)	N Block (Block 13)	Internal	Roof Level 1	GARAGE	AC SHEETING ON PARTITION OUTSIDE HORTICULTURAL STORE UNDER HOUSE	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITNN	24574006	N Block (Block 13)	N Block (Block 13)	External	Roof Level 2	FRONT VERANDAH	AC SHEETS ADJ. FRONT DOOR & ON WALL BELOW WINDOWS IN VERANDAH ON NIE CORNER OF HOUSE	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITOO	24574042	O Block (Block 14)	O Block (Block 14)	Internal	Level 1	VARIOUS ROOMS	VINYL FLOOR TILES IN TOILET & OFFICE ON NIE CORNER OF UNDER HOUSE AREA	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITOO	24574042	O Block (Block 14)	O Block (Block 14)	Internal	Level 2	BATHROOM	AC SHEETING TO SHOWER PARTITION WALLS & LINING AROUND SHOWER CUBICLE	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITOO	24574042	O Block (Block 14)	O Block (Block 14)	Internal	Level 1	DOG GROOMING	COMBINATION OF AC FIBRO PLY & MASONITE WALLS TO ALL ROOMS UNDER HOUSE	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITOO	24574042	O Block (Block 14)	O Block (Block 14)	External	Level 1	SOUTH, EAST & NORTHERN WALLS	AC SHEETING ON WALL ON SOUTH EAST & NORTH WALLS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITOO	24574042	O Block (Block 14)	O Block (Block 14)	External	Level 1	PERIMETER FENCE	AC PERIMETER FENCE TO THE REAR OF THE GARDEN	Fencing	Cement Based	Mixed	2	Removed	34	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITOO	24574042	O Block (Block 14)	O Block (Block 14)	External	Level 1	NORTHERN SIDE	SHEETING TO GABLE END NORTHERN SIDE	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITOO	24574042	O Block (Block 14)	O Block (Block 14)	External	Level 1	GROOMING OFFICE	AC SHEETING ON WALL ON WESTERN SIDE OF GROOMING OFFICE ENTRANCE DOOR ON N SIDE OF HOUSE	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITOO	24574042	O Block (Block 14)	O Block (Block 14)	Internal	Level 2	VARIOUS ROOMS	AC CEILING THROUGHOUT UPPER LEVEL OF HOUSE	Ceiling	Cement Based	Mixed	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITPP	24574039	P Block (Block 19)	P Block (Block 19)	Internal	Level 1	WESTERN WING/ROOMS	SHEETING TO WINDOW REVEALS IN VARIOUS ROOMS IN WESTERN WING	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITPP	24574039	P Block (Block 19)	P Block (Block 19)	Internal	Level 1	FURNITURE STORE	SHEETING TO WALL IN FURNITURE STORE AT WESTERN END OF WESTERN WING	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITPP	24574039	P Block (Block 19)	P Block (Block 19)	Internal	Various levels Internal	EASTERN & WESTERN STAIRWELLS	VINYL FLOOR TILES TO STAIRWELLS ON EASTERN AND WESTERN ENDS	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITPP	24574039	P Block (Block 19)	P Block (Block 19)	Internal	Level 2	WESTERN WING/ROOMS	SHEETING TO WALLS & WINDOW REVEALS IN VARIOUS ROOMS OF WESTERN WING	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITPP	24574039	P Block (Block 19)	P Block (Block 19)	Internal	Level 2	WESTERN WING/ROOMS	FLOOR TILES TO WESTERN WING VARIOUS ROOMS	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITPP	24574039	P Block (Block 19)	P Block (Block 19)	Internal	Level 2	TOILET & ARC WELD ROOM	NO ACCESS TO TOILET AND ARC WELDING ROOM	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITPP	24574039	P Block (Block 19)	P Block (Block 19)	Internal	Level 2	SOUTH WEST WING	SHEETING TO WINDOW REVEALS IN SOUTH WEST WING	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITPP	24574039	P Block (Block 19)	P Block (Block 19)	Internal	Level 2	INTERNAL	CEILING TILES IN WESTERN WING EXCLUDING CHEMICAL STORE AT SOUTH WEST CORNER	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITPP	24574039	P Block (Block 19)	P Block (Block 19)	Internal	Level 2	EASTERN WING/ROOMS	VINYL FLOOR TILES THROUGHOUT EASTERN WING	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITPP	24574039	P Block (Block 19)	P Block (Block 19)	Internal	Level 2	EASTERN WING/ROOMS	CEILING TILES TO VARIOUS ROOMS TO EASTERN WING	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITPP	24574039	P Block (Block 19)	P Block (Block 19)	Internal	Level 2	CHEMICAL STORE/ROOM	SHEETING TO CHEMICAL STORE ROOM, SOUTH WEST CORNER	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITPP	24574039	P Block (Block 19)	P Block (Block 19)	External	Various levels External	NORTHERN & SOUTHERN SIDES	VENT PIPES FROM LEVEL 1 PENETRATING THROUGH TO ROOF ON NORTHERN & SOUTHERN SIDES OF BLOCK 19	Drains/Pipes/Fittings	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITPP	24574039	P Block (Block 19)	P Block (Block 19)	Internal	Level 1	INTERNAL	SHEETING TO WINDOW REVEALS IN VARIOUS ROOMS SOUTH EAST & WEST SIDE OF EASTERN WING	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HITPP	24574039	P Block (Block 19)	P Block (Block 19)	Internal	Level 1	INTERNAL	VINYL FLOOR TILES TO FOREMAN'S OFFICE ENTRY FOYER AIR LOCK AND CLEANER'S ROOM IN WESTERN WING	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HTPP	24574039	P Block (Block 19)	P Block (Block 19)	External	Level 2	SOFFIT	SOFFIT TO EXTERNAL OF BLOCK 19	Gable/Soffit ascb	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HTPP	24574039	P Block (Block 19)	P Block (Block 19)	Internal	Ground Floor	STORE ROOM	SHEET VINYL FLOOR TO GROUND FLOOR STORE ROOM	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HTPP	24574039	P Block (Block 19)	P Block (Block 19)	Internal	Level 1	EASTERN WING STAIRWELL	WALL LINING TO SUSPENDED CEILINGS IN EASTERN WING STAIRWELL	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HTPP	24574039	P Block (Block 19)	P Block (Block 19)	Internal	Level 1	EASTERN WING/ROOMS	CEILING TILES TO VARIOUS ROOMS IN EASTERN WING	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HTPP	24574039	P Block (Block 19)	P Block (Block 19)	Internal	Level 1	EASTERN WING/ROOMS	VINYL FLOOR TILES TO VARIOUS ROOMS IN EASTERN WING	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HTPP	24574039	P Block (Block 19)	P Block (Block 19)	Internal	Level 1	INTERNAL	CEILING TILES TO AIR LOCK TOILETS AND FIRST AID ROOM IN WESTERN WING	Ceiling	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HTPP	24574039	P Block (Block 19)	P Block (Block 19)	External	Level 2	FASCIA	FASCIA BARGE TO EXTERNAL OF BLOCK 19	Gable/Soffit ascb	Cement Based		4	Presumed	18	-	
Brisbane North		ITHACA TAFE CAMPUS	ITHACA TAFE CAMPUS	HTQQ		Q Block (Block 20)	Q Block (Block 20)											-	
Brisbane North		REDCLIFFE TAFE CAMPUS - BNI	REDCLIFFE TAFE CAMPUS - BNI	HRE	34461000	** Site - Grounds	** Site - Grounds											-	
Brisbane North		REDCLIFFE TAFE CAMPUS - BNI	REDCLIFFE TAFE CAMPUS - BNI	HRE01	34461004	Amenities	Amenities											-	
Brisbane North		REDCLIFFE TAFE CAMPUS - BNI	REDCLIFFE TAFE CAMPUS - BNI	HRE02	34461005	Canteen	Canteen											-	
Brisbane North		REDCLIFFE TAFE CAMPUS - BNI	REDCLIFFE TAFE CAMPUS - BNI	HRE03	34461007	Grounds Shed	Grounds Shed											-	
Brisbane North		REDCLIFFE TAFE CAMPUS - BNI	REDCLIFFE TAFE CAMPUS - BNI	HREAA	34461001	A Block	A Block											-	
Brisbane North		REDCLIFFE TAFE CAMPUS - BNI	REDCLIFFE TAFE CAMPUS - BNI	HREBB	34461006	B Block	B Block											-	
Brisbane North		REDCLIFFE TAFE CAMPUS - BNI	REDCLIFFE TAFE CAMPUS - BNI	HRECC	34461002	C Block	C Block											-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSB	25687000	** Site - Grounds	** Site - Grounds											-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 3	FEMALE TOILET ROOM 306 LEVEL 3	INSULATION TO SANITARY INCINERATOR	Plant, Equipment & Machinery	Milboard		4	Presumed	64	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 3	STAIRWELL 6 LEVEL 3	INTERNAL LINING TO EXIT FIRE DOOR	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 3	STAIRWELL 3 LEVEL 3	INTERNAL LINING TO EXIT FIRE DOOR	Fire Door	Milboard		4	Presumed	64	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 3	STAIRWELL 2 LEVEL 3	INTERNAL LINING TO EXIT FIRE DOOR	Fire Door	Milboard	AMO - Amosite	4	Confirmed	64	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 3	STAIRWELL 1 LEVEL 3	INTERNAL LINING TO EXIT FIRE DOOR	Fire Door	Milboard		4	Presumed	64	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 3	STAFF RESOURCE LEVEL 3	VERMICULITE TO STEEL ROOF AND SUPPORT BEAMS	Ceiling	Sprayed Coating	CHR - Chrysotile	4	Confirmed	64	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 3	STAFF RESOURCE LEVEL 3	INTERNAL LINING TO HEATER BANKS IN CEILING SPACE	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 3	STAFF FACILITY LEVEL 3	CREAM VINYL TILES TYPE ENTIRE LEVEL	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 3	REST ROOM LEVEL 3	CREAM VINYL TILES TYPE ENTIRE LEVEL	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Basement 1	SPRINKLER PUMP BASEMENT 1	LOOSE FILL TO HEAT SHIELD FOR DIESEL MOTOR EXHAUST PIPE	Drains/Pipes/Floors	Loose Fill	CHR - Chrysotile	4	Confirmed	64	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	MALE CHANGE ROOM LEVEL 1	GREY AND BLACK VINYL SHEETING TO THE FLOOR	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	MALE CHANGE ROOM LEVEL 1	CREAM VINYL TILES	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	GENERATOR ROOM LEVEL 1	INTERNAL LINING TO EXHAUST PIPE MUFFLER STORED	Stored Material	Woven Textile		4	Presumed	64	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	GENERATOR ROOM LEVEL 1	INTERNAL LINING TO EXHAUST PIPE MUFFLER	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	GENERATOR ROOM LEVEL 1	GASKETS TO VOLVO PENTA DIESEL MOTOR AND DUNLITE ALTERNATOR	Gasket	Polymer Bound		4	Presumed	25	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	FEMALE TOILET SOUTH LEVEL 1	INSULATION TO SANITARY INCINERATOR	Plant, Equipment & Machinery	Milboard		4	Presumed	64	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	FEMALE TOILET LEVEL 1	SHEETING TO TOILET PARTITIONS NORTH END	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	ENTRY LOBBY LEVEL 1	VERMICULITE TO CEILING OF ENTRY FOYER	Ceiling	Sprayed Coating	CHR - Chrysotile	4	Confirmed	64	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	ENTRY LOBBY LEVEL 1	SHEETING OVER ENTRY FOYER	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	ENTRY LOBBY LEVEL 1	ORANGE VINYL SHEETING TYPICAL ENTIRE LEVEL	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Ground Floor	GROUND'S PERSONS ROOM GROUND LEVEL	GASKETS TO COMPRESSOR	Gasket	Polymer Bound		4	Presumed	25	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 3	MALE TOILET LEVEL 3	SHEETING TO TOILET PARTITIONS NORTH END	Wall	Cement Based		4	Presumed	18	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Basement 1	STAIRWELL 5 BASEMENT 1	INTERNAL LINING TO EXIT FIRE DOOR	Fire Door	Milboard		4	Presumed	64	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	ROOM 101 LUNCH ROOM LEVEL 1	BLACK VINYL SKIRTING TYPE ENTIRE LEVEL	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Basement 1	SPRINKLER PUMP BASEMENT 1	GASKETS TO DIESEL MOTOR FOR SPRINKLER WATER PUMP	Gasket	Polymer Bound		4	Presumed	25	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Basement 1	HYDRANT PUMP ROOM BASEMENT 1	GREY MASTIC EXPANSION JOINT SEALANT TYPE ENTIRE LEVEL	Floor	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Basement 1	HYDRANT PUMP ROOM BASEMENT 1	GASKETS TO DIESEL MOTOR FOR FIRE HYDRANT PUMP	Gasket	Polymer Bound		4	Presumed	25	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Basement 1	CAR PARK BASEMENT 1	INTERNAL LINING TO FIRE DOOR AT REAR EXIT TUNNEL	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Basement 1	CAR PARK BASEMENT 1	INTERNAL LINING TO EXIT FIRE DOOR ADJACENT ROLLER DOOR	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	External	Roof Level 1	ROOF AND PLANT AREA ROOF LEVEL 1	MASTIC TO DUCT JOINTS	Membrane	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	External	Roof Level 1	ROOF AND PLANT AREA ROOF LEVEL 1	BITUMEN ROOF MEMBRANE TO THE PERIMETER	Membrane	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	External	Level 1	DRAIN LEVEL 1	CB CEMENT BASED PROFILE TO DRAIN ADJACENT TO THE PRINT ROOM ENTERANCE	Drains/Pipes/Floors	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMR Score	Attention Required	Comments
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	External	Level 1	ASSESSMENT OFFICE LEVEL 1	SHEETING TO REAR EXTERNAL WALL	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	External	Ground Floor	SWITCHBOARD BOX GROUND LEVEL	BACKING BOARD TO THE ELECTRICAL METER BOARD	Plant, Equipment & Machinery	Polymer Board	No asbestos detected (NAD)	NA	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	External	Basement 1	CAR PARK BASEMENT 1	BITUMINOUS MEMBRANE BETWEEN BRICK WALL AND CONCRETE CEILING	Membrane	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Ground Floor	CAR PARK GROUND LEVEL	CORE INSULATION TO FIRE DOOR	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 2	FEMALE TOILET LEVEL 2	SHEETING TO TOILET PARTITIONS NORTH END	Wall	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 2	STAIRWELL 3 LEVEL 2	INTERNAL LINING TO EXIT FIRE DOOR	Fire Door	Millboard	No asbestos detected (NAD)	4	Presumed	64	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 3	FEMALE TOILET LEVEL 3	SHEETING TO TOILET PARTITIONS NORTH END	Wall	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 2	STAIRWELL 6 LEVEL 2	INTERNAL LINING TO EXIT FIRE DOOR	Fire Door	Millboard	No asbestos detected (NAD)	4	Presumed	64	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 2	STAIRWELL 2 LEVEL 2	INTERNAL LINING TO EXIT FIRE DOOR	Fire Door	Millboard	No asbestos detected (NAD)	4	Presumed	64	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 2	ROOM 207A SEQEB LEVEL 2	ZELEMIT BACKING BOARD TO ELECTRICAL METER BOARD	Insulation/Fill	Polymer Board	CHR - Chrysotile	4	Confirmed	25	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 2	ROOM 207A SEQEB LEVEL 2	CREAM VINYL SHEETING TYPICAL ALL LEVEL	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 2	ROOM 207A SEQEB LEVEL 2	BLACK VINYL SKIRTING TYPE ENTIRE LEVEL	Wall	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Presumed	62	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 2	MALE TOILET LEVEL 2	SHEETS SOUTH END	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 2	MALE TOILET LEVEL 2	SHEETING TO TOILET PARTITIONS NORTH END	Wall	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 2	LIBRARY LEVEL 2	SHEETING TO REAR WALL AND OFFICE	Wall	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 2	FEMALE TOILET SOUTH LEVEL 2	INSULATION TO SANITARY INCINERATOR	Plant, Equipment & Machinery	Millboard	No asbestos detected (NAD)	4	Presumed	64	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	MALE CHANGE ROOM LEVEL 1	YELLOW VINYL TILES	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 2	FEMALE TOILET LEVEL 2	SHEETS SOUTH END	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	MALE TOILET LEVEL 1	SHEETING TO TOILET PARTITIONS NORTH END	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 2	DISABLED TOILET LEVEL 2	CEILING SHEETS SOUTH END	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 2	BUSINESS PROPERTY CONSORTIUM LEVEL 2	BUSINESS PROPERTY CONSORTIUM INTERNAL LINING TO HEATER BANK ENTIRE LEVEL	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	STAIRWELL 4 LEVEL 1	INTERNAL LINING TO EXIT FIRE DOOR	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	STAIRWELL 3 LEVEL 1	INTERNAL LINING TO INTERNAL EXIT FIRE DOOR	Fire Door	Millboard	Mixed	4	Confirmed	64	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	STAIRWELL 2 LEVEL 1	INTERNAL LINING TO EXIT FIRE DOOR	Fire Door	Millboard	Mixed	4	Confirmed	64	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	STAIRWELL 1 LEVEL 1	INTERNAL LINING TO INTERNAL EXIT FIRE DOOR	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	SALES AND DISTRIBUTION LEVEL 1	INTERNAL LINING TO HEATER BANK TYPE ENTIRE LEVEL	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	ROOM 106 PRESENTER'S OFFICE LEVEL 1	BRAKE PAD AND GASKETS TO 3 ONLY VICKERS STAPLERS	Gasket	Polymer Board	No asbestos detected (NAD)	4	Presumed	25	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	ROOM 105 STORE ROOM LEVEL 1	LIGHT BROWN VINYL SHEETING TYPE	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	ROOM 101 LUNCH ROOM LEVEL 1	GREY VINYL SHEETING TYPE ENTIRE LEVEL	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 1	ROOM 101 LUNCH ROOM LEVEL 1	GRAY VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 3	FEMALE TOILET ROOM 341 LEVEL 3	INSULATION TO SANITARY INCINERATOR	Plant, Equipment & Machinery	Millboard	No asbestos detected (NAD)	4	Presumed	64	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 2	FEMALE TOILET NORTH LEVEL 2	INSULATION TO SANITARY INCINERATOR	Plant, Equipment & Machinery	Millboard	No asbestos detected (NAD)	4	Presumed	64	-	
Brisbane North		SOUTH BRISBANE TAFE - OLI	SOUTH BRISBANE TAFE - OLI	HSBAA	25687001	A Block	A Block	Internal	Level 2	STAIRWELL 1 LEVEL 2	INTERNAL LINING TO EXIT FIRE DOOR	Fire Door	Millboard	Mixed	4	Confirmed	64	-	
Brisbane North		STH BRIS 52 MANNING ST	STH BRIS 52 MANNING ST	37149000	37149000	-- Site - Grounds	-- Site - Grounds	External	Ground Floor	CARPORT	FLAT SHEET FIXED TO CEILING IN CARPORT	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		BARCALDINE TAFE CAMPUS	BARCALDINE TAFE CAMPUS	51817003	51817003	-- Site - Grounds	-- Site - Grounds	External	Ground Floor	INTERNAL	FLAT SHEET FIXED TO SOFFIT, SAMPLE:WS1283	Gable/Soffit/Based	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		BILOELA TAFE CAMPUS	BILOELA TAFE CAMPUS	49842008	49842008	-- Site - Grounds	-- Site - Grounds	Internal	Ground Floor	THROUGHOUT	FLAT SHEET FIXED TO CEILING, SAMPLE:WS1282	Ceiling	Cement Based	Mixed	4	Confirmed	18	-	
Central Queensland		BLACKWATER TAFE CAMPUS	BLACKWATER TAFE CAMPUS	29502008	29502008	-- Site - Grounds	-- Site - Grounds	Internal	Ground Floor	TOILET	SHEET VINYL FLOOR COVERING IN TOILET, SAMPLE:WS1281	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		CLERMONT TAFE CAMPUS	CLERMONT TAFE CAMPUS	TCL	30274000	-- Site - Grounds	-- Site - Grounds	Internal	Ground Floor	BUILDING	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Baffles/Lining	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Central Queensland		CLERMONT TAFE CAMPUS	CLERMONT TAFE CAMPUS	TECAA	30274001	A Block	A Block	Internal	Various levels Internal	ENGINE ROOM	PERFORATED WALL SHEETING SAMPLE CP4517	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		CLERMONT TAFE CAMPUS	CLERMONT TAFE CAMPUS	TECAA	30274001	A Block	A Block	Internal	Various levels Internal	ENGINE ROOM CEILING SPACE	SHEETING TO CEILING SPACE SAMPLE CP4518	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		CLERMONT TAFE CAMPUS	CLERMONT TAFE CAMPUS	TECAA	30274001	A Block	A Block	Internal	Various levels Internal	ENGINE ROOM	PERFORATED CEILING TILES SAMPLE CP4516	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		CLERMONT TAFE CAMPUS	CLERMONT TAFE CAMPUS	TECAA	30274001	A Block	A Block	External	Ground Floor	PUMP SHED	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Baffles/Lining	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Central Queensland		CLERMONT TAFE CAMPUS	CLERMONT TAFE CAMPUS	TECAA	30274001	A Block	A Block	External	Ground Floor	GREENHOUSE	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Baffles/Lining	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	

TAFEs from BEMR-TAFEs

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMR Score	Attention Required	Comments
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS		27101010	TIMBER RACKS	TIMBER RACKS	External	Ground Floor	TIMBER RACKS	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS		27101011	COVERED AREA	COVERED AREA	External	Ground Floor	COVERED AREA	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS		27101012	COVERED WALKWAYS	COVERED WALKWAYS	External	Ground Floor	COVERED WALKWAYS	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS		27101013	SHADE AREA	SHADE AREA	External	Ground Floor	SHADE AREA	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEM	27101000	** Site - Grounds	** Site - Grounds											-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEM01	27101008	Pump Room	Pump Room											-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEM02		Engine Clean	Engine Clean											-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEM03	27101002	Fuel Store	Fuel Store	External	Ground Floor	BUILDING	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMAA	27101007	A Block	A Block	Internal	Ground Floor	STAFF/PUBLIC TOILETS	WALL SHEETING NOT SUSPECTED (ASBESTOS FREE STAMPED ON BACK)	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMAA	27101007	A Block	A Block	Internal	Level 1	PUBLIC TOILETS	PERFORATED CEILING TILES NOT SUSPECTED (ASBESTOS FREE STAMPED ON BACK)	Ceiling	Other (refer to description)		4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMAA	27101007	A Block	A Block	Internal	Ground Floor	STAFF/PUBLIC TOILETS	PERFORATED CEILING TILES NOT SUSPECTED (ASBESTOS FREE STAMPED ON BACK)	Ceiling	Other (refer to description)		4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMAA	27101007	A Block	A Block	External	Various levels External	SIGNS	COMPRESSED SHEET TO SIGNAGE SAMPLE CP4538	Sign	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMAA	27101007	A Block	A Block	External	Various levels External	COMPUTER ROOM & AC UNITS	WALL SHEETING TO COMPUTER ROOM AND A/C UNITS SAMPLE CP4539	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMAA	27101007	A Block	A Block	Internal	Level 1	PUBLIC TOILETS	WALL SHEETING NOT SUSPECTED (ASBESTOS FREE STAMPED ON BACK)	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMAA	27101007	A Block	A Block	Internal	Level 2	BUILDING	INSULATION TO RISER SHAFTS SAMPLE CP4540	Insulation/Fill	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMAA	27101007	A Block	A Block	Internal	Level 2	TOILETS	PERFORATED CEILING TILES NOT SUSPECTED (ASBESTOS FREE STAMPED ON BACK)	Ceiling	Other (refer to description)		4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMAA	27101007	A Block	A Block	Internal	Level 3	TOILETS	WALL SHEETING NOT SUSPECTED (ASBESTOS FREE STAMPED ON BACK)	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMBB	27101006	B Block	B Block	Internal	Various levels Internal	PHOTOCOPIER	PERFORATED CEILING SHEETING (PHOTOCOPIER & FACILITIES MANAGERS OFFICE) CP4537	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMBB	27101006	B Block	B Block	Internal	Various levels Internal	ROOM B1-05	COMPRESSED SHEET TO WALLS SAMPLE CP4532	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMBB	27101006	B Block	B Block	Internal	Various levels Internal	ROOM B1-06	COMPRESSED SHEET TO BENCHES SAMPLE CP4531	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMBB	27101006	B Block	B Block	Internal	Various levels Internal	BUILDING	WALL SHEETING THROUGHOUT SAMPLE CP4536	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMBB	27101006	B Block	B Block	Internal	Various levels Internal	BUILDING	SHEETING TO CEILINGS SAMPLE CP4535	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMBB	27101006	B Block	B Block	External	Various levels External	SIGN	COMPRESSED SHEET TO SIGN SAMPLE CP4530	Sign	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMBB	27101006	B Block	B Block	External	Various levels External	ENTRANCE B1-06	CEILING SHEETING EXTERNAL TO B1-06 ENTRANCE SAMPLE CP4534	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMBB	27101006	B Block	B Block	Internal	Various levels Internal	CLASSROOMS	VINYL FLOORING SAMPLE CP4533	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMCC	27101005	C Block	C Block	Internal	Various levels Internal	ROOM C1-05	PERFORATED CEILING TILES SAMPLE CP4529	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMCC	27101005	C Block	C Block	Internal	Various levels Internal	STORE ROOMS	PERFORATED CEILING SHEETING SAMPLE CP4528	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMCC	27101005	C Block	C Block	Internal	Various levels Internal	ROOM C1-06	COMPRESSED SHEET TO WELDING BOOTHS SAMPLE CP4527	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMCC	27101005	C Block	C Block	Internal	Various levels Internal	CLASSROOMS/STAFFROOM	VINYL FLOORING TO CLASSROOMS AND STAFFROOM SAMPLE CP4524	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMCC	27101005	C Block	C Block	External	Various levels External	EAVES	SHEETING TO EAVES SAMPLE CP4523	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMCC	27101005	C Block	C Block	Internal	Various levels Internal	BUILDING	WALL SHEETING THROUGHOUT SAMPLE CP4526	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMCC	27101005	C Block	C Block	Internal	Various levels Internal	BUILDING	SHEETING TO CEILINGS THROUGHOUT SAMPLE CP4525	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMCC	27101005	C Block	C Block	External	Various levels External	STEEL RACKS	COMPRESSED SHEET TO BENCHES OUTSIDE ENCLOSURE SAMPLE CP4522	Furniture	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMDD	27101004	D Block	D Block	External	Various levels External	SIGN	COMPRESSED SHEET TO SIGN SAMPLE CP4519	Sign	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMDD	27101004	D Block	D Block	Internal	Various levels Internal	GROUNDSMAN'S ROOM	SHEETING TO CEILING SAMPLE CP4520	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		EMERALD TAFE CAMPUS	EMERALD TAFE CAMPUS	TEMDD	27101004	D Block	D Block	Internal	Various levels Internal	STORE	WALL SHEETING SAMPLE CP4521	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444003	MAIN STORE	MAIN STORE	Internal	Various levels Internal	ALL ROOMS	AC PERFORATED CEILING SHEETING TO STOREROOMS 226, 227 & 228 DOES CONTAIN ASBESTOS	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444003	MAIN STORE	MAIN STORE	Internal	Ground Floor	C228 (TOILETS)	AC COMPRESSED WALL SHEETING TO TOILET CUBICLE DOES CONTAIN ASBESTOS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444003	MAIN STORE	MAIN STORE	Internal	Ground Floor	ELECT PROJECT ROOM	FIBROUS INSULATION TO BOILER IN ELECTRICAL PROJECTS ROOM DOES NOT CONTAIN ASBESTOS	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444003	MAIN STORE	MAIN STORE	Internal	Ground Floor	ROOM C226	AC CEILING SHEETING TO FRONT COUNTER AREA DOES CONTAIN ASBESTOS	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444003	MAIN STORE	MAIN STORE	Internal	Ground Floor	ROOMS C226 & C226	POLYMER BOUND FLOOR COVERINGS TO C226/C226 WOULD NOT CONTAIN ASBESTOS AS INSTALLED IN 1997	Floor Finish/Covering	Vinyl Sheetting (includes backing)	4	Presumed	62	-		

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444006	COVERED LINKS	COVERED LINKS	External	Ground Floor	BLK B & C LINK	AC CEILING SHEETING TO COVERED LINK BETWEEN BLOCK B & C DOES NOT CONTAIN ASBESTOS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444006	COVERED LINKS	COVERED LINKS	External	Level 1	BLK B & C LINK	AC CEILING SHEETING TO COVERED LINK BETWEEN BLOCK B & C DOES NOT CONTAIN ASBESTOS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444007	FUEL STORE	FUEL STORE	External	Site / Grounds	FUEL STORE	BUILDING ENTERED WITH NO SUSPECT ASBESTOS CONTAINING MATERIALS LOCATED	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444008	GYMNASIUM	GYMNASIUM	External	Various levels	NORTH AWNING	AC CEILING SHEETING TO AWNING ON NORTHERN SIDE OF GYMNASIUM DOES CONTAIN ASBESTOS	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444008	GYMNASIUM	GYMNASIUM	Internal	Ground Floor	BOOK SHOP	AC CEILING SHEETING TO BOOK SHOP DOES NOT CONTAIN ASBESTOS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444008	GYMNASIUM	GYMNASIUM	Internal	Ground Floor	BOOK SHOP	AC INTERNAL WALL SHEETING TO NORTH SOUTH & WEST SIDES DOES NOT CONTAIN ASBESTOS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444008	GYMNASIUM	GYMNASIUM	Internal	Ground Floor	BOOK SHOP	POLYMER BOUND FLOOR COVERINGS TO BOOK SHOP DO NOT CONTAIN ASBESTOS	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444008	GYMNASIUM	GYMNASIUM	Internal	Ground Floor	PUBLISHING UNIT	POLYMER BOUND FLOOR COVERINGS WOULD NOT CONTAIN ASBESTOS AS INSTALLED IN 1996	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444008	GYMNASIUM	GYMNASIUM	External	Ground Floor	NORTH SIDE	AC HARDIPLANK SHEETING TO NORTHERN SIDE DOES NOT CONTAIN ASBESTOS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444009	GAS/AC ENCLOSURE	GAS/AC ENCLOSURE	External	Site / Grounds	STORE	BUILDING ENTERED WITH NO SUSPECT ASBESTOS CONTAINING MATERIALS LOCATED	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444010	ELECTRICAL STORE	ELECTRICAL STORE	Internal	Ground Floor	STORE	AC PERFORATED CEILING TILE STORED IN EASTERN BAY DOES CONTAIN ASBESTOS	Stored Material	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444011	FERNERY/STORE	FERNERY/STORE	Internal	Ground Floor	N E & W WALLS	AC INTERNAL WALL SHEETING TO NORTH EAST & WEST WALLS DOES NOT CONTAIN ASBESTOS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444011	FERNERY/STORE	FERNERY/STORE	External	Ground Floor	NORTH SIDE	AC EXTERNAL WALL SHEETING TO NORTHERN WALL DOES NOT CONTAIN ASBESTOS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444011	FERNERY/STORE	FERNERY/STORE	External	Ground Floor	W E & S SIDES	AC HARDIPLANK SHEETING TO WEST EAST & SOUTH SIDES DOES NOT CONTAIN ASBESTOS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444011	FERNERY/STORE	FERNERY/STORE	External	Various levels	ALL SIDES	AC SOFFIT SHEETING TO ALL SIDES DOES NOT CONTAIN ASBESTOS	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444012	GENERAL STORE	GENERAL STORE	External	Site / Grounds	STORE	BUILDING ENTERED WITH NO SUSPECT ASBESTOS CONTAINING MATERIALS LOCATED	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS		28444013	AUTOMOTIVE STORAGE SHED	AUTOMOTIVE STORAGE SHED	External	Site / Grounds	STORE	BUILDING ENTERED WITH NO SUSPECT ASBESTOS CONTAINING MATERIAL DETECTED	Baffles/Lining	Other (refer to description)		4	Presumed	-	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGL	28444000	SITE/GROUNDS	SITE/GROUNDS	External	Site / Grounds	ADJ MAIN STORE	FIBROUS INSULATION TO HOT GAS AIR HEATER DOES NOT CONTAIN ASBESTOS	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGL01		Store	Store											-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGL02		Ground Store	Ground Store											-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGL03		Oil Store	Oil Store											-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGL04		GP Shed 1	GP Shed 1											-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGL05		GP Shed 2	GP Shed 2											-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGL06		Storage Shed	Storage Shed											-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGL08		Shed - 2 Bay	Shed - 2 Bay											-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGL09		Shed - 3 Bay	Shed - 3 Bay											-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGL11		Shed - 2 Bay	Shed - 2 Bay											-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLB0		B Block	B Block											-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLBB	28444004	B Block	B Block	Internal	Level 1	MALE & FEMALE TOILETS	AC COMPRESSED SHEETING TO TOILET CUBICLE DIVIDERS DOES CONTAIN ASBESTOS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLBB	28444004	B Block	B Block	Internal	Ground Floor	NTWEST CORNER	POLYMER BOUND FLOOR TILES TO CANTEN Foyer & ADMIN AREA DOES CONTAIN ASBESTOS	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLBB	28444004	B Block	B Block	Internal	Level 1	VARIOUS ROOMS	POLYMER BOUND FLOOR COVERINGS TO ROOMS 210 213 217 & READY PAYS ROOM DO CONTAIN ASBESTOS	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLBB	28444004	B Block	B Block	Internal	Level 1	VARIOUS ROOMS	POLYMER BOUND FLOOR COVERINGS TO ROOMS 202-209 DO CONTAIN ASBESTOS	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLBB	28444004	B Block	B Block	Internal	Level 1	EXECUTIVE AREA	POLYMER BOUND FLOOR COVERINGS IN WET AREA WOULD NOT CONTAIN ASBESTOS AS INSTALLED IN 1997	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLBB	28444004	B Block	B Block	Internal	Level 1	EXECUTIVE AREA	AC WALL SHEETING TO ALL ROOMS IN EXECUTIVE AREA DOES NOT CONTAIN ASBESTOS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLBB	28444004	B Block	B Block	Internal	Ground Floor	PLANT ROOM	FIBROUS MATERIAL TO HEATER BANKS IN AIR CONDITIONER UNITS DOES NOT CONTAIN ASBESTOS	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLBB	28444004	B Block	B Block	Internal	Ground Floor	MALE & FEMALE TOILETS	AC COMPRESSED SHEETING TO TOILET CUBICLE DIVIDERS DOES CONTAIN ASBESTOS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLBB	28444004	B Block	B Block	Internal	Ground Floor	LIBRARY	POLYMER BOUND FLOOR TILES TO WESTERN FOYER & LIBRARY STAFF ROOM DO CONTAIN ASBESTOS	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLBB	28444004	B Block	B Block	Internal	Ground Floor	LIBRARY	POLYMER BOUND FLOOR COVERINGS TO LIBRARY STOREROOM ON SOUTH SIDE DO NOT CONTAIN ASBESTOS	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLBB	28444004	B Block	B Block	External	Ground Floor	N & S SIDES	AC EXTERNAL WALL SHEETING ABOVE WINDOWS TO COMPUTER RM & LIBRARY DOES CONTAIN ASBESTOS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLBB	28444004	B Block	B Block	External	Ground Floor	ALL SIDES	AC WALL SHEETING TO ABOVE WINDOWS & BLOCK WORK DOES CONTAIN ASBESTOS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLBB	28444004	B Block	B Block	External	Various levels	N & S SIDES	AC EXTERNAL RAIN WATER DOWN PIPES DO CONTAIN ASBESTOS	Drains/Pipes/Fascia	Cement Based	CHR - Chrysotile	4	Removed	16	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLBB	28444004	B Block	B Block	External	Various levels	N & E SIDES	AC BULKHEAD SHEETING TO NORTH AND EAST SIDES DOES CONTAIN ASBESTOS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLBB	28444004	B Block	B Block	External	Various levels	ALL SIDES	AC SOFFIT SHEETING TO ALL SIDES OF BUILDING DOES CONTAIN ASBESTOS	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLBB	28444004	B Block	B Block	External	Ground Floor	WESTERN SIDE	AC CEILING SHEETING TO WESTERN EXIT DOES CONTAIN ASBESTOS	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLBB	28444004	B Block	B Block	Internal	Ground Floor	ROOM 209 - FEMALE TOILETS	CEILING TILES - G/FLOOR, ROOM 209 - FEMALE TOILETS	Ceiling	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	Internal	Ground Floor	ROOM C120	AC COMPRESSED SHEETING STORED IN SERVICE DUCT DOES CONTAIN ASBESTOS	Stored Material	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	Internal	Ground Floor	ROOM C120	AC PERFORATED CEILING TILES STORED ON SHELVES DO CONTAIN ASBESTOS	Stored Material	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	Internal	Ground Floor	VARIOUS ROOMS	AC PERFORATED CEILING SHEETING TO CLEANER'S ROOM, FIRST AID, LAUNDRY & TOILETS DOES CONTAIN ASBESTOS	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	Internal	Level 1	ALL ROOMS	AC PERFORATED CEILING SHEETING TO ALL ROOMS, EXCEPT ROOMS C208 & C218 DOES CONTAIN ASBESTOS	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	Internal	Level 1	VARIOUS ROOMS	AC SHEETING TO ABOVE BLOCK WORK HEIGHT ON INTERNAL WALLS DOES CONTAIN ASBESTOS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	Internal	Level 1	ROOM C216 & C107	POLYMER BOUND FLOOR COVERINGS TO ROOMS C216 & C107 DO NOT CONTAIN ASBESTOS	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	Internal	Level 1	ROOM C216 WELDING ROOM	AC SHEETING TO DIVIDING WALL AT EASTERN END OF ARC WELDING ROOM DOES CONTAIN ASBESTOS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444006	C Block	C Block	Internal	Level 1	ROOM C208 & C209	POLYMER BOUND FLOOR COVERINGS TO ROOMS C208 & C209 DO NOT CONTAIN ASBESTOS	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	Internal	Level 1	ROOM C 204	POLYMER BOUND FLOOR TILES TO ROOM C204 AND QUIET ROOM DO NOT CONTAIN ASBESTOS	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	Internal	Ground Floor	MALE & FEMALE TOILETS	AC COMPRESSED WALL SHEETING TO TOILET CUBICLE DIVIDERS DOES CONTAIN ASBESTOS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	Internal	Level 1	BREEZE WAY	AC PERFORATED CEILING SHEETING TO BREEZE WAY DOES CONTAIN ASBESTOS	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	Internal	Level 1	BREEZE WAY	AC WALL SHEETING BETWEEN BLOCK WORK AND CEILING DOES CONTAIN ASBESTOS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	Internal	Level 1	ROOM C216 WELDING BAYS	AC COMPRESSED SHEETING TO WELDING BAYS DOES CONTAIN ASBESTOS	Plant, Equipment & Machinery	Cement Based	CHR - Chrysotile	4	Confirmed	16	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	External	Various levels External	SOUTHERN RAMP	AC CEILING SHEETING TO RAMP & WALKWAY ADJOINING BUILDING DOES CONTAIN ASBESTOS	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	External	Various levels External	N & S SIDES	AC RAIN WATER DOWN PIPES TO NORTH & SOUTH SIDES DO CONTAIN ASBESTOS	Drains/Pipes/Floors	Cement Based	Mixed	4	Removed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	External	Various levels External	N & E SIDES	AC BULKHEAD SHEETING TO NORTH AND EAST SIDES DOES CONTAIN ASBESTOS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	External	Various levels External	ALL SIDES	AC SOFFIT SHEETING TO ALL SIDES DOES CONTAIN ASBESTOS	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	External	Ground Floor	SOUTH SIDE	AC PERFORATED CEILING SHEETING STORED UNDER DUST CHUTE ON STM SIDE DOES NOT CONTAIN ASBESTOS	Stored Material	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	External	Ground Floor	NORTH SIDE	AC HARDIPLANK WALL SHEETING BELOW WINDOWS ON NORTHERN SIDE DOES NOT CONTAIN ASBESTOS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	External	Ground Floor	NORTH SIDE	AC EXTERNAL WALL SHEETING ABOVE WINDOWS ON NORTHERN SIDE DOES NOT CONTAIN ASBESTOS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	Internal	Level 1	WESTERN END	POLYMER BOUND FLOOR TILES TO WESTERN FOYER DO CONTAIN ASBESTOS	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	Internal	Ground Floor	PLUMB QUIET RM	AC SAMPLE PIPES IN PLUMBING QUIET ROOM DO CONTAIN ASBESTOS	Stored Material	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLCC	28444005	C Block	C Block	Internal	Ground Floor	PLUMBING WORKSHOP	AC INTERNAL WALL SHEETING TO PLUMBING WORKSHOP DOES NOT CONTAIN ASBESTOS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLDD	28444001	D Block	D Block	External	Level 1	SOUTH ENTRY	AC CEILING SHEETING TO SOUTHERN ENTRY DOES NOT CONTAIN ASBESTOS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLDD	28444001	D Block	D Block	External	Various levels External	N E & W SIDES	AC SOFFIT SHEETING TO NORTH EAST & WEST SIDES DOES NOT CONTAIN ASBESTOS	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLDD	28444001	D Block	D Block	Internal	Level 1	ROOM D303 & D312	AC SHEETING TO DIVIDING WALL BETWEEN ROOMS DOES NOT CONTAIN ASBESTOS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLDD	28444001	D Block	D Block	Internal	Level 1	FEMALE TOILET	AC COMPRESSED WALL SHEETING TO TOILET CUBICLES DOES NOT CONTAIN ASBESTOS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLDD	28444001	D Block	D Block	Internal	Ground Floor	MALE TOILET	AC COMPRESSED WALL SHEETING TO TOILET CUBICLES DOES NOT CONTAIN ASBESTOS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLDD	28444001	D Block	D Block	External	Various levels External	ALL SIDES	COMPRESSED SHEETING AS FASCIA BOARDS DOES NOT CONTAIN ASBESTOS	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLDD	28444001	D Block	D Block	External	Various levels External	N S & W SIDES	AC SANDWICH PANELS TO NORTH SOUTH & WEST WALLS DOES NOT CONTAIN ASBESTOS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLEE	28444002	E Block	E Block	External	Ground Floor	S & E SIDES	AC WALL SHEETING TO SOUTH & EAST SIDES DOES NOT CONTAIN ASBESTOS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLEE	28444002	E Block	E Block	External	Level 1	ALL SIDES	AC EXTERNAL WALL SHEETING ABOVE BLOCK WORK & WINDOWS DOES NOT CONTAIN ASBESTOS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLEE	28444002	E Block	E Block	External	Various levels External	ALL SIDES	AC SOFFIT SHEETING TO ALL SIDES DOES NOT CONTAIN ASBESTOS	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLEE	28444002	E Block	E Block	Internal	Various levels Internal	VARIOUS ROOMS	POLYMER BOUND FLOOR COVERINGS TO ROOMS 204, 402 & TOILETS DO NOT CONTAIN ASBESTOS	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLEE	28444002	E Block	E Block	Internal	Ground Floor	PLANT ROOM	FIBROUS MATERIAL TO HEATER BANKS DOES NOT CONTAIN ASBESTOS	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		GLADSTONE TAFE CAMPUS	GLADSTONE TAFE CAMPUS	TGLEE	28444002	E Block	E Block	External	Various levels External	ALL SIDES	COMPRESSED SHEETING AS FASCIA BOARDS TO ALL SIDES DOES NOT CONTAIN ASBESTOS	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190002	38190002	ADMINISTRATION	ADMINISTRATION											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190003	38190003	DINING HALL/KITCH	DINING HALL/KITCH											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190004	38190004	UNDER COVER AREA	UNDER COVER AREA											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190005	38190005	BOWEN DOWNS	BOWEN DOWNS											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190006	38190006	DORMITORY A	DORMITORY A											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190007	38190007	DORMITORY B	DORMITORY B											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190008	38190008	ASSEMBLY HALL	ASSEMBLY HALL											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190009	38190009	SWIM POOL CHNGERM	SWIM POOL CHNGERM											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190010	38190010	ENGINEERING	ENGINEERING											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190011	38190011	BUILD CONS SECTION	BUILD CONS SECTION											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190012	38190012	SHEEP & WOOL	SHEEP & WOOL											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190013	38190013	WELDING SECTION	WELDING SECTION											-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Em	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190014	38190014	STN ACTIVITY SECT	STN ACTIVITY SECT											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190015	38190015	CATTLE/HORSE SECT	CATTLE/HORSE SECT											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190016	38190016	SLAUGHTER HOUSE	SLAUGHTER HOUSE											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190017	38190017	STRATHDARR DORM	STRATHDARR DORM											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190018	38190018	BREEDON DORMITORY	BREEDON DORMITORY											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190019	38190019	TOTAL DORMITORY	TOTAL DORMITORY											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190020	38190020	MANEROO DORMITORY	MANEROO DORMITORY											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190021	38190021	TALLEYRAND DORM	TALLEYRAND DORM											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190022	38190022	EVESHAM DORMITORY	EVESHAM DORMITORY											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190023	38190023	CORONA DORMITORY	CORONA DORMITORY											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190025	38190025	CPORT RES 11/12/13	CPORT RES 11/12/13											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190026	38190026	ACCOMMODATION 1	ACCOMMODATION 1											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190027	38190027	ACCOMMODATION 2	ACCOMMODATION 2											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190028	38190028	ACCOMMODATION 3	ACCOMMODATION 3											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190029	38190029	ACCOMMODATION 4	ACCOMMODATION 4											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190030	38190030	ACCOMMODATION 5	ACCOMMODATION 5											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190031	38190031	ACCOMMODATION 6	ACCOMMODATION 6											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190032	38190032	ACCOMMODATION 7	ACCOMMODATION 7											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190034	38190034	SPORT OVAL C/HOUSE	SPORT OVAL C/HOUSE											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190036	38190036	MAIN S/B PUMP SHED	MAIN S/B PUMP SHED											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190037	38190037	LAUNDRY	LAUNDRY											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190038	38190038	STAFF ROOM/GYM	STAFF ROOM/GYM											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190039	38190039	OLD CANTEEN	OLD CANTEEN											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190040	38190040	MAINTENANCE SHED	MAINTENANCE SHED											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190041	38190041	MAINTENANCE SHED	MAINTENANCE SHED											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190042	38190042	HORTICULTURE SHED	HORTICULTURE SHED											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190043	38190043	NEW WORKSHOP	NEW WORKSHOP											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190044	38190044	SHEARING SHED/PENS	SHEARING SHED/PENS											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190045	38190045	OLD SLAUGHTER HSE	OLD SLAUGHTER HSE											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190046	38190046	HAY SHED	HAY SHED											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190047	38190047	CONCENTRATE SHED	CONCENTRATE SHED											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190048	38190048	RAM SHED	RAM SHED											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190049	38190049	AUXILIARY PWR SHED	AUXILIARY PWR SHED											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190050	38190050	HAY SHED 2	HAY SHED 2											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190051	38190051	HAY SHED 3	HAY SHED 3											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190052	38190052	SHOEING BAY	SHOEING BAY											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190053	38190053	STUD CATTLE SHED	STUD CATTLE SHED											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190054	38190054	STUD CATTLE L/RAMP	STUD CATTLE L/RAMP											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190055	38190055	ACCOMMODATION 11	ACCOMMODATION 11											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190056	38190056	EL PASCOL SHED	EL PASCOL SHED											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190057	38190057	AL SHED/BULL MILK	AL SHED/BULL MILK											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190058	38190058	DOG HOUSE	DOG HOUSE											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190059	38190059	ACCOMM 12 & 13	ACCOMM 12 & 13											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190060	38190060	CARPORT	CARPORT											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190061	38190061	STABLES	STABLES											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190062	38190062	STABLES 11 & 12	STABLES 11 & 12											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190063	38190063	INDOOR ARENA	INDOOR ARENA											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190064	38190064	DRAFTING RACE 1	DRAFTING RACE 1											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190065	38190065	DRAFTING RACE 2	DRAFTING RACE 2											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190066	38190066	CHOOK PEN	CHOOK PEN											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190067	38190067	DOG SHED 2	DOG SHED 2											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190068	38190068	STORAGE SHED	STORAGE SHED											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	38190069	38190069	CHOOK SHED 2	CHOOK SHED 2											-	
Central Queensland		LONGREACH AUST AG COLL C	LONGREACH	TEL	38190000	-- Site - Grounds	-- Site - Grounds											-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS		28609009	SUGAR RESEARCH BLOCK	SUGAR RESEARCH BLOCK	Inter nal	Ground Floor	ROOM G 1.03AL	EXHAUST/VENT PIPE TO H.W.S.	Plant, Equipment & Machinery	Polymer Bound	Mixed	4	Confirmed	25	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS		28669009	SUGAR RESEARCH BLOCK	SUGAR RESEARCH BLOCK	Inter nal	Level 1	ROOM G2.05	SEAMLESS VINYL TO FLOOR	Floor Finish/Coverin g	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMK	28669000	SITE	SITE	Exter nal	Site / Grounds	EXTERNAL	SHEETING STORED ON THE GROUND AND AGAINST H BLOCK BETWEEN G AND H BLOCKS	Stored Material	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMK	28669000	SITE	SITE	Exter nal	Site / Grounds	NORTHERN COURTYARD	2 X DT SURROUNDS ON THE NORTHERN SIDE OF BLOCK H IN THE COURTYARD BETWEEN G AND H BLOCKS	Drains/Pipes/Floors	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMK	28669000	SITE	SITE	Exter nal	Site / Grounds	WOOD ST CAR PARK	LOOSE FILL DEBRIS BESIDE THE WOOD ST CAR PARK AND UNDER BLOCK E	Debris	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMK01		Greenhouse	Greenhouse												
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMK02		Greenhouse	Greenhouse												
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMK03		Greenhouse	Greenhouse												
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMK04	28689021	FLAMMABLE STORE	FLAMMABLE STORE												
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKAA	28669014	A BLOCK	A BLOCK	Inter nal	Level 2	LIBRARY	CEILING SHEETING - STUDIO ROOM	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKAA	28669014	A BLOCK	A BLOCK	Exter nal	Various levels External	EXTERNAL	CEMENTITIOUS MATERIAL - SUNSHADE EAST END LEVEL 1	Roof Sheeting	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKAA	28669014	A BLOCK	A BLOCK	Exter nal	Various levels External	EXTERNAL	WALL SHEETING - 20mm COMPRESSED SHEET UNDER PEBBLE FINISH - EASTERN ELEVATION	Wall	Cement Based	CHR - Chrysotile	2	Confirmed	34	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKAA	28669014	A BLOCK	A BLOCK	Exter nal	Various levels External	EXTERNAL	WALL SHEETING - 20mm COMPRESSED SHEET UNDER PEBBLE FINISH - SOUTHERN ELEVATION	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	EXTERIOR SAMPLE WS0096
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKAA	28669014	A BLOCK	A BLOCK	Exter nal	Various levels External	EXTERNAL	WALL SHEETING - 20mm COMPRESSED SHEETING UNDER PEBBLE FINISH - NORTHERN ELEVATION	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKAA	28669014	A BLOCK	A BLOCK	Exter nal	Various levels External	EXTERNAL	WALL SHEETING - 20mm COMPRESSED SHEETING UNDER PEBBLE FINISH - WESTERN ELEVATION	Wall	Cement Based	CHR - Chrysotile	2	Confirmed	34	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKAA	28669014	A BLOCK	A BLOCK	Inter nal	Ground Floor	ROOM A1.05, A1.05A & A1.08	TERRACOTTA FLOOR TILES (150X150MM) - ASBESTOS FREE	Floor Finish/Coverin g	Other (refer to description)	4	Not Present(Not Tested)	-		ROOMS A1.05, A1.05A & A1.08	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKAA	28669014	A BLOCK	A BLOCK	Inter nal	Ground Floor	ROOM A1.05, A1.05A & A1.08	WALL SHEETING - LAMPANEL (NO ASBESTOS DETECTED)	Wall	Other (refer to description)	4	Not Present(Not Tested)	-			
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKAA	28668014	A BLOCK	A BLOCK	Inter nal	Ground Floor	ROOM A1.09	TERRACOTA FLOOR TILES (150X150MM) - ASBESTOS FREE	Floor Finish/Coverin g	Other (refer to description)	4	Not Present(Not Tested)	-			
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKAA	28669014	A BLOCK	A BLOCK	Inter nal	Ground Floor	ROOM A100/6 PLANT ROOM	SPRAYED MATERIAL TO CEILING- PLANT ROOM, WS.0094	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKAA	28669014	A BLOCK	A BLOCK	Exter nal	Ground Floor	ROOM A100/2 FAN ROOM	WALL SHEETING PANELS - INTERNAL/EXTERNAL FAN ROOM	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	SAMPLE WS0093	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKAA	28669014	A BLOCK	A BLOCK	Inter nal	Level 2	LIBRARY	CEILING SHEETING - READING AREA / LIBRARY	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKAA	28669014	A BLOCK	A BLOCK	Inter nal	Level 2	LIBRARY	CEILING SHEETING - WORKROOM	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKAA	28669014	A BLOCK	A BLOCK	Inter nal	Level 3	ENTRY TO ROOM A3.02 & A3.18	WALL SHEETING - 3RD SHEET FROM GLASS DOORS - NORTH WALL	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKAA	28669014	A BLOCK	A BLOCK	Inter nal	Level 3	ROOM A3.02	WALL SHEETING - 2ND SHEET FROM OPENING TO A3.18 RIGHT HAND SIDE	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKAA	28669014	A BLOCK	A BLOCK	Exter nal	Roof Level 1	ROOF (WALKWAY)	BITUMINOUS MATERIAL TO ROOF - WALKWAY, SAMPLE WS.0095	Floor Finish/Coverin g	Vinyl Sheeting (includes backing)	CHR - Chrysotile	4	Confirmed	82	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKAA	28669014	A BLOCK	A BLOCK	Inter nal	Level 2	LIBRARY	CEILING SHEETING - PRODUCTION ROOM	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKBB	28669013	B BLOCK	B BLOCK	Inter nal	Level 1	ROOM B1.09	VINYL TILES TO THE ENTRY FOYER ROOM B1.09	Floor Finish/Coverin g	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKBB	28668013	B BLOCK	B BLOCK	Exter nal	Level 1	SOFFIT	SOFFIT SHEETING TO THE NORTHERN AND SOUTHERN ELEVATION	Gable/Soffit/Fascia	Cement Based	4	Presumed	18	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKBB	28669013	B BLOCK	B BLOCK	Inter nal	Level 1	ROOM B1.05 CLASSROOM	VINYL FLOOR TILES TO CLASSROOM B1.05	Floor Finish/Coverin g	Vinyl Tiles	4	Presumed	18	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKBB	28669013	B BLOCK	B BLOCK	Inter nal	Level 1	ROOM B1.06	VINYL FLOOR TILES TO ROOM B1.06	Floor Finish/Coverin g	Vinyl Tiles	4	Presumed	18	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKBB	28669013	B BLOCK	B BLOCK	Inter nal	Level 1	ROOM B1.07	PB TYPE FLOOR COVERINGS TO ROOM B1.07 (POSSIBLY MELTHOID)	Floor Finish/Coverin g	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Inter nal	Level 3	ROOM 3.10	CEILING SHEETING - PARTLY PERFORATED SHEETS	Ceiling	Cement Based	4	Presumed	18	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Inter nal	Level 1	ROOM 1.20 STAFF ROOM	VINYL FLOOR SHEETING - BACKING (1985 VINYL)	Floor Backing/Under lay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Inter nal	Level 1	ROOM 1.08	CEILING SHEETING - PARTLY PERFORATED SHEETS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Inter nal	Level 1	ROOMS 1.17 & 1.18	VINYL FLOOR SHEETING - BACKING	Floor Backing/Under lay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Inter nal	Level 1	ROOMS 1.15 & 1.16	VINYL FLOOR SHEETING - BACKING	Floor Backing/Under lay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Inter nal	Level 1	ROOMS 1.15 & 1.16	CEILING SHEETING - PERFORATED	Ceiling	Cement Based	4	Presumed	18	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Inter nal	Level 1	ROOMS 1.11 & 1.12	CEILING SHEETING	Ceiling	Cement Based	4	Presumed	18	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Inter nal	Level 1	ROOM 1.23 COMPRESSOR ROOM	WALL SHEETING - PERFORATED	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Inter nal	Level 1	ROOM 1.23 COMPRESSOR ROOM	CEILING SHEETING - PERFORATED	Ceiling	Cement Based	4	Presumed	18	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Inter nal	Level 1	STAIRS 1.39	CEILING & SOFFIT SHEETING - STAIRWELL ENTRANCE	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Inter nal	Level 1	ROOM 1.21 CLEANER STORE ROOM	CEILING SHEETING - PERFORATED TILES	Ceiling	Cement Based	4	Presumed	18	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Inter nal	Level 2	HAIREQUIN	CEILING SHEETING TILES	Ceiling	Cement Based	4	Presumed	18	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Inter nal	Level 1	ROOM 1.20 STAFF ROOM	CEILING SHEETING - PERFORATED TILES	Ceiling	Cement Based	4	Presumed	18	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Inter nal	Level 1	ROOM 1.19 PLANT ROOM	WALL SHEETING - PERFORATED	Wall	Cement Based	4	Presumed	18	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Inter nal	Level 1	ROOM 1.19 PLANT ROOM	CEILING SHEETING - PERFORATED	Ceiling	Cement Based	4	Presumed	18	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Inter nal	Level 1	ROOM 1.17 & 1.18	CEILING SHEETING - PERFORATED	Ceiling	Cement Based	4	Presumed	18	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Inter nal	Level 1	ROOM 1.11 & 1.12	WALL SHEETING TO PART OF WALLS TO ROOMS 1.11 AND 1.12	Wall	Cement Based	4	Presumed	18	-		
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Inter nal	Level 1	ROOM 1.09	FLOOR SHEETING - MILLBOARD BACKING TO SHEET VINYL	Floor Backing/Under lay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		

TAFEs from BEMIR-TAFEs

Current as at 10-May-11

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEIR Score	Attention Required	Comments
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 3	ROOM 3.11	HEATER BANK NO 2 INSIDE ROOM 3.11	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 1	ROOM 1.21 CLEANER STORE ROOM	VINYL FLOOR SHEETING - BACKING	Floor Backing/Under lay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 2	ROOM 2.13 PLANT ROOM	WALL SHEETING - PERFORATED	Wall	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 2	ROOMS 2.14 & 2.15	CEILING SHEETING - PERFORATED TILES	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 2	ROOMS 2.11 & 2.12 CLASSROOMS	PERFORATED CEILING TILES TO CLASSROOMS 2.11 AND 2.12	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 2	ROOMS 2.11 & 2.12	VINYL FLOOR SHEETING - BACKING	Floor Backing/Under lay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 2	ROOM C 2.04	WALL SHEETING - TO 30 WELDING BAYS	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 2	ROOM C 2.04	WALL SHEETING - BULKHEAD OVER WALLS, DOORS & WINDOWS	Wall	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 2	ROOM C 2.04	CEILING SHEETING - PERFORATED - ROOMS C2.04, C2.06, C2.09, C2.10	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	ROOMS C2.04, C2.06, C2.09, C2.10
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 2	ROOM 2.28	WALL SHEETING - LAUNDRY ROOM	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 1	SERVICE DUCT	SHEETING COVER TO WASTE/VENT PIPE SERVICE DUCT BETWEEN ROOMS 1.01 AND 1.02	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 2	ROOM 2.22 PLANT ROOM	CEILING SHEETING - PERFORATED SHEETS	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 1	ROOM 1.05	WALL SHEETING - PERFORATED - ABOVE WINDOWS	Wall	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 2	ROOM 2.13 PLANT ROOM	CEILING SHEETING - PERFORATED	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 2	ROOM 2.05	CEILING SHEETING - PERFORATED	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 2	PASSAGEWAY	WALL SHEETING - DOORWAY PARTITION NORTHERN & SOUTHERN ENDS OF PASSAGEWAY	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 2	PASSAGEWAY	VINYL FLOOR TILES (BLACK AND WHITE) IN THE PASSAGEWAY	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 2	LOCKER ROOM	VINYL FLOOR SHEETING - BACKING	Floor Backing/Under lay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 2	HAIR/REIN	WALL SHEETING - PERFORATED TO SOME SALON SECTIONS THROUGHOUT	Wall	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 2	HAIR/REIN	VINYL FLOOR SHEETING - BACKING	Floor Backing/Under lay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 2	ROOM 2.22 PLANT ROOM	WALL SHEETING - PERFORATED	Wall	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	External	Various levels	EXTERNAL	DOWNPIPES - 12 X 300MM	Drains/Pipes/Floors	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	DOWNPIPES LOCATED ADJOINING ROOMS: 1.08 (4), 1.20 (1), 1.26 (4), 1.37 (1), 1.03 (1), 1.38 (1)
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 1	ROOM 1.09	CEILING SHEETING - PERFORATED	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 2	ROOMS 2.14 & 2.15	VINYL FLOOR SHEETING - BACKING	Floor Backing/Under lay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 3	ROOM 3.11	HEATER BANK NO 1 IN ROOM 3.11	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 3	ROOM 3.12	CEILING SHEETING - PERFORATED SECTION	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 3	ROOM 3.20	CEILING SHEETING - PARTLY PERFORATED SHEETS	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 3	ROOM 3.22	CEILING SHEETING - PARTLY PERFORATED SHEETS	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 3	ROOM 3.24	CEILING SHEETING - PARTLY PERFORATED SHEETS	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 3	ROOM 3.07	CEILING SHEETING - PARTIAL PERFORATED SHEETS	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 3	ROOMS 3.11 & 3.13	VINYL FLOOR SHEETING - BACKING	Floor Backing/Under lay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 3	ROOM 3.04 PLANT ROOM	WALL SHEETING - PARTLY PERFORATED SHEETING	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	External	Roof Level 1	FASCIA	FASCIA BARGE SHEETING - PART OF THE ROOF SECTION	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	External	Other (refer to description)	300mm DIAMETER DOWNPIPES				No asbestos detected (NAD)	-	-	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	External	Level 3	SOFFIT	SOFFIT SHEETING TO THE PERIMETER OF THE BUILDING	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	External	Level 3	FASCIA	FASCIA BARGE SHEETING - THE PERIMETER OF THE BUILDING	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	External	Level 1	OPEN AREA	PERFORATED WALL SHEETING TO THE OPEN AREA 1 - 25 INCLUDING ABOVE BULKHEADS	Wall	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	External	Level 1	OPEN AREA	2 X 15 CM DECORATIVE CEILING PANELS IN THE OPEN AREA 1 - 25	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	External	Level 1	METAL WORK SECTION	WALL SHEETING TO THE WINDOW BULKHEADS IN THE METAL WORK SECTION	Wall	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 3	ROOMS 3.11 & 3.13	CEILING SHEETING - PERFORATED SECTION	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 1	FURNACE ROOM	1 X 'LABHEAT' FURNACE STORED ON THE WORKBENCH IN THE MAIN ROOM 1.04 FURNACE SECTION	Stored Material	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 1	ROOM 1.05	PUMP PACKING MATERIAL STORED IN THE SHELVEING 'BESTOBELL' PORTABLE ITEM	Stored Material	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 1	ROOM 1.05	CEILING SHEETING - PERFORATED	Ceiling	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 1	ROOM 1.05	1 X LABORO HEAT STIRRER STORED IN BROWN BUILT SHELVEING, ONE (1) OF TWO (2) PORTABLE ITEM	Stored Material	Millboard	CHR - Chrysotile	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 1	ROOM 1.05	1 X LABORO HEAT STIRRER STORED IN BROWN BUILT SHELVEING, ONE (1) OF TWO (2) PORTABLE ITEM	Stored Material	Millboard	CHR - Chrysotile	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 1	ROOM 1.05	1 X 'TOWNSON' HOTPLATE STIRRER STORED IN THE BROWN BUILT SHELVEING, PORTABLE ITEM	Stored Material	Millboard	CHR - Chrysotile	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 1	ROOM 1.04 METAL WORKROOM	WALL SHEETING - PERFORATED ABOVE WINDOW BULKHEADS	Wall	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 1	ROOM 1.04 METAL WORKROOM	WALL SHEETING - PARTITIONS TO THE WELDING AREA	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 3	ROOM 3.07	VINYL FLOOR SHEETING - BACKING	Floor Backing/Under lay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	ROOM 3.07

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Internal	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEIMR Score	Attention Required	Comments
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 1	ROOM 1.01 & 1.02 MALE & FEMALE TOILETS	CEILING SHEETING TILES	Ceiling	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	External	Level 1	EXTERNAL	CEILING SHEETING - OUTSIDE EXIT DOOR TO ROOM 1.06	Ceiling	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 1	FIRE HOSE CABIN	WALL SHEETING TO FIRE HOSE REEL CUPBOARD ON NORTHERN SIDE OF ROOM 1.04	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	External	Various levels	OPEN AREA 1.26	WALL SHEETING TO THE OPEN AREA 1 - 26	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	External	Various levels	EXTERNAL	DOWNPIPES 300MM DIAMETER (2) - ADJACENT 1.46 & 1.45 - NEW	Drains/Pipes/Floor	Cement Based	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	REPLACEMENT FOR 2 OLD DOWNPIPES REMOVED
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	External	Various levels	EXTERNAL	DOWNPIPES 2 X 300 MM TO BLOCK C - ADJACENT 1.46 & 1.45	Drains/Pipes/Floor	Cement Based	CHR - Chrysotile	4	Removed	18	-	2 DOWNPIPES HAVE BEEN REMOVED. 12 REMAIN
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 3	ADMINISTRATION	CEILING SHEETING - PARTLY PERFORATED SHEET - TECHNICAL ADMIN OFFICE	Ceiling	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 3	PASSAGEWAY	VINYL FLOOR SHEETING - BACKING - EASTERN SIDE PASSAGEWAY	Floor Backing/Underlay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 3	PASSAGEWAY	VINYL FLOOR SHEETING - WESTERN PASSAGEWAY	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	Internal	Level 1	ROOM 1.04 METAL WORKROOM	CEILING SHEETING - PERFORATED	Ceiling	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKCC	28669012	C Block	C BLOCK	External	Level 1	EXTERNAL	CEILING SHEETS TO THE TWO (2) AWNINGS OUTSIDE THE COLLEGE STOREROOM 1.08	Ceiling	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 2	DARK ROOM	VINYL FLOOR TILES TO THE DARK ROOM	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 2	VERANDAH PASSAGEWAY	VINYL FLOOR TILES TO EASTERN AND WESTERN VERANDAH AND PASSAGEWAY TO CLASSROOM 2.10	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 2	ROOM 2.10	VINYL FLOOR TILES TO ROOM 2.10	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 2	ROOM 2.08	VINYL FLOOR TILES TO ROOM 2.08	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 2	ROOM 2.07 CLASSROOM	VINYL FLOOR TILES TO THE TEACHERS AREA OF THE CLASSROOM	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 2	ROOM 2.07 CLASSROOM	SHEETING ABOVE WESTERN SIDE WINDOW BULKHEAD	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 2	ROOM 2.07 CLASSROOM	BACKING TO THE SHEET VINYL IN ROOM 2.07 LAID OVER OLD VINYL TILES	Floor Backing/Underlay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 2	ROOM 2.07 CLASSROOM	AC SHEET TO THE WINDOW BULKHEAD OUTSIDE ROOM 2.07	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 2	ROOM 2.06 STORE ROOM	VINYL FLOOR TILES TO THE STOREROOM 2.06	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 2	ROOM 2.06 STORE PIPEWORK	VENT PIPE THROUGH THE ROOM AND THE CEILING SPACE	Drains/Pipes/Floor	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Ground Floor	ROOM D 1.03	DOUBLE LAYERED SHEETING - TO WALL	Wall	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 2	OPEN AREA	VINYL FLOOR TILES TO THE OPEN TEACHING AREA BETWEEN ROOMS 2.10 AND 2.06	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 1	SHOWERS	TILUX WALL SHEETING TO THE TWO (2) SHOWER CUBICLES IN THE MALE TOILETS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 1	ROOM D 1.09	INSULATION TO ELECTRICAL WIRING STORED ON DESK, PORTABLE ITEM	Stored Material	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 1	ROOM 1.10 STOREROOM	VINYL FLOOR TILES TO THE STOREROOM IN ROOM 1.10	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 1	ROOM 1.08	BACKING TO VINYL FLOOR IN ROOM 1.08	Floor Backing/Underlay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 1	ROOM 1.03 STOREROOM	WALL SHEETING TO THE STOREROOM AND OTHER SIDE OF PASSAGEWAY	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 1	ROOM 1.01 CLASSROOM & ENTRY FOYER	VINYL FLOOR TILES TO THE CLASSROOM 1.01 AND EASTERN ENTRY FOYER	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 1	ENTRY FOYER	BACKING TO THE ENTRY FOYER AND PASSAGEWAY ALFRED STREET SIDE ENTRY	Floor Backing/Underlay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Ground Floor	ROOM D 1.09	230 X 230MM VIA TILES SAMPLE WS.0150	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Ground Floor	ROOM D 1.07	110MM O.D. VENT PIPE (S.W. CNR)	Drains/Pipes/Floor	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKDD	28669011	D BLOCK	D BLOCK	Internal	Level 2	ROOM 2.02	VINYL FLOOR TILES TO ROOM 2.02	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKEE	28669001	E BLOCK	E BLOCK	Internal	Level 1	ADMIN OFFICE	VINYL BACKING TO HALLWAY GROUND FLOOR	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKEE	28669001	E BLOCK	E BLOCK	Internal	Level 1	ADMIN OFFICE	WALL SHEETING TO SPLASHBACK OVER THE HAND BASIN IN ADMIN OFFICE	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKEE	28669001	E BLOCK	E BLOCK	Internal	Level 1	ENTRY FOYER/PASSAGE	SHEET VINYL BACKING IN THE ENTRY FOYER AND PASSAGEWAY FLOOR	Floor Backing/Underlay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKEE	28669001	E BLOCK	E BLOCK	External	Various levels	WESTERN SIDE	VENT PIPE ON THE WESTERN SIDE OF BLOCK E FACING WOOD STREET	Drains/Pipes/Floor	Cement Based	Mixed	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKEE	28669001	E BLOCK	E BLOCK	External	Level 2	WESTERN VERANDAH	FLOOR BOARDS ON THE WESTERN SIDE VERANDAH - MALTHOID MEMBRANE	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	Internal	Level 1	OFFICE	CEILING SHEETS TO THE OFFICE AREA	Ceiling	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	Internal	Level 2	WELDING BAYS	13MM SHEETING TO WELDING BAYS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	Internal	Level 2	SERVICE DUCT	1 X AC VENT PIPE FIXED TO THE CAST IRON PIPE IN SERVICE DUCT F2002	Drains/Pipes/Floor	Cement Based	Mixed	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	Internal	Level 2	BULK STORE	SHEETING TO THE BULK STORE DOUBLE DOOR BULKHEAD	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	Internal	Level 1	WELDING BAY #2	COMPRESSED SHEETING TO THE WELDING BAY 2 ROOM	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	Internal	Level 1	WELDING BAY #2	CEILING SHEETS TO THE WELDING BAY ROOM NO 2	Ceiling	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	Internal	Level 1	STOREROOM	VINYL FLOOR TILES (300 X 300 MM) TO THE STOREROOM	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	Internal	Level 1	STOREROOM	CEILING TILES TO THE STOREROOM	Ceiling	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	Internal	Level 1	SHEET METAL SWITCHBOARD	ZELEMITTE BACKING TO THE SWITCHBOARD IN THE SHEET METAL OPEN WORKSHOP	Insulation/Fill	Polymer Bound	CHR - Chrysotile	3	Confirmed	25	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	Internal	Level 1	SHEET METAL SWITCHBOARD	ZELEMITTE BACKING TO THE MAIN SWITCHBOARD EASTERN END OF THE ROOM	Insulation/Fill	Polymer Bound	CHR - Chrysotile	3	Confirmed	25	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	Internal	Level 1	ROOM F1.01	COMPRESSED FC SHEET ABOVE THE WASH AREA.	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	Internal	Ground Floor	ROOM F 1.02	PANELS TO CEILING- SAMPLE WS.0151	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	External	Various levels	SOFFIT	MOULDED AC SOFFIT SHEETS TO VARIOUS LEVELS OF BLOCK F	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	External	Various levels	EXTERNAL	SHEETING OVER ALL DOOR BULKHEADS INCLUDING LOADING DOCKS AND ENTRY TO ALFRED STREET	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	External	Roof Level 1	EXTERNAL	GABLE END SECTIONS TO THE ROOF (LEFT SIDE OF ROOF, CLIMBING OUT OF WINDOW)	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	External	Roof Level 1	EXTERNAL	2 X VENT PIPES THROUGH ONTO THE ROOF OF BLOCK F	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	External	Level 2	SERVICE DUCT	CHIMNEY PIPE FOR THE GAS HOT WATER UNIT IN SERVICE DUCT F2003	Drains/Pipes/Floors	Cement Based	Mixed	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	Internal	Level 1	WELDING BAYS #1	COMPRESSED SHEETING TO THE WELDING BAYS ON GROUND FLOOR, WELDING BAY NO 1	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	Internal	Level 1	SHEET METAL	CEILING TILE TO THE SHEET METAL WORK AREA	Ceiling	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKFF	28669010	F BLOCK	F BLOCK	Internal	Level 2	ROOM F202/1	VINYL FLOOR TILES (300 X 300 MM) TO ROOM F202/1	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	ROOM 1.07 FUME CUPBOARD	3 X HAMILTON FUME CUPBOARD ON THE EASTERN WALL OF THE ROOM 1.07	Baffles/Lining	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	POLARIMETRY RM	CEILING TILES TO THE POLARIMETRY ROOM	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	PREP ROOM	VINYL FLOOR TILES TO THE PREPARATION ROOM	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	ROOM 1.06	VINYL FLOOR TILES UNDER THE CARPET TO ROOM G1.06	Floor Backing/Underlay	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	ROOM 1.07 CLASSROOM	BUNSEN BURNER MATS STORED IN THE CUPBOARDS, PORTABLE ITEM	Stored Material	Cement Based	CHR - Chrysotile	2	Confirmed	34	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	ROOM 1.07 CLASSROOM	DEBRIS IN CUPBOARD WHERE BURNER MATS AND EQUIPMENT WAS STORED	Debris	Cement Based		2	Removed	34	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	ROOM G2.12	SHEETING TO NORTH & SOUTH WALL	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	ROOM 1.07 CLASSROOM	VINYL FLOOR TILES TO ROOM 1.07	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	LABORATORY 1 CANE DRYING UNIT	INSULATION TO THE ELECTRICAL WIRING TO THE CANE DRYING UNIT, NO EQ008028	Insulation/Fill	Woven Textile	CHR - Chrysotile	4	Removed	84	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	ROOM 1.11	SUSPECTED GASKETS TO HEATER ON REAR SHELVING, PORTABLE ITEM	Gasket	Milboard	CHR - Chrysotile	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	ROOM 1.11	VINYL FLOOR TILES TO ROOM 1.11	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	ROOM G1.01 CLASSROOM	VINYL FLOOR TILES TO CLASSROOM G1.01	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	ROOM G1.02 CLASSROOM	VINYL FLOOR TILES TO CLASSROOM G1.02 AND UNDER THE CARPET	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	ROOM G2.09	WALL SHEETING - ADJACENT TO THE SHOWER AND OVEN AREA	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	External	Level 2	SOFFIT	SOFFIT SHEETING ON THE SOUTHERN SIDE OF BLOCK G AND PART NORTHERN SIDE OF NEW EXTENSION	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	ROOM 1.07 CLASSROOM	FURNACE ON THE EASTERN END OF THE CLASSROOM IS LINED WITH COMPRESSED SHEETING	Plant, Equipment & Machinery	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	FEMALE TOILETS	SHEET CEILING TILES TO THE FEMALE TOILETS	Ceiling	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	External	Roof Level 1	EXTERNAL	1 X AC VENT PIPE ON THE EASTERN SIDE OF BLOCK G	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	External	Roof Level 1	FLAMMABLE GOOD STORE	CORRUGATED ROOF SHEETING OVER THE FLAMMABLE GOODS STORE ON THE EASTERN SIDE OF BLOCK G	Roof Sheeting	Cement Based		3	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	External	Various levels	SOFFIT	SOFFIT SHEETING TO THE ORIGINAL BUILDING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Ground Floor	ADJACENT TO ROOM G2.14	DUCT ACCESS PANEL IN THE SERVICE DUCT ADJACENT TO ROOM G2.14	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Ground Floor	FLAMMABLE GOODS STORE	WALLS OUTSIDE THE FLAMMABLE GOODS STORE G1.08	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Ground Floor	MAIN ENTRANCE	WALL LINING ADJACENT TO THE MAIN ENTRANCE	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	PASSAGEWAY	VINYL FLOOR TILES TO THE PASSAGEWAY TO THE NEWEST EXTENSION TO BLOCK G	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	BALANCE ROOM	VINYL FLOOR TILES TO THE BALANCE ROOM	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	PASSAGEWAY	VINYL FLOOR TILES (WHITE) TO THE PASSAGEWAY IN THE OLD SECTION OF BLOCK G	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	FEMALE TOILETS	VINYL FLOOR TILES TO THE ENTRY OF THE FEMALE TOILETS	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	FLAMMABLE	SHEETING TO ALL THE SHELVING IN THE FLAMMABLE GOODS STORE	Furniture	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	FLAMMABLE STORE	FIRE DOOR TO THE FLAMMABLE GOODS STORE	Fire Door	Cement Based	Mixed	2	Removed	34	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	INTERNAL	FLOOR TILES - 230 X 230MM V/A	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	LABORATORY 1	CEILING TO LABORATORY 1 AND STOREROOM - VERMICULITE	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	LABORATORY 1 CANE DRYING UNIT	GASKET MATERIALS TO THE CANE DRYING UNIT, NO EQ008028	Gasket	Polymer Based	CHR - Chrysotile	4	Confirmed	25	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	STAIRWELL	CEILING SHEETING TO EASTERN ENTRY STAIRWELL AND STRINGERS - VERMICULITE	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Ground Floor	ROOM G 1.07	HEET UNDER KILN - 700 X 500MM	Floor Finish/Covering	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ref No	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEIR Score	Attention Required	Comments
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.09	SHEETING UNDER THE TWO (2) FURNACES TO PROTECT THE WORKBENCH REAR OF ROOM. PORTABLE ITEM	Stored Material	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.09	1 X LINING UNDER THE LARGE 250 MM SEM HOT PLATE STORED IN CUPBOARD SG. PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.09	1 X TOWNER SMALL FURNACE STORED ON THE WORKBENCH. PORTABLE ITEM	Stored Material	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.09	1 X WASHERS TO A LABORO HEAT STIRRER STORED IN CUPBOARD NO SG. PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.09	BAFFLES TO FUME CUPBOARD NO. FC-06	Baffles/Lining	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.09	BAFFLES TO THE FUME CUPBOARD NO FC-67	Baffles/Lining	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.09	BUNSEN BURNER MATS STORED IN CUPBOARD NO SF. PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	ROOM G2.12	CEILING SHEET - NORTH WEST CNR - 750 X 750MM	Ceiling	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.09	DOOR SEAL AND INSULATION TO THE INCUBATOR STORED ABOVE BENCH 7E. PORTABLE ITEM	Stored Material	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.09	1 X GALLENKAMP FURNACE STORED ON A BENCH TO THE REAR OF ROOM 2.09	Stored Material	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.09	VINYL FLOOR TILES TO ROOM	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.14	1 X SEM HOT PLATE STORED IN THE BROWN BUILT CUPBOARD. PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.14	VINYL FLOOR TILES TO ROOM 2.14	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOMS 2.01 & 2.02	VINYL FLOOR TILES TO ROOMS 2.01 AND 2.02	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	STAFFROOM	VINYL FLOOR TILES TO THE STAFFROOM	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Various levels	STAIRWELL	VINYL FLOOR TILES TO BOTH SETS OF INTERNAL STAIRCASES INCLUDING THE LANDINGS	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.09	DOOR SEAL AND INSULATION TO INCUBATOR STORED ABOVE BENCH 7E. PORTABLE ITEM	Stored Material	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.03	3 HOT PLATES AND STIRRERS WITH SUSPECT WASHERS ABOVE CUPBOARD 4D. PORTABLE ITEM	Plant, Equipment & Machinery	Milboard	CHR - Chrysotile	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	BALANCE ROOM	VINYL FLOOR TILES TO THE BALANCE ROOM	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	INTERNAL	INTERNAL WALL SHEETING TO 2.12 2.09 STAFFROOM LUNCHROOM PASSAGEWAY PREP ROOM BALANCE ROOM	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	LUNCH ROOM	VINYL FLOOR TILES TO THE LUNCH ROOM	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	MALE TOILET	CEILING TILES TO THE MALE TOILET	Ceiling	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	PASSAGEWAY	VINYL FLOOR TILES IN THE PASSAGEWAY OF THE OLD AND NEW BUILDING SECTIONS	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	PREPARATION RM	VINYL FLOOR TILES TO THE PREPARATION ROOM	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.09	1 X LINING TO A 200 MM ROUND SEM HOT PLATE STORED IN CUPBOARD NO SG. PORTABLE ITEM	Stored Material	Milboard	Mixed	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.03	1 x SEM 200MM ROUND HOT PLATE STORED ON SHELVING ABOVE CUPBOARD 4D. PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.09	1 X LINING TO A 200 MM ROUND SEM HOT PLATE STORED IN CUPBOARD 8G. PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.03	BUNSEN BURNER MATS STORED UNDER THE FUME CUPBOARDS 7D. PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.03	HEAT STIRRER WITH SUSPECTED WASHERS UNDER PLATE. STORED ON SHELVING. PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.03	SEAL AND INSULATION TO INCUBATOR STORED IN BENCH EASTERN WALL OF BUILDING. PORTABLE ITEM	Stored Material	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.03	SHEETING TO BASE OF LABORO INCUBATOR TO PROTECT THE WORK BENCH. PORTABLE ITEM	Stored Material	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.03	VINYL FLOOR TILES TO ROOM 2.03	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.05	1 X TOWNSON HEAT STIRRER PLATE STORED UNDER WORKBENCH IN ROOM 2.05	Stored Material	Milboard	CHR - Chrysotile	2	Removed	69	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	PASSAGEWAY	WALL SHEETING TO THE WESTERN WALL OF THE PASSAGEWAY NEAR THE FEMALE TOILETS	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 2	ROOM 2.03	FUME CUPBOARDS IN ROOM 2.03 ALL HAVING BAFFLES X 5	Baffles/Lining	Cement Based	Mixed	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKGG	28669008	G BLOCK	G BLOCK	Internal	Level 1	POLARIMETRY RM	VINYL FLOOR TILES TO THE POLARIMETRY ROOM	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKH	28669002	H BLOCK	H BLOCK	Internal	Ground Floor	ROOM H1.06	CEILING PANELS & FASCIAS TO ROOM.	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKH	28669002	H BLOCK	H BLOCK	Internal	Ground Floor	ROOM H 1.26	CEILING INSULATION	Insulation/Fill	Insulation Board	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKH	28669002	H BLOCK	H BLOCK	Internal	Ground Floor	ROOM H 1.17	WALL PANELS - (EAST ELEVATION)	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKH	28669002	H BLOCK	H BLOCK	Internal	Ground Floor	ROOM H 1.17	CEILING INSULATION	Insulation/Fill	Insulation Board	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKH	28669002	H BLOCK	H BLOCK	Internal	Ground Floor	ROOM H 1.10	WALL PANELS - NTH. & EAST ELEVATIONS.	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKH	28669002	H BLOCK	H BLOCK	Internal	Ground Floor	ROOM H 1.07	VINYL TO FLOOR - SEAMLESS	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKH	28669002	H BLOCK	H BLOCK	External	Roof Level 1	ROOM G 1.08	CORRUGATED ROOF SHEETING	Roof Sheeting	Cement Based		4	Presumed	18	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKJJ	28669016	J BLOCK	J BLOCK	Internal	Level 5	INTERNAL	VINYL FLOOR COVERING TO HALLWAY TO KEG ROOM	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	NA	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKKK	28669017	K BLOCK	K BLOCK	Internal	Ground Floor	ROOM K138 TEAROOM	SEAMLESS VINYL TO FLOOR	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		MACKAY TAFE CAMPUS	MACKAY TAFE CAMPUS	TMKLL	28669015	L BLOCK	L BLOCK	Internal	Ground Floor	ROOM J10	VINYL FLOORING IN OFFICE SUSPECTED	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Central Queensland		MORANBAH TAFE CAMPUS	MORANBAH TAFE CAMPUS	TMZ	30405000	-- Site - Grounds	-- Site - Grounds	Internal	Ground Floor										
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET		27909001	J Block	J Block	Internal	Ground Floor										

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEIRIR Score	Attention Required	Comments
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	STORE	SHEETED WALL UNDER STORE COUNTER, SAMPLE CP1459	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	STAFF TOILETS	SHEET BEHIND HAND BASIN SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	STAFF	VINYL FLOORING IN STAFF ROOM SUSPECTED	Floor Finish/Coverin g	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	SHOWER	WALLS AND ABOVE SHOWER PARTITIONS SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	ROOM J9	GREY/BROWN FLOOR TILES SUSPECTED	Floor Finish/Coverin g	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	ROOM J8	GREY/BROWN FLOOR TILES SUSPECTED SIMILAR TO ROOM J7	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	ROOM J7	GREY/BROWN FLOOR TILES SUSPECTED	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	ROOM J7	CEILING TILES IN SUSPENDED CEILING SAMPLE CP1466	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	ROOM J6	VINYL FLOOR SHEETING SUSPECTED	Floor Finish/Coverin g	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	ROOM J5	VINYL FLOOR SHEETING SUSPECTED	Floor Finish/Coverin g	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	ROOM J3	INSULATION ON EXHAUST ON LARGE DIESEL MOTOR, SAMPLE CP1464 & CP1465	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	ROOM J2	BROWN FLOOR TILES SUSPECTED	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	TEACHING	BROWN FLOOR TILES IN ROOM BEHIND MECHANICS WORKSHOP AREA SUSPECTED	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	ROOM J12	GREEN FLOOR TILES SUSPECTED	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	ROOM J8	CEILING TILES IN SUSPENDED CEILING SUSPECTED SIMILAR TO ROOM J7	Ceiling	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	ROOM J1	GREY FLOOR TILES SUSPECTED	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	MOTOR MECHANICS	(MOTOR MECHANICS WORKSHOP) WALL SHEETING ALMA STREET END OF WORKSHOP SAMPLE CP1458	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	MALE TOILETS	WALLS AND ABOVE TOILET PARTITIONS SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	HALLWAY	VINYL FLOOR SHEETING SUSPECTED	Floor Finish/Coverin g	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	FEMALE TOILETS	WALL SHEETING IN FEMALE TOILETS SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	DIESEL FITTERS	WALL AT ALMA STREET END OF WORKSHOP SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	CLEANERS	GREY FLOOR TILES SUSPECTED	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	BUILDING	MILLBOARD LINING TO HEATER BANKS THROUGHOUT BUILDING SUSPECTED	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	ALL WORKSHOPS	(ALL WORKSHOPS & STORE) BRAKE LININGS & GASKETS STORED & USED IN WORKSHOP SUSPECTED	Plant, Equipment & Machinery	Polymer Based		4	Presumed	25	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Exter nal	Various levels External	CAGED STORE	DISTRIBUTION TRAP SURROUNDS STORED ON RACK AT REAR OF STORAGE AREA SUSPECTED	Stored Material	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	ROOM J18	GREEN FLOOR TILES SUSPECTED	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Exter nal	Various levels External	CLEANERS STORE	SHEETING UNDER THE EAVES OF CLEANER'S STORE, SAMPLE CP1457	Gable/Soffit/HF asla	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	TEACHING	FAWN FLOOR TILES SAMPLE CP1461	Floor Finish/Coverin g	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	TEACHING	GREENISH FLOOR TILES SAMPLE CP1460	Floor Finish/Coverin g	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	TEACHING	GREY FLOOR TILES SAMPLE CP1462	Floor Finish/Coverin g	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	TEACHING	LIGHT GREEN FLOOR TILES SAMPLE CP1463	Floor Finish/Coverin g	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	TEACHING	WALL SHEETING ON WALL FACING ALMA STREET AND REAR WALL SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	ROOM J8	CEILING TILES IN CEILING SUSPECTED SIMILAR TO ROOM J7 AND J9	Ceiling	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909001		J Block	J Block	Inter nal	Ground Floor	TEACHING	CEILING IN TEACHING AREA SUSPECTED	Ceiling	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909003		G Block	G Block	Inter nal	Ground Floor	STORAGE	(HOT WATER UNIT STORAGE ROOM) BACKING BOARD SUSPECTED	Plant, Equipment & Machinery	Millboard		4	Presumed	64	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909003		G Block	G Block	Inter nal	Roof Level 1	ROOM G13	VINYL FLOOR TILES AROUND CLEANER'S SINK SUSPECTED	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909003		G Block	G Block	Inter nal	Roof Level 1	ROOM G11	BROWN VINYL FLOOR TILES SUSPECTED	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909003		G Block	G Block	Inter nal	Roof Level 1	ROOM G10	FAWN VINYL FLOOR TILES SUSPECTED	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ed.	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909003	G Block	G Block	G Block	Internal	Roof Level 1	MALE STAFF TOILETS	CEILING SHEETS IN TOILETS SUSPECTED	Ceiling	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909003	G Block	G Block	G Block	Internal	Roof Level 1	HALLWAY	JADE COLOURED VINYL FLOOR TILES SAMPLE CP1447	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909003	G Block	G Block	G Block	Internal	Roof Level 1	CLEANERS	CEILING IN CLEANER'S ROOM SUSPECTED	Ceiling	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909003	G Block	G Block	G Block	Internal	Ground Floor	METAL FAB.	WALLS TO WELDING BAYS COMPRESSED ASBESTOS CEMENT SHEETED SAMPLE CP1444	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909003	G Block	G Block	G Block	Internal	Ground Floor	METAL FAB.	PEGBOARD WALLS IN GRINDING BAYS SAMPLE CP1445	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909003	G Block	G Block	G Block	External	Various levels	BUILDING	VENT PIPE AT REAR OF BUILDING SUSPECTED	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909003	G Block	G Block	G Block	External	Various levels External	BUILDING	ASBESTOS CEMENT SHEETING UNDER EAVES SUSPECTED	Gables/Soffits/Fascia	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909003	G Block	G Block	G Block	Internal	Roof Level 1	HALLWAY	GREEN VINYL FLOOR TILES IN HALLWAY SAMPLE CP1446	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909004	F Block	F Block	F Block	Internal	Roof Level 1	BUILDING	RED FLOOR TILES THROUGHOUT UPPER FLOOR SAMPLE CP1453	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909004	F Block	F Block	F Block	External	Various levels External	BUILDING EXTERNAL	SOFFITS UNDER THE EAVES AND VERANDAHS SUSPECTED	Gables/Soffits/Fascia	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909004	F Block	F Block	F Block	Internal	Roof Level 1	ROOM F8	PARTITION WALL BETWEEN ROOM 7 & 8 SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909004	F Block	F Block	F Block	Internal	Roof Level 1	ROOM F5	WELDING BAYS INTERNAL WALLS, SAMPLE CP1455	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909004	F Block	F Block	F Block	Internal	Roof Level 1	FEMALE STAFF TOILETS	TILUX SPLASHBACK TO HAND BASIN SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909004	F Block	F Block	F Block	Internal	Roof Level 1	ROOM 7	LEFT HAND WALL AS YOU ENTER ROOM, SAMPLE CP1421	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909004	F Block	F Block	F Block	Internal	Roof Level 1	PLUMBING STORE	GREEN FLOOR TILES IN STORE AREA ROOM 9 SAMPLE CP1451	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909004	F Block	F Block	F Block	Internal	Roof Level 1	FEMALE STAFF TOILETS	PARTITION WALL IN TOILET SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909004	F Block	F Block	F Block	Internal	Ground Floor	FEMALE TOILETS	PARTITION WALLS BETWEEN CUBICLES SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909004	F Block	F Block	F Block	Internal	Ground Floor	BUILDING	GREY TILES IN FOYER STAIRWELL & FEMALE TOILETS SUSPECTED SIMILAR TO TILES UPSTAIRS	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909004	F Block	F Block	F Block	Internal	Ground Floor	BUILDING	RED TILES IN FOYER STAIRWELL & FEMALE TOILETS SUSPECTED SIMILAR TO TILES UPSTAIRS	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909004	F Block	F Block	F Block	Internal	Roof Level 1	BUILDING	GREY VINYL FLOOR TILES THROUGHOUT THE UPPER FLOOR SAMPLE CP1452	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909004	F Block	F Block	F Block	Internal	Roof Level 1	BUILDING	BLACK FLOOR TILES THROUGHOUT UPPER FLOOR SAMPLE CP1454	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909004	F Block	F Block	F Block	Internal	Roof Level 1	BUILDING	CEILING SHEETING THROUGHOUT UPPER FLOOR, SAMPLE CP1450	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909004	F Block	F Block	F Block	Internal	Ground Floor	BUILDING	BLACK TILES IN FOYER STAIRWELL & FEMALE TOILETS SUS. SIMILAR TO TILES UPSTAIRS	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909005	E Block	E Block	E Block	Internal	Ground Floor	SWITCHBOARD	BACKING BOARD TO SWITCHBOARD, SAMPLE CP1441	Insulation/Fill	Polymer Bound	CHR - Chrysotile	4	Confirmed	25	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909005	E Block	E Block	E Block	Internal	Roof Level 1	BUILDING	VINYL FLOOR TILES SAMPLE CP1443	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909005	E Block	E Block	E Block	Internal	Ground Floor	ROOM E4 (DAIS)	VINYL FLOOR TILES SUSPECTED	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909005	E Block	E Block	E Block	Internal	Various levels Internal	BUILDING	CEILING THROUGHOUT BUILDING, SAMPLE CP1436	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909005	E Block	E Block	E Block	Internal	Ground Floor	ROOM E2	WALL SHEETING ON END WALL SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909005	E Block	E Block	E Block	External	Ground Floor	STORE	STEAM PIPE 6" CASTABLE ENCASED IN ALUMINIUM SURROUND, SAMPLE CP1456	Drains/Pipes/Floors	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909005	E Block	E Block	E Block	External	Various levels External	BUILDING EXTERNAL	SOFFIT SHEETING UNDER THE EAVES SUSPECTED	Gables/Soffits/Fascia	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909005	E Block	E Block	E Block	Internal	Ground Floor	ROOM E2	BULKHEAD SURROUNDS SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909005	E Block	E Block	E Block	Internal	Ground Floor	ROOM E1 FAN CONTROLS	BACKING BOARD TO FAN CONTROLS SUSPECTED	Insulation/Fill	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909005	E Block	E Block	E Block	Internal	Ground Floor	SWITCHBOARD	INSULATION IN FUSES, SAMPLE CP1442	Insulation/Fill	Woven Textile	CHR - Chrysotile	4	Confirmed	14	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909005	E Block	E Block	E Block	Internal	Ground Floor	ROOM E3	VINYL FLOOR SHEETING SAMPLE CP1439	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909005	E Block	E Block	E Block	Internal	Ground Floor	ROOM E4	BULKHEAD SURROUNDS SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909005	E Block	E Block	E Block	Internal	Ground Floor	ROOM E4	VINYL FLOOR TILES SAMPLE CP1437	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909005	E Block	E Block	E Block	Internal	Ground Floor	ROOM E4	VINYL FLOOR TILES SAMPLE CP1438	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909005	E Block	E Block	E Block	Internal	Ground Floor	ROOM E3	BULKHEAD SURROUNDS SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	27909005	E Block	E Block	E Block	Internal	Ground Floor	ROOM E1	WALL SHEETING ON END WALL (WESTERN) SAMPLE CP1440	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET		27909006	D Block	D Block	Internal	Ground Floor	ROOM D5	FAWN COLOURED LINOLEUM (ROOM RIGHT OF ENTRY) SAMPLE CP1448	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET		27909006	D Block	D Block	Internal	Ground Floor	FOYER ROOM D1	FAWN COLOURED LINOLEUM SIMILAR TO ROOM D3 SUSPECTED	Floor Finish/Covering	Vinyl Sheetting (includes backing)		3	Presumed	62	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET		27909006	D Block	D Block	Internal	Ground Floor	ROOM D3	FAWN VINYL FLOOR TILES (REAR ROOM) SUSPECTED	Floor Finish/Covering	Vinyl Tiles		3	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET		27909006	D Block	D Block	Internal	Roof Level 1	BUILDING	FLOOR TILES THROUGHOUT UPPER FLOOR SAMPLE CP1449	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	3	Not Present(Not Tested)	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET		27909007	B Block	B Block	External	Ground Floor	MAINT/CARPENTER	LOOSE BROKEN SIPER SIX LYING ON ROOF FROM ROOF REMOVAL	Debris	Cement Based		2	Removed	34	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET		27909007	B Block	B Block	External	Various levels	PRINT EXTERNAL	(PRINT ROOM COUNTER) SOFFIT SHEETING UNDER EAVES ABOVE COUNTER SUSPECTED	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET		27909007	B Block	B Block	External	Ground Floor	PRINT STORE	4M RIGHT OF ENTRY IN WALL AND EXTENDING TO ABOVE ROOF. SAMPLE CP1422	Drains/Pipes/Floors	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET		27909007	B Block	B Block	Internal	Ground Floor	PRINT	(PRINT ROOM COUNTER) PARTITION WALLS TO PRINT ROOM. SAMPLE CP1430	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET		27909007	B Block	B Block	Internal	Ground Floor	PRINT	CEILING IN PRINT ROOM COUNTER AREA. SAMPLE CP1429	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET		27909007	B Block	B Block	Internal	Ground Floor	PRINT/B1 & B2	CEILING IN OFFICES AND HALLWAY SUSPECTED	Ceiling	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET		27909009	PERGOLA	PERGOLA	External	Ground Floor	PERGOLA	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Battles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRB	27909000	" Site - Grounds	" Site - Grounds											-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRB01	27909010	Sub-Station	Sub-Station	Internal	Ground Floor	SWITCHBOARD	BACKING BOARD ON SWITCHBOARD	Insulation/Fill	Polymer Board		4	Presumed	25	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	Internal	Level 1	A/C UNIT	PANELS AROUND A/C UNITS SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	Internal	Ground Floor	HALLWAY	FAWN FLOOR TILES IN ENTRY AND HALLWAY SAMPLE CP1423	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	Internal	Level 1	STAIRCASE	RED TILES ON TREAD AND GREEN TILES ON RISER SUSPECTED	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	Internal	Level 1	STAIRCASE	BROWN & WHITE FLOOR TILES SUSPECTED SIMILAR TO SAMPLES CP1423 AND CP1425	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	Internal	Level 1	HALLWAY	TILES (BROWN/WHITE/FAWN) SIMILAR TO GROUND FLOOR HALLWAY SUSPECTED	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	Internal	Level 1	FEMALE STAFF TOILETS	TILUX SPLASHBACKS TO HAND BASINS SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	Internal	Level 1	FEMALE STAFF TOILETS	GREEN FLOOR TILES IN TOILETS SUSPECTED	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	Internal	Level 1	FEMALE STAFF TOILETS	COMPRESSED AC SHEETING FOR CUBICLE PARTITION WALLS SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	Internal	Site / Grounds	HALLWAY	WHITE FLOOR TILES IN ENTRY AND HALLWAY SAMPLE CP1425	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	Internal	Ground Floor	HALLWAY	BROWN FLOOR TILES IN ENTRY AND HALLWAY SAMPLE CP1424	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	Internal	Ground Floor	ROOM A11	TILES IN ROOM A11 SAMPLE CP1428	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	Internal	Ground Floor	MALE STAFF TOILET	TILUX SPLASHBACK ABOVE CLEANER'S SINK SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	Internal	Ground Floor	MALE STAFF TOILET	PARTITION WALLS FOR TOILET CUBICLES SAMPLE CP1426	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	Internal	Ground Floor	MALE STAFF TOILET	BOTTOM HALF OF WALL BESIDE URINAL SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	External	Level 1	FEMALE TOILETS	CEILING IN FEMALE TOILETS (EXTERNAL) SUSPECTED	Ceiling	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	Internal	Ground Floor	ROOM A11	TILUX SPLASHBACK ABOVE SINK SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	External	Site / Grounds	FRONT ENTRANCE	PIPEWORK 3M RIGHT OF ENTRANCE (BOLSOVER ST) SAMPLE CP1420	Drains/Pipes/Floors	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	Internal	Ground Floor	MALE STAFF TOILET	CEILINGS IN TOILET SAMPLE CP1427	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBAA	27909008	A Block	A Block	External	Various levels	REAR OF BLDG	VENT PIPE AT REAR OF BUILDING SUSPECTED	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBHH	27909002	H Block	H Block	Internal	Level 1	ART	VINYL TILES SUSPECTED	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBHH	27909002	H Block	H Block	Internal	Ground Floor	SIDE ENTRANCE	(SIDE ENTRANCE FOYER) BACKING TO VINYL FLOOR COVERING SUSPECTED. NO RISK IF NOT DISTURBED	Floor Backing/Underlay	Milboard		4	Presumed	64	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBHH	27909002	H Block	H Block	Internal	Ground Floor	ROOM B6	FLOOR TILES IN ROOM BESIDE DARK ROOM SAMPLE CP1432	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBHH	27909002	H Block	H Block	External	Various levels	SHADE AWNINGS	AC SHEETING UNDER SHADE AWNINGS SAMPLE CP1431	Sun Hood	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBHH	27909002	H Block	H Block	Internal	Level 1	ROOM H19	VINYL TILES SUSPECTED	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBHH	27909002	H Block	H Block	Internal	Level 1	COMPRESSOR	SPRAYED WALL INSULATION SAMPLE CP1435	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBHH	27909002	H Block	H Block	Internal	Ground Floor	FRONT ENTRANCE	FLOOR COVERING IN ENTRANCE SAMPLE CP1433	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	

Region	District	Facility Name	Site Name	Agency Ref No.	Other Ref No.	Improvement	Improvement Other Name	Int. Ed.	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBHH	27909002	H Block	H Block	Internal	Level 1	ROOM H13	VINYL TILES SUSPECTED	Floor Finish/Covering	Vinyl Tiles	4		Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBHH	27909002	H Block	H Block	Internal	Level 1	ROOM H16	VINYL TILES SUSPECTED	Floor Finish/Covering	Vinyl Tiles	4		Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBHH	27909002	H Block	H Block	Internal	Level 1	ROOM H18	VINYL TILES SUSPECTED	Floor Finish/Covering	Vinyl Tiles	4		Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBHH	27909002	H Block	H Block	Internal	Level 1	ROOM H20	VINYL TILES SUSPECTED	Floor Finish/Covering	Vinyl Tiles	4		Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBHH	27909002	H Block	H Block	Internal	Level 1	ROOM H24 CLEANERS ROOM	FLOOR TILES IN CLEANER'S ROOM SUSPECTED	Floor Finish/Covering	Vinyl Tiles	4		Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBHH	27909002	H Block	H Block	Internal	Level 1	STAIRWELL	FLOOR TILES SIMILAR TO ROOM B6 SUSPECTED	Floor Finish/Covering	Vinyl Tiles	4		Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBHH	27909002	H Block	H Block	Internal	Level 1	STAIRWELL	VINYL TILES SUSPECTED	Floor Finish/Covering	Vinyl Tiles	4		Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBHH	27909002	H Block	H Block	Internal	Level 1	HALLWAY	FLOOR TILES SAME AS IN ROOM B6 AND STAIRWELL	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	ROCKHAMPTON TAFE CAMPUS - BOLSOVER STREET	TRBHH	27909002	H Block	H Block	Internal	Level 1	ROOM H17	VINYL TILES SUSPECTED	Floor Finish/Covering	Vinyl Tiles	4		Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET		27810064	SHED 3	SHED 3	External	Ground Floor	SHED 3	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Baffles/Lining	Other (refer to description)	3		Not Present(Not Tested)	-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET		27810005	GROUNDS STORE	GROUNDS STORE	External	Ground Floor	GROUNDS STORE	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Baffles/Lining	Other (refer to description)	3		Not Present(Not Tested)	-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET		27810007	SHED 1	SHED 1	External	Ground Floor	SHED 1	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Baffles/Lining	Other (refer to description)	3		Not Present(Not Tested)	-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET		27810009	SHED 2	SHED 2	External	Ground Floor	SHED 2	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Baffles/Lining	Other (refer to description)	3		Not Present(Not Tested)	-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET		27810010	COVERED WALKWAY	COVERED WALKWAY	External	Ground Floor	COVERED WALKWAY	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Baffles/Lining	Other (refer to description)	3		Not Present(Not Tested)	-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	27810000	27910000	** Site - Grounds	** Site - Grounds										-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRK01		Shed	Shed										-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRK02		Shed/ Spray Booth	Shed/ Spray Booth										-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRK03		Shed	Shed										-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRK04		Demountable	Demountable										-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRK05		Shed	Shed										-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRK06		Greenhouse	Greenhouse										-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRK07		Store/ Shed	Store/ Shed										-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRK08		Greenhouse	Greenhouse										-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRK09		Greenhouse	Greenhouse										-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRK10		Work Area	Work Area										-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRK11		Work Area	Work Area										-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRK12		Shed	Shed										-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRK13		Shed	Shed										-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRK14	27910006	Sub-Station	Sub-Station	External	Ground Floor	CEB SUBSTATION BLDG	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Baffles/Lining	Other (refer to description)	3		Not Present(Not Tested)	-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRK15		Demountable	Demountable										-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKAA	27910015	A Block	A Block										-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKBB	27910001	B Block	B Block	External	Ground Floor	BUILDING	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Baffles/Lining	Other (refer to description)	3		Not Present(Not Tested)	-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKCC	27910016	C Block	C Block										-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKDD	27910017	D Block	D Block										-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKEE	27910002	E Block	E Block	External	Ground Floor	BUILDING	A COMPLETE ASBESTOS AUDIT OF THIS BUILDING FOUND TO BE ASBESTOS FREE	Baffles/Lining	Other (refer to description)	3		Not Present(Not Tested)	-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKFF	27910003	F Block	F Block	Internal	Ground Floor	ENTRY (REAR)	VINYL FLOOR TILES SIMILAR TO CLASSROOMS ARE SUSPECTED	Floor Finish/Covering	Vinyl Tiles	4		Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKFF	27910003	F Block	F Block	External	Various levels External	EAVES & VERANDAH	ALL EAVES AND VERANDAH SOFFIT SHEETING IS SUSPECTED	Gable/Soffit/Fascia	Cement Based	4		Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKFF	27910003	F Block	F Block	External	Various levels External	INFILL PANELS	AC INFILL PANELS TO EXTERNAL OF THE BUILDING IS SUSPECTED INCLUDING VERANDAH WALLS	Wall	Cement Based	4		Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKFF	27910003	F Block	F Block	Internal	Ground Floor	CLASSROOM	INFILL PANEL ABOVE WINDOWS AROUND CLASSROOM IS SUSPECTED	Wall	Cement Based	4		Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKFF	27910003	F Block	F Block	Internal	Ground Floor	CLASSROOMS	BEIGE VINYL FLOOR TILES SAMPLE CP5412	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKFF	27910003	F Block	F Block	Internal	Ground Floor	CLASSROOMS	BROWN VINYL FLOOR TILES SAMPLE CP5413	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKFF	27910003	F Block	F Block	Internal	Ground Floor	CLASSROOMS	VINYL FLOOR TILES THROUGHOUT SAMPLE CP5411	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKFF	27910003	F Block	F Block	Internal	Level 1	TOILETS M & F	COMPRESSED SHEETING TO DIVISIONAL WALLS BETWEEN PEDESTALS CP5419	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKFF	27910003	F Block	F Block	Internal	Ground Floor	MALE TOILETS	AC WALL SHEET TO TOILET PARTITION AND ENTRYWAY IS SUSPECTED	Wall	Cement Based		4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKFF	27910003	F Block	F Block	Internal	Ground Floor	STORE	AC HARDIGRAM SHEETING TO NORTH WESTERN STOREROOM UNDERNEATH STAIRWELL SAMPLE CP5415	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKFF	27910003	F Block	F Block	Internal	Ground Floor	STORE SWITCHBOARD	BACKING BOARD TO THE SWITCHBOARD IN NORTH WESTERN STOREROOM SAMPLE CP5416	Insulation/Fill	Polymer Bound	CHR - Chrysotile	4	Confirmed	25	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKFF	27910003	F Block	F Block	Internal	Ground Floor	TOILETS	COMPRESSED SHEET TO DIVISIONAL WALLS BETWEEN PEDESTALS (MALE & FEMALE) SAMPLE CP5418	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKFF	27910003	F Block	F Block	Internal	Ground Floor	TOILETS/HALLWAY	VINYL FLOOR COVERING VINYL BACKING CP5417 - NAD VINYL SAMPLE CP5417A - NAD	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKFF	27910003	F Block	F Block	Internal	Level 1	MAIN STAIRWELL	VINYL FLOOR TILES TO STAIRWELL ARE SUSPECTED	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Presumed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKFF	27910003	F Block	F Block	Internal	Ground Floor	CLASSROOMS	ORANGE VINYL FLOOR TILES SAMPLE CP5414	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKGG		G Block	G Block											-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKHH		H Block	H Block											-	
Central Queensland		ROCKHAMPTON TAFE CAMPUS - CANNING STREET	ROCKHAMPTON TAFE CAMPUS - CANNING STREET	TRKPP	27910019	P Block	P Block											-	
Central Queensland		YEPPOON TAFE CAMPUS - TABONE STREET	YEPPOON TAFE CAMPUS - TABONE STREET	TRY	50074000	Site/Grounds	Site/Grounds											-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS			B BLOCK	B BLOCK	External	Ground Floor	EXTERNAL NORTH	SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS			B BLOCK	B BLOCK	External	Ground Floor	EXTERNAL EAST	SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS			B BLOCK	B BLOCK	External	Ground Floor	EXTERNAL EAST	SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS			B BLOCK	B BLOCK	External	Ground Floor	EXTERNAL NORTH	SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS			B BLOCK	B BLOCK	External	Ground Floor	SOFFIT	SHEETING - SUNSHADE SOFFITS	Sun Hood	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS			B BLOCK	B BLOCK	External	Ground Floor	EXTERNAL WEST	SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS			B BLOCK	B BLOCK	External	Ground Floor	EXTERNAL WEST	SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS			B BLOCK	B BLOCK	External	Ground Floor	SOFFIT	SOFFIT SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS			B BLOCK	B BLOCK	External	Ground Floor	FASCIA/BARGE	SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS			B BLOCK	B BLOCK	External	Ground Floor	EXTERNAL GARAGE	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS			B BLOCK	B BLOCK	External	Ground Floor	EXTERNAL SOUTH	SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS		24067015	Child Care Centre Modular	Child Care Centre Modular	Internal	Ground Floor	ROOM 1.13 INTERNAL ROOM 1	WALL SHEETING - EXCEPT REAR WALL	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS		24067015	Child Care Centre Modular	Child Care Centre Modular	Internal	Ground Floor	ROOM 1.22 INTERNAL ROOM 2	WALL SHEETING - REAR WALL	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS		24067015	Child Care Centre Modular	Child Care Centre Modular	Internal	Ground Floor	ROOM 1.13 INTERNAL ROOM 1	WALL SHEETING - REAR WALLS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS		24067015	Child Care Centre Modular	Child Care Centre Modular	External	Ground Floor	EXTERNAL	SOFFIT SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS		24067015	Child Care Centre Modular	Child Care Centre Modular	External	Ground Floor	EXTERNAL	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS		24067015	Child Care Centre Modular	Child Care Centre Modular	Internal	Ground Floor	ROOM 1.22 INTERNAL ROOM 2	WALL SHEETING - EXCEPT REAR WALL	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS		24067016	GROUNDSMAN'S RESIDENCE	GROUNDSMAN'S RESIDENCE	External	Ground Floor	GROUNDSMAN'S RESIDENCE	BRICK VENEER CONST GYPROCK LININGS ASBESTOS FREE	Wall	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS		24067017	STORAGE SHED TRACTOR	STORAGE SHED TRACTOR	External	Ground Floor	STORAGE SHED TRACTOR	BESSER BLOCK WALLS ASBESTOS FREE MATERIAL	Other (refer to description)	Other (refer to description)		NA	Not Present(Not Tested)	-	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS		24067018	Child Care Centre Shade Structure	Child Care Centre Shade Structure	External	Ground Floor	SHADE STRUCTURE	METAL CONSTRUCTION ASBESTOS FREE (SHADE STRUCTURE)	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS		24067018	Child Care Centre Shade Structure	Child Care Centre Shade Structure	External	Ground Floor	SHADE STRUCTURE	TIMBER CONSTRUCTION ASBESTOS FREE (SHADE STRUCTURE)	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS		24067019	GAZEBO	GAZEBO	External	Ground Floor	GAZEBO	TIMBER AND METAL CONSTRUCTION ASBESTOS FREE	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS		24067020	Child Care Centre Shed	Child Care Centre Shed	Internal	Ground Floor	METAL SHED	METAL CONSTRUCTION ASBESTOS FREE	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PAS	24067000	SITE	SITE	Internal	Ground Floor	VARIOUS LOCATIONS	ELECTRICAL TELECOM PITS - VARIOUS SITES OF CAMPUS GROUNDS	Plant, Equipment & Machinery	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PAS	24067000	SITE	SITE	External	Ground Floor	WATERFALL POND PUMP	WATERFALL POND PUMP FIXTURE ON SOUTH WEST CORNER OF CAMPUS - ASBESTOS FREE MATERIAL	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PAS	24067000	SITE	SITE	External	Ground Floor	PATHWAY	ELECTRICAL PIT LIGHTS - ON PATH FROM CAR PARK (CANTEN TO OFFICE)	Furniture	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PAS01		Shed (Timber Storage)	Shed (Timber Storage)	External	Ground Floor	ROOM 03:12 FUEL STORE	SHEETING	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PAS02	24067005	Flammable Store	Flammable Store	External	Ground Floor	ROOM 03:12 FUEL STORE	SHEETING	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PAS03	24067013	Pump House	Pump House	Internal	Ground Floor	EXHAUST PIPE	INSULATION WRAP - LOWER HALF OF EXHAUST PIPE	Pipe Insulation	Woven Textile	No asbestos detected (NAD)	4	Not Present(Not Tested)	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PAS03	24067013	Pump House	Pump House	Internal	Ground Floor	EXHAUST PIPE	INSULATION WRAP - TOP HALF OF EXHAUST PIPE	Pipe Insulation	Woven Textile	No asbestos detected (NAD)	4	Not Present(Not Tested)	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PAS04		Shed (Horticulture)	Shed (Horticulture)	External	Ground Floor									-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	REAR KITCHEN ENTRY	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Ground Floor	CEILING SPACE	HEATER BANKS - IN CEILING SPACE VARIOUS LOCATIONS	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	External	Level 4	SOUTH EAST STAIRWAY	FIRE EXIT DOORS TO LEVEL FOUR EXTERNAL SOUTH EAST STAIRWELL	Fire Door	Millboard	Mixed	3	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Ground Floor	LIFT GARAGE	SHEET VINYL FLOORING - LIFT GARAGE	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Not Tested)	62	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	CEILING SPACE	HEATER BANKS IN CEILING SPACE AT VARIOUS LOCATIONS Sample 11823 to 11831 all (NAD) 2000/01 program	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	EXIT DOUBLE DOOR	FIRE EXIT DOUBLE DOOR TO HALLWAY BELOW AUDITORIUM	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	HALLWAY EXIT	FIRE EXIT DOUBLE DOORS TO THE HALLWAY BELOW THE AUDITORIUM	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Ground Floor	CANTEEN EATING AREA	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	MAIN STAIRS	FIRE EXIT SINGLE DOOR MAIN STAIRWELL LEVEL 1	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	External	Level 3	SOUTH EAST STAIRWAY	FIRE EXIT DOOR TO LEVEL THREE ON SOUTH EAST STAIRWELL	Fire Door	Millboard	Mixed	4	Removed	64	-	

TAFEs from BEMIR-TAFEs

Current as at 10-May-11

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Alteration Required	Comments
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	REAR KITCHEN ENTRY	WALL SHEETING	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	ROOM 1.1 TELECOM ROOM	TELECOM ROOM DOORS IN HALLWAY (DOUBLE DOORS) MAIN FOYER	Fire Door	Millboard	Mixed	3	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 5	FASCIA	FASCIA SHEETING - TO PERIMETER	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	ROOM 1.12 ELECTRICAL ROOM	DOUBLE DOORS ELECTRICAL ROOM	Fire Door	Millboard	Mixed	3	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	LEVEL 1 MAIN STAIRS	FIRE EXIT SINGLE DOOR MAIN STAIR WELL	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	External	Level 2	ROOM 2.12E ELECTRICAL PLANT ROOM	EXTERNAL DOUBLE DOORS TO ELECTRICAL MAIN SWITCHBOARD FOR PLANT ROOM	Fire Door	Millboard	Mixed	3	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	ROOM 1.53 STORE ROOM	INTERNAL FIRE DOOR TO ROOM 1.53 STORE ROOM UNDER THEATRE STAGE	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 4	ROOM A4 14	SMALL INT DOOR ON AC DUCTING SHAFT IN WALL IN ROOM A4 14	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	ROOM 1.56 STORE ROOM	INTERNAL DOOR TO STORE ROOM 1.56 UNDER THEATRE STAIRS	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	External	Level 1	ENTRANCE WALKWAY	FASCIA SHEETING - ENTRANCE WALKWAY	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	External	Level 1	FIRE EXIT DOOR	EXTERNAL FIRE EXIT DOOR AT BOTTOM OF STAIRS TO OUTSIDE COURTYARD	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	External	Level 3	SOUTH EAST STAIRWAY	FIRE EXIT DOOR TO LEVEL THREE ON SOUTH EAST STAIRWELL	Fire Door	Millboard	CHR - Chrysotile	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	External	Level 1	SUN HOODS	SHEETING - SUN HOOD	Sun Hood	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	External	Level 5	ROOF AREA	WALL SHEETING - TO PARAPET WALL	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	External	Level 2	ROOM 2.12E ELECTRICAL PLANT ROOM	EXTERNAL DOUBLE DOORS TO ELECTRICAL MAIN SWITCHBOARD FOR PLANT ROOM	Fire Door	Millboard	Mixed	3	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	External	Level 2	SUN HOODS	SHEETING - SUN HOOD	Sun Hood	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	External	Level 3	SOUTH EAST STAIRWAY	FIRE EXIT DOOR TO LEVEL THREE ON SOUTH EAST STAIRWELL	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	External	Level 3	SOUTH EAST STAIRWAY	FIRE EXIT DOOR TO LEVEL THREE ON SOUTH EAST STAIRWELL	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	External	Level 3	SOUTH EAST STAIRWAY	FIRE EXIT DOOR TO LEVEL THREE ON SOUTH EAST STAIRWELL	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	External	Level 4	SOUTH EAST STAIRWAY	FIRE EXIT DOOR TO LEVEL 4 EXTERNAL SOUTH EAST STAIR WELL	Fire Door	Other (refer to description)	No asbestos detected (NAD)	3	Removed	-	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	External	Level 1	FOYER	WALL SHEETING - EXTERNAL OF ID CARD ROOM	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 3	CEILING SPACE	HB IN CEILING SPACE AT VARIOUS LOCATIONS Sampled (NAD)	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 3	ROOM 3.05 COMP	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 3	MAIN STAIRWELL	FIRE EXIT DOOR TO LEVEL 3 MAIN STAIRWELL	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 3	MAIN STAIRWELL	FIRE EXIT DOOR FROM MAIN STAIRWELL TO LEVEL THREE	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 3	HOSE REEL CUPBOARD	CEILING SHEETING - (SOME DAMAGE & DEBRIS) TO FIRE HOSE REEL CUPBOARD	Ceiling	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 3	FOYER	SINGLE DOOR TO TELECOM ROOM 3RD LEVEL IN FOYER	Fire Door	Millboard	Mixed	3	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	ROOM 1.53 STORE ROOM	INTERNAL FIRE DOOR TO ROOM 1.53 STORE ROOM UNDER THEATRE STAGE	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 3	CEILING SPACE	HB IN CEILING SPACE AT VARIOUS LOCATIONS Sampled (NAD)	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 4	FIRE EXIT WELL	FIRE DOOR IN FIRE WELL SAMPLE SC 3352 (MIX)	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 3	CEILING SPACE	HB IN CEILING SPACE AT VARIOUS LOCATIONS	Heater Bank Insulation	Millboard	Mixed	4	Confirmed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 3	AC UNIT ROOM	SHEET VINYL TO AIR CONDITIONING UNIT ROOM OFF HALLWAY SIM TO SAMPLE SC 3292	Floor Finish/Covering	Vinyl Sheeting (includes backing)	4	Presumed	62	-		
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 3	AC UNIT ROOM	SHEET VINYL TO AIR CONDITIONING UNIT ROOM OFF HALLWAY SAMPLE SC 3292 (NAD)	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 3	AC UNIT ROOM	SHEET VINYL FLOORING - AIR CONDITIONING UNIT ROOM OFF HALLWAY	Floor Finish/Covering	Vinyl Sheeting (includes backing)	4	Presumed	62	-		
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	ROOM 1.55 STORE ROOM	INTERNAL DOOR TO STORE ROOM 1.55 UNDER THEATRE STAIRS	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 3	AC DUCTING	INTERNAL SMALL DOORS TO AC DUCTING IN PASSAGE HALLWAY TO NORTH END	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 3	FOYER	DOUBLE DOORS TO ELECTRICAL ROOM 3RD LEVEL IN FOYER	Fire Door	Millboard	Mixed	3	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 4	ROOM A4 13	SMALL DOOR TO AC DUCTING SHAFT ON WALL IN ROOM A4 13	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 4	ROOM A4 14	SMALL INT DOOR ON AC DUCTING SHAFT IN WALL IN ROOM A4 14	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 5	FIRE ESCAPE	CORE INSULATION - TO FIRE DOOR IN FIRE ESCAPE	Fire Door	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 5	LIFT PLANT ROOM	BREAK PADS TO LIFT MOTOR EQUIPMENT	Plant, Equipment & Machinery	Polymer Bound	4	Presumed	25	-		
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 5	LIFT PLANT ROOM	WALL SHEETING	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 5	LIFT PLANT ROOM	ZELEMITE BACKING TO LIFT ELECTRICAL CABINET	Plant, Equipment & Machinery	Polymer Bound	4	Presumed	25	-		
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 5	ROOM 5.01 PLANT ROOM	FIRE DOOR - LEVEL 5 PLANT ROOM ABOVE STAIRWELL	Fire Door	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 3	SOUTH EAST STAIRWAY	FIRE EXIT DOOR TO LEVEL 3 SOUTH EAST STAIRWELL	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 5	ROOM 5.01 PLANT ROOM	WALL SHEETING	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 4	CEILING SPACE	HEATER BANK IN CEILING SPACE - VARIOUS LOCATIONS	Heater Bank Insulation	Insulation Board	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 4	ROOM A4 13	SMALL DOOR TO AC DUCTING SHAFT ON WALL IN ROOM A4 13	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 4	MAIN STAIRWELL	FIRE EXIT DOOR ON MAIN STAIRWELL TO LEVEL FOUR	Fire Door	Millboard	Mixed	4	Removed	64	-	
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 4	MAIN STAIRWELL	FIRE EXIT DOOR ON MAIN STAIR WELL LEVEL 4	Fire Door	Millboard	4	Removed	64	-		
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 4	FOYER	SINGLE DOOR TO TELECOM ROOM ON 4TH LEVEL	Fire Door	Millboard	Mixed	3	Removed	64	-	

TAFes from BEMIR-TAFes

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ed.	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 4	FOYER	DOUBLE DOORS IN FOYER ELECTRICAL ROOM 4TH FLOOR	Fire Door	Miliboard	Mixed	3	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 3	AC DUCTING	INTERNAL SMALL DOORS TO AC DUCTING IN PASSAGE HALLWAY TO NORTH END	Fire Door	Miliboard	Mixed	4	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 5	ROOM 5.01 PLANT ROOM	WALL SHEETING	Wall	Cement Based	Mixed	4	Confirmed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	ROOM 2.12A ID CARD ROOM	WALL SHEETING	Wall	Cement Based	Mixed	4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 2	ROOM 2.12E PLANT ROOM	INTERNAL DOUBLE DOORS TO BACK ELECTRICAL ROOM IN PLANT ROOM MAIN SWITCHBOARD	Fire Door	Miliboard	Mixed	3	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 2	ROOM 2.12E PLANT ROOM	INTERNAL DOUBLE DOORS TO BACK ELECTRICAL ROOM IN PLANT ROOM MAIN SWITCHBOARD	Fire Door	Miliboard	Mixed	3	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 2	ROOM 2.12A PABX ROOM	SINGLE DOOR TO PABX ROOM IN SIDE HALLWAY OF MAIN FOYER 2ND LEVEL	Fire Door	Miliboard	Mixed	3	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 2	MAIN FOYER	INTERNAL DOUBLE DOORS FROM FOYER TO THEATRE ROOM	Fire Door	Miliboard	Mixed	4	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 2	FOYER	DOUBLE DOORS TO ELECTRICAL ROOM 2ND LEVEL IN FOYER	Fire Door	Miliboard	Mixed	3	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 2	CEILING SPACE	HEATER BANKS - IN CEILING SPACE AT VARIOUS LOCATIONS	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 2	ROOM 2.12E PLANT ROOM	LARGE SLIDING PLANT ROOM DOOR METAL COVER AT EDGES	Fire Door	Miliboard	Mixed	3	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	STAIRWELL	FIRE EXIT DOOR TO SOUTH EAST STARWAY TO OUTSIDE GROUND LEVEL	Fire Door	Miliboard	CHR - Chrysotile	3	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 2	MAIN FOYER	INTERNAL DOUBLE DOORS FROM FOYER TO THEATRE ROOM 2ND LEVEL	Fire Door	Miliboard	Mixed	4	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	ROOM 1.56B PLANT ROOM	M1 SHEETING - AROUND MILBOARD IN DUCT	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	ROOM 1.56B PLANT ROOM	INSULATION WRAP TO PIPES - PENETRATION DUCT	Pipe Insulation	Woven Textile	No asbestos detected (NAD)	4	Not Present(Not Tested)	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	ROOM 1.56 STORE ROOM	INTERNAL DOOR TO STORE ROOM 1.56 UNDER THEATRE STAIRS	Fire Door	Miliboard	Mixed	4	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	ROOM 1.55 STORE ROOM	INTERNAL DOOR TO STORE ROOM 1.55 UNDER THEATRE STAIRS	Fire Door	Miliboard	Mixed	4	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	ROOM 1.54 STORE ROOM	INTERNAL FIRE DOOR TO ROOM 1.54 STORE ROOM UNDER THEATRE STAGE	Fire Door	Miliboard	Mixed	4	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	ROOM 1.54 STORE ROOM	INTERNAL FIRE DOOR TO ROOM 1.54 STORE ROOM UNDER THEATRE STAGE	Fire Door	Miliboard	Mixed	4	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 1	STAIRWELL FIRE DOOR	FIRE EXIT DOOR TO SOUTH EAST STARWAY TO OUTSIDE GROUND LEVEL	Fire Door	Miliboard	Mixed	3	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 2	SOUTH EAST STAIRWAY	FIRE EXIT DOOR SOUTH EAST LIBRARY ON STAIRWELL LEVEL TWO	Fire Door	Miliboard	Mixed	4	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 2	SOUTH EAST STAIRWAY	SOUTH EAST LIBRARY FIRE EXIT DOOR ON STAIRWELL	Fire Door	Miliboard	Mixed	4	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 2	STAIRWELL	FIRE DOOR TO MAIN STAIRWELL ON LEVEL TWO	Fire Door	Miliboard	CHR - Chrysotile	4	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 2	STAIRWELL FIRE DOOR	FIRE DOOR TO MAIN STAIRWAY ON LEVEL 2	Fire Door	Miliboard	Mixed	4	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 2	FOYER	SINGLE DOOR TO TELECOM ROOM 2ND LEVEL MAIN FOYER	Fire Door	Miliboard	Mixed	3	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASAA	24067012	A Block	A Block	Internal	Level 2	ROOM 2.12E PLANT ROOM	LARGE SLIDING PLANT ROOM DOOR METAL COVER AT EDGES	Fire Door	Miliboard	Mixed	3	Removed	64	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB1	B Block - Build 1 (Electrical)	B Block - Build 1 (Electrical)	B Block - Build 1 (Electrical)	Internal	Ground Floor	ROOM B1:4 MACHINE SHOP	WALL SHEETING	Wall	Cement Based	Mixed	4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB1	B Block - Build 1 (Electrical)	B Block - Build 1 (Electrical)	B Block - Build 1 (Electrical)	Internal	Ground Floor	ELECTRICAL SWITCHBOARD	CEILING SHEETING	Ceiling	Cement Based	Mixed	4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB1	B Block - Build 1 (Electrical)	B Block - Build 1 (Electrical)	B Block - Build 1 (Electrical)	Internal	Ground Floor	RESOURCE U B1:2	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	Mixed	4	Presumed	62	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB1	B Block - Build 1 (Electrical)	B Block - Build 1 (Electrical)	B Block - Build 1 (Electrical)	Internal	Ground Floor	ROOM B1:1 ELECTRICAL	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Not Tested)	62	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB1	B Block - Build 1 (Electrical)	B Block - Build 1 (Electrical)	B Block - Build 1 (Electrical)	Internal	Ground Floor	ROOM B1:3 STORES	WALL SHEETING	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB2	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	Internal	Ground Floor	ROOM B2:4 CARPENTRY	WALL SHEETING - ABOVE BLOCK WORK	Wall	Cement Based	Mixed	4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB2	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	Internal	Ground Floor	ROOM B2:8	WALL SHEETING - ABOVE BLOCK WORK	Wall	Cement Based	Mixed	4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB2	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	External	Ground Floor	EXTERNAL EAST	CEILING SHEETING - IN FRONT OF ROLLER DOORS TO MECHANIC	Ceiling	Cement Based	Mixed	4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB2	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	Internal	Ground Floor	ROOM B2:4 STORE STAFF	SHEET VINYL FLOORING - UNDER CARPET	Floor Backing/Underlay	Vinyl Sheeting (includes backing)	Mixed	4	Presumed	62	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB2	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	External	Ground Floor	INT GARDENS	SHEETING - ABOVE GARDENS	Gable/Soffit/ascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB2	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	Internal	Ground Floor	ELECTRICAL SWITCHBOARD	WALL SHEETING - ABOVE SWITCHBOARD DOORS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB2	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	Internal	Ground Floor	JOINING HALLWAY	WALL SHEETING - ABOVE BLOCK WORK	Wall	Cement Based	Mixed	4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB2	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	Internal	Ground Floor	ROOM B2:1	WALL SHEETING - ABOVE BLOCK WORK	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB2	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	Internal	Ground Floor	ROOM B2:2 SAW SHARP	WALL SHEETING - ABOVE BLOCK WORK	Wall	Cement Based	Mixed	4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB2	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	B Block - Build 2 (C & J, Auto 3)	Internal	Ground Floor	ROOM B2:7 TOOL STORE	WALL SHEETING - ABOVE BLOCK WORK	Wall	Cement Based	Mixed	4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB3	B Block - Build 3 (Auto 2)	B Block - Build 3 (Auto 2)	B Block - Build 3 (Auto 2)	Internal	Ground Floor	ROOM B3:1 STORE	WALL SHEETING - TO APEX OF END WALLS	Wall	Cement Based	Mixed	4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB3	B Block - Build 3 (Auto 2)	B Block - Build 3 (Auto 2)	B Block - Build 3 (Auto 2)	Internal	Ground Floor	ROOM 1.08 MALE TOILET	CEILING SHEETING	Ceiling	Cement Based	Mixed	4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB3	B Block - Build 3 (Auto 2)	B Block - Build 3 (Auto 2)	B Block - Build 3 (Auto 2)	Internal	Ground Floor	ROOM B 3:9	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	Mixed	4	Presumed	62	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB3	B Block - Build 3 (Auto 2)	B Block - Build 3 (Auto 2)	B Block - Build 3 (Auto 2)	Internal	Ground Floor	ROOM B 3:5	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Not Tested)	62	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB3	B Block - Build 3 (Auto 2)	B Block - Build 3 (Auto 2)	B Block - Build 3 (Auto 2)	Internal	Ground Floor	ROOM B 3:4	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	Mixed	4	Presumed	62	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	External	Ground Floor	WALKWAY & LINK	SHEETING	Gable/Soffit/ascia	Cement Based	Mixed	4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	Internal	Ground Floor	ROOM B4:7 WELDING	SHEETING - WELDING BOOTHS	Furniture	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	Internal	Ground Floor	RES 4-11 A&B	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	Mixed	4	Presumed	62	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BSMR Score	Attention Required	Comments
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	Internal	Ground Floor	ROOM B4:7 WELDING	WALL SHEETING - ABOVE BLOCK WORK	Wall	Cement Based	4	Presumed	18	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	Internal	Ground Floor	ROOM B4:13 HALL	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	4	Presumed	62	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	Internal	Ground Floor	ROOM B4:12 MET FAB	WALL SHEETING - ABOVE BLOCKS	Wall	Cement Based	4	Presumed	18	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	Internal	Ground Floor	ROOM B2:5 CAR WORKSHOP	WALL SHEETING - TO APOC OF WALL	Wall	Cement Based	4	Presumed	18	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	Internal	Ground Floor	ROOM 1.33 GAS BOTTLE STORE	CEILING SHEETING	Ceiling	Cement Based	4	Presumed	18	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	Internal	Ground Floor	ROOM 1.13 STAFF ROOM	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	4	Presumed	62	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	Internal	Ground Floor	ROOM 1.00 ENGINE WASH BAY	CEILING SHEETING	Ceiling	Cement Based	4	Presumed	18	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	External	Ground Floor	CENTRAL WALKWAY/GRD	EIGHT (8) DOWN PIPES	Drains/Pipes/Floors	Cement Based	Mixed	4	Confirmed	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	Internal	Ground Floor	WALKWAY & LINK	CEILING SHEETING	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	External	Ground Floor	EXTERNAL WEST	FOUR (4) DOWN PIPES	Drains/Pipes/Floors	Cement Based	4	Presumed	18	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	External	Ground Floor	EXTERNAL NORTH	ONE (1) DOWN PIPE	Drains/Pipes/Floors	Cement Based	4	Presumed	18	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	External	Ground Floor	EXTERNAL EAST	TWO (2) DOWN PIPES	Drains/Pipes/Floors	Cement Based	4	Presumed	18	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	External	Ground Floor	EXT VERANDAH	SHEETING	Gable/Soffit/Fascia	Cement Based	4	Presumed	18	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	External	Ground Floor	EXT VERANDAH	CEILING SHEETING	Ceiling	Cement Based	4	Presumed	18	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	External	Ground Floor	ADJACENT GAS BOTTLE STORE	WALL SHEETING - ADJACENT TO GAS BOTTLE STORE	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB4	B Block - Build 4 (Eng. Admin, Auto 1)	B Block - Build 4 (Eng. Admin, Auto 1)	External	Ground Floor	WALKWAYS	SUPER SIX PROFILE CEILING LINING - TO WALKWAYS	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB5	B Block - Build 5 (Maint. C & J)	B Block - Build 5 (Maint. C & J)	Internal	Ground Floor	ROOM B5:4 ANCILLARY STAFF	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	4	Presumed	62	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB5	B Block - Build 5 (Maint. C & J)	B Block - Build 5 (Maint. C & J)	Internal	Ground Floor	ROOM B5:7	CEILING SHEETING	Ceiling	Cement Based	4	Presumed	18	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASB5	B Block - Build 5 (Maint. C & J)	B Block - Build 5 (Maint. C & J)	Internal	Ground Floor	ROOM B5:5 MAINTENANCE	CEILING SHEETING	Ceiling	Cement Based	4	Presumed	18	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	Internal	Ground Floor	CONSTRUCTION AREA	WALL SHEETING - STORAGE AREA	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-		
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	Internal	Ground Floor	ROOM 1.14C MAIN STORE OFFICE 1	NEW SHEET VINYL ASBESTOS FREE	Floor Finish/Covering	Other (refer to description)	4	Not Present(Not Tested)	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	Internal	Ground Floor	ROOM 1.15 MAIN STORE OFFICE	NEW SHEET VINYL ASBESTOS FREE	Floor Finish/Covering	Other (refer to description)	4	Not Present(Not Tested)	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	Internal	Ground Floor	ROOM 1.01 WELDING BAY	WALL SHEETING	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-		
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	Internal	Ground Floor	HALLWAYS	CEILING SHEETING (WITH SET JOINS) - INCLUDING SKYLIGHTS	Ceiling	Cement Based	4	Presumed	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	Internal	Ground Floor	ROOM 1.14D MAIN STORE	CEILING SHEETING	Ceiling	Cement Based	4	Presumed	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	Internal	Ground Floor	CONSTRUCTION AREA	SHEETING - BENCH TOPS AND SHELVES	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	External	Level 1	EXTERNAL NORTH	SHEETING	Gable/Soffit/Fascia	Cement Based	4	Presumed	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	Internal	Ground Floor	ROOM 1:11 FEMALE TOILET	CEILING SHEETING	Ceiling	Cement Based	4	Presumed	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	External	Ground Floor	EXTERNAL WEST	SHEETING	Gable/Soffit/Fascia	Cement Based	4	Presumed	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	External	Ground Floor	CONSTRUCTION AREA	SHEETING	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-		
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	Internal	Ground Floor	EXTERNAL	CEILING SHEETING	Ceiling	Cement Based	4	Presumed	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	External	Level 1	EXTERNAL EAST	SHEETING	Gable/Soffit/Fascia	Cement Based	4	Presumed	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	Internal	Ground Floor	EXTERNAL NORTH	SHEETING	Gable/Soffit/Fascia	Cement Based	4	Presumed	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	Internal	Ground Floor	ROOM 1:13 DISABLED TOILET	CEILING SHEETING	Ceiling	Cement Based	4	Presumed	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	Internal	Ground Floor	ROOM 1:19 STORAGE	CEILING SHEETING - INCLUDING SKYLIGHT PENETRATION	Ceiling	Cement Based	4	Presumed	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	Internal	Ground Floor	ROOM 1:20 TOOL STORE	CEILING SHEETING - INCLUDING SKYLIGHT PENETRATION	Ceiling	Cement Based	4	Presumed	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	External	Ground Floor	EXTERNAL SOUTH	CEILING SHEETING	Ceiling	Cement Based	4	Presumed	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	Internal	Ground Floor	ROOM 1:04 PROJECT STORE	CEILING SHEETING	Ceiling	Cement Based	4	Presumed	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	Internal	Ground Floor	ROOM 1:08 MALE TOILET	CEILING SHEETING	Ceiling	Cement Based	4	Presumed	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCC	24067002	C Block	C Block	Internal	Ground Floor	ROOM 1:09 CLEANERS ROOM	CEILING SHEETING	Ceiling	Cement Based	4	Presumed	18	-			
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCH	24067014	Child Care Centre	Child Care Centre	External	Ground Floor	SHADE STRUCTURE	METAL CONSTRUCTION OF SAIL SHADE ASBESTOS FREE	Wall	Other (refer to description)	4	Not Present(Not Tested)	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCH	24067014	Child Care Centre	Child Care Centre	External	Ground Floor	GABLES	SHEETING TO GABLE ASBESTOS FREE	Wall	Other (refer to description)	4	Not Present(Not Tested)	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCH	24067014	Child Care Centre	Child Care Centre	External	Ground Floor	SHADE STRUCTURE	METAL CONSTRUCTION ASBESTOS FREE	Baffles/Lining	Other (refer to description)	4	Not Present(Not Tested)	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCH	24067014	Child Care Centre	Child Care Centre	External	Ground Floor	SHADE STRUCTURE	METAL CONSTRUCTION ASBESTOS FREE	Baffles/Lining	Other (refer to description)	4	Not Present(Not Tested)	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCH	24067014	Child Care Centre	Child Care Centre	External	Ground Floor	SHADE STRUCTURE	SHADE STRUCTURE METAL CONSTRUCTION ASBESTOS FREE	Wall	Other (refer to description)	4	Not Present(Not Tested)	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCH	24067014	Child Care Centre	Child Care Centre	External	Ground Floor	SOFFIT	SHEETING TO SOFFIT ASBESTOS FREE	Gable/Soffit/Fascia	Other (refer to description)	4	Not Present(Not Tested)	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCH	24067014	Child Care Centre	Child Care Centre	Internal	Ground Floor	SWING SET	TIMBER CONSTRUCTION ASBESTOS FREE	Wall	Other (refer to description)	4	Not Present(Not Tested)	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCH	24067014	Child Care Centre	Child Care Centre	External	Ground Floor	SHADE STRUCTURE	METAL CONSTRUCTION ASBESTOS FREE	Baffles/Lining	Other (refer to description)	4	Not Present(Not Tested)	-				
Gold Coast	Ashmore	ASHMORE GCIT CAMPUS	PASCR	PIE Community Centre	PIE Community Centre														

Region	District	Facility Name	Site Name	Agency Ref No.	Other Ref No.	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASDD	24067011	D Block	D Block	External	Ground Floor	EXTERNAL	EXTERNAL VIEW OF BUILDING FOR ID ASBESTOS FREE	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASDD	24067011	D Block	D Block	External	Level 2	DRIVEWAY	WALL SHEETING - NORTH WEST WALL	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASFE		E Block	E Block											-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASFF		F Block (Demountable near Auto 1)	F Block (Demountable near Auto 1)											-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASGG		G Block (Marine Workshop)	G Block (Marine Workshop)											-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASHH		H Block (Demountable near Oval)	H Block (Demountable near Oval)											-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASRC	24067001	Sports Club (Rugby), Grounds Shed	Sports Club (Rugby), Grounds Shed	Internal	Ground Floor	ROOM 1.07 VISIT DRESS ROOM	CEILING SHEETING - ABOVE LOUVRES SOUTH	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASRC	24067001	Sports Club (Rugby), Grounds Shed	Sports Club (Rugby), Grounds Shed	Internal	Ground Floor	ROOM 1.07 HTHEAM DRESS RM	CEILING SHEETING - SHEETING ABOVE LOUVRES SOUTH	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASRC	24067001	Sports Club (Rugby), Grounds Shed	Sports Club (Rugby), Grounds Shed	Internal	Ground Floor	ROOM 1.08 LADIES TOILET	PATCH IN CEILING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASRC	24067001	Sports Club (Rugby), Grounds Shed	Sports Club (Rugby), Grounds Shed	External	Ground Floor	CLUB HOUSE EXTERNAL	WALL PANELS	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASRC	24067001	Sports Club (Rugby), Grounds Shed	Sports Club (Rugby), Grounds Shed	External	Ground Floor	TRACTOR SHED SOFFIT	SOFFIT SHEETING	Gable/Soffit/Jacile	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASRC	24067001	Sports Club (Rugby), Grounds Shed	Sports Club (Rugby), Grounds Shed	Internal	Ground Floor	DUCT ACC MALE TOILET	CEILING SHEETING SOUTH	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASRC	24067001	Sports Club (Rugby), Grounds Shed	Sports Club (Rugby), Grounds Shed	Internal	Ground Floor	ROOM 1.03 MALE TOILET	WALL SHEETING - ABOVE LOUVRES	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASRC	24067001	Sports Club (Rugby), Grounds Shed	Sports Club (Rugby), Grounds Shed	Internal	Ground Floor	DUCT ACC MALE TOILET	SHEETING - DRAIN PROFILE	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASRC	24067001	Sports Club (Rugby), Grounds Shed	Sports Club (Rugby), Grounds Shed	Internal	Ground Floor	ROOM 1.01 MAIN CLUB ROOM	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Ashmore	ASHMORE GCIT CAMPUS	PASRC	24067001	Sports Club (Rugby), Grounds Shed	Sports Club (Rugby), Grounds Shed	External	Ground Floor	CLUB HOUSE EXTERNAL	SOFFIT SHEETING	Gable/Soffit/Jacile	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCO	23087000	-- Site - Grounds	-- Site - Grounds											-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Level 1	ROOM 2.03 STORE OFFICE	CEILING SHEETING	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1.02 KITCHEN	WALL PANELS - NEAR OUTSIDE DOOR (NORTH)	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1:14	MILLBOARD IN HEATER BANKS WITH AIR CONDITION. UNIT SAMPLE #SC1895	Heater Bank Insulation	Millboard	CHR - Chrysotile	2	Removed	69	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1:13	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Level 1	ROOM 2.05 CAGED STORE	WALL SHEETING - EAST WALL	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1:14	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Level 1	ADJ STORE OFFICE	WALL SHEETING - SPLASHBACK BEHIND BASIN AND DRINK FOUNTAIN	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Level 1	ROOM 1.07 COUNSELLOR OFF	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Level 1	ROOM 1.07 COUNSELLOR OFF	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Level 1	ROOM 2.03 STORE OFFICE	VINYL FLOOR TILES - UNDER CARPET	Floor Backing/Underlay	Vinyl Tiles		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Level 1	ROOM 2.03 STORE OFFICE	MILLBOARD IN DUCTING ON OFFICE ROOF ACTUAL HEATER SAMPLE #SC2000	Heater Bank Insulation	Millboard	CHR - Chrysotile	2	Removed	69	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Level 1	ROOM 2.13 TEMP LOCKER ROOM	EXTERNAL WALL SHEETING - TO LOCKER ROOM	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1.064 CONFERENCE ROOM	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1.02 KITCHEN	KITCHEN STORE WALL PANELS - NORTH WALL	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1.06B HAIRDRESS RECEPTION	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	16	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1:14	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Level 1	STORE	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Level 1	STORE	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Level 1	ROOM 201	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Not Tested)	62	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Level 1	ROOM 2.13 TEMP LOCKER ROOM	INTERNAL WALL SHEETING - TO LOCKER ROOM	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	External	Level 1	LIFT SHAFT	FIBRE CEMENT WALL PANELS - TO EXTERIA OF LIFT SHAFT (GROUND FLOOR AND LEVEL 1)	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1.080 MAIN OFFICE	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1:08	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1:08	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1:10	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1:13	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1:08	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1:06	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1:06	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1:06	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1:06	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1.33 PLANT ROOM	3 HEATER BANKS & LINING WALLS OF DUCT & MIXING SAMPLE #SC1999	Heater Bank Insulation	Millboard	CHR - Chrysotile	2	Removed	69	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1.23 FEMALE TOILET	CEILING TILES	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1.23 MALE TOILET	CEILING TILES	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1.15 SWITCH ROOM	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	External	Ground Floor	EXTERNAL WEST	SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	External	Roof Level 1	EXTERNAL NORTH	FASCIA SHEETING - CURVED COMPRESSED SHEET	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	External	Ground Floor	COLD ROOM ENTRY	WALL PANELS - NEAR ENTRY TO COLD ROOM	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	External	Ground Floor	EXTERNAL	SPRAYED STUCCO- VARIOUS SURFACES ON OUTSIDE OF BUILDING	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	External	Ground Floor	EXTERNAL EAST	SHEETING	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	External	Ground Floor	EXTERNAL NORTH	SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	External	Ground Floor	EXTERNAL SOUTH	SHEETING - ADJACENT PLANT ROOM EXTERNAL VENTED DOORS	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	External	Roof Level 1	EXTERNAL EAST	FASCIA SHEETING - CURVED COMPRESSED SHEET	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1.15 SWITCH ROOM	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	External	Roof Level 1	EXTERNAL SOUTH	FASCIA SHEETING - CURVED COMPRESSED SHEET	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	External	Roof Level 1	EXTERNAL WEST	FASCIA SHEETING - CURVED COMPRESSED SHEET	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	HALLWAY	CEILING SHEETING	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1.01A RESTAURANT	CEILING SHEETING	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	Internal	Ground Floor	ROOM 1.06B HAIRDRESS RECIPE	SHEET VINYL FLOORING - UNDER CARPET	Floor Backing/Underlay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	External	Ground Floor	CAR PARK AREA	WALL PANELS - SMALL COVERED STORE IN THE CAR PARK AREA	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		Coolangatta	COOLANGATTA GCIT CAMPUS	PCOAA	23087001	A Block	A Block	External	Ground Floor	GARAGE AREA	WALL LINING - ADJACENT TO EXIT IN THE GARAGE AREA	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		GOLD COAST TAPE	COOMERA MARINE	50941001	50941001	COOMERA ANNEX	COOMERA ANNEX												
Gold Coast		GOLD COAST TAPE	COOMERA MARINE	PCM	50941000	-- Site Grounds	-- Site Grounds												
Gold Coast	Southport	SOUTHPORT GCIT CAMPUS	SOUTHPORT GCIT CAMPUS	PBR	32565000	-- Site - Grounds	-- Site - Grounds												
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 3	ALL ROOMS	ALL WALLS PLASTERBOARD PARTITIONING	Wall	Other (refer to description)		4	Presumed		-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 2	FIRE WELL SOUTH	VERMICULITE AREA	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 1	FIRE WELLS	TEXTILE TO WALL AND CEILING JOINTS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 1	ROOM 11.27 FIRE PUMP ROOM	TEXTILE INSULATION - TO EXHAUST OF PUMP	Pipe Insulation	Woven Textile	No asbestos detected (NAD)	4	Not Present(Not Tested)	64	-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 2	FIRE WELL SOUTH	U RATE DOOR	Fire Door	Cement Based		4	Presumed	18	-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 2	FIRE WELL SOUTH	VERMICULITE SHEETING ABOVE THRESHOLD	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 2	FIRE WELL SOUTH EAST	VERMICULITE SHEETING TO CEILING	Ceiling	Sprayed Coating		4	Presumed	64	-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 2	FIRE WELLS	TEXTILE TO WALL AND CEILING JOINTS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 4	FIRE WELL EAST	U RATE DOOR	Fire Door	Sprayed Coating		4	Presumed	64	-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 2	METER CUPBOARD	BACKING BOARD TO SPARES ONLY METER CUPBOARD	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Ground Floor	CEILING CAVITY	SP TO AIR CONDITIONING DUCT	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 3	ELECT RISER	LAGGING TO PENETRATIONS	Insulation/Fill	LAGGING		4	Presumed	64	-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 3	FIRE WELLS	TEXTILE TO WALL AND CEILING JOINTS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 3	MAIN AREA	DBT FIRE DOORS - TO SOUTHERN WALL	Fire Door	Cement Based		4	Presumed	18	-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 3	ROOM 13.34 PLANT ROOM NORTH	TEXTILE FIRE PROOFING - TO WALL AND CEILING JOINTS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 3	ROOM 13.35 PLANT ROOM SOUTH	TEXTILE FIRE PROOFING - TO WALL AND CEILING JOINTS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 4	ALL ROOMS	ALL WALLS PLASTERBOARD PARTITIONING	Wall	Other (refer to description)		4	Presumed		-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 3	FIRE WELL SOUTH	U RATE DOOR	Fire Door	Cement Based		4	Presumed	18	-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 2	FIREWELL STH -EAST	CASTING TO PENETRATIONS IN EARTH	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	External	Level 6	CAR PARK	TEXTILE TO WALLS, CEILINGS AND EXPANSION JOINTS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	External	Ground Floor	ALL LEVELS	MASTIC TO EXPANSION JOINTS IN CONCRETE BLOCK WALLS	Membrane	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	External	Ground Floor	ALL LEVELS	TEXTURED DECORATIVE COATING TO ALL EXTERNAL WALLS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	External	Ground Floor	TOILET WALKWAY	SHEETING	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	External	Level 1	CAR PARK	TEXTILE TO WALLS, CEILINGS AND EXPANSION JOINTS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	External	Level 2	CAR PARK	TEXTILE TO WALLS, CEILINGS AND EXPANSION JOINTS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	External	Level 3	CAR PARK	TEXTILE TO WALLS, CEILINGS AND EXPANSION JOINTS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	External	Level 4	CAR PARK	TEXTILE WALLS, CEILINGS AND EXPANSION JOINTS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	Internal	Level 1	FIRE WELL NORTH WEST	VERMICULITE LINING TO CEILING	Ceiling	Sprayed Coating		4	Presumed	64	-	
Gold Coast	Southport		SOUTHPORT GCIT CAMPUS	PBRII	32565001	I Block	I Block	External	Level 5	CAR PARK	WALL SHEETING - NEAR AUTOMATIC DOOR	Wall	Cement Based		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 1	--	VERMICULITE COATING TO CEILING	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	External	Level 7	CAR PARK	TEXTILE TO WALLS, CEILINGS AND EXPANSION JOINS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	External	Level 8	CAR PARK	TEXTILE TO WALLS, CEILINGS AND EXPANSION JOINS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	External	Level 9	CAR PARK	GREY MEMBRANE TO CARPARK FLOOR	Floor Finish/Coverings	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Basement 1	FIRE WELL EAST	VERMICULITE LINING TO CEILING BULKHEAD	Ceiling	Sprayed Coating		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Basement 1	FIRE WELLS	TEXTILE TO WALL AND CEILING JOINTS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Ground Floor	ALL ROOMS	UNDER CONSTRUCTION - ALL NEW WORK	Baffles/Lining	Other (refer to description)		4	Presumed		-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 4	FIRE WELL SOUTH	PYROPANEL DOOR	Fire Door	Other (refer to description)		4	Presumed		-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	External	Level 5	CAR PARK	TEXTILE TO WALLS, CEILINGS AND EXPANSION JOINS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 8	FIRE WELL SOUTH EAST	U RATE DOOR	Fire Door	Cement Based		4	Presumed	18	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 7	FIRE WELL EAST	U RATE DOOR	Fire Door	Cement Based		4	Presumed	18	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 7	FIRE WELL SOUTH EAST	U RATE DOOR	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 7	FIRE WELL WEST	U RATE DOOR	Fire Door	Sprayed Coating		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 7	FIRE WELLS	TEXTILE TO WALL AND CEILING JOINTS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 7	ROOM 17.04 GOODS LIFT MR	LIFT MOTOR BREAK GEAR AND SHOES	Plant, Equipment & Machinery	Polymer Bound		4	Presumed	25	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 7	ROOM 17.04 NTH LIFT M/ROOM	NEW LIFT MOTORS 1988	Plant, Equipment & Machinery	Other (refer to description)		4	Presumed		-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 4	ELECT RISER	LAGGING TO PENETRATIONS	Insulation/Fill	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 8	FIRE WELL EAST	PYROPANEL DOOR	Fire Door	Other (refer to description)		4	Presumed		-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 6	FIRE WELLS	TEXTILE TO WALL AND CEILING JOINTS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 8	FIRE WELL WEST	PYROPANEL DOOR	Fire Door	Other (refer to description)		4	Presumed		-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 8	FIRE WELLS	TEXTILE TO WALLS AND CEILING JOINTS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 9	ELECT RISER	CORE INSULATION - TO FIRE DOOR	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 9	ELECT RISER	FIBROUS INSULATION - AROUND PENETRATION IN CEILINGS	Insulation/Fill	Woven Textile		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 9	FIRE WELLS	TEXTILE TO WALL AND CEILING JOINTS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 9	ROOF TOP	FIRE DOORS TO ROOFTOP EXITS	Fire Door	Cement Based		4	Presumed	18	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 9	ROOM 19.01 LIFT ROOM	BRAKE SHOE MATERIAL UNKNOWN	Plant, Equipment & Machinery	Polymer Bound		4	Presumed	25	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 8	ELECT RISER	LAGGING TO PENETRATION AND CEILINGS	Insulation/Fill	Woven Textile		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 5	ROOM 15.18 CENTRE STORE/RM	WALL SHEETING	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 4	FIRE WELLS	TEXTILE WALL AND CEILING JOINTS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 4	ROOM 14.16 MARINE EQUIP RM	SP COATING TO CEILING	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 4	ROOM 14.49 MAIN ROOM	FIRE DOORS TO LIFTS - SOUTHERN DOOR	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 4	ROOM 14.92 PLANT ROOM NORTH	TEXTILE TO WALL AND CEILING JOINS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 4	ROOM 14.95 PLANT ROOM SOUTH	TEXTILE FIRE PROOFING - TO WALL AND CEILING JOINS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 5	ELECT RISER	LAGGING TO PENETRATIONS	Insulation/Fill	Woven Textile		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 5	FIRE WELL EAST	PYROPANEL DOOR	Fire Door	Other (refer to description)		4	Presumed		-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 7	ELECT RISER	LAGGING TO PARTITIONS	Insulation/Fill	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 5	FIRE WELLS	TEXTILE TO WALL AND CEILING JOINTS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 6	ROOM 16.17 WEST LIFT M/RM	LIFT MOTOR BREAK SHOES	Plant, Equipment & Machinery	Polymer Bound		4	Presumed	25	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 5	ROOM 16.21 FAN ROOM	TEXTILE FIRE PROOFING TO MASONITE JOINS	Ceiling	Woven Textile		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 5	ROOM 15.22 PLANT ROOM	TEXTILE FIRE PROOFING TO MASJNS	Wall	Woven Textile		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 6	ELECT RISER	LAGGING TO PENETRATION AND CEILINGS	Insulation/Fill	Woven Textile		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 6	FIRE WELL EAST	U RATE DOOR X 2	Fire Door	Cement Based		4	Presumed	18	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 6	FIRE WELL SOUTH EAST	U RATE DOOR	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 6	FIRE WELL WEST	U RATE DOOR	Fire Door	Sprayed Coating		4	Presumed	64	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 9	ROOM 19.14 GENERATOR ROOM	GENERATOR	Plant, Equipment & Machinery	Polymer Bound	Mixed	4	Confirmed	25	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 5	FIRE WELL SOUTH	U RATE DOOR X 2	Fire Door	Cement Based		4	Presumed	18	-	
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRU	32565001	I Block	I Block	Internal	Level 2	ALL OFFICES	ALL WALLS PLASTERBOARD PARTITIONING	Wall	Other (refer to description)		4	Presumed		-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEIR Score	Attention Required	Comments
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRTT		T Block (Terraces Building)	T Block (Terraces Building)	External	Level 4	TERRACES	ALL WALLS NEW PART (1997)	Wall	Other (refer to description)		4	Presumed	-		
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRTT		T Block (Terraces Building)	T Block (Terraces Building)	External	Level 3	TERRACES	ALL WALLS NEW PART (1997)	Wall	Other (refer to description)		4	Presumed	-		
Gold Coast		Southport	SOUTHPORT GCIT CAMPUS	PBRTT		T Block (Terraces Building)	T Block (Terraces Building)	External	Level 5	TERRACES CARPARK	PLANT TO CAR PARK NEW 1997	Furniture	Other (refer to description)		4	Presumed	-		
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921003	29921003	B BLOCK LECTURE/AMENITIES	B BLOCK LECTURE/AMENITIES	Internal	Ground Floor	ROOM B 4	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	3	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921003	29921003	B BLOCK LECTURE/AMENITIES	B BLOCK LECTURE/AMENITIES	Internal	Ground Floor	ROOM B 4	WALL SHEETING	Wall	Cement Based	CHR AMO - Chrysotile Amosite	4	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921003	29921003	B BLOCK LECTURE/AMENITIES	B BLOCK LECTURE/AMENITIES	Internal	Ground Floor	STORE	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	3	Confirmed	18	-	TILES LOOSE
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921003	29921003	B BLOCK LECTURE/AMENITIES	B BLOCK LECTURE/AMENITIES	Internal	Ground Floor	STORE	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	IMPORTANT: THIS MATERIAL BECOMES FRILABLE IF DAMAGED.
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921003	29921003	B BLOCK LECTURE/AMENITIES	B BLOCK LECTURE/AMENITIES	Internal	Ground Floor	STORE HALLWAY	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921003	29921003	B BLOCK LECTURE/AMENITIES	B BLOCK LECTURE/AMENITIES	Internal	Ground Floor	STORE HALLWAY	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921003	29921003	B BLOCK LECTURE/AMENITIES	B BLOCK LECTURE/AMENITIES	Internal	Lower Ground 1	CLEANER'S ROOM	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921003	29921003	B BLOCK LECTURE/AMENITIES	B BLOCK LECTURE/AMENITIES	Internal	Lower Ground 1	CLEANER'S STORE	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	2	Confirmed	34	-	LOOSE AND BREAKING DOWN.
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921003	29921003	B BLOCK LECTURE/AMENITIES	B BLOCK LECTURE/AMENITIES	Internal	Lower Ground 1	STORE	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	2	Confirmed	34	-	TILES LOOSE AND BREAKING DOWN.
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921003	29921003	B BLOCK LECTURE/AMENITIES	B BLOCK LECTURE/AMENITIES	Internal	Ground Floor	ROOM B 4	CEILING SHEETING	Ceiling	Cement Based	CHR AMO - Chrysotile Amosite	4	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921003	29921003	B BLOCK LECTURE/AMENITIES	B BLOCK LECTURE/AMENITIES	Internal	Ground Floor	ROOM B 3	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921003	29921003	B BLOCK LECTURE/AMENITIES	B BLOCK LECTURE/AMENITIES	External	Roof Level 1	EXTERNAL NORTH	DUPLICATE ENTRY - SHEETING	Gable/Soffit/Fascia	Cement Based		4	Removed	18	-	IMPORTANT: THIS MATERIAL BECOMES FRILABLE IF DAMAGED.
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921003	29921003	B BLOCK LECTURE/AMENITIES	B BLOCK LECTURE/AMENITIES	External	Roof Level 1	EXTERNAL NORTH	SOFFIT SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921003	29921003	B BLOCK LECTURE/AMENITIES	B BLOCK LECTURE/AMENITIES	External	Roof Level 1	EXTERNAL SOUTH	FASCIA SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921003	29921003	B BLOCK LECTURE/AMENITIES	B BLOCK LECTURE/AMENITIES	Internal	Ground Floor	ROOM B 3	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921003	29921003	B BLOCK LECTURE/AMENITIES	B BLOCK LECTURE/AMENITIES	Internal	Ground Floor	ROOM B 3	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	3	Confirmed	18	-	TILES DAMAGED AT DOORWAYS
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921003	29921003	B BLOCK LECTURE/AMENITIES	B BLOCK LECTURE/AMENITIES	Internal	Ground Floor	STORE	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	IMPORTANT: THIS MATERIAL BECOMES FRILABLE IF DAMAGED.
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921003	29921003	B BLOCK LECTURE/AMENITIES	B BLOCK LECTURE/AMENITIES	Internal	Ground Floor	STORE HALLWAY	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	3	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	External	Roof Level 1	EXTERNAL WEST	FASCIA SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	IMPORTANT: THIS MATERIAL BECOMES FRILABLE IF DAMAGED.
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	Internal	Ground Floor	DUPLICATE									
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	Internal	Ground Floor	DUPLICATE									
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	External	Ground Floor	EXTERNAL NORTH	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	External	Ground Floor	EXTERNAL WEST	VENT PIPE - ON WALL PENETRATING THROUGH ROOF	Drains/Pipes/Fans	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	Internal	Ground Floor	STORE ROOM -B2.18	WALL SHEETING - SOUTH WALL ABOVE WINDOWS	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	External	Ground Floor	SURROUNDS - WEST	PROFILE SURROUNDS	Preformed Moulded Product	Cement Based	Mixed	3	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	External	Roof Level 1	EXTERNAL EAST	SOFFIT SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	External	Roof Level 1	EXTERNAL EAST	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	External	Roof Level 1	EXTERNAL NORTH	SOFFIT SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	External	Roof Level 2	EXTERNAL EAST	SOFFIT SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	External	Roof Level 1	EXTERNAL SOUTH	SOFFIT SHEETING	Gable/Soffit/Fascia	Cement Based		4	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	External	Ground Floor	EXTERNAL EAST	WALL SHEETING - ABOVE BRICK WORK	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	External	Roof Level 1	VENT PIPE	VENT PIPE - EAST	Drains/Pipes/Fans	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	External	Roof Level 2	EXTERNAL EAST	SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	Internal	Ground Floor	DUPLICATE									
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	Internal	Ground Floor	DUPLICATE									
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	Internal	Ground Floor	DUPLICATE									
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	Internal	Ground Floor	DUPLICATE									
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	Internal	Ground Floor	ADMINISTRATION OFFICE WEST - B2.12	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	Internal	Ground Floor	ADMINISTRATION OFFICE B2.12	VINYL FLOOR TILES - UNDER CARPET	Floor Finish/Covering	Vinyl Tiles		4	Removed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	External	Roof Level 2	EXTERNAL SOUTH	SOFFIT SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	External	Roof Level 2	EXTERNAL SOUTH									
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	External	Roof Level 1	EXTERNAL SOUTH	SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	Internal	Ground Floor	REAR ENTRY EXTERNAL	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	External	Ground Floor	EXTERNAL EAST	WALL SHEETING	Wall	Cement Based		4	Removed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	Internal	Ground Floor	TOILET ACCESS	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	B BLOCK ADMINISTRATION	Internal	Ground Floor	STORE ROOM -B2.18	WALL SHEETING - EAST WALL	Wall	Cement Based		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29821005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	STORE ROOM -B2.18	VINYL FLOOR TILES	Floor Finish/Coverings	Vinyl Tiles		4	Removed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29821005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	STAFF COMMON ROOM - B2.13 AND B2.14	WALL SHEETING - WEST WALL	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	STAFF COMMON ROOM - B2.13 AND B2.14	WALL SHEETING - EAST WALL	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	STAFF COMMON ROOM - B2.13 AND B2.14	WALL SHEETING - ABOVE BRICK WORK NORTH WALL	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	STAFF COMMON ROOM - B2.13 AND B2.14	VINYL FLOOR TILES - UNDER GREY VINYL	Floor	Vinyl Tiles	CHR - Chrysotile	3	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	STAFF COMMON ROOM - B2.13 AND B2.14	SHEET VINYL FLOORING - KITCHEN AREA (GREY FLECK)	Floor Finish/Coverings	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	STAFF COMMON ROOM - B2.13 AND B2.14	DIVIDING WALL - OF COMMON ROOM AND KITCHEN	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	SERVER COMPUTER STORE - B2.15	SHEET VINYL FLOORING - GREY FLECK	Floor Finish/Coverings	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	3	Confirmed	62	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	GENERAL ADMINISTRATION OFFICE -B2.12	VINYL FLOOR TILES - UNDER CARPET	Floor Finish/Coverings	Vinyl Tiles		4	Removed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	REAR ENTRY HALL	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	External	Ground Floor	ENTRY EXTERNAL	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	MANAGERS OFFICE - B2.11	WALL SHEETING - WEST WALL	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921008	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	MANAGERS OFFICE - B2.11	WALL SHEETING - SOUTH WALL ABOVE WINDOWS	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	MANAGERS OFFICE - B2.11	WALL SHEETING - EAST WALL ABOVE WINDOWS	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	MANAGERS OFFICE - B2.11	VINYL FLOOR TILES - UNDER CARPET	Floor Finish/Coverings	Vinyl Tiles		4	Removed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	GENERAL ADMINISTRATION OFFICE -B2.12	WALL SHEETING - WEST WALL	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	ENTRY EXTERNAL	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	GENERAL ADMINISTRATION OFFICE -B2.12	WALL SHEETING - SOUTH WALL	Wall	Cement Based	Mixed	4	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	GENERAL ADMINISTRATION OFFICE -B2.12	WALL SHEETING - NORTH WALL	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	GENERAL ADMINISTRATION OFFICE -B2.12	WALL SHEETING - EAST WALL	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	GENERAL ADMINISTRATION OFFICE -B2.12	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921005	29921005	B BLOCK ADMINISTRATION	BLOCK B ADMINISTRATION	Internal	Ground Floor	SERVER COMPUTER STORE - B2.15	INTERNAL REAR WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921007	29921007	COVERED LINKS	COVERED LINKS	Internal	Ground Floor									-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921008	29921008	STORE SHED	STORAGE SHED	External	Ground Floor	EXTERNAL	METAL SHEETING - NO ASBESTOS DETECTED	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921008	29921008	STORE SHED	STORAGE SHED	External	Ground Floor	EXTERNAL	METAL SHEETING - NO ASBESTOS DETECTED	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921009	29921009	HOT HOUSE	HOT HOUSE	External	Ground Floor									-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921010	29921010	PLANT NURSERY	PLANT NURSERY	External	Ground Floor									-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921011	29921011	BLOCK C PROPOGATION ROOMS	BLOCK C PROPOGATION ROOMS	External	Ground Floor									-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921012	29921012	GARDEN SHED NO.1	GARDEN SHED NO.1	External	Ground Floor	EXTERNAL	METAL SHEETING - NO ASBESTOS DETECTED	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921013	29921013	POTTING SHELTER	POTTING SHELTER	External	Ground Floor									-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921014	29921014	SHADE STRUCTURE	SHADE STRUCTURE	External	Ground Floor									-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921015	29921015	SHADE STRUCTURE	SHADE STRUCTURE	External	Ground Floor									-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	29921016	29921016	GARDEN SHED NO.2	GARDEN SHED NO.2	External	Ground Floor	EXTERNAL	METAL SHEETING - NO ASBESTOS DETECTED	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRW	29921000	SITE/GROUNDS	SITE/GROUNDS	External	Site / Grounds	STORAGE BINS - FUEL STORE	SHEETING - STORES NEXT TO FUEL STORE - ON POTTING TABLES	Stored Material	Cement Based	Mixed	2	Confirmed	34	-	DISPOSE OF ACM STORED ITEMS RE-USED AS POTTING TABLE TOPS.
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRW	29921000	SITE/GROUNDS	SITE/GROUNDS	External	Ground Floor	NORTH EAST BOUNDRY FENCE	FLAT CEMENT BASED FENCE SHEETING (18LM)	Other (refer to description)	Cement Based	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRW	29921000	SITE/GROUNDS	SITE/GROUNDS	External	Ground Floor	NORTH EAST BOUNDRY FENCE	SUPER SIX PROFILE CEMENT BASED FENCE (34LM)	Other (refer to description)	Cement Based	CHR AMO - Chrysotile Anisotile	3	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRW	29921000	SITE/GROUNDS	SITE/GROUNDS	External	Site / Grounds	NORTH COURTYARD	SHEETING - BENCH CHAIR TOP	Furniture	Cement Based		4	Removed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRW01		Storage Shed/Water Tank	Storage Shed/Water Tank	External	Ground Floor									-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRW02		Shed (Small irrigation shed near C Block)	Shed (Small irrigation shed near C Block)	External	Ground Floor									-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRW03		Shed (Double door irrigation shed near storage tan	Shed (Double door irrigation shed near storage tan	External	Ground Floor									-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRW04		Shadehouse	Shadehouse	External	Ground Floor	EXTERNAL	SHADE CLOTH TO WALLS - NO ASBESTOS DETECTED	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRW05		Glasshouse	Glasshouse	External	Ground Floor	EXTERNAL	WALL SHEETING - BELOW GLASS PANELS	Wall	Cement Based	No asbestos detected (NAD)	3	Not Present(Not Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRW05		Glasshouse	Glasshouse	Internal	Ground Floor	INTERNAL	SHEETING - TOP OF WIRE TRAYS	Furniture	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRW06		Flammable Store	Flammable Store	External	Ground Floor	EXTERNAL	METAL SHEETING - NO ASBESTOS DETECTED	Other (refer to description)	Other (refer to description)		NA	Not Present(Not Tested)	-	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRW09	29921005	Amenities Block - Courtyard Toilet Block	AMENITIES	External	Ground Floor									-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A BLOCK HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Internal	Ground Floor	ROOM A01,10A - STAFFROOM	WALL LINING - ADJACENT TO SINK	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A BLOCK HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	External	Roof Level 1	EXTERNAL WEST	FASCIA SHEETING - INSIDE AND OUTSIDE	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A BLOCK HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Internal	Ground Floor	ROOM A 10								-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A BLOCK HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Internal	Ground Floor	ROOM A 11	WALL PANELS - BLOCKWORK WEST WALL	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A BLOCK HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Internal	Ground Floor	ROOM A 11	WALL SHEETING - SOUTH WALL	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A BLOCK HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Internal	Ground Floor	ROOM A 7	SHEET VINYL FLOORING	Floor Finish/Coverings	Vinyl Sheeting	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Est	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Ground Floor	ROOM A 6	SHEET VINYL FLOORING	Floor Finish/Coverin g	Vinyl Sheetin g (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Ground Floor	ROOM A01.010 ADMINISTRATION	MOULD - BASE OF WASTE PIPE	Floor	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Ground Floor	ROOM A01.010 ADMINISTRATION	WALL SHEETING - AROUND DOOR EAST WALL	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Ground Floor	RECEPTION AREA								-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Ground Floor	ROOM A01.10A - STAFFROOM	SHEET VINYL FLOORING - 2 LAYERS OF UNDER CARPET	Floor Finish/Coverin g	Vinyl Sheetin g (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Exter nal	Roof Level 1	EXTERNAL EAST	SOFFIT SHEETING	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Ground Floor	ROOM A01.10A - STAFFROOM	BOX DUCTING - ADJACENT TO SINK	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Ground Floor	OLD CANTEN - ROOMS A1.01, A1.10.B, A.01.003 TEA ROOM AND X2 STOREROOMS	WALL SHEETING - DUCT WORK SOUTH WEST CORNER - A01.003	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Ground Floor	OLD CANTEN - ROOMS A1.01, A1.10.B, A.01.003 TEA ROOM AND X2 STOREROOMS	VINYL FLOOR TILES	Floor Finish/Coverin g	Vinyl Tiles	No asbestos detected (NAD)	2	Not Present(Tested)		-	TILES LOOSE AND BRITTLE
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Ground Floor	HALLWAY	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Ground Floor	HALLWAY	SHEET VINYL FLOORING - GREY PUTTY SQUARES	Floor Finish/Coverin g	Vinyl Sheetin g (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Exter nal	Roof Level 1	EXTERNAL WEST	SOFFIT SHEETING	Gable/Soffit/F ascia	Cement Based	Mixed	4	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Exter nal	Roof Level 1	EXTERNAL NORTH	SOFFIT SHEETING	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Exter nal	Roof Level 1	EXTERNAL EAST	FASCIA SHEETING - INSIDE AND OUTSIDE	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Exter nal	Level 1	EXTERNAL SOUTH	CEILING SHEETING - ABOVE DOORWAY	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Exter nal	Level 1	EXTERNAL NORTH	CEILING SHEETING - ABOVE ENTRY DOOR	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Exter nal	Level 1	EXTERNAL EAST	WALL PANELS - BELOW LOUVRES	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Ground Floor	ROOM A01.10A - STAFFROOM	WALL SHEETING - DUCT WALLS BETWEEN SINKS	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Exter nal	Ground Floor	EXTERNAL EAST	WALL SHEETING - AROUND DOOR	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Ground Floor	ROOM A 11	SHEET VINYL FLOORING	Floor Finish/Coverin g	Vinyl Sheetin g (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Exter nal	Roof Level 1	EXTERNAL SOUTH	SOFFIT SHEETING	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	ROOM A 5 A	WALL PANELS - UNDER LOUVRES	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Ground Floor	ROOM 1.06 AND ROOM 1.10	SHEET VINYL FLOORING - VARIOUS GROUND FLOOR ROOMS	Floor Finish/Coverin g	Vinyl Sheetin g (includes backing)	No asbestos detected (NAD)	4	Not Present(Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 2	FLOORING	VINYL FLOOR TILES - GREY	Floor Finish/Coverin g	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 2	CEILINGS	PERFORATED CEILING PANELS - ROOMS A.2.01A AND A.2.01B	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	STORE ROOM 2	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	STORE ROOM 1	VINYL FLOOR TILES	Floor Finish/Coverin g	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	STORE ROOM 1	CEILING SHEETING	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	STAFF ROOM	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	ROOM A201A AND ROOM A201B	VINYL FLOOR TILES	Floor Finish/Coverin g	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	ROOM A201A AND ROOM A201B	CEILING SHEETING	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	ROOM A02.01G - SERVER CUPBOARD	VINYL FLOOR TILES	Floor Finish/Coverin g	Vinyl Tiles	No asbestos detected (NAD)	3	Not Present(Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Ground Floor	ROOM A01.10A - STAFFROOM	WALL SHEETING - DUCT WALLS BETWEEN SINKS	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	ROOM A 5 B	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	ROOM A 5 A	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	ROOM A 4	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	DUPLICATE ENTRY								-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Ground Floor	ROOM A01.10A - STAFFROOM	WALL SHEETING - DUCT WALLS BETWEEN SINKS	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Ground Floor	ROOM A01.10A - STAFFROOM	WALL SHEETING - NORTH WALL	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Ground Floor	ROOM A01.10A - STAFFROOM	WALL SHEETING - SOUTH WALL	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	DOOR SURROUNDS	WALL SHEETING - AROUND DOOR TO ROOM A1.01.0	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	ROOM A 3	WALL PANELS - UNDER WINDOWS	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	FEMALE TOILET	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	HALL/FOYER	CEILING SHEETING - SOUTH END	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	HALL/FOYER	VINYL FLOOR TILES - SOUTH END	Floor Finish/Coverin g	Vinyl Tiles	No asbestos detected (NAD)	3	Not Present(Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	MALE TOILET	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	NORTH HALLWAY	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	NORTH HALLWAY	DUCT WORK - PANEL ON WEST WALL	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921004	A Block HORT ADMILECTURE	BLOCK A HORT ADMILECTURE	Inter nal	Level 1	ROOM A 3	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	

TAFes from BEMIR-TAFes

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWAA	29921094	A BLOCK HORT ADM LECTURE	BLOCK A HORT ADM LECTURE	Internal	Level 1	CLEANERS STORE	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWBB	29921092	B BLOCK LECTURE ROOMS	BLOCK B LECTURE ROOMS	Internal	Ground Floor	STORE	SHEET VINYL FLOORING	Floor	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWBB	29921092	B BLOCK LECTURE ROOMS	BLOCK B LECTURE ROOMS	Internal	Ground Floor	STORE	DUPUGATE ENTRY - SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Removed	62	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWBB	29921092	B BLOCK LECTURE ROOMS	BLOCK B LECTURE ROOMS	Internal	Ground Floor	KITCHEN	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWBB	29921092	B BLOCK LECTURE ROOMS	BLOCK B LECTURE ROOMS	Internal	Ground Floor	STORE	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWBB	29921092	B BLOCK LECTURE ROOMS	BLOCK B LECTURE ROOMS	Internal	Ground Floor	SOUTH STAIRWELL	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWBB	29921092	B BLOCK LECTURE ROOMS	BLOCK B LECTURE ROOMS	Internal	Ground Floor	ROOM B 2	VINYL FLOOR TILES - UNDER CARPET	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWBB	29921092	B BLOCK LECTURE ROOMS	BLOCK B LECTURE ROOMS	Internal	Ground Floor	ROOM B 2	CEILING SHEETING	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWBB	29921092	B BLOCK LECTURE ROOMS	BLOCK B LECTURE ROOMS	Internal	Ground Floor	ROOM B 1	VINYL FLOOR TILES - UNDER CARPET	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWBB	29921092	B BLOCK LECTURE ROOMS	BLOCK B LECTURE ROOMS	Internal	Ground Floor	KITCHEN	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Not Tested)	62	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWBB	29921092	B BLOCK LECTURE ROOMS	BLOCK B LECTURE ROOMS	Internal	Ground Floor	HALL	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWBB	29921092	B BLOCK LECTURE ROOMS	BLOCK B LECTURE ROOMS	External	Roof Level 2	EXTERNAL NORTH	SOFFIT SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWBB	29921092	B BLOCK LECTURE ROOMS	BLOCK B LECTURE ROOMS	External	Roof Level 1	EXTERNAL WEST	SOFFIT SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWBB	29921092	B BLOCK LECTURE ROOMS	BLOCK B LECTURE ROOMS	External	Roof Level 1	EXTERNAL SOUTH	SOFFIT SHEETING	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWBB	29921092	B BLOCK LECTURE ROOMS	BLOCK B LECTURE ROOMS	External	Roof Level 1	EXTERNAL NORTH	SOFFIT SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWBB	29921092	B BLOCK LECTURE ROOMS	BLOCK B LECTURE ROOMS	External	Roof Level 1	EXTERNAL EAST	FASCIA SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWBB	29921092	B BLOCK LECTURE ROOMS	BLOCK B LECTURE ROOMS	Internal	Ground Floor	ROOM B 1	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWBB	29921092	B BLOCK LECTURE ROOMS	BLOCK B LECTURE ROOMS	Internal	Ground Floor	HALL	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWCC	29921091	C Block (Horticulture)	C Block (Horticulture)	External	Ground Floor	PRAC.CLASS RM 1 EXTERNAL WEST	WALL SHEETING - ABOVE LOUVRES	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWCC	29921091	C Block (Horticulture)	C Block (Horticulture)	Internal	Ground Floor	PRAC.CLASS RM 1 INTERNAL	SHEETING - BENCH TOPS AND SPLASH BACKS	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWCC	29921091	C Block (Horticulture)	C Block (Horticulture)	Internal	Ground Floor	PRAC.CLASS RM 1 INTERNAL	WALL SHEETING - ABOVE LOUVRES EAST AND WEST	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWCC	29921091	C Block (Horticulture)	C Block (Horticulture)	Internal	Ground Floor	PRAC.CLASS RM 2 INTERNAL	SHEETING - BENCH TOPS AND SPLASH BACKS	Furniture	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWCC	29921091	C Block (Horticulture)	C Block (Horticulture)	External	Ground Floor	PRAC.CLASS RM 2 EXTERNAL WEST	WALL SHEETING - ABOVE LOUVRES	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWCC	29921091	C Block (Horticulture)	C Block (Horticulture)	External	Ground Floor	PRAC.CLASS RM 2 EXTERNAL EAST	WALL SHEETING - ABOVE LOUVRES	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWCC	29921091	C Block (Horticulture)	C Block (Horticulture)	Internal	Ground Floor	PRAC.CLASS RM 2 INTERNAL	WALL SHEETING - ABOVE LOUVRES EAST AND WEST WALLS	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWCC	29921091	C Block (Horticulture)	C Block (Horticulture)	External	Ground Floor	PRAC.CLASS RM 1-2 EXTERNAL NORTH	WALL SHEETING - ADJOINING PRACTISE CLASS RMS 1 - 2	Wall	Cement Based		4	Presumed	18	-	
Gold Coast		Southport Ridgeway Ave	RIDGEWAY GCIT CAMPUS	PRWCC	29921091	C Block (Horticulture)	C Block (Horticulture)	External	Ground Floor	PRAC.CLASS RM 1 EXTERNAL EAST	WALL SHEETING - ABOVE LOUVRES	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Metropolitan South		ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	20634003	20634003	COVERED LINKS	COVERED LINKS	External	Ground Floor	COVERED LINKS	NO ASBESTOS CONTAINING MATERIALS DETECTED IN COVERED LINKS	Baffles/Lining	Other (refer to description)	3	Not Present(Not Tested)		-		
Metropolitan South		ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBB	20634090	00 - Site - Grounds	** Site - Grounds											-	
Metropolitan South		ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBB01	20634094	01 - MAIN SWITCHBOARD (BB)	Main Switchboard (Bb)	Internal	Ground Floor	INTERNAL	UNABLE TO ACCESS INTERNAL AREA TO IDENTIFY ANY POSSIBLE ASBESTOS CONTAINING MATERIAL	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBB01	20634094	01 - MAIN SWITCHBOARD (BB)	Main Switchboard (Bb)	External	Ground Floor	EXTERNAL	EXTERIOR WALL PANELS TOP OF BLOCKWORK WALLS OF SEQEB STN SG1120. SIM SAMPLE 1957-NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBB02		02 - SUBSTATION - ENERGEX (Bc)	Substation - Energex (Bc)											-	
Metropolitan South		ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBB03		03 - GARAGE (Ii)	Garage (Ii)											-	
Metropolitan South		ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBB04	20634092	04 - FUEL STORE (If)	Fuel Store (If)	External	Ground Floor	FLAMMABLE LIQUIDS STORE	NO ASBESTOS CONTAINING MATERIALS DETECTED IN FLAMMABLE LIQUIDS STORE	Baffles/Lining	Other (refer to description)	3	Not Present(Not Tested)		-		
Metropolitan South		ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBB05	20634013	05 - FACILITIES STORE (Ig)	Facilities Store (Ig)	Internal	Ground Floor	CENTRAL WORKSHOP	BAFFLES ON TOP OF ALL PERIMETER WALLS IN CENTRAL WORKSHOP. SIM SAMPLE 1957	Baffles/Lining	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBB06	20634030	06 - SHED - TRACTOR (RR)	Tractor Shed (RR)	Internal	Ground Floor	TRACTOR SHED	UNABLE TO ACCESS TRACTOR SHED TO IDENTIFY ANY POSSIBLE ASBESTOS CONTAINING MATERIALS	Wall	Cement Based		3	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBB07		07 - GREENHOUSE (RR)	Greenhouse (RR)											-	
Metropolitan South		ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBB08	20634022	08 - AMENITIES (G)	Amenities (G)	Internal	Ground Floor	M & F TOILETS	WALL SHEETING - PARTITIONS - MALE TOILETS AND FEMALE TOILETS	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBB08	20634022	08 - AMENITIES (G)	Amenities (G)	Internal	Ground Floor	M & F TOILETS	CEILING SHEETING - MALE TOILETS AND FEMALE TOILETS	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBB09		09 - COMPRESSOR AND WASH-DOWN (If)	Compressor/Washdown (If)											-	
Metropolitan South		ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBBAA		AA - BLOCK A - ADMINISTRATION	A Block											-	
Metropolitan South		ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBBBA	20634028	BA - BLOCK BA - CANTEN	Ba Block	Internal	Ground Floor	CANTEN	WALL SHEETING - EAST AND WEST ELEVATIONS - UNDER WINDOWS - DINING AREA - CANTEN	Wall	Other (refer to description)		4	Presumed		-	
Metropolitan South		ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBBBA	20634028	BA - BLOCK BA - CANTEN	Ba Block	Internal	Ground Floor	M & F TOILETS	WALL SHEETING - CUBICLE PARTITIONS - MALE TOILETS AND FEMALE TOILETS	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAFF CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBBBA	20634028	BA - BLOCK BA - CANTEN	Ba Block	Internal	Ground Floor	M & F TOILETS	SKYLIGHT LINING PANELS	Ceiling	Cement Based		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEIRIR Score	Attention Required	Comments
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBBA	20634028	BA - BLOCK BA - CANTEN	Ba Block	Inter nal	Ground Floor	M & F TOILETS	CEILING TILES - MALE TOILETS AND FEMALE TOILETS	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBBA	20634028	BA - BLOCK BA - CANTEN	Ba Block	Inter nal	Ground Floor	CHANGE ROOM	CEILINGS TO ALL ROOMS NORTH OF CANTEN. SIM SAMPLE 1852 - NAD	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBCA	20634027	CA - BLOCK CA - BUSINESS	Ca Block	Exter nal	Ground Floor	EXTERNAL	CREAMY WHITE WALL PANELS BELOW WINDOWS ON EXTERNAL WALLS. SIM SAMPLE 1859 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBCA	20634027	CA - BLOCK CA - BUSINESS	Ca Block	Exter nal	Ground Floor	EXTERNAL	FIBRO PANELS AT TOP OF NORTH SOUTH END EXTERNAL BLOCKWORK. SIM SAMPLE 1862 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBCA	20634027	CA - BLOCK CA - BUSINESS	Ca Block	Inter nal	Ground Floor	CLASSROOM	FIBRO BAFFLES TO CLASSROOM CEILING SIM SAMPLE 1857 - NAD	Baffles/Lining	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBCB	20634024	CB - BLOCK CB - BUSINESS AND GENERAL STUDIES	Cb Block	Inter nal	Ground Floor	CLASSROOM	FIBRO BAFFLES TOP OF PERIMETER WALLS SIMILAR SAMPLE 1857 - NAD	Baffles/Lining	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBCB	20634024	CB - BLOCK CB - BUSINESS AND GENERAL STUDIES	Cb Block	Exter nal	Ground Floor	EXTERNAL	CREAMY COLOURED WALL PANELS BENEATH WINDOWS OF EXTERIOR WALLS	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBCB	20634024	CB - BLOCK CB - BUSINESS AND GENERAL STUDIES	Cb Block	Exter nal	Ground Floor	EXTERNAL	EXTERNAL FIBRO PANELS AT TOP OF NORTH/SOUTH END BLOCKWORK WALLS	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBDD	20634091	DD - BLOCK D - STAFF ACCOMMODATION	D Block	Inter nal	Ground Floor	LIBRARY FOYER	PORT RACKS IN LIBRARY FOYER SIM SAMPLE 1855 - NAD	Furniture	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBDD	20634091	DD - BLOCK D - STAFF ACCOMMODATION	D Block	Inter nal	Ground Floor	INTERNAL	INTERNAL WALL PANNELLING OF CENTRAL SKYLIGHT SIM SAMPLE 1862 - NAD	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBDD	20634091	DD - BLOCK D - STAFF ACCOMMODATION	D Block	Exter nal	Ground Floor	EXTERNAL	EXTERNAL WALLS - CREAM COLOUR SET BELOW WINDOWS SIM SAMPLE 1859 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBDD	20634091	DD - BLOCK D - STAFF ACCOMMODATION	D Block	Exter nal	Ground Floor	EXTERNAL	EAVES - BUILDING PERIMETER SIM SAMPLE 1857 - NAD	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBEE	20634026	EE - BLOCK E - PERFORMING ARTS	E Block	Inter nal	Ground Floor	VARIOUS AREAS	PINK VINYL FLOOR TILES TO VARIOUS AREAS REFER SAMPLE 1853 - NAD	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBEE	20634026	EE - BLOCK E - PERFORMING ARTS	E Block	Inter nal	Ground Floor	ALL ROOMS	CEILING TILES TO ALL CLASSROOMS. SIM SAMPLE 1852 - NAD	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBEE	20634026	EE - BLOCK E - PERFORMING ARTS	E Block	Exter nal	Ground Floor	EXTERNAL	THICK COMPRESSED SHEET TO SUNSHADES ON N SIDE OF BLDG SIMILAR SAMPLE 1861 - NAD	Sun Hood	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBEE	20634026	EE - BLOCK E - PERFORMING ARTS	E Block	Exter nal	Ground Floor	EXTERNAL	EXTERIOR WINDOW INFILL PANELS TO NORTH & SOUTH WALLS. SIM SAMPLE 1852 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBEE	20634026	EE - BLOCK E - PERFORMING ARTS	E Block	Exter nal	Ground Floor	EXTERNAL	EAVES/FASCIA PANELS TO BUILDING PERIMETER. SIM SAMPLE 1857 - NAD	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBFF	20634025	FF - BLOCK F - GENERAL STUDIES	F Block	Inter nal	Ground Floor	ARTS/CRAFTS	THICK CS ON CENTRAL BENCHTOP IN ARTS/CRAFTS CAGE SIMILAR SAMPLE 1855 - NAD	Furniture	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBFF	20634025	FF - BLOCK F - GENERAL STUDIES	F Block	Exter nal	Ground Floor	EXTERNAL	EXTERIOR PANELS BELOW WINDOWS SIM SAMPLE 1859 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBFF	20634025	FF - BLOCK F - GENERAL STUDIES	F Block	Inter nal	Ground Floor	CORRIDOR	INTERNAL WALLS OF CENTRAL CORRIDOR SIM SAMPLE 1862 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBFF	20634025	FF - BLOCK F - GENERAL STUDIES	F Block	Inter nal	Ground Floor	CORRIDOR/LOUNGE	VINYL FLOOR SHEETING TO CENTRAL CORRIDOR AND STAFF LOUNGE	Floor Finish/Coverin g	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBRFF	20634025	FF - BLOCK F - GENERAL STUDIES	F Block	Inter nal	Ground Floor	M & F TOILETS	LINING TO SKYLIGHTS IN MALE AND FEMALE TOILETS. SIM SAMPLE 1857 - NAD	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBRFF	20634025	FF - BLOCK F - GENERAL STUDIES	F Block	Inter nal	Ground Floor	ROOM F13	PINK VINYL FLOOR TILES TO ROOM F13 REFER SAMPLE 1853 - NAD	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBRFF	20634025	FF - BLOCK F - GENERAL STUDIES	F Block	Inter nal	Ground Floor	STUDENT TOILETS	THICK COMPRESSED SHEET TOILET CUBICLE PARTITIONS SIMILAR SAMPLE 1855 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBRFF	20634025	FF - BLOCK F - GENERAL STUDIES	F Block	Inter nal	Ground Floor	TOILETS/LOCKER	CEILING TILES TO TOILETS/ LOCKER AREA. SIM SAMPLE 1852 - NAD	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBRFF	20634025	FF - BLOCK F - GENERAL STUDIES	F Block	Exter nal	Ground Floor	GENERAL STUDIES	THICK CS INFILL PANELS ABOVE N & S ENDS BLOCKWORK WALLS SIMILAR SAMPLE 1862 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBGG	20634023	GG - BLOCK G - SCIENCE	G Block	Exter nal	Ground Floor	GROUND	EAVES - BUILDING PERIMETER. SIM SAMPLE 1857 - NAD	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBGG	20634023	GG - BLOCK G - SCIENCE	G Block	Inter nal	Ground Floor	ROOM G8	ELECTRICAL WORKSHOP & LAB WALLS (BENEATH WINDOWS). SIM SAMPLE 1859 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBGG	20634023	GG - BLOCK G - SCIENCE	G Block	Inter nal	Ground Floor	ROOM G10	DRAWING ROOM WALLS (BENEATH WINDOWS) SIM SAMPLE 1859 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBGG	20634023	GG - BLOCK G - SCIENCE	G Block	Exter nal	Ground Floor	VERANDAHS	PORT RACKS X 5. SIM SAMPLE 1855 - NAD	Furniture	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBGG	20634023	GG - BLOCK G - SCIENCE	G Block	Exter nal	Ground Floor	EXTERNAL	SUNSHADES ON NORTH SIDE OF BUILDING. SIM SAMPLE 1861 - NAD	Sun Hood	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBGG	20634023	GG - BLOCK G - SCIENCE	G Block	Inter nal	Ground Floor	FOYER	PINK FLOOR TILES IN FOYER OUTSIDE G3 REFER SAMPLE 1853 - NAD	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBHH	20634021	HH - BLOCK H - HAIR/BEAUTY	H Block												
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIA	20634018	IA - BLOCK IA	Ia Block	Exter nal	Ground Floor	CLIRMS 124 & 125	EAVES - BUILDING PERIMETER. SIM SAMPLE 1857 - NAD	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIA	20634018	IA - BLOCK IA	Ia Block	Exter nal	Ground Floor	CLIRMS 124 & 125	EXTERIOR WALLS (SAME AS CREAM WALLS IN CANTEN) SIM SAMPLE 1859 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIA	20634018	IA - BLOCK IA	Ia Block	Inter nal	Ground Floor	CLIRMS 124 & 125	PORT RACK. SIM SAMPLE 1855 - NAD	Furniture	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIB	20634017	IB - BLOCK IB	Ib Block	Inter nal	Ground Floor	M & F TOILETS	CEILINGS TO MALE & FEMALE TOILETS SIM SAMPLE 1862 - NAD	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIB	20634017	IB - BLOCK IB	Ib Block	Inter nal	Ground Floor	CLIRMS 126 & 127	PINK FLOOR TILES TO CLASSROOMS 128 & 127 REFER SAMPLE 1853 - NAD	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIB	20634017	IB - BLOCK IB	Ib Block	Inter nal	Ground Floor	M & F TOILETS	WALL PARTITIONS IN MALE & FEMALE TOILETS SIM SAMPLE 1855 - NAD	Wall	Cement Based		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIB	20634017	IB - BLOCK IB	lb Block	External	Ground Floor	EXTERNAL	POR RACKS ON WEST SIDE SIM SAMPLE 1855 - NAD	Furniture	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIB	20634017	IB - BLOCK IB	lb Block	External	Ground Floor	EXTERNAL	EAVES - BUILDING PERIMETER SIM SAMPLE 1857 - NAD	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIB	20634017	IB - BLOCK IB	lb Block	External	Ground Floor	EXTERNAL	CREAM COLOUR PANELS ON EXTERNAL WALLS (LOWER BENEATH WINDOWS)-SIM SAMPLE 1859-NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIB	20634017	IB - BLOCK IB	lb Block	Internal	Ground Floor	M & F TOILETS	INSIDE PANELS TO SKYLIGHTS IN MALE & FEMALE TOILETS SIM SAMPLE 1857 - NAD	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIC	20634007	IC - BLOCK IC - TECHNICAL STAFF	lc Block	External	Ground Floor	EXTERNAL	EAVES - BUILDING PERIMETER SIM SAMPLE 1857 - NAD	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIC	20634007	IC - BLOCK IC - TECHNICAL STAFF	lc Block	External	Ground Floor	EXTERNAL	EXTERNAL WALLS (CREAMY COLOURED) SIM SAMPLE 1862 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIC	20634007	IC - BLOCK IC - TECHNICAL STAFF	lc Block	Internal	Ground Floor	INTERNAL	CEILING TO BUILDING - SAME AS BLUE INTERIOR SHEETING SIM SAMPLE 1862 - NAD	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIC	20634007	IC - BLOCK IC - TECHNICAL STAFF	lc Block	Internal	Ground Floor	INTERNAL	INTERNAL WALLS - SAME AS BLUE INTERIOR WALLS SIM SAMPLE 1862 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBID	20634019	ID - BLOCK ID - AUTO/CAB	ld Block	External	Ground Floor	EXTERNAL	SUNSHADES ON NORTH EAST & WEST SIDES OF BUILDING. SIM SAMPLE 1861 - NAD	Sun Hood	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBID	20634019	ID - BLOCK ID - AUTO/CAB	ld Block	Internal	Ground Floor	CARPENTRY/WOOD	BLUE PERFORATED TOOLS FIXTURE IN CARPENTRY & WOOD MACHINERY WORKSHOP. SIM SAMPLE 1860-NAD	Furniture	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBID	20634019	ID - BLOCK ID - AUTO/CAB	ld Block	External	Ground Floor	EXTERNAL	POR RACKS X 2 ON PERIMETER WEST AND SOUTH SIDES. SIM SAMPLE 1855 - NAD	Furniture	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBID	20634019	ID - BLOCK ID - AUTO/CAB	ld Block	External	Ground Floor	EXTERNAL	EAVES - BUILDING PERIMETER. SIM SAMPLE 1857 - NAD	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBID	20634019	ID - BLOCK ID - AUTO/CAB	ld Block	External	Ground Floor	CARPENTRY/WOOD	VARIOUS EXT WALLS TO CARPENTRY & WOOD MACHINING W/SHOP-CREAMY COLOUR - SIM SAMPLE 1861-NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBID	20634019	ID - BLOCK ID - AUTO/CAB	ld Block	Internal	Ground Floor	CARPENTRY/WOOD	BLUE WALLING TO CARPENTRY WOOD MACHINING AND MASONRY WORKSHOPS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIE	20634020	IE - BLOCK IE - TECH/METAL	le Block	External	Ground Floor	EXTERNAL	CREAMY COLOUR SHEET ON VARIOUS LOCATIONS N E & W SIDES OF BLDG. SIM SAMPLE 1861 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIE	20634020	IE - BLOCK IE - TECH/METAL	le Block	External	Ground Floor	EXTERNAL	EAVES EAST AND WEST SIDES OF BUILDING PERIMETER. SIM SAMPLE 1857 - NAD	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIE	20634020	IE - BLOCK IE - TECH/METAL	le Block	External	Ground Floor	LATHE WORKSHOP	SUNSHADE EAST SIDE OF LATHE WORKSHOP	Sun Hood	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIE	20634020	IE - BLOCK IE - TECH/METAL	le Block	External	Ground Floor	VERANDAHS N&W	BAG STORAGE RACKS NORTH & WEST SIDES. SIM SAMPLE 1855 - NAD	Furniture	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIE	20634020	IE - BLOCK IE - TECH/METAL	le Block	Internal	Ground Floor	VEHICLE WORKSHOPS	BLUE PERFORATED WALL FIXTURE TO HANG TOOLS FROM IN 3 OF 4 WORKSHOPS	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIE	20634020	IE - BLOCK IE - TECH/METAL	le Block	Internal	Ground Floor	VEHICLE WORKSHOPS	BLUE UPPER INT PERIMETER WALL SUPPER PARTITION WALLS BETWEEN CLASSROOMS. SIM 1862 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIE	20634020	IE - BLOCK IE - TECH/METAL	le Block	Internal	Ground Floor	VEHICLE WORKSHOPS	FLOOR TILES TO VEHICLE WORKSHOP REFER SAMPLE 1853 - NAD	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIE	20634020	IE - BLOCK IE - TECH/METAL	le Block	Internal	Ground Floor	VEHICLE WORKSHOPS	THICK COMPRESSED SHEET BEHIND WELDING FUME HOOD SIMILAR SAMPLE 1855 - NAD	Plant, Equipment & Machinery	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIB		IH - BLOCK IH	lh Block	External	Ground Floor	EXTERNAL	EAVES - BUILDING PERIMETER. SIM SAMPLE 1857 - NAD	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBIB		IH - BLOCK IH	lh Block	Internal	Ground Floor	CLASSROOMS	MAJORITY OF INTERNAL WALL PANNELLING OF CLASSROOMS - ALL OF BLDG. SIM SAMPLE 1862-NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBJA	20634015	JA - BLOCK JA - COFFEE SHOP/FITCHEN	Ja Block	External	Ground Floor	EXTERNAL	EXTERIOR WALL PANNELLING BELOW WINDOWS TO STUDENT SERVICES SIM SAMPLE 1859 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBJA	20634015	JA - BLOCK JA - COFFEE SHOP/FITCHEN	Ja Block	Internal	Ground Floor	M & F TOILETS	MALE & FEMALE TOILET PARTITIONS - STAMPED 'MANUFACTURED WITHOUT ASBESTOS'-SIM SAMPLE 1855-NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBJA	20634015	JA - BLOCK JA - COFFEE SHOP/FITCHEN	Ja Block	Internal	Ground Floor	ROOM J06 KITCHENETTE	PINK FLOOR TILES TO STUDENT SERVICES KITCHENETTE REFER SAMPLE 1853 - NAD	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBJA	20634015	JA - BLOCK JA - COFFEE SHOP/FITCHEN	Ja Block	External	Ground Floor	EXTERNAL	CREAM COLOURED EXTERIOR WALL PANNELLING BELOW WINDOWS OF HOME EC. -SIM. SAMPLE 1859-NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBJB		JB - BLOCK JB	Jb Block												
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBJC	20634016	JC - BLOCK JC - RESTAURANT	Jc Block	External	Ground Floor	EXTERNAL	EAVES - BUILDING PERIMETER SIM SAMPLE 1857 - NAD	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBJC	20634016	JC - BLOCK JC - RESTAURANT	Jc Block	Internal	Ground Floor	KITCHEN	CEILING TILES IN KITCHEN SIM SAMPLE 1852 - NAD	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBJC	20634016	JC - BLOCK JC - RESTAURANT	Jc Block	Internal	Ground Floor	PLANT ROOM	RE-HEAT UNIT IN AIR CON PLANT ROOM AT SOUTH END OF BUILDING	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBJD	20634031	JD - BLOCK JD	Jd Block	External	Ground Floor	EXTERNAL	EAVES - BUILDING PERIMETER. SIM SAMPLE 1857 - NAD	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBJD	20634031	JD - BLOCK JD	Jd Block	Internal	Ground Floor	TEACHING ROOM	FIBRO CLG TILES IN TEACHING ROOM - STAMPED 'ASBESTOS FREE'.	Ceiling	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBJD	20634031	JD - BLOCK JD	Jd Block	Internal	Ground Floor	M & F TOILETS	TOILET PARTITIONS IN MALE & FEMALE TOILETS. SIM SAMPLE 1855 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBJD	20634031	JD - BLOCK JD	Jd Block	Internal	Ground Floor	M & F TOILETS	LINING PANELS TO SKYLIGHTS IN MALE AND FEMALE TOILETS. SIM SAMPLE 1857 - NAD	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBJD	20634031	JD - BLOCK JD	Jd Block	External	Ground Floor	EXTERNAL	WALL PANELS BENEATH WINDOWS - CREAMY COLOURED. SIM SAMPLE 1859 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBJD	20634031	JD - BLOCK JD	Jd Block	Internal	Ground Floor	M & F TOILETS	FIBRO CEMENT SHEETING CEILING TO MALE & FEMALE TOILETS. SIM SAMPLE 1862 - NAD	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAFE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBKK	20634014	KK - BLOCK K - GENERAL STUDIES/GYM	CHLD CARE LANGUAGE AND LEARNING - BLOCK K	Internal	Ground Floor	MAIN ENTRANCE	VINYL TILES (CREAMY BROWN) - NEAR GYM - MAIN ENTRANCE	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	NA	Not Present(Not Tested)	-	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ed	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBK	20634014	KK - BLOCK K - GENERAL STUDIES/GYM	CHLD CARE LANGUAGE AND LEARNING - BLOCK K	Inter nal	Ground Floor	MAIN CORRIDOR	WALL SHEETING (CREAM) - MAIN CORRIDOR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBK	20634014	KK - BLOCK K - GENERAL STUDIES/GYM	CHLD CARE LANGUAGE AND LEARNING - BLOCK K	Inter nal	Ground Floor	GYM TOILETS	CEILING SHEETING - GYM TOILETS	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBK	20634014	KK - BLOCK K - GENERAL STUDIES/GYM	CHLD CARE LANGUAGE AND LEARNING - BLOCK K	Inter nal	Ground Floor	STAFF TOILETS	WALL PARTITIONS - BETWEEN STAFF TOILETS - STAFF TOILETS	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBK	20634014	KK - BLOCK K - GENERAL STUDIES/GYM	CHLD CARE LANGUAGE AND LEARNING - BLOCK K	Inter nal	Ground Floor	FOYER	CEILING SHEETING - FOYER	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBK	20634014	KK - BLOCK K - GENERAL STUDIES/GYM	CHLD CARE LANGUAGE AND LEARNING - BLOCK K	Exter nal	Ground Floor	EXTERNAL WALL SHEETING	WALL SHEETING (CREAM) - GROUND FLOOR - CHLD CARE LANGUAGE AND LEARNING - BLOCK K	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBK	20634014	KK - BLOCK K - GENERAL STUDIES/GYM	CHLD CARE LANGUAGE AND LEARNING - BLOCK K	Exter nal	Ground Floor	SOFFIT	PLYWOOD SOFFIT SHEETING - CONTINUOUS - ALL ELEVATIONS	Gable/Soffit/F ascia	Other (refer to description)		NA	Not Present(Not Tested)	-	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBL	20634029	LL - BLOCK L	L Block	Inter nal	Ground Floor	ADMIN OFFICE	FLOORING TO ADMINISTRATION OFFICE	Floor Finish/Coverin g	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBL	20634029	LL - BLOCK L	L Block	Inter nal	Ground Floor	ADMIN OFFICE	FIBROUS CEMENT SHEET BAFFLE TOP OF ALL PERIMETER WALLS	Baffles/Lining	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBL	20634029	LL - BLOCK L	L Block	Inter nal	Ground Floor	ADMIN OFFICE	LINING IN CEILING SPACE OF SKYLIGHTS (ALSO CEILING TOP OF SWBOARD); SIM SAMPLE 1857 -NAD	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBL	20634029	LL - BLOCK L	L Block	Inter nal	Ground Floor	ADMIN OFFICE	SEVERAL INTERNAL WALL LININGS REMAINING WALL LININGS PLASTERBOARD, SIM SAMPLE 1857 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBL	20634029	LL - BLOCK L	L Block	Inter nal	Ground Floor	KITCHENETTE	PINK VINYL FLOOR TILES TO ENROLMENTS KITCHENETTE REFER SAMPLE 1833 - NAD	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBL	20634029	LL - BLOCK L	L Block	Exter nal	Ground Floor	EXTERNAL	EAVES TO ADMIN BUILDING - STAMPED/MANUFACTURED WITHOUT ASBESTOS - SIM SAMPLE 1857 -NAD	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBMM	20634012	MM - BLOCK M - MULTI PURPOSE	M Block	Inter nal	Ground Floor	OFFICE	PINK VINYL FLOOR TILES IN OFFICE	Floor Finish/Coverin g	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBMM	20634012	MM - BLOCK M - MULTI PURPOSE	M Block	Exter nal	Roof Level 1	BASKETBALL COURT	UPPER GABLE ENDS OF BASKETBALL COURT	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBMM	20634012	MM - BLOCK M - MULTI PURPOSE	M Block	Inter nal	Ground Floor	M & F TOILETS	CEILING TO MALE AND FEMALE TOILETS SIM SAMPLE 1852 - NAD	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBMM	20634012	MM - BLOCK M - MULTI PURPOSE	M Block	Inter nal	Ground Floor	OFFICE	CEILING TILES IN OFFICE	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBMM	20634012	MM - BLOCK M - MULTI PURPOSE	M Block	Inter nal	Ground Floor	OFFICE & TOILETS	WALLS PANELS IN OFFICE AND TOILETS SIM SAMPLE 1854 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBMM	20634012	MM - BLOCK M - MULTI PURPOSE	M Block	Inter nal	Ground Floor	SNOOKER ROOM	NARROW FIBROUS CEMENT INFILL PANELS - TOP OF MASONRY WALLS	Baffles/Lining	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBMM	20634012	MM - BLOCK M - MULTI PURPOSE	M Block	Inter nal	Ground Floor	UTILITY ROOM	VINYL TILES TO UTILITY ROOM	Floor Finish/Coverin g	Vinyl Tiles	No asbestos detected (NAD)	2	Not Present(Not Tested)	-	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBMM	20634012	MM - BLOCK M - MULTI PURPOSE	M Block	Inter nal	Ground Floor	M & F TOILETS	TOILET/SHOWER CUBICLE PARTITIONS IN MALE & FEMALE TOILETS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBNN	20634032	NN - BLOCK N - BUSINESS AND GENERAL STUDIES	N Block	Exter nal	Ground Floor	EXTERNAL	ACCESS TO EAVES OF AWNINGS HEIGHT RESTRICTED (BLDG 3 YRS OLD & ASBESTOS NOT SUSPECTED)	Gable/Soffit/F ascia	Other (refer to description)		4	Presumed	-	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBNN	20634032	NN - BLOCK N - BUSINESS AND GENERAL STUDIES	N Block	Exter nal	Ground Floor	EXTERNAL	THICK COMPRESSED SHEET TO SUNSHADES N SIDE OF BUILDING SIMILAR SAMPLE 1861 - NAD	Sun Hood	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBO		OO - BLOCK OO	O Block											-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBQA	20634005	QA - BLOCK QA - HORTICULTURE	Qa Block	Exter nal	Ground Floor	RURAL STUDIES NO 2	NO ASBESTOS CONTAINING MATERIALS DETECTED IN RURAL STUDIES NO. 2	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)	-	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBQA	20634005	QA - BLOCK QA - HORTICULTURE	Qa Block	Exter nal	Ground Floor	RURAL STUDIES NO 1	NO ASBESTOS CONTAINING MATERIALS DETECTED IN RURAL STUDIES NO. 1	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)	-	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBQB	20634006	QB - BLOCK QB - HORTICULTURE	Qb Block											-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBOC		QC - BLOCK QC - HORTICULTURE SHED	Qc Block											-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBTA	20634008	TA - BLOCK TA - MODULAR	Ta Block	Exter nal	Ground Floor	EXTERNAL	EXTERNAL WALL PANELS SIM SAMPLE 1862 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBTA	20634008	TA - BLOCK TA - MODULAR	Ta Block	Inter nal	Ground Floor	CLASSROOMS X 2	REMOVED AND REPLACED VINYL SHEET FLOORING TO TWO CLASSROOMS - BACKING MATERIAL	Floor Finish/Coverin g	Vinyl Sheeting (includes backing)		4	Removed	62	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBTA	20634008	TA - BLOCK TA - MODULAR	Ta Block	Exter nal	Ground Floor	EXTERNAL	EAVES - BUILDING PERIMETER SIM SAMPLE 1857 - NAD	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBTA	20634008	TA - BLOCK TA - MODULAR	Ta Block	Inter nal	Ground Floor	INTERNAL	INTERNAL WALL PANELS SIM SAMPLE 1862 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBTB	20634009	TB - BLOCK TB - MODULAR	Tb Block	Exter nal	Ground Floor	EXTERNAL	EXTERNAL WALL PANELS SIM SAMPLE 1862 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBTB	20634009	TB - BLOCK TB - MODULAR	Tb Block	Inter nal	Ground Floor	INTERNAL	INTERIOR WALL PANELS SIM SAMPLE 1862 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBTB	20634009	TB - BLOCK TB - MODULAR	Tb Block	Inter nal	Ground Floor	CLASSROOM	CEILING PANELS IN CLASSROOM SIM SAMPLE 1862 - NAD	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBTB	20634009	TB - BLOCK TB - MODULAR	Tb Block	Exter nal	Ground Floor	EXTERNAL	EAVES - BUILDING PERIMETER SIM SAMPLE 1857 - NAD	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBTB	20634009	TB - BLOCK TB - MODULAR	Tb Block	Inter nal	Ground Floor	CLASSROOMS X 2	REMOVED AND REPLACED - VINYL SHEET FLOORING TO TWO CLASSROOMS	Floor Finish/Coverin g	Vinyl Sheeting (includes backing)		4	Removed	62	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBTC	20634010	TC - BLOCK TC - MODULAR	Tc Block	Exter nal	Ground Floor	EXTERNAL	EAVES - BUILDING PERIMETER SIM SAMPLE 1857 - NAD	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Wic No - 20634)	GBBTC	20634010	TC - BLOCK TC - MODULAR	Tc Block	Exter nal	Ground Floor	EXTERNAL	EXTERNAL WALL PANELS SIM SAMPLE 1862 - NAD	Wall	Cement Based		4	Presumed	18	-	

TAFes from BEMIR-TAFes

Current as at 10-May-11

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBBTC	20634010	TC - BLOCK TC - MODULAR	Tc Block	Internal	Ground Floor	CLASSROOM	CEILING PANELS TO CLASSROOM SIM SAMPLE 1862 - NAD	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBBTC	20634010	TC - BLOCK TC - MODULAR	Tc Block	Internal	Ground Floor	CLASSROOMS X 2	REMOVED AND REPLACED - VINYL SHEET FLOORING TO TWO CLASSROOMS	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Removed	62	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBBTC	20634010	TC - BLOCK TC - MODULAR	Tc Block	Internal	Ground Floor	INTERNAL	INTERIOR WALL PANELS SIM SAMPLE 1862 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBBTD	20634011	TD - BLOCK TD - MODULAR	Td Block	External	Ground Floor	EXTERNAL	EAVES - BUILDING PERIMETER SIM SAMPLE 1857 - NAD	Gable/Soffit/Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBBTD	20634011	TD - BLOCK TD - MODULAR	Td Block	Internal	Ground Floor	ROOM T8 CLASSROOM	REMOVED AND REPLACED - VINYL SHEET FLOORING IN CLASSROOM	Floor Finish/Covering	Vinyl Sheeting (includes backing)	CHR - Chrysotile	4	Removed	62	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBBTD	20634011	TD - BLOCK TD - MODULAR	Td Block	Internal	Ground Floor	T7 CLASSROOM	REMOVED AND REPLACED - VINYL SHEET FLOORING - ROOM T7	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBBTD	20634011	TD - BLOCK TD - MODULAR	Td Block	Internal	Ground Floor	INTERNAL	INTERIOR WALLS - CREAM COLOUR SIM SAMPLE 1862 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBBTD	20634011	TD - BLOCK TD - MODULAR	Td Block	External	Ground Floor	EXTERNAL	EXTERIOR WALLS - CREAMY COLOUR SIM SAMPLE 1862 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBBTD	20634011	TD - BLOCK TD - MODULAR	Td Block	Internal	Ground Floor	CLASSROOM	CLASSROOM CEILING (SAME AS MODULAR BUILDING 07) SIM SAMPLE 1862 - NAD	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBBU1		U1 - STORE - CHILDCARE	Store - Childcare											-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBBU2		U2 - SHED - CHILDCARE	Shed - Childcare											-	
Metropolitan South		ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	ALEXANDRA HILLS TAPE CAMPUS - (Agency Ref -GBB) (Vic No - 20634)	GBBUU		UU - BLOCK UU - CHILDCARE	U Block											-	
Metropolitan South		BROWNS PLAINS-LOGAN TAPE	BROWNS PLNS MSIT CAMPUS	GBP	43551000	** Site - Grounds	** Site - Grounds											-	
Metropolitan South		BROWNS PLAINS-LOGAN TAPE	BROWNS PLNS MSIT CAMPUS	GBPA	43551001	A Block	A Block											-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	24124003	24124003	COVERED WALKWAYS	COVERED WALKWAYS	External	Ground Floor	EXTERNAL	COLORBOND PRESSED METAL CLADDING - POST 1990 CONSTRUCTION ASBESTOS FREE	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	1 X JAMES HARDIES TRANSPORTABLE MODULAR BUILDINGS
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	24124010	24124010	AMEP MODULARS	AMEP MODULARS BLOCK T	External	Roof Level 1	ROOFING	ZINCALUME ROOFING - POST 1990 CONSTRUCTION - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		NA	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	24124010	24124010	AMEP MODULARS	AMEP MODULARS BLOCK T	Internal	Ground Floor	FLOORING	CARPET AND VINYL FLOORING - POST 1990 CONSTRUCTION - ASBESTOS FREE	Floor	Other (refer to description)		NA	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	24124010	24124010	AMEP MODULARS	AMEP MODULARS BLOCK T	Internal	Ground Floor	WALLS	TEXTURED PAINTED PLYWOOD WALL CLADDING THROUGHOUT ALL ROOMS POST 1990 CONSTRUCTION - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		NA	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	24124012	24124012	CARP JOIN W/SHOP	CARP JOIN W/SHOP BLOCK D	External	Various levels Internal	CARP JOIN WORKSHOP	BUILDING POST 1999, A COMPLETE INSPECTION IT TO BE ASBESTOS FREE AT THE TIME OF THE AUDIT	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	24124015	24124015	TOOL STORE SHED	TOOL STORE SHED	External	Various levels Internal	TOOL STORE SHED	BUILDING POST 1999, A COMPLETE INSPECTION IT TO BE ASBESTOS FREE AT THE TIME OF THE AUDIT	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	24124017	24124017	CLEANER STORE SHED	CLEANER STORE SHED	External	Various levels Internal	CLEANER STORE SHED	BUILDING POST 1999, A COMPLETE INSPECTION IT TO BE ASBESTOS FREE AT THE TIME OF THE AUDIT	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	24124019	24124019	A BLOCK ANNEX	A BLOCK ANNEX	External	Ground Floor	SERVICE PIT	FIBRE CEMENT PIT PROFILE SURROUND	Preformed Moulded Product	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLL01	24124013	METAL CUTTING K BLOCK	TAL CUTTING BLOCK K	External	Ground Floor	MTL CUTTING	BUILDING POST 1999, A COMPLETE INSPECTION IT TO BE ASBESTOS FREE AT THE TIME OF THE AUDIT	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLL02		Horticulture - Shadehouse	Horticulture - Shadehouse											-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLL03		Horticulture - Shadehouse	Horticulture - Shadehouse											-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLL04		Horticulture - Shadehouse	Horticulture - Shadehouse											-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLL05		Horticulture - Shadehouse	Horticulture - Shadehouse											-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLL06		Horticulture - Greenhouse	Horticulture - Greenhouse											-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLL07		Horticulture - Greenhouse	Horticulture - Greenhouse											-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLL08		Horticulture - Greenhouse	Horticulture - Greenhouse											-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLL09		Shed	Shed											-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLL10	24124004	FUEL STORE	FUEL STORE	External	Roof Level 1	EXTERNAL	SHEET METAL	Roof Sheeting	Other (refer to description)		4	Presumed		-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLL10	24124004	FUEL STORE	FUEL STORE	External	Various levels Internal	FUEL STORE	A COMPLETE AUDIT OF THIS BUILDING SHOWED IT TO BE ASBESTOS FREE AT THE TIME	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLL11	24124016	GARDENERS SHED	GARDENERS SHED ON OVAL	External	Other (refer to description)	GROUNDSMANS SHED ON OVAL	BUILDING POST 1999, A COMPLETE INSPECTION IT TO BE ASBESTOS FREE AT THE TIME OF THE AUDIT	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLL12		Shed	Shed											-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLL13		Shed - Storage	Shed - Storage											-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLL14		Shed - Storage (Construct	Shed - Storage (Construct											-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 4	STAIRWELL	SOUTHERN FIRE ESCAPE DOOR - 4th FLOOR EXIT STAIRS	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 4	BEAUTY	HEATER BANK INSULATING PANELS - IN CEILING SPACE ABOVE POWER POINTS	Heater Bank Insulation	Other (refer to description)		4	Presumed		-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 4	MITOILET DUCT	JOINTING COMPOUND - BETWEEN SHAFT AND WALL	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 4	ROOM A4-01	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAPE CAMPUS	LOGANLEA TAPE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 4	ROOM A4-12	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 4	SALON	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	###	4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 4	SALON 3 STORE EAST	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	###	4	Not Present(Not Tested)	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 4	SALON 3 WEST STORE	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	###	4	Not Present(Not Tested)	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 4	SALON No2	HEATERBANK INSULATION PANELS - IN CEILING SPACE OF MAIN SALON No2 - STORE ROOM WALL END	Heater Bank Insulation	Other (refer to description)		4	Presumed		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 4	STAIR WELL	NORTHERN FIRE ESCAPE DOOR - 4th FLOOR EXIT STAIRWELL	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 5	AC ROOM	FIXTURES AND FANS	Furniture	Cement Based		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 5	LIFT ROOM	LIFT MOTORS AND BRAKE SYSTEM	Plant, Equipment & Machinery	Polymer Bound		4	Presumed	25	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Roof Level 1	SWITCH BOARD / COMMS CUPBOARD	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 4	A4-15 HDR RM	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 4	SALON No3	HEATERBANK INSULATION PANELS - IN CEILING SPACE ABOVE THE STORE ROOM DOOR IN SALON No3	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 2	FEMALE LOCKERS	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	###	4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	External	Ground Floor	EXTERNAL EAST	WALL PANELS - UNDER WINDOWS	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	External	Ground Floor	EXTERNAL NORTH	WALL PANELS - UNDER WINDOWS	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	External	Ground Floor	EXTERNAL SOUTH	WALL PANELS - UNDER WINDOWS	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	External	Roof Level 1	EXTERNAL	METAL ROOF SHEETING AND GUTTERING	Roof Sheeting	Other (refer to description)		4	Presumed		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 1	STAIRWELL	FIRE DOORS - SOUTHERN END STAIRWELL ON THE LIBRARY SIDE (BLUE COLOUR NEAR LIBRARY STEPS)	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 4	A4-08 STORE	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 2	A2-000 ADJACENT TO LIFTS	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	###	4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 1	ROOM A1-06 ST LOCH RM	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 2	FIRE HYD RISER	VERMICULITE TO PLASTERBOARD	Insulation/Fill	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 2	MALE LOCKERS	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	###	4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 2	ROOM A2-04 STORE	VINYL FLOOR TILES	Floor	Vinyl Tiles	###	4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 2	STAIRWELL	NORTH EASTERN FIRE ESCAPE DOOR - 2nd LEVEL EXIT STAIRWELL	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 2	STAIRWELL	SOUTHERN END FIRE ESCAPE DOOR - 2nd LEVEL EXIT STAIRWELL	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 2	WASTE PIPE DUCT	WALL (BOTTOM HALF) IN THE WASTE PIPE DUCT NORTH EAST END BY THE FIRE HOSE CUPBOARD	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 2	WASTE PIPE DUCT	WALL OF THE WASTE PIPE SERVICE DUCT AT THE NORTH EAST END BY THE FIRE HOSE CUPBOARD	Wall	Other (refer to description)		4	Presumed		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 3	ROOM A3-10	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 3	ROOM A3-18 STORE IN ROOM A3-06	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 3	STAIRWELL	NORTH EASTERN FIRE ESCAPE DOOR - 3rd LEVEL EXIT STAIRS	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 3	STAIRWELL	SOUTH WEST FIRE ESCAPE DOOR - 3rd FLOOR EXIT STAIRWELL	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 1	STAIRWELL	SOUTHERN END FIRE ESCAPE DOOR - 1st LEVEL EXIT STAIRS (STAINED BROWN)	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLAA	24124002	ADMINISTRATION A BLOCK	ADMINISTRATION BLOCK A	Internal	Level 1	STAIRWELL	NORTHERN END FIRE ESCAPE DOOR - 1st LEVEL EXIT STAIRWELL	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	External	Ground Floor	EXTERNAL EAST	WALL PANELS - UNDER WINDOWS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	External	Roof Level 1	EXTERNAL	SHEET METAL ROOFING AND GUTTERING	Roof Sheeting	Other (refer to description)		4	Presumed		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	AC UNIT	UNIT - VISUALLY INSPECTED	Plant, Equipment & Machinery	Other (refer to description)		4	Presumed		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	ENTRANCE	FIBRE CEMENT INFILL PANELS - ABOVE THE ENTRANCE	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	LIBRARY	MILLBOARD IN HEATER BANK LOCATED IN CEILING SPACE	Heater Bank Insulation	Other (refer to description)		4	Presumed		-	(SAMPLED NAD UNDER THE 2004/05 REMOVAL PROGRAM)
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	LIBRARY FOYER	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	LIBRARY STR RM	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	LIBRARY WORK RM	VINYL TILES SIM TO SAMPLE # 5791	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	MEZZINE ABOVE STORE	HEATERBANK INSULATION ABOVE THE WHITE BOARD ROOM NEXT DOOR TO THE LIBRARY	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	

TAFEs from BEMIR-TAFEs

Region	District	Facility Name	Site Name	Agency Ref No.	Other Ref No.	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEIMR Score	Attention Required	Comments
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	MEZZINE ABOVE STORE	HEATERBANK'S INSULATION - MEZZANINE FLOOR IN LIBRARY ABOVE STOREROOM	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	PLANT ROOM	CLUTCH LINING ON FIRE BOOSTER PUMP IN PLANT ROOM AT REAR OF RESOURCE BLDG	Plant, Equipment & Machinery	Woven Textile	CHR - Chrysotile	3	Confirmed	64	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	PLANT ROOM	HEATERBANKS - CONCRETE WALL IN PLANT ROOM	Heater Bank Insulation	Cement Based		4	Presumed	18	-	CONCRETE WALL IN THE PLANT ROOM. NOT SAMPLED SPACE TOO SMALL TO ACCESS
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	ROOM B08 LIBRARY	HEATERBANK INSULATION IN CEILING SPACE - MIDDLE OF THE ROOM ABOVE THE SPEAKER PANELS	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	External	Ground Floor	EXTERNAL WEST	WALL PANELS - UNDER WINDOWS	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	External	Ground Floor	EXTERNAL SOUTH	WALL PANELS - UNDER WINDOWS	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	ROOM B09	HEATERBANK INSULATION IN CEILING SPACE - ENTRY DOOR TO ROOM B09 IN LIBRARY	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	ROOM B10	HEATERBANK INSULATION IN CEILING SPACE - ROOM B10 AT THE WINDOW END	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	ROOM B106 ADMIN	HEATERBANK INSULATION IN ADMINISTRATION/MARKETING AREA - ABOVE WORK BENCHES	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	ROOM B11	HEATERBANK INSULATION IN CEILING SPACE - ABOVE WHITE BOARD AREA IN ROOM B11	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	ROOM B11 LIBRARY	HEATERBANK INSULATION IN CEILING SPACE - ABOVE COMPUTERS BY WINDOW FACING THE GARDEN	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	SWITCHROOM	FIBRE CEMENT INFILL PANEL - ABOVE SWITCHROOM	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	ROOM B1.04.1	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLBB	24124001	RESOURCE B BLOCK	RESOURCE BLOCK B	Internal	Ground Floor	ROOM B1.02.1 TEA RM	SHEET VINYL FLOORING	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLCC	24124011	APP SCI/COMPUTER C BLOCK	APP SCI/COMPUTER BLOCK C	External	Ground Floor	APP SCI COMP	BUILDING POST 1999, A COMPLETE INSPECTION IT TO BE ASBESTOS FREE AT THE TIME OF THE AUDIT	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLDA		D Block (Annex)	D Block (Annex)											-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLDD	24124009	TEACHING/CARPENTRY D BLOCK	NURSING BLOCK D	Internal	Ground Floor	WORKING ROOMS	WALL SHEETING	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLDD	24124009	TEACHING/CARPENTRY D BLOCK	NURSING BLOCK D	External	Roof Level 1	EXTERNAL	WALL PANEL - BELOW WINDOWS	Wall	Cement Based	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLDD	24124009	TEACHING/CARPENTRY D BLOCK	NURSING BLOCK D	Internal	Ground Floor	INTERNAL	WALL PANELS - BELOW WINDOWS	Wall	Cement Based	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLDD	24124009	TEACHING/CARPENTRY D BLOCK	NURSING BLOCK D	Internal	Ground Floor	PANEL	SWITCHBOARD PANEL	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLDD	24124009	TEACHING/CARPENTRY D BLOCK	NURSING BLOCK D	Internal	Ground Floor	WORKING ROOMS	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLDD	24124009	TEACHING/CARPENTRY D BLOCK	NURSING BLOCK D	External	Roof Level 1	EXTERNAL	SHEET METAL ROOFING AND GUTTERING	Roof Sheeting	Other (refer to description)		4	Presumed		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLDD	24124008	TEACHING/CARPENTRY D BLOCK	NURSING BLOCK D	External	Ground Floor	EXTERNAL SOUTH	WALL PANELS - UNDER WINDOWS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLDD	24124009	TEACHING/CARPENTRY D BLOCK	NURSING BLOCK D	External	Ground Floor	EXTERNAL NORTH	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLFE	24124008	TEACHING/MASONRY E BLOCK	TEACHING/MASONRY BLOCK E	Internal	Ground Floor	BILAYING WISHOP	CEILING SHEETING - AROUND WINDOWS	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLFE	24124008	TEACHING/MASONRY E BLOCK	TEACHING/MASONRY BLOCK E	Internal	Ground Floor	COMP & EXT UNIT	NO VISIBLE AIR CONDITIONING UNIT	Furniture	Cement Based		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLFE	24124008	TEACHING/MASONRY E BLOCK	TEACHING/MASONRY BLOCK E	External	Ground Floor	EXTERNAL EAST	WALL PANELS - UNDER WINDOWS	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLFE	24124008	TEACHING/MASONRY E BLOCK	TEACHING/MASONRY BLOCK E	External	Ground Floor	EXTERNAL NORTH	WALL SHEETING - UNDER WINDOWS	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLFE	24124008	TEACHING/MASONRY E BLOCK	TEACHING/MASONRY BLOCK E	External	Ground Floor	EXTERNAL SOUTH	WALL SHEETING - UNDER WINDOWS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLFE	24124008	TEACHING/MASONRY E BLOCK	TEACHING/MASONRY BLOCK E	External	Roof Level 1	EXTERNAL	SHEET METAL ROOFING AND GUTTERING	Roof Sheeting	Other (refer to description)		4	Presumed		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLFF	24124007	CH/REFRIGERATION F BLOCK	CH/REFRIGERATION BLOCK F	Internal	Ground Floor	EXTERNAL NORTH	COMPRESSED SHEET PANELS - UNDER WINDOWS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLFF	24124007	CH/REFRIGERATION F BLOCK	CH/REFRIGERATION BLOCK F	External	Ground Floor	EXTERNAL SOUTH	WALL PANELS - UNDER WINDOWS	Wall	Cement Based	###	4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLFF	24124007	CH/REFRIGERATION F BLOCK	CH/REFRIGERATION BLOCK F	External	Ground Floor	EXTERNAL WEST	COMPRESSED SHEET PANELS - UNDER WINDOWS	Wall	Cement Based	###	4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLFF	24124007	CH/REFRIGERATION F BLOCK	CH/REFRIGERATION BLOCK F	External	Roof Level 1	EXTERNAL	METAL ROOF SHEETING AND GUTTERING	Roof Sheeting	Other (refer to description)		4	Presumed		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLFF	24124007	CH/REFRIGERATION F BLOCK	CH/REFRIGERATION BLOCK F	Internal	Ground Floor	REFRIG WORKSHOP	WALL SHEETING - IN WORKSHOP NORTH WALL WEST END	Wall	Cement Based	###	4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLFF	24124007	CH/REFRIGERATION F BLOCK	CH/REFRIGERATION BLOCK F	Internal	Ground Floor	ROOM 1-08 SCIENCE	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLFF	24124007	CH/REFRIGERATION F BLOCK	CH/REFRIGERATION BLOCK F	Internal	Ground Floor	WELDING ROOM	WALL SHEETING - WELDING BOOTH WALLS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLFF	24124007	CH/REFRIGERATION F BLOCK	CH/REFRIGERATION BLOCK F	External	Ground Floor	EXTERNAL EAST	WALL PANELS - UNDER WINDOWS	Wall	Cement Based	###	4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLGG	24124006	TEACHING STORE G BLOCK	TEACHING STORE BLOCK G	Internal	Ground Floor	MN STR OFFICE 2	SHEET VINYL FLOORING	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLGG	24124006	TEACHING STORE G BLOCK	TEACHING STORE BLOCK G	Internal	Ground Floor	MN STR OFFICE 2	SHEET VINYL FLOORING	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLGG	24124006	TEACHING STORE G BLOCK	TEACHING STORE BLOCK G	External	Ground Floor	EXTERNAL	CONCRETE BLOCK WALLS	Wall	Other (refer to description)		4	Presumed		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLGG	24124006	TEACHING STORE G BLOCK	TEACHING STORE BLOCK G	External	Roof Level 1	EXTERNAL	SHEET METAL ROOFING	Roof Sheeting	Other (refer to description)		4	Presumed		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLGG	24124006	TEACHING STORE G BLOCK	TEACHING STORE BLOCK G	Internal	Ground Floor	MN STR OFFICE 1	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLGG	24124006	TEACHING STORE G BLOCK	TEACHING STORE BLOCK G	External	Ground Floor	EXTERNAL SOUTH	COMPRESSED SHEET PANELS - UNDER WINDOWS	Wall	Cement Based		4	Presumed	18	-	

TAFEs from BEIMR-TAFEs

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLHH	24124005	TEACHING STAFF H BLOCK	TEACHING STAFF BLOCK H	Inter nal	Ground Floor	STAFF ROOM	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLHH	24124005	TEACHING STAFF H BLOCK	TEACHING STAFF BLOCK H	Exter nal	Roof Level 1	EXTERNAL	SHEET METAL ROOFING AND GUTTERING	Roof Sheeting	Other (refer to description)		4	Presumed		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLHH	24124005	TEACHING STAFF H BLOCK	TEACHING STAFF BLOCK H	Exter nal	Ground Floor	SERVICE PIT	FIBRE CEMENT PIT PROFILE SURROUND	Preformed Moulded Product	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLHH	24124005	TEACHING STAFF H BLOCK	TEACHING STAFF BLOCK H	Exter nal	Ground Floor	EXTERNAL SOUTH	WALL PANELS - UNDER WINDOWS	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLHH	24124005	TEACHING STAFF H BLOCK	TEACHING STAFF BLOCK H	Exter nal	Ground Floor	EXTERNAL NORTH	WALL PANELS - UNDER WINDOWS	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLHH	24124005	TEACHING STAFF H BLOCK	TEACHING STAFF BLOCK H	Exter nal	Ground Floor	EXTERNAL EAST	WALL PANELS - UNDER WINDOWS	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLJI	24124018	BLOCK I	BLOCK I	Exter nal	Ground Floor									-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLJJ	24124014	APP SCI ANNEX J BLOCK	APP SCI ANNEX BLOCK J	Exter nal	Ground Floor	APP SCI ANNEX	BUILDING POST 1999. A COMPLETE INSPECTION IT TO BE ASBESTOS FREE AT THE TIME OF THE AUDIT	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLTT		T Block	T Block											-	
Metropolitan South		LOGANLEA TAFE CAMPUS	LOGANLEA TAFE CAMPUS	GLLZZ		Childcare	Childcare											-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG	25023000	00 - SITE GROUNDS	SITE	Inter nal	Various levels Internal	SERVICE TUNNEL	POSSIBLE MATERIALS IN STUFFING BOX OF GATE VALVE	Drains/Pipes/F lues	Woven Textile		3	Removed	64	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG	25023000	00 - SITE GROUNDS	SITE	Exter nal	Site / Grounds	EXTERNAL	FORMWORK BENEATH CONCRETE TABLE COVERED WITH CERAMIC TILES. SIM SAMPLE 1780	Furniture	Cement Based		3	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG	25023000	00 - SITE GROUNDS	SITE	Inter nal	Various levels Internal	SERVICE TUNNEL	100 MM 160 MM AC WPPIPES INSIDE BETWEEN AB BLKS	Drains/Pipes/F lues	Cement Based	Mixed	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG	25023000	00 - SITE GROUNDS	SITE	Exter nal	Site / Grounds	WASTE OIL SUMP	PIPEWORK TO WASTE OIL SUMP - LOCATED NORTH OF TENNIS SHED SIM SAMPLE 1743	Drains/Pipes/F lues	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG	25023000	00 - SITE GROUNDS	SITE	Exter nal	Site / Grounds	WASTE OIL SUMP	FORMWORK TO WASTE OIL SUMP - LOCATED NORTH OF TENNIS SHED SIM SAMPLE 1780	Plant, Equipment & Machinery	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG	25023000	00 - SITE GROUNDS	SITE	Exter nal	Site / Grounds	HORTICULTURAL SECTION	DEBRIS - LOCATED IN THE VEGGIE GARDEN	Debris	Cement Based	CHR AMO - Chrysotile Amosite	1	Confirmed	60	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG	25023000	00 - SITE GROUNDS	SITE	Exter nal	Site / Grounds	GARDEN AREA	1 X ELECT PIT WESTERN SIDE BELOW STREET LIGHT	Drains/Pipes/F lues	Cement Based	Mixed	3	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG	25023000	00 - SITE GROUNDS	SITE	Exter nal	Site / Grounds	EXTERNAL	ROOFING TO THREE SEATING AREAS 450M EACH - SHEETING IS IN TILE FORM	Roof Sheeting	Cement Based	Mixed	3	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG	25023000	00 - SITE GROUNDS	SITE	Exter nal	Site / Grounds	EXTERNAL	10 PIPE BOLLARD TO CONC APRON EAST NTH SIDE BLK B	Drains/Pipes/F lues	Cement Based	Mixed	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG	25023000	00 - SITE GROUNDS	SITE	Exter nal	Site / Grounds	EXTERNAL	1 X ELECTRICAL CABLE PIT WESTERN SIDE OF BLOCK F	Drains/Pipes/F lues	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG	25023000	00 - SITE GROUNDS	SITE	Exter nal	Site / Grounds	ELECTRICAL PIPES	MAIN ELECT FEED PIPE ENCASED AC PIPES THROUGHOUT SITE	Drains/Pipes/F lues	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG	25023000	00 - SITE GROUNDS	SITE	Exter nal	Site / Grounds	CAR PARK LIGHTING	ELECTRICAL PITS THROUGHOUT SITE BESIDE CPARK LIGHTING	Drains/Pipes/F lues	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG	25023000	00 - SITE GROUNDS	SITE	Exter nal	Site / Grounds	BBQ AREA	FORMWORK TO CONCRETE TABLE - BBQ AREA LOCATED E OF GARAGE & STORE 04. SIM SAMPLE 1780	Furniture	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG	25023000	00 - SITE GROUNDS	SITE	Exter nal	Site / Grounds	BBQ AREA	FORMWORK BENEATH CONCRETE TABLES IN BBQ AREA	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG	25023000	00 - SITE GROUNDS	SITE	Exter nal	Ground Floor	COVERED LINKS	NO ASBESTOS CONTAINING MATERIALS DETECTED IN COVERED LINKS	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG	25023000	00 - SITE GROUNDS	SITE	Exter nal	Site / Grounds	EXTERNAL	FASCIA BOARD INSTALLED TO THREE SEATING AREAS IN BBQ AREA	Gable/Soffit/F ascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG	25023000	00 - SITE GROUNDS	SITE	Exter nal	Ground Floor	EXTERNAL	FASCIA BOARD INSTALLED TO PERIMETER OF COVERED WALKWAY AREA. SIM SAMPLE 1742 - NAD	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG01	25023023	01 - BLOCK BB - CAMPUS STORE	Campus Store (Bb)	Exter nal	Ground Floor	STORAGE SHED	NO ASBESTOS CONTAINING MATERIALS DETECTED IN STORAGE SHED	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG02	25023002	02 - BLOCK CC - COURTYARD COVERED AREA	COVERED AREA	Inter nal	Level 1	SERVICE TUNNEL	FIRE DOORS DOUBLE SOUTH ENTRY UNDER BLOCK A STAGE	Fire Door	Millboard	Mixed	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG02	25023002	02 - BLOCK CC - COURTYARD COVERED AREA	COVERED AREA	Inter nal	Level 1	SERVICE TUNNEL	FIRE DOORS DOUBLE NORTH ENTRY UNDER STAGE BLK A	Fire Door	Millboard	Mixed	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG03	25023018	03 - BLOCK EE - STORE/FACILITIES	Store - Facilities (E)	Exter nal	Ground Floor	KILN SHED BLOCK E	NO ASBESTOS CONTAINING MATERIALS DETECTED IN KILN SHED - BLOCK E	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG04	25023012	04 - BLOCK Ka - BATTERY/PALLET STORE	Battery/Pallet Store (Ka)	Inter nal	Ground Floor	STORAGE AREA	CAR AXLES WITH BRAKE PADS ON RACKS THROUGHOUT BLOCK K - PORTABLE ITEM	Stored Material	Polymer Based	CHR - Chrysotile	2	Confirmed	39	-	Advised by DET 16/07/2010 item kept for Teaching/Display purposes
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG04	25023012	04 - BLOCK Ka - BATTERY/PALLET STORE	Battery/Pallet Store (Ka)	Exter nal	Ground Floor	PALET STORE BLOCK K	NO ASBESTOS CONTAINING MATERIALS DETECTED IN PALLET STORE - BLOCK K	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG05	25023003	05 - BLOCK KB - FUEL STORE	Fuel Store (Kb)	Exter nal	Roof Level 1	EXTERNAL	SOFFIT INSTALLED TO EAST AND WEST SIDES OF BUILDING SIM SAMPLE 1746 - CHR	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG05	25023003	05 - BLOCK KB - FUEL STORE	Fuel Store (Kb)	Inter nal	Ground Floor	ROOM LINING MATERIAL	WALLS AND CEILING TO THE FUEL STORE	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG06	25023009	06 - BRICKLAYING SHELTER	BRICKLAYING SHELTER	Exter nal	Ground Floor	FASCIA	FIBRE CEMENT WALL AND FACIA LINING	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG06	25023009	06 - BRICKLAYING SHELTER	BRICKLAYING SHELTER	Exter nal	Roof Level 1	EXTERNAL	LOOSE WALL PANEL ADJACENT TO TOILET BLOCK TO REAR OF BRICKLAYING SHELTER	Stored Material	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG06	25023009	06 - BRICKLAYING SHELTER	BRICKLAYING SHELTER	Exter nal	Roof Level 1	EXTERNAL	SOFFIT TO BRICKLAYING SHELTER	Gable/Soffit/F ascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG08	25023009	06 - BRICKLAYING SHELTER	BRICKLAYING SHELTER	Inter nal	Ground Floor	INTERNAL	WALL SHEETING INSIDE FASCIA BARGE BETWEEN TRUSSES	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG07	25023022	07 - BLOCK N - TENNIS SHED/AMENITIES (N)	Tennis Shed/Amenities (N)	Exter nal	Roof Level 1	EXTERNAL	SOFFIT TO EXTERNAL PERIMETER OF BUILDING SIM SAMPLE 1781 - NAD	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG07	25023022	07 - BLOCK N - TENNIS SHED/AMENITIES (N)	Tennis Shed/Amenities (N)	Exter nal	Roof Level 1	EXTERNAL	FASCIA BOARD TO EAST AND WEST ENDS OF BUILDING SIM SAMPLE 1781 - NAD	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG07	25023022	07 - BLOCK N - TENNIS SHED/AMENITIES (N)	Tennis Shed/Amenities (N)	Exter nal	Ground Floor	FRONT VERANDAH	CEILING PANELS INSTALLED TO FRONT VERANDAH AREA OF TENNIS SHED	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG09	25023005	09 - BLOCK Oa - GROUNDSMENS SHED	Groundsmens Shed (Oa)	Exter nal	Ground Floor	EXTERNAL	AWNING LINING TO CANOPY	Sun Hood	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG09	25023005	09 - BLOCK Oa - GROUNDSMENS SHED	Groundsmens Shed (Oa)	Exter nal	Ground Floor	EXTERNAL	CEILING PANELS TO GARDENER'S SHED SIM SAMPLE 1782 - CHR & AMO	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG09	25023005	09 - BLOCK Oa - GROUNDSMENS SHED	Groundsmens Shed (Oa)	Exter nal	Ground Floor	EXTERNAL	SOFFIT LINING	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG09	25023005	09 - BLOCK Oa - GROUNDSMENS SHED	Groundsmens Shed (Oa)	Exter nal	Roof Level 1	EXTERNAL	SOFFIT TO GARDENER'S SHED SIM SAMPLE 1782 - CHR & AMO	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG09	25023005	09 - BLOCK Oa - GROUNDSMENS SHED	Groundsmens Shed (Oa)	Inter nal	Ground Floor	GR(05)	WALL PANELS TO GARDENER'S SHED	Wall	Cement Based	Mixed	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG10	25023004	10 - BLOCK Ob - STORE SHED	Store Shed (Ob)	Exter nal	Roof Level 1	EXTERNAL	SOFFIT TO GARAGE AND STORE SIM SAMPLE 1782 - CHR & AMO	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG10	25023004	10 - BLOCK Ob - STORE SHED	Store Shed (Ob)	Inter nal	Ground Floor	GARAGE & STORE	WALL PANELS TO GARAGE AND STORE SIM SAMPLE 1782 - CHR & AMO	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG11		11 - BLOCK Oa - LARGE FLEET SHED	Fleet Shed - Large (Oa)											-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMG12		12 - BLOCK Ob - SMALL FLEET SHED	Fleet Shed - Small (Ob)											-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEHMR Score	Attention Required	Comments
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 6	STORE ROOM	INSULATION AROUND FRIG LINE MOUNTING BRACKET	Insulation/Fill	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 6	SERVICE RISER	ASB. CEMENT INSTALLED AROUND PIPE PENETRATION ON WALL-RISER IN MALE TOILET. SIM SAMPLE 1740	Wall	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 5	PLANT ROOM	INSULATION AROUND FRIG PIPE LINE MOUNTING BRACKET	Insulation/Fill	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 4	FEMALE STAFF TOILETS & REST ROOM	INSULATION AROUND REFRIGERATION PIPE BRACKETS OVER	Insulation/Fill	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 3	ROOM A3-9 KITCHEN	WALL LINING TO SWITCHBOARD IN KITCHEN A3-9 SIM SAMPLE 1740 - CHR	Insulation/Fill	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 6	STORE ROOM	UNABLE TO ACCESS STORE ROOM TO IDENTIFY ANY POSSIBLE ASBESTOS CONTAINING MATERIAL	Other (refer to description)	Other (refer to description)	3	Presumed		-		
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 3	ROOM A3.12	CORE TO PLANT ROOM FIRE DOOR IN KITCHEN AREA	Fire Door	Milboard	Mixed	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Various levels Internal	FIRE ESCAPE	SHEET INFILLS TO STEP TREADS FROM LEVEL 3 TO 6	Floor	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 3	ROOM A3-8 KITCHEN ENTRY	WALL PANELS TO KITCHEN ENTRY SIM SAMPLE 1740 - CHR	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Roof Level 2	LIFT MOTOR ROOM	ADHESIVE BITUMEN TO CONCRETE FLOOR SLABS	Floor	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Roof Level 2	LIFT MOTOR ROOM	BONDED BRAKE PAD MATERIAL TO LIFT WINCH BRAKES	Plant, Equipment & Machinery	Polymer Bound		4	Presumed	25	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Roof Level 2	LIFT MOTOR ROOM	FIBRE CEMENT LINING TO BOX DUCTING IN LIFT MOTOR ROOM	Baffles/Lining	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 3	BALCONY	1 X FIRE DOOR WEST SIDE BALCONY LEADING ESCAPE FR	Fire Door	Milboard	Mixed	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Roof Level 2	LIFT MOTOR ROOM	ZELEMITE BACKING BOARD TO LIFT CABINET IN LIFT MOTOR ROOM	Plant, Equipment & Machinery	Insulation Board		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 5	PLANT ROOM	HEATER BANK NO. 1 IN PLANT ROOM IN STAFF LUNCH ROOM	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Various levels Internal	FIRE EXIT NORTH	FIRE DOORS TO NORTH FIRE EXIT EACH DOOR 35QM REFER SAMPLE 1739 - CHR & AMO	Fire Door	Milboard		4	Removed	64	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Various levels Internal	FIRE EXIT WEST	FIRE DOORS - UNSEALED AT TOP & BOTTOM - AT FIRE EXITS WEST SIDE, 35QM EACH DOOR	Fire Door	Milboard	Mixed	4	Removed	64	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Various levels Internal	SERVICE RISER N	WALL PANELS TO SERVICE RISER NORTH SIDE - 4 SQM EACH FLOOR REFER SIM 1740 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Various levels Internal	W SERVICE RISER	FIRE HYDRANT ELECT. SWITCH FIRE DETECTORS & TELECOM RISER WALLS. 165QM EACH FLOOR	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Roof Level 2	LIFT MOTOR ROOM LOBBY	FIBRE CEMENT LINING TO BOX DUCTING IN LIFT MOTOR ROOM	Baffles/Lining	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	External	Various levels External	EXTERNAL	FASCIA BOARD INSTALLED TO PERMETER OF BUILDING	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 6	A6-1 PLANT ROOM	HEATER BANK NO. 1 IN A6-1 PLANT ROOM REFER SAMPLE 1779 - NAD	Heater Bank Insulation	Milboard		4	Removed	64	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 2	BALCONY	1 X FIRE DOOR ON WEST SIDE OF NORTHERN BALCONY	Fire Door	Milboard	Mixed	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	External	Level 1	SERVICE TUNNEL	2 PIPES - TUNNEL LOCATED BWN BLOCKS A & B - 4' DOMESTIC WTR & 6' FIRE SERVICE	Drains/Pipes/F Jues	Cement Based	Mixed	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	External	Level 1	WALKWAY	FASCIA BOARD TO WALKWAY W SIDE OF BLOCK A - BETWEEN BLOCKS A & F. SIM SAMPLE 1742 - NAD	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	External	Level 3	BALCONY	CEILING SHEETS TO BALCONY EAST SIDE OF THE KITCHEN	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	External	Level 3	BALCONY EAST	THREE PLANTER BOXES TO BALCONY EAST SIDE - 45QM EACH EACH R. SAMPLE 1741- NAD	Furniture	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	External	Various levels External	EXTERNAL	SHEETING TO SUNHOODS ON LEVEL 56 WEST ELEVATION	Sun Hood	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	External	Various levels Internal	BALCONY NORTH	PLANTER BOXES ON NORTHERN BALCONIES, EACH BOX 55QM ON EACH FLOOR	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 1	CANTEEN	WALL LINING TO FIRE HOSE REEL CUPBOARD LEVELS 1 TO 5	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 1	DB13 OFFICE	WALL PANELS TO KITCHEN MANAGERS OFFICE SIM SAMPLE 1740 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 1	LOADING DOCK	2 X FIRE DOORS WEST SIDE LOAD DOCKS BESIDE SERLIF	Fire Door	Milboard	No asbestos detected (NAD)	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	External	Level 3	BALCONY EAST	ADHESIVE BITUMEN TO CONCRETE FLOOR SLABS - 45QM TO EACH N BALCONY. SIM SAMPLE 1738-NAD	Floor	Polymer Bound		4	Removed	25	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 1	SWITCH ROOM	SHEETING INSTALLED TO SOIL WATER & ELECTRICAL CABLE WALL PENETRATIONS. SIM SAMPLE 1740	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 1	FIRE ESCAPE	STORMWATER PIPE INSIDE NORTH FESCAPE LEVEL 1 TO 3	Stormwater Plumbing	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 1	LOADING DOCK	2 X FIRE DOORS WEST SIDE LOAD DOCKS BESIDE SERLIF	Fire Door	Milboard	Mixed	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 1	LOADING DOCK	CEILING SHEETS TO LOADING DOCK OUT SIDE KITCHEN AREA	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 1	LIFT MOTOR ROOM	FIRE DOOR TO SERVICE LIFT MOTOR ROOM REFER SAMPLE 1738 - CHR & AMO	Fire Door	Milboard		4	Removed	64	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 1	KITCHEN	ZELEMITE BBBOARD TO SBOARD DISTRIBUTION BRD DB 13	Insulation/Fill	Polymer Bound	CHR - Chrysotile	4	Confirmed	25	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 1	KITCHEN	WALL LINING BEHIND HOT WATER BOILER IN KITCHEN SIM SAMPLE 1740 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 1	KITCHEN	SHEETING TO SERV CBOARD LOCATED DISTRIBUTION BRD	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGAA	25022020	AA - BLOCK A	A Block	Internal	Level 1	KITCHEN	SHEETING TO PASSAGE WAY OSIDE TOILETS LUNCH ROOMS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25022019	BA - BLOCK Ba	Ba Block	Internal	Level 1	CAMPUS STORE	6 X MAZDA GASKET 6 X HEAD GASKET KITS ON SHELVING - PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Confirmed	69	-	Advised by DET 16/07/2019 Items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25022019	BA - BLOCK Ba	Ba Block	External	Ground Floor	EXTERNAL	SHEET TO CONC WALL USED TANKING COMPAWALK LEVEL SE	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25022019	BA - BLOCK Ba	Ba Block	Internal	Level 1	CLASSROOM	SPRAYED CEILING TO CLASSROOM	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25022019	BA - BLOCK Ba	Ba Block	Internal	Level 1	CLASSROOM	SPRAYED CEILING TO CLASSROOM	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25022019	BA - BLOCK Ba	Ba Block	Internal	Level 1	CHEMICAL STORE	UNABLE TO ACCESS CHEMICAL STORE TO IDENTIFY ANY POSSIBLE ASBESTOS CONTAINING MATERIAL	Stored Material	Other (refer to description)		3	Presumed		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25022019	BA - BLOCK Ba	Ba Block	Internal	Level 1	CORRIDOR	INFILL PANEL ABOVE DOOR TO WORKSHOP IN CORRIDOR BETWEEN WORKSHOPS. SIM SAMPLE 1746	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25022019	BA - BLOCK Ba	Ba Block	Internal	Level 1	CENTRE OF NORTHERN FACING WALL	SHEET VINYL	Floor Finish/Covering	Vinyl Sheeting (includes ballistics)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	

TAFes from BEHMR-TAFes

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	STORE ROOM	UNABLE TO ACCESS SEE CHR STOREROOM TO IDENTIFY ANY POSSIBLE ASBESTOS CONTAINING MATERIALS	Stored Material	Other (refer to description)		3	Presumed		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	CAMPUS STORE	FIRE DOORS TO CAMPUS STORE REFER SAMPLE 1751 - CHR & AMO	Fire Door	Milboard	Mixed	4	Confirmed	64	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	CAMPUS STORE	BEIGE COLOURED FLOOR TILES TO CAMPUS STORE REFER SAMPLE 1748 - CHR	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	CLEANERS STORE	CEILING PANELS TO CLEANERS STORE SIM SAMPLE 1746 - CHR	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	CAMPUS STORE	6 X DRAWS IN SHELVING SYSTEM CONTAINING EXHAUST GASKETS - PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Confirmed	69	-	Advised by DET 16/07/2019 Items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	CAMPUS STORE	1 X SET BRAKE SHOES TO LIFT MOTOR LOCATED PLANT RM	Plant, Equipment & Machinery	Polymer Bound		3	Presumed	25	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	External	Various levels	FASCIA	FASCIA BOARD AROUND PERIMETER OF BUILDING	Gables/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	External	Various levels	EXTERNAL	SPRAYED GRANISITE AFFIXED EXTERNAL SURFACES BLDG	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	External	Various levels	EXTERNAL	SHEETING TO SOFFITS ON SOUTH NORTH EASTERN ELEVATION	Gables/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	External	Various levels	EXTERNAL	SHEETING BEHIND DECOR FINISH TO WALL EXTERNAL BLDG	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	External	Roof Level 1	EXTERNAL	WALL SHEETING TO THE ATRIUM ON THE ROOF	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	External	Roof Level 1	EXTERNAL	SOFFIT SHEETING TO THE ATRIUM ON THE ROOF	Gables/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	External	Roof Level 1	EXTERNAL	ADHESIVE BITUMEN TO CONCRETE FLOOR SLABS ON ROOF SURFACE SIM SAMPLE 1739 - NAD	Floor	Polymer Bound		4	Presumed	25	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	External	Level 1	WALKWAY	FASCIA BOARD - LOCATED AT ENTRY TO B BLOCK ON L1 SIM SAMPLE 1746 - CHR	Gables/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	External	Level 1	WELDERS W/SHOP	FASCIA BOARD TO WELDERS WORKSHOP	Gables/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 4	ROOM 4.7A	LINING TO INSIDE OF 7 WORK AND TEST BENCHES	Furniture	Milboard	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM 2-6	BEIGE COLOURED FLOOR TILES TO ROOM 2-6 REFER SAMPLE 1748 - CHR	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM 2-6	COMPRESSED SHEET TO WINDOW SILL IN ROOM 2-6 SIMILAR SAMPLE 1749 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM 2	WALL PANELS TO ROOM 2-6 SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM B2-09	WALL PANELS TO ROOM B2-09 SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM B2-11	WALL PANELS TO ROOM B2-11 SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 3	CORRIDOR	COMPRESSED SHEET TO WINDOW SILL AT WEST END OF CORRIDOR	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 3	M & F TOILETS	WALL PANELS TO MALE & FEMALE TOILETS SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 3	MALE SHOWER	COMPRESSED SHEET TO SEATS OF MALE SHOWER CHANGE AREA SIMILAR SAMPLE 1749 - CHR	Furniture	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 3	ROOM 3-3 TO 3-5	CREAM/YELLOW COLOURED FLOOR TILES TO ROOMS 3-3 TO 3-5	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 3	THROUGHOUT	BEIGE COLOURED FLOOR TILES THROUGHOUT INCL. STAIRWELLS & LANDINGS. REFER SAMPLE 1748	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 3	THROUGHOUT	WALL PANELS TO ROOMS 3-1 2 3 3 4 5 6 7 8 9 10 & WEST END ENTRY. SIM SAMPLE 1748 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 4	FOYER	SHEETING TO WINDOW SILLS IN THE LIFT ENTRY FOYER	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM 2-5A	WALL PANELS TO ROOM 2-5A SIM SAMPLE 1745 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 4	MALE & FEMALE TOILETS	WALL SHEETING IN MALE FEMALE TOILET BEHIND WALL TILES	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM B2-09	BEIGE COLOURED FLOOR TILES IN ROOM B2-09 REFER SAMPLE 1748 - CHR	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 4	ROOM 4.7B	1 X MERCURY TRANSFORMER ON SHELVING BACK OF ROOM - PORTABLE ITEM	Plant, Equipment & Machinery	Woven Textile	CHR - Chrysotile	2	Confirmed	69	-	Advised by DET 16/07/2019 Items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 4	ROOM 4.7B	LINING TO FIVE (5) WORK AND TEST BENCHES	Furniture	Milboard	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 4	ROOM 4.7B	MATERIAL ON WIRING ON WALL MOUNTED RESISTANCE STAR	Insulation/Fill	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 4	ROOM 4.7B	MATERIAL ON WIRING SECONDARY RESISTANCE STARTER STORED AGAINST THE EASTERN WALL - PORTABLE ITEM	Insulation/Fill	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 4	ROOM 4.7B	MATERIALS ON WIRING RESISTANCE STARTER NWALL	Insulation/Fill	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 4	THROUGHOUT	BEIGE COLOURED FLOOR TILES THROUGHOUT INCLUDING STAIRWELLS AND LANDINGS	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 4	THROUGHOUT	WALL PANELS TO ROOMS 4-2 3 4 5 6 7A 7B 8 11 12 13 16&21	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Various levels	ELECT RISER	WALL PANELS TO ELECTRICAL RISER ON WEST SIDE - FLOORS 1 2 3 & 4. SIM SAMPLE 1746	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Various levels	SERVICE RISER	TELECOM FIRE HOSE REEL & ELECT SERVICE RISER ON WEST SIDE OF FLOORS 1-4. SIM SAMPLE 1746	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Various levels	STAIRWELL EXITS	FIRE DOORS AT STAIRWELL EXITS EAST & WEST ENDS OF B BLOCK	Fire Door	Milboard	Mixed	3	Confirmed	64	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Various levels	STAIRWELLS & CORRIDORS	FLOOR TILES TO STAIRWELLS AT EAST AND WEST ENDS OF B BLOCK REFER SAMPLE 1748 - CHR	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	CORRIDOR	PARTITION WALL ADJACENT TO OLD WELDING AREA	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	SHEET METAL	SHEETING TO SOLDERING BENCH IN WORKSHOP	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 4	MALE & FEMALE SHOWERS	SHEETING TO THE MALE FEMALE SHOWER SEATS	Furniture	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	WELDING BAYS	SHEETING TO ALL 14 WELDING BAYS	Furniture	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	WORKSHOP	SPRAYED CEILING IN LRG WORKSHOP OSIDE 1.11,2C ROOMS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Est	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	WORKSHOP	SPRAYED CEILING IN LRG WORKSHOP OSIDE 1.11.2C ROOMS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM 2-4	WALL PANELS TO ROOM 2-4 SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	WORKSHOP	SPRAYED CEILING IN LRG WORKSHOP OSIDE 1.11.2C ROOMS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM B2-10	WALL PANELS TO ROOM B2-10 SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	WORKSHOP E END	FIRE DOORS TO WORKSHOP AT EAST END REFER SAMPLE 1751 - CHR & AMO	Fire Door	Millboard		3	Presumed	64	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	WELDING ROOM	SPRAYED CEILING TO WELDING ROOM WORKSHOP	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	WORKSHOP	SPRAYED CEILING IN LRG WORKSHOP OSIDE 1.11.2C ROOMS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	SHEET METAL	SPRAYED CEILING TO SHEET METAL ROOM	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	SERVICE DUCT	DUCT LINING TO PLUMBING SERVICE RISER	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	ROOM S6-02 TRANSFORMER	UNABLE TO ACCESS TRANSFORMER ROOM TO IDENTIFY ANY POSSIBLE ASBESTOS CONTAINING MATERIAL	Insulation/Fill	Other (refer to description)		3	Presumed		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	ROOM 1-3	INFILL PANEL ABOVE DOOR IN ROOM 1-3 SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	OXYGEN STORE	NO ACCESS TO OXYGEN STORE - LOCATED IN THE EAST END OF WORKSHOP ADJACENT TO SHED	Stored Material	Other (refer to description)		3	Presumed		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	CORRIDOR	WALL AND BULKHEAD PANELS TO FIRE DAMPER AREA	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	WET AREA WESTERN END OF BUILDING	VINYL TILES	Floor Finish/Covering	Vinyl Tiles	3	Confirmed	18	-		
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM 2-2	WALL PANELS TO ROOM 2-2 SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM 2-3	WALL PANELS TO ROOM 2-3 SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 1	WORKSHOP	CEILING THROUGHOUT WORKSHOP	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM 2-2A	WALL PANELS TO ROOM 2-2A SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ENTRY	INFILL PANEL ABOVE ENTRY DOOR TO B BLOCK SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM 2-13	WALL PANELS TO ROOM 2-13 SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM 2-12	WALL PANELS TO ROOM 2-12 SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM 2-05 STOREROOM	WALL PANELS TO STOREROOM 2-05 SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM 2-06	WALL PANELS TO ROOM 2-06 SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM 2-06	BEIGE COLOURED FLOOR TILES TO ROOM 2-05 REFER SAMPLE 1748 - CHR	Floor Finish/Covering	Vinyl Tiles	4	Presumed	18	-		
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	MALE TOILET	WALL PANELS TO MALE TOILET ALSO BEHIND CERAMIC WALL TILES SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	M & F TOILETS	COMPRESSED SHEET TO SEATING OF SHOWER AREAS- MALE & FEMALE BLOCKS- SIMILAR SAMPLE 1748-CHR	Furniture	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	FEMALE TOILET	WALL PANELS TO FEMALE TOILET ALSO BEHIND CERAMIC WALL TILES SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM 2-1 PRINT ROOM	WALL PANELS TO PRINT ROOM 2-1 SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGBA	25023019	BA - BLOCK Ba	Ba Block	Internal	Level 2	ROOM 2-3	BEIGE COLOURED FLOOR TILES TO ROOM 2-3 REFER SAMPLE 1748 - CHR	Floor Finish/Covering	Vinyl Tiles	4	Presumed	18	-		
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	Internal	Level 2	SERVICE RISER E	WALL PANELS TO SERVICE RISER EAST SIDE SIM SAMPLE 1740 - CHR	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	Internal	Level 1	ROOM F1-14	WALL PANELS TO ROOM F1-14 SIM SAMPLE 1744 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	Internal	Level 2	ADJ ROOM F2-17	WALL PANELS TO SERVICE RISER IN LIBRARY AREA ADJACENT ROOM F2-17; SIM SAMPLE 1740 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	Internal	Level 2	F2-04	HEATER BANK IN ROOM F2-04 REFER SAMPLE 1777 - NAD	Heater Bank Insulation	Millboard		4	Presumed	64	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	Internal	Level 2	F2-05	HEATER BANK IN ROOM F2-05 REFER SAMPLE 1777 - NAD	Heater Bank Insulation	Millboard		4	Presumed	64	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	Internal	Level 2	F2-06A	HEATER BANK IN ROOM F2-06A REFER SAMPLE 1777 - NAD	Heater Bank Insulation	Millboard		4	Presumed	64	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	Internal	Level 2	F2-06B	HEATER BANK IN ROOM F2-06B REFER SAMPLE 1777 - NAD	Heater Bank Insulation	Millboard		4	Presumed	64	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	Internal	Level 2	F2-20 - RISER	HEATER BANKS - EDH6 EDH7A & EDH7B LOCATED WITHIN SERVICE RISER IN EAST CORNER OF F2-20	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	Internal	Level 2	ROOM F2-20	WALL PANELS TO ROOM F2-20 SIM SAMPLE 1740 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	Internal	Level 1	ADJ ROOM F1-08	WALL PANELS IN WOODWORK AREA EASTERN CORNER ADJACENT ROOM F1-08; SIM SAMPLE 1740 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	Internal	Level 1	ROOM F1-12 CLEANERS	WALL PANELS TO CLEANERS ROOM F1-12 SIM SAMPLE 1744 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	Internal	Level 2	RISER								-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	External	Level 2	EXTERNAL	WALL SHEETING ABOVE WINDOWS BULKHEADS THROUGHOUT	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	External	Level 1	EXTERNAL	WALL SHEETING TO THE LOADING DOCK AREA	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	Internal	Level 1	ROOM F1-03 ARTS & CRAFTS	WALL PANELS TO ARTS AND CRAFTS ROOM F1-03	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	External	Level 2	EXTERNAL	FASCIA BARGE TO THE PERIMETER OF THE BUILDING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	External	Level 2	EXTERNAL	SOFFIT SHEETING TO PERIMETER LIBRARY BULKHEADS	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	Internal	Level 1	CLEANERS ROOM	WALL LINING TO CUPBOARDS AND SOME DAMAGE AND DEBRIS	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	Internal	Level 1	F1-09 FEMALE TOILET	WALL PANELS BEHIND CERAMIC WALL TILES IN FEMALE TOILET F1-09; SIM SAMPLE 1744 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	Internal	Level 1	F1-10 MALE TOILET	WALL PANELS BEHIND CERAMIC WALL TILES IN MALE TOILET F1-10; SIM SAMPLE 1744 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	Internal	Level 1	F1-15 PLANT RM	HEATER BANKS - EDH1 EDH2 AND EDH3 IN PLANT ROOM F1-15	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25023017	FF - BLOCK F	F Block	Internal	Level 1	POTTERY AREA	COMPRESSED SHEET TO 18 TABLES EACH 25QM	Furniture	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	

TAFEs from BEMIR-TAFEs

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25022017	FF - BLOCK F	F Block	Internal	Level 1	ROOM F1-01 REAR	WALL PANELS TO REAR ENTRY OF ROOM F1-01 SIM SAMPLE 1740 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGFF	25022017	FF - BLOCK F	F Block	Internal	Level 1	CUPBOARD	WALL LINING TO FIRE HOSE REEL CUPBOARDS ON LEVELS 1 & 2	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	CHANGING ROOMS	WALL PANELS TO CHANGING ROOMS SIM SAMPLE 1757 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	CLEANERS ROOM	CEILING PANELS TO CLEANERS ROOM IN FEMALE TOILET	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	PATTERN MAKING 2	WALL PANELS TO PATTERN MAKING 2 SIM SAMPLE 1757 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	KITCHEN/STAFFRM	DARK BLUE VINYL FLOOR TILES TO KITCHEN/STAFFROOM	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	CORRIDOR	LIGHT GREY COLOURED SHEET VINYL FLOORING TO CORRIDOR	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	CORRIDOR	PLASTERBOARD WALLS TO CORRIDOR BETWEEN ROOMS G3-07 & G3-17. SIM SAMPLE 1757 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	CORRIDOR	WALL PANELS TO CORRIDOR SIM SAMPLE 1757 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	FASHION STORE	PARTITION WALLS TO FASHION STORE	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	FOYER/ADMIN	BEIGE COLOURED FLOOR TILES TO FOYER & FASHION ADMIN REFER SAMPLE 1748 - CHR	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	KITCHEN/STAFFRM	LIGHT BLUE VINYL FLOOR TILES TO KITCHEN/STAFFROOM	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	MACHINE ROOM 2	WALL PANELS TO MACHINE ROOM 2 SIM SAMPLE 1757 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	WORKSHOP & G2-24	SPRAYED UNDERSIDE OF CONCRETE CEILING SLAB - WORKSHOP & G2-24 ADJ CORRIDOR. REF. SAMPLE 1752	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	PATTERN MAKING 1	WALL PANELS TO PATTERN MAKING 1 SIM SAMPLE 1757 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	ROOM G2-19	COVER OVER GALENKAMP FURNACE COMPRESSED SHEET SIMILAR SAMPLE 1749 - CHR	Plant, Equipment & Machinery	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	PATTERN MAKING 3	PARTITION WALLS TO PATTERN MAKING 3 SIM SAMPLE 1757 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	ROOM G3-07	WALL PANELS TO ROOM G3-07 SIM SAMPLE 1757 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	ROOM G3-10	BEIGE COLOURED FLOOR TILES TO ROOM G3-10 REFER SAMPLE 1748 - CHR	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	ROOM G3-12	BEIGE COLOURED FLOOR TILES TO ROOM G3-13 REFER SAMPLE 1748 - CHR	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	ROOM G3-14	BEIGE COLOURED FLOOR TILES TO ROOM G3-14 REFER SAMPLE 1748 - CHR	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	SICKROOM/TOILETS	CEILING PANELS TO SICK ROOM M & F STAFF TOILETS N SIDE OF G BLOCK. SIM SAMPLE 1755-CHR	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Roof Level 1	PLANT ROOMS	SHEET INSTALLED BENEATH HOT WATER SERVICE	Floor	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 3	MACHINE ROOM 3	WALL PANELS TO MACHINE ROOM 3 - DOUBLE SIDED SIM SAMPLE 1757 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	NUMERICAL CONTROL WORKSHOP	VERMICULITE SPRAYED TO UNDERSIDE OF CONCRETE CEILING SLAB REFER SAMPLE 1752 - NAD	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Various levels Internal	PLANT ROOMS	FIRE EXITS TO E & W STAIRWELLS ALSO E & W PLANT ROOMS ON LEVEL R1. REFER SAMPLE 1751-CHR&AMO	Fire Door	Milboard	CHR - Chrysotile	4	Removed	64	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 1	ROOM G1-12	WRAPPED AROUND RADIATOR PIPE CLARK BORCAT 632	Plant, Equipment & Machinery	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 1	STORAGE AREA	UNABLE TO ACCESS STORAGE AREA UNDER COVERED AREA ADJACENT TO G1-08; 3 E CORNER OF BUILDING	Stored Material	Other (refer to description)		3	Presumed		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 1	STORAGE ROOM	CEILING PANELS TO STORAGE ROOM SIM SAMPLE 1755 - CHR	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	ARC WELDING	INSULATION TO BODY OF GAS FURNACE (OPEN TOP)	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	ARC WELDING	TEXTILE DOOR SEAL TO WELDING ROD OVEN	Plant, Equipment & Machinery	Woven Textile	CHR - Chrysotile	2	Confirmed	69	-	Advised by DET 18/07/2010 Items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	CORRIDOR	SPRAYED TO UNDERSIDE OF CONCRETE CEILING SLAB REFER SAMPLE 1752 - NAD	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	CORRIDOR	WALL LINING TO CORRIDOR ADJACENT TO ROOMS G2 05 - G2 07	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	CORRIDOR	WALL PANELS TO CORRIDOR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	ROOM G2-19	SHEETING TO THE TERMINAL STRIPE	Plant, Equipment & Machinery	Cement Based	CHR - Chrysotile	2	Confirmed	34	-	Advised by DET 18/07/2010 Items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	N/ CONTROL WORKSHOP	1 X SET BRAKE SHOES SHAFT CRYPTON ELECT TEST BENC	Plant, Equipment & Machinery	Polymer Bound		3	Presumed	25	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	WELDING BOOTHS	WALL PANELS TO WELDING BOOTHS - NORTH OF ROOM G2-12 SIM SAMPLE 1757 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	NUMERICAL CONTROL WORKSHOP	WALL PANELS TO NUMERICAL CONTROL WORKSHOP SIM SAMPLE 1757 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	ROOM G2.11	CEILING SHEETS TO WELDING BOOTHS IN ROOM G2.11	Ceiling	Calmet Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	ROOM G2.11	SHEETING TO 15 WELDING BOOTHS IN ROOM G2.11	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	ROOM G2.11	SHEETING TO THE OLD SOLDERING WORK BENCH	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	ROOM G2-03 MALE TOILET & CLEANERS STORE	CEILING PANELS TO MALE TOILET G2-03 & CLEANERS STORE ADJ TO TOILET. SIM SAMPLE 1758 -CHR	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	ROOM G2-07	BACKING TO SHEET VINYL FLOOR LIGHT GREY COLOUR - IN ROOM G2-07. SIM SAMPLE 1756 - NAD	Floor Backing/Underlay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	ROOM G2-08 & 12	BACKING TO SHEET VINYL FLOOR LIGHT GREY COLOUR - ROOMS G2-08 & 12. SIM SAMPLE 1756 NAD	Floor Backing/Underlay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	ROOM G2-19	INSULATION TO WIRING TO THE MARTIN FURNACE	Plant, Equipment & Machinery	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25022016	GG - BLOCK G	G Block	Internal	Level 2	WELDING BAYS	14 X WELDING BOOTH CEILINGS	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	

TAFEs from BEMIR-TAFEs

Current as at 10-May-11

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Est	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 2	WELDING BAYS	14 X WELDING BOOTHS HAVE COMPRESSED SHEETING	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 2	MAINT. OFFICE	CEILING PANELS TO MAINTENANCE OFFICE SIM SAMPLE 1755 - CHR	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	ROOM G1-12	BRAKE PADS & CLUTCH PLATES STORED IN BROWNBUILD CUPBOARD & SHELVING THROUGHOUT G1-12 G1-13 PORTABLE	Stored Material	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	ROOM G1-06	MATERIALS INSIDE DOUBLE SET FIRE DOORS TO THE EASTERN ENTRY TO ROOM G1-06	Fire Door	Millboard	Mixed	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	ROOM G1-08	LIGHT GREY FLOOR TILES TO ROOM G1-9B REFER SAMPLE 1760 - NAD	Floor Finish/Covering	Vinyl Tiles	4	Presumed	18	-		
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	ROOM G1-13	VERMICULITE COAT TO CEILING OPEN AREA NOT CROOMS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	ROOM G1-13	VERMICULITE COAT TO CEILING OPEN AREA NOT CROOMS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	ROOM G1-13	VERMICULITE COAT TO CEILING OPEN AREA NOT CROOMS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	ROOM G1-13	VERMICULITE COAT TO CEILING OPEN AREA NOT CROOMS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	ROOM G1-13	SPRAYED ON UNDERSIDE OF CONCRETE CEILING SLAB TO G1-13 REFER SAMPLE 1752 - NAD	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	ROOM G1-10A	LIGHT GREY FLOOR TILES TO ROOM G1-10A	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	ROOM G1-08	WALL PANELS TO ROOM G1-08 SIM SAMPLE 1757 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	ROOM G1-07	WALL PANELS TO ROOM G1-07 - CONCEALED BY WOODEN PEG BOARD SIM SAMPLE 1757 - NAD	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	ROOM G1-06	SPRAYED ON UNDERSIDE OF CONCRETE CEILING SLAB IN G1-06 REFER SAMPLE 1752 - NAD	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	SERVICE TUNNEL	300 MM STORMWATER PIPE INSIDE SERVICE TUNNEL	Stormwater Plumbing	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	SERVICE TUNNEL	1 X BOX OF GASKETS FOR GATE VALVES PORTABLE ITEM	Stored Material	Millboard	CHR - Chrysotile	2	Confirmed	69	-	Advised by DET 16/07/2010 items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	ROOM G1-06	GASKET MATERIAL IN RM G1-06 SHELVE OUTSIDE ROOM G1-09 - PORTABLE ITEM	Stored Material	Millboard	CHR - Chrysotile	2	Confirmed	69	-	Advised by DET 16/07/2010 items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	ROOM G1-11	GASKET MATERIAL SHELIVING 4B IN STORE ROOM G1-11 SHELIVING 4B - PORTABLE ITEM	Stored Material	Millboard	CHR - Chrysotile	2	Confirmed	69	-	Advised by DET 16/07/2010 items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	ROOM G1-11	GASKET MATERIAL IN CARDBOARD BOX SHELIVING 4 B PORTABLE ITEM	Stored Material	Millboard	CHR - Chrysotile	2	Confirmed	69	-	Advised by DET 16/07/2010 items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	ROOM G1-07	GASKET STORED ABOVE SHELIVING IN ROOM G1-07 PORTABLE ITEM	Stored Material	Millboard	CHR - Chrysotile	2	Confirmed	69	-	Advised by DET 16/07/2010 items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	Internal	Level 1	MALE TOILET	WATER DAMAGED CEILING TILES, (NO ENTRY TO G1-03 & ELECTRICAL ROOM) SIM SAMPLE 1755 - CHR	Ceiling	Cement Based	CHR - Chrysotile	3	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	External	Various levels	EXTERNAL	FIBROULITE PIPE N SIDE & S SIDE OF BUILDING - EACH 37LM SIM SAMPLE 1743 - CHR & AMO	Drains/Pipes/Floor	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	External	Level 1	EXTERNAL	1 X D T SURROUND ON THE SOUTHERN ELEVATION	Drains/Pipes/Floor	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGG	25023016	GG - BLOCK G	G Block	External	Various levels	EXTERNAL	7 DOWNPIPES ON BOTH S & N SIDES OF BUILDING APPROX 7LM EACH PIPE	Drains/Pipes/Floor	Cement Based	Mixed	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH		H Block	H Block	External	Mezzanine 1	THEATRE EXTERNAL	FASCIA BOARD ABOVE THEATRE SIM SAMPLE 1746 - CHR	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH		H Block	H Block	Internal	Various levels	THEATRE INTERNAL	BACKING TO MEZZANINE SICK CLASSROOMS AND STAGE	Floor Backing/Underlay	Vinyl Sheeting (includes backing)	CHR - Chrysotile	4	Confirmed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH		H Block	H Block	Internal	Mezzanine 1	THEATRE PROJECTOR ROOM	BACKING TO FLOORING IN PROJECTOR ROOM SIM SAMPLE 1762 - NAD	Floor Backing/Underlay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH		H Block	H Block	Internal	Ground Floor	THEATRE ELECTRONIC & PNEUMATIC ROOM	SHEETING UNDER THE JEM HOT WATER UNIT	Floor	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH		H Block	H Block	External	Roof Level 1	THEATRE EXTERNAL	FASCIA BOARD INSTALLED TO NORTH SOUTH & EAST SIDES OF I BLOCK. SIM SAMPLE 1746-CHR	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH		H Block	H Block	External	Ground Floor	THEATRE EXTERNAL	WALL PANELS OUTSIDE THEATRE - W SIDE OF THEATRE IN WALKWAY PAINTED RED. SIM SAMPLE 1765	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH		H Block	H Block	Internal	Ground Floor	THEATRE	BACKING TO BROWN SHEET VINYL FLOORING TO THEATRE; INCLUDING FIRST AID ROOM	Floor Backing/Underlay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH	25023015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Internal	Level 2	MIDDLE CLASSROOM	WALL PANELS TO MIDDLE CLASS ROOM SIM SAMPLE 1763 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH	25023015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Internal	Level 2	MIDDLE CLASSROOM	BACKING TO BROWN SHEET VINYL FLOOR N MIDDLE CLASSROOM SIM SAMPLE 1762 - NAD	Floor Backing/Underlay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH	25023015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Internal	Roof Level 1	COOLING TOWER AREA	MATERIALS TO VIBR. BLK OF COOL TOWER FEEDER PIPES	Insulation/Fill	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH	25023015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Internal	Level 1	ROOM 2-9	BACKING MATERIAL TO BROWN SHEET VINYL FLOORING TO 2-9 SIM SAMPLE 1762 - NAD	Floor Backing/Underlay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH	25023015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	External	Level 1	EXTERNAL	WALL PANELS TO ROOM 2-4 - PAINTED RED SIM SAMPLE 1765 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH	25023015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	External	Level 1	EXTERNAL	WALL PANELS TO ROOM 2-2 - PAINTED RED SIM SAMPLE 1765 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH	25023015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Internal	Ground Floor	ROOM 2.2	1 X BOX CLUTCH PLATES HOUSING STORED IN GEAR BOX - PORTABLE ITEM	Stored Material	Polymer Bound	CHR - Chrysotile	2	Confirmed	39	-	Advised by DET 16/07/2010 items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH	25023015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Internal	Ground Floor	ROOM 2.2 ENGINE TEST ROOM	SHEET LINED FUEL STORE INSIDE ENGINE TEST ROOM 2.2	Fire Door	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH	25023015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Internal	Level 1	ENGINE ROOM	GASKET MATERIAL IN ALL FOUR ENGINE EXHAUST PIPES	Gasket	Polymer Bound	CHR - Chrysotile	3	Confirmed	25	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH	25023015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Internal	Level 1	MOST ROOMS	WALL LINING ABOVE INTERNAL WINDOWS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH	25023015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Internal	Level 1	ROOM 3-10	BACKING MATERIAL TO LIGHT GREY SHEET VINYL FLOORING TO 2-10 SIM SAMPLE 1760 - NAD	Floor Backing/Underlay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH	25023015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Internal	Level 1	ROOM 3-2	BACKING MATERIAL TO BROWN SHEET VINYL FLOORING TO 2-2 SIM SAMPLE 1762 - NAD	Floor Backing/Underlay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH	25023015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Internal	Level 1	ROOM 3-6	BACKING MATERIAL TO LIGHT GREY SHEET VINYL FLOORING TO 2-6 SIM SAMPLE 1760 - NAD	Floor Backing/Underlay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGGH	25023015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Internal	Level 2	PLANT ROOM	VIBRATION AND INSULATION PADS TO PIPEWORK IN PLANT ROOM	Insulation/Fill	Woven Textile	CHR - Chrysotile	3	Removed	64	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Est	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGHH	25022015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Inter nal	Level 1	ROOM 2-8	BACKING MATERIAL TO BLUE SHEET VINYL FLOORING TO 2-8	Floor Backing/Under lay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGHH	25022015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Inter nal	Level 2	TRANSFORMER RM	WALL PANELS TO TRANSFORMER RM LOCATED OFF PLANT RM ON E SIDE OF H BLOCK. SIM SAMPLE 1763	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGHH	25022015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Inter nal	Level 1	WORKSHOP	WALL PANELS TO NORTH & SOUTH WALLS OF WORKSHOP SIM SAMPLE 1765 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGHH	25022015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Inter nal	Level 2	CLASSRM NW CNR	BACKING MATERIAL TO LIGHT GREY SHEET VINYL FLOORING TO NW CNR CLASSROOM. SIM SAMPLE 1760	Floor Backing/Under lay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGHH	25022015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Inter nal	Level 2	DIESEL ROOM	WALL PANELS TO DIESEL ROOM SIM SAMPLE 1763 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGHH	25022015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Inter nal	Level 2	ENGINE RECORD	BACKING MATERIAL TO BROWN SHEET VINYL FLOORING IN ENGINE RECORD ROOM. SIM SAMPLE 1762	Floor Backing/Under lay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGHH	25022015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Inter nal	Level 2	ENGINE RECORD	WALL PANELS TO ENGINE RECORD ROOM	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGHH	25022015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Inter nal	Level 2	ENGINE RECORD	WALL PANELS TO S & N SIDES OF ENGINE RECORD ROOM BELOW WINDOWS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGHH	25022015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Inter nal	Level 2	LANDINGS	WALL PANELS INSTALLED TO E & W ENTRY POINTS TO LANDINGS SIM SAMPLE 1765 - CHR	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGHH	25022015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Exter nal	Various levels External	EXTERNAL	FASCIA BOARD TO NORTH SOUTH & WEST SIDES OF BUILDING SIM SAMPLE 1745 - CHR	Gable/Soffit/ascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGHH	25022015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Inter nal	Level 2	PLANT ROOM	1 HALF & 1 3/4 FIRE DOOR AND 3 FULL DOORS AT E END OF PLANT ROOM. REFER SAMPLE 1751-CHRSAM	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Removed	-	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGHH	25022015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Inter nal	Level 2	PLANT ROOM	WALL PANELS TO PLANT ROOM LOCATED E END OF H BLOCK ON N & W WALLS. SIM SAMPLE 1763	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGHH	25022015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Inter nal	Level 1	ROOM 2-7	BACKING MATERIAL TO LIGHT GREY SHEET VINYL FLOORING TO 2-7 SIM SAMPLE 1760 - NAD	Floor Backing/Under lay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGHH	25022015	HH - BLOCK H - ENGINE RECONSTRUCTION	ENGINE RECONSTRUCTION	Inter nal	Level 2	PLANT ROOM	12 HEATERBANKS LOCATED IN PLANT ROOM	Heater Bank Insulation	Milboard	CHR - Chrysotile	3	Removed	64	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGJA	25022008	JA - BLOCK Ja	Ja Block	Inter nal	Ground Floor	WESTERN STORE ROOM	2 X EASYFIT HEAD GASKET KITS IN BOX WEST STORE ROOM - PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Confirmed	69	-	Advised by DET 16/07/2010 items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGJA	25022008	JA - BLOCK Ja	Ja Block	Inter nal	Ground Floor	BOOKSHOP/TOILET BLOCK	NO ASBESTOS CONTAINING MATERIALS DETECTED IN BOOKSHOP/TOILETS BLOCK	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)	-	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGJA	25022008	JA - BLOCK Ja	Ja Block	Inter nal	Ground Floor	WESTERN STORE ROOM	4 X CARBURETOR GASKETS IN SMALL BROWNBUILD CUPBOARD - PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Confirmed	69	-	Advised by DET 16/07/2010 items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGJA	25022008	JA - BLOCK Ja	Ja Block	Inter nal	Ground Floor	WESTERN STORE ROOM	2 X ROLLS GREY BLACK GASKET MAT. ABOVE BROWNBUILD CUPBOARD - PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Confirmed	69	-	Advised by DET 16/07/2010 items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGJA	25022008	JA - BLOCK Ja	Ja Block	Inter nal	Ground Floor	WESTERN STORE ROOM	1 x ROLL GREEN GASKET MAT. ABOVE BROWNBUILD CRBD - PORTABLE ITEM	Stored Material	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)	-	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGJA	25022008	JA - BLOCK Ja	Ja Block	Inter nal	Ground Floor	ROOM 3-5	BACKING MATERIAL TO LIGHT GREY SHEET VINYL FLOORING TO 3-5 SIM SAMPLE 1760 - NAD	Floor Backing/Under lay	Vinyl Sheeting (includes backing)		4	Removed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGJA	25022008	JA - BLOCK Ja	Ja Block	Inter nal	Ground Floor	ROOM 3-4	UNABLE TO GAIN ACCESS TO ROOM 3-4 TO IDENTIFY ANY POSSIBLE ASBESTOS CONTAINING MATERIAL	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGJA	25022008	JA - BLOCK Ja	Ja Block	Inter nal	Ground Floor	ROOM 3-3	BACKING MATERIAL TO BROWN SHEET VINYL FLOORING TO 3-3 SIM SAMPLE 1762 - NAD	Floor Backing/Under lay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGJA	25022008	JA - BLOCK Ja	Ja Block	Inter nal	Ground Floor	M & F TOILETS	SOUTH WALL OF MALE TOILET & NORTH SIDE OF FEMALE TOILET	Wall	Cement Based	Mixed	4	Confirmed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGJA	25022008	JA - BLOCK Ja	Ja Block	Inter nal	Ground Floor	BOOK STORE	BACKING TO SHEETING IN BOOK STORE CLEANERS RM WEST	Floor Backing/Under lay	Milboard	CHR - Chrysotile	4	Confirmed	64	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGJA	25022008	JA - BLOCK Ja	Ja Block	Inter nal	Ground Floor	AUTO WORKSHOP	INFILL PANEL ABOVE CLASSROOMS 3-3 AND 3-4 SIM SAMPLE 1765 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGJA	25022008	JA - BLOCK Ja	Ja Block	Inter nal	Ground Floor	AUTO ELECTRONIC STORE	2 X WORKBENCHES INSIDE THE AUTO ELECTRONICS STORE ROOM	Furniture	Cement Based	CHR - Chrysotile	3	Removed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGJA	25022008	JA - BLOCK Ja	Ja Block	Inter nal	Ground Floor	AUTO ELEC WORKSHOP	WALL PANELS TO AUTO ELEC WORKSHOP SIM SAMPLE 1765 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGJA	25022008	JA - BLOCK Ja	Ja Block	Exter nal	Roof Level 1	EXTERNAL	FASCIA BOARD TO PERIMETER OF BUILDING SIM SAMPLE 1746 - CHR	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGJA	25022008	JA - BLOCK Ja	Ja Block	Exter nal	Roof Level 1	EXTERNAL	EXTERNAL FASCIA AND WALL PANELS (PAINTED RED) TO REAR OF THE WALKWAY	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGJA	25022008	JA - BLOCK Ja	Ja Block	Inter nal	Ground Floor	HOIST WORKSHOP	INFILL PANELS ABOVE CLASSROOMS 3-6 3-5 & ON NORTH WALL ABOVE TYRE BALANCE. SIM SAMPLE 1765	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGJA	25022008	JA - BLOCK Ja	Ja Block	Inter nal	Ground Floor	WESTERN STORE ROOM	2 X SMALL EXHAUST MANIFOLD GASKET ON SHELVEING - PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Confirmed	69	-	Advised by DET 16/07/2010 items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGJA	25022008	JA - BLOCK Ja	Ja Block	Exter nal	Ground Floor	EXTERNAL	EXTERNAL WALL EAST SIDE OF J-39E (PAINTED RED) SIM SAMPLE 1765 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25022011	LA - BLOCK La	La Block	Inter nal	Ground Floor	WORKSHOP AREA	1 X METAL EXPIE WITH TEXTILE LNK DETROIT DEMO	Plant, Equipment & Machinery	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25022011	LA - BLOCK La	La Block	Inter nal	Ground Floor	ROOM 4-5	BACKING MATERIAL TO LIGHT GREY SHEET VINYL FLOORING TO 4-5 SIM SAMPLE 1760 - NAD	Floor Backing/Under lay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25022011	LA - BLOCK La	La Block	Inter nal	Ground Floor	ROOM 4-7	BACKING MATERIAL TO BROWN SHEET VINYL FLOORING TO 4-7 SIM SAMPLE 1762 - NAD	Floor Backing/Under lay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25022011	LA - BLOCK La	La Block	Inter nal	Ground Floor	ROOM 4-9	BACKING MATERIAL TO BROWN SHEET VINYL FLOORING TO 4-9 SIM SAMPLE 1762 - NAD	Floor Backing/Under lay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25022011	LA - BLOCK La	La Block	Inter nal	Ground Floor	ROOM L4-1	WALL PANELS TO SOUTH SIDE OF ROOM L4-1 SOUTH EAST CORNER SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25022011	LA - BLOCK La	La Block	Inter nal	Ground Floor	WORKSHOP	1 X BOX EXHAUST GASKET BOTTOM SHELVEING BROWNBUILD - PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Confirmed	69	-	Advised by DET 16/07/2010 items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25022011	LA - BLOCK La	La Block	Inter nal	Ground Floor	WORKSHOP	CLUTCH PLATES & PRESSURE PLATES IN THIS AREA OUTSIDE ROOM 4-4 - PORTABLE ITEM	Stored Material	Polymer Bound		3	Presumed	25	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25022011	LA - BLOCK La	La Block	Inter nal	Ground Floor	WORKSHOP	EXHAUST MANIFOLD DISPLAY BOARD BESIDE THE SHELVEING IN THE WORKSHOP - PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Confirmed	69	-	Advised by DET 16/07/2010 items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25022011	LA - BLOCK La	La Block	Inter nal	Ground Floor	WORKSHOP AREA	1 X CLUTCH PLATE & HOUSING STUDENT DEMONSTRATION UNIT OUTSIDE THE CLASSROOM - PORTABLE ITEM	Stored Material	Polymer Bound		3	Presumed	25	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25022011	LA - BLOCK La	La Block	Inter nal	Ground Floor	WORKSHOP AREA	MATERIAL STORED IN A CARDBOARD BOX OUT SIDE RM 4-1 - PORTABLE ITEM	Stored Material	Polymer Bound	CHR - Chrysotile	3	Confirmed	25	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25022011	LA - BLOCK La	La Block	Inter nal	Ground Floor	ROOM 4-4	BACKING TO BROWN SHEET VINYL FLOORING TO 4-4 SIM SAMPLE 1762 - NAD	Floor Backing/Under lay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25022011	LA - BLOCK La	La Block	Inter nal	Ground Floor	OPEN STORE ROOM	CLUTCH PLATES ON PEG BOARD STUDENT DISPLAY MOBILE - PORTABLE ITEM	Stored Material	Polymer Bound	CHR - Chrysotile	2	Confirmed	39	-	Advised by DET 16/07/2010 items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25022011	LA - BLOCK La	La Block	Inter nal	Ground Floor	WORKSHOP	GASKETS IN BLUE CUPBOARD IN WORKSHOP LOTS OF GASKETS - PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Confirmed	69	-	Advised by DET 16/07/2010 items kept for Teaching/Display purposes.

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int-Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEIRP Score	Attention Required	Comments
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25023011	LA - BLOCK La	La Block	Internal	Ground Floor	OPEN STORE ROOM	POSSIBLE BRAKE PADS CLUTCH PLATES IN PALLETES IN THIS AREA & STUDENT DISPLAY AXLES - PORTABLE ITEM	Stored Material	Polymer Bound		3	Presumed	25	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25023011	LA - BLOCK La	La Block	External	Ground Floor	EXTERNAL	EAST WALL OF ROOM L4-1 - PAINTED RED ON EXTERNAL SURFACE. SIM SAMPLE 1785	Wall	Cement Based		4	Presumed	18	-	
		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25023011	LA - BLOCK La	La Block	External	Ground Floor	EXTERNAL	WALL LINING ABOVE INTERNAL WINDOWS TO RMS 4-8&9 (N SIDE OF L4-1) SIM SAMPLE 1746-CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25023011	LA - BLOCK La	La Block	External	Roof Level 1	EXTERNAL	FASCIA BOARD TO PERIMETER OF BLOCK L SIM SAMPLE 1746 - CHR	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25023011	LA - BLOCK La	La Block	Internal	Ground Floor	PIT BAY	1 X METAL FLEXIBLE EXHAUST PIPE WITH TEXTILE INSIDE EACH LINK - PORTABLE ITEM	Stored Material	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25023011	LA - BLOCK La	La Block	Internal	Ground Floor	ADMIN KITCHEN	BACKING MATERIAL TO BROWN SHEET VINYL FLOORING TO ADMIN KITCHEN. SIM SAMPLE 1782-NAD	Floor Backing/Under lay	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25023011	LA - BLOCK La	La Block	Internal	Ground Floor	ROOM 4-2 TRUCK WORKSHOP	WALL PANELS ON SOUTHERN WALL BETWEEN SETS OF ROLLER DOORS SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25023011	LA - BLOCK La	La Block	Internal	Ground Floor	PIT BAY	POSSIBLE DUST RESIDUE ON THE FLOOR WORK BENCH AREA	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)	-	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25023011	LA - BLOCK La	La Block	Internal	Ground Floor	ROOM 4.5 CLASSROOM	BRAKE PADS CLUTCH PLATES IN CLASSROOM 4.5 - PORTABLE ITEM	Stored Material	Polymer Bound		3	Presumed	25	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25023011	LA - BLOCK La	La Block	Internal	Ground Floor	ROOM 4.6 STORE ROOM	2 X CLUTCH PLATES PRESSURE PLATES STORED IN ROOM 4.6 - PORTABLE ITEM	Stored Material	Polymer Bound	CHR - Chrysotile	2	Confirmed	39	-	Advised by DET 16/07/2010 items kept for Teaching/Display purposes.
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25023011	LA - BLOCK La	La Block	Internal	Ground Floor	ROOM 4-2 TRUCK WORKSHOP	WALL PANELS ABOVE INTERNAL WINDOWS TO ROOMS 4-7 & 4-8 SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25023011	LA - BLOCK La	La Block	Internal	Ground Floor	ROOM 4-2 TRUCK WORKSHOP	WALL PANELS ABOVE ROOMS 4-6 4-5 & 4.4 SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGLA	25023011	LA - BLOCK La	La Block	Internal	Ground Floor	ROOM 4-2 TRUCK WORKSHOP	WALL PANELS OF ROOM 4-2 SOUTH EAST CORNER - TRUCK WORKSHOP SIM SAMPLE 1746 - CHR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	External	Ground Floor	EXTERNAL	CREAM PAINTED FFC INFILL PANELS BELOW WINDOWS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Removed	-	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	External	Ground Floor	EXTERNAL	SHEET TACKING TO THE TOILET SECTION OF BLOCK M	Wall	Cement Based	CHR - Chrysotile	3	Removed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	CLEANERS CPBRD	UNABLE TO ACCESS CLEANERS CUPOBOARD/ROOM TO IDENTIFY ANY POSSIBLE ASBESTOS CONTAINING MATERIALS	Baffles/Lining	Other (refer to description)	3	Removed	-	-		
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Lower Ground 1	AUTO LIGHT/TOILETS BRICKLAYING	INFILL PANEL TO STAIRWELL ENTRY TO LOWER GROUND FLOOR SIM SAMPLE 1783 - NAD	Wall	Cement Based		4	Removed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Various Internal	WORKSHOP	GASKET ON EXHAUST MUFFLERS ABOVE ENGINE ROOM	Gasket	Milboard	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	External	Roof Level 1	AUTO LIGHT/TOILETS EXTERNAL	FASCIA BOARD TO PERIMETER OF BLOCK SIM SAMPLE 1768 - CHR	Gable/Soffit/Fascia	Cement Based		4	Removed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Lower Ground 1	AUTO LIGHT/TOILETS BRICKLAYING	UNABLE TO ACCESS STORAGE AREA BENEATH STAIRS TO IDENTIFY ANY POSSIBLE ASBESTOS MATERIALS	Stored Material	Other (refer to description)	3	Removed	-	-		
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	External	Roof Level 1	EXTERNAL	FASCIA BOARD TO PERIMETER OF BLOCK	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	WORKSHOP ADJ 5-8	WALL PANELS INSTALLED TO SOUTH AND WEST WALLS OF WORKSHOP ADJACENT TO ROOM 5.8	Wall	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	STORE ROOM	5 X PKTS AUTOMOTIVE GASKET IN SHELVEING EASTERN END STORE ROOM - PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	4	Removed	64	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	ROOM 5-9 WORKSHOP	WALL PANELS INSTALLED TO S E & W WALLS OF WORKSHOP REFER SAMPLE 1789 - CHR	Wall	Cement Based		4	Removed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	ROOM 5-7	BACKING MATERIAL TO GREY SHEET VINYL FLOORING TO ROOM 5-7	Floor Backing/Under lay	Other (refer to description)	No asbestos detected (NAD)	4	Removed	-	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	ROOM 5-5	BACKING MATERIAL TO GREY SHEET VINYL FLOORING TO 5-5 REFER SAMPLE 1770 - NAD	Floor Backing/Under lay	Polymer Bound		4	Removed	25	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	ROOM 5-4	BACKING MATERIAL TO GREY SHEET VINYL FLOORING TO 5-4 REFER SAMPLE 1770 - NAD	Floor Backing/Under lay	Polymer Bound		4	Removed	25	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	ROOM 5-3	BACKING MATERIAL TO GREY SHEET VINYL FLOORING TO 5-3 REFER SAMPLE 1770 - NAD	Floor Backing/Under lay	Polymer Bound		4	Removed	25	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	ROOM 5-2	BACKING MATERIAL TO LIGHT BLUE SHEET VINYL FLOORING TO 5-2	Floor Backing/Under lay	Other (refer to description)	No asbestos detected (NAD)	4	Removed	-	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	ROOM 5-10 WORKSHOP	WALL PANELS INSTALLED TO S E & W WALLS OF WORKSHOP REFER SAMPLE 1789 - CHR	Wall	Cement Based		4	Removed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	ROOM 5.6	1 X ROLL GASKET MATERIAL STORED IN CANE BASKET IN ROOM 5.6 - PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Lower Ground 1	AUTO LIGHT/TOILETS BRICKLAYING	WALL PANELS TO BRICKLAYING AREA SIM SAMPLE 1783 - NAD	Wall	Cement Based		4	Removed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	MALE TOILET	PARTITION WALLS BETWEEN TOILET CUBICLES & ALSO TO DOOR JAM OF SHOWERS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Removed	-	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	ROOM 5.10	EXHAUST PIPE GASKET ON OLD EXHAUST PIPE STORED ON BENCH IN THE WORKSHOP AREA - PORTABLE ITEM	Stored Material	Other (refer to description)	No asbestos detected (NAD)	2	Removed	-	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	ROOM 5-1 & 5-2	EAST WALL OF WORKSHOP ADJ ROOM 5-1 REFER SAMPLE 1785 - CHR	Wall	Cement Based		4	Removed	18	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	ROOM 5.6	1 X BOX FULL OF BRAKE PADS & SHOES STORE IN THE SHELVEING - PORTABLE ITEM	Stored Material	Polymer Bound	CHR - Chrysotile	3	Removed	25	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	ROOM 5.6	1 X ROLL GASKET STORED SHELVEING OF ROOM 5.6 - PORTABLE ITEM	Stored Material	Milboard	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	ROOM 5.6	FLEXIBLE EXHAUST PIPE TO COMPUTER DETROIT MTR DIES	Plant, Equipment & Machinery	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	ROOM 5.8	FLEXIBLE EXHAUST HOSE OVER THE V8 DETROIT ENGINE	Plant, Equipment & Machinery	Woven Textile		2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	ROOM 5.8	FLEXIBLE EXHAUST PIPE LINKS FROM 6 CYLINDER CUMMIN	Plant, Equipment & Machinery	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	ROOM 5.8	GASKET TO WASTE OF THE TURBINE ON THE DIESEL MOTOR	Gasket	Milboard	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	ROOM 5.8	TEXTILE EXHAUST TO DETROIT MOTOR	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	4	Removed	-	-	
Metropolitan South		MOUNT GRAVATT TAFE CAMPUS	MOUNT GRAVATT TAFE CAMPUS	GMGMA	25023010	MA - BLOCK Ma	Ma Block	Internal	Ground Floor	ROOM 5.3	APPROXIMATELY 5 CLUTCH PLATES STORED IN ROOM 5.3 - PORTABLE ITEM	Stored Material	Other (refer to description)	No asbestos detected (NAD)	3	Removed	-	-	
Metropolitan South		SPRINGWOOD ROAD TAFE ANNEX	SPRINGWOOD ROAD TAFE ANNEX	GSS	35104000	** Site - Grounds	** Site - Grounds										-	-	
Metropolitan South		SPRINGWOOD ROAD TAFE ANNEX	SPRINGWOOD ROAD TAFE ANNEX	GSSAA	35104001	A Block	A Block										-	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	25635001	25635001	COVERED LINKS	COVERED LINKS										-	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	25635002	25635002	PLUMBERS STORE	PLUMBERS STORE		Ground Floor	Room description not provided	NO ASBESTOS DETECTED	Wall			4	Not Present(Not Tested)	-	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	25635003	25636003	PLMBS PRAC PLATFRM	PLMBS PRAC PLATFRM										-	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	25635020	25635020	DRAINERS AREA	DRAINERS AREA	###		Room description not provided	BESSER BLK WALLS, IRON ROOF, TIMBER PARTITIONS, I BEAM RF SUPPORTS (NO ACCESS TO FURN AREA)					Presumed	-	-	

TAFES from BEIR-TAFES

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	GVR	25635000	** Site - Grounds	** Site - Grounds	Site / Grounds	EXTERNAL		1 X PMG TELECOMMUNICATION PIT AT THE BOTTOM OF THE RAMP WALKWAY TO BLOCK G	Drains/Pipes/Floors	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	GVR	25635000	** Site - Grounds	** Site - Grounds	Site / Grounds	EXTERNAL		1 X TELECOMMUNICATION PIT ON THE WESTERN SIDE OF THE BRICK LAYING BLOCK F	Drains/Pipes/Floors	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	GVR	25635000	** Site - Grounds	** Site - Grounds	Site / Grounds	EXTERNAL		1 X PMG TELECOMMUNICATIONS PIT ON THE WESTERN SIDE OF BLOCK B UNDER THE BENCH SEATING	Drains/Pipes/Floors	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	GVR	25635000	** Site - Grounds	** Site - Grounds	Site / Grounds	EXTERNAL		1 X PM6 TELECOMMUNICATIONS PIT AT THE WESTERN SIDE OF THE MOULDING BLOCK E	Drains/Pipes/Floors	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	GVR	25635000	** Site - Grounds	** Site - Grounds	Site / Grounds	EXTERNAL		1 X PMG TELECOMMUNICATIONS PIT OUTSIDE THE STAFFROOM OF BLOCK F	Drains/Pipes/Floors	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYR01		Painting Portal Frame	Painting Portal Frame												
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYR02	25635023	Plumbing Practical	Plumbing Practical		Ground Floor	Room description not provided	ALL BESSER BLOCK STRUCTURE WITH AN IRON ROOF					Presumed			
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYR03		Hort - Greenhouse 1	Hort - Greenhouse 1												
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYR04		Hort - Greenhouse 2	Hort - Greenhouse 2												
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYR05		Hort - Greenhouse 3	Hort - Greenhouse 3												
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYR06		Hort - Shed	Hort - Shed												
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYR07	25635022	Hort - Chemical Store	Hort - Chemical Store		###	Room description not provided	BUILT POST 1990 ALL METAL STRUCTURE					Presumed			
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYR08	25635015	Flammable Store	Flammable Store		Ground Floor	Room description not provided	NO ASBESTOS DETECTED	Wall			4	Not Present(Not Tested)			
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYR09	25635019	Grounds/Maintenance	Grounds/Maintenance		Ground Floor	EXTERNAL	BUILT POST 1990 ALL METAL CONSTRUCTION					Presumed			
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYR10	25635024	Painting Portal Frame	Painting Portal Frame	###		Room description not provided	BUILT POST 1990					Presumed			
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRAA	25635014	A Block	A Block	Internal	Level 2	INTERNAL CEILING	VERMICULITE SPRAYED CEILING - LEVEL 02 (SECOND FLOOR) - A BLOCK	Ceiling	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Not Tested)			
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRAA	25635014	A Block	A Block	Internal	Level 3	ROOM A3.13	VINYL FLOOR TILES UNDER THE CARPET TO ROOM A3.13	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRAA	25635014	A Block	A Block	Internal	Level 2	INTERNAL CEILING	VERMICULITE SPRAYED CEILING - LEVEL 02 (FIRST FLOOR) - BLOCK A	Ceiling	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Not Tested)			
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRAA	25635014	A Block	A Block	Internal	Level 1	ROOM A2.13	VINYL TILES UNDER CARPET UNDER CARPET IN ROOM A2.13	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	1	Confirmed	93	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRAA	25635014	A Block	A Block	Internal	Level 1	PLANT ROOM	VINYL FLOOR TILES ON WALL IN PLANT ROOM NO. A1.02	Wall	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)			
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRAA	25635014	A Block	A Block	Internal	Level 1	PLANT ROOM	PERFORATED WALL PANELS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)			
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRAA	25635014	A Block	A Block	Internal	Level 1	INTERNAL CEILING	VERMICULITE SPRAYED CEILING ON GROUND FLOOR	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)			
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRAA	25635014	A Block	A Block	Internal	Level 1	ROOM A2.14	VINYL TILES UNDER CARPET UNDER CARPET IN ROOM A2.14	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	1	Confirmed	60	-	VINYL TILES ARE BROKEN/LIFTING - DIRECT STICK TO CONCRETE
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRAA	25635014	A Block	A Block	Internal	Ground Floor	FOYER AND STAIRS	ADHESIVE (BLACK JACK) - BENEATH CERAMIC TILES (INCL STAIR LANDING BETWEEN GROUND AND LEVEL 01)	Floor Finish/Covering	Adhesive	No asbestos detected (NAD)	NA	Not Present(Not Tested)			
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRAA	25635014	A Block	A Block	Level 3	PLANT RM A3.12	VINYL FLOOR TILES TO THE ENTRY OF THE ROOF PLANT ROOM A3.12	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)				
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRAA	25635014	A Block	A Block	Level 2	ROOM A2.12	VINYL FLOOR TILES IN THE HOSE REEL CUPBOARD IN ROOM A2.12	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)				
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRAA	25635014	A Block	A Block	Level 2	ROOM A2.11	VINYL FLOOR TILES TO THE DATA CUPBOARD A2.11	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Presumed	16	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRAA	25635014	A Block	A Block	Level 2	ROOF PLANT RM	AC PERFORATED WALL SHEETING TO ROOF PLANT ROOM	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)				
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRAA	25635014	A Block	A Block	Level 2	EXTERNAL	AC SOFFIT SHEETS TO PERIMETER	Gable/Soffit/Roof	Cement Based		4	Presumed	18	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Level 3	B3.08	VINYL FLOOR TILES TO ROOM B3.08	Floor	Vinyl Tiles		4	Presumed	18	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Level 3	B3.08	TEXTILE INSULATION MATERIAL WRAPPED AROUND WIRING OF CAPASITOR USED FOR STUDENT DEMO	Stored Material	Woven Textile	CHR - Chrysotile	2	Removed	69	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Level 2	TOP FLOOR	PERFORATED CEILING SHEETS TO TOP FLOOR	Ceiling	Cement Based	Mixed	4	Confirmed	18	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Level 2	TOP FL VERANDAH	VINYL TILES TO VERANDAH FLOOR AND UNDER CARPET	Floor	Vinyl Tiles		4	Presumed	16	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Level 2	TOILET/B2.03	PERFORATED CEILING TILES TO MALE STAFF TOILETS AND LOCKER ROOM B2.03	Ceiling	Cement Based		4	Presumed	18	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Level 3	B3.6	VINYL FLOOR TILES TO ROOM B3.6	Floor	Vinyl Tiles		4	Presumed	18	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Level 2	ROOM B2.03	VINYL FLOOR TILES TO THE FLOOR AREA OF LOCKER ROOM B2.03	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)				
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Level 3	B3.7A	VINYL FLOOR TILES TO ROOM B3.7A	Floor	Vinyl Tiles		4	Presumed	18	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Level 2	OPEN AREA	AC CEILING TILES TO COMPLETE FLOOR OPEN AREA	Ceiling	Cement Based		4	Presumed	18	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Level 2	FEMALE TOILETS	PERFORATED CEILING TILES TO THE FEMALE STAFF TOILET ON LEVEL 2	Ceiling	Cement Based		4	Presumed	16	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Level 2	B205	VINYL FLOOR TILES TO RAISED FLOOR AREA	Floor	Vinyl Tiles		3	Presumed	18	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Level 1	ROOM B1.11	BACKING BOARD TO THE STUDENT DISPLAY OF A WORKING GAS ROOM HEATER IN ROOM B1.11	Furniture	Other (refer to description)	No asbestos detected (NAD)	1	Not Present(Not Tested)				
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Level 1	OFFICE	VINYL FLOOR TILES TO OFFICE	Floor	Vinyl Tiles		4	Presumed	18	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Level 2	ROOM B2.03	VINYL FLOOR TILES ON THE PART OF THE WALL TO LOCKER ROOM B2.03	Wall	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)				
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Internal	Level 1	GAS ROOM B1.1	AC CEILING SHEETS PERFORATED	Ceiling	Cement Based	Mixed	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Internal	Level 3	ROOM & CORRIDOR	AC CEILING TILES PERFORATED SIM TO SAMPLE 62565/10-06	Ceiling	Cement Based		3	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Internal	Level 3	B3.05	VINYL TILES	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	2	Confirmed	34	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Internal	Level 2	ROOM B2.1A	VINYL FLOOR TILES TO ROOM B2.1A	Floor	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Internal	Level 2	ROOM B2.1A	VINYL FLOOR TILES TO PART OF THE WALLS TO ROOM B2.1A	Wall	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Internal	Level 2	ROOM B2.1A	PERFORATED CEILING TILES TO ROOM B2.1A	Ceiling	Cement Based	Mixed	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Internal	Level 2	FIRE HOSE	AC WALL SHEETING	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)			
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Level 3	B3.6	PERFORATED CEILING SHEETS TO ROOM B3.6	Ceiling	Cement Based		4	Presumed	18	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Internal	Level 2	CLEANERS ROOM	VINYL FLOOR TILES TO THE SPLASHBACK TO THE CLEANERS SINK TO ROOM B2.13	Wall	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)			
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Internal	Level 3	ROOM B3.18 - CUPBOARD	3 STRIPS OF AC SHEETING STORED IN THE CUPBOARD - REMOVED BY O&V SERVICES AS REQUESTED BY AL NORMAN	Stored Material	Cement Based	Mixed	2	Removed	34	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Level 3	STORE ROOM	VINYL FLOOR TILES TO THE PARTS STORE ROOM OF ROOM B3.3	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)				
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Level 3	ROOM B3.3	ZELEMITE SWITCHBOARD BACKING MATERIAL TO A TRAINING AID ON THE SHELF IN ROOM B3.3	Stored Material	Polymer Board	CHR - Chrysotile	2	Removed	39	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Internal	Level 3	ROOM B3.08	VINYL TILES	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	2	Confirmed	34	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Level 3	PRACT STORE	VINYL FLOOR TILES TO THE PRAC STORE ROOM BETWEEN ROOMS B3.2 AND B3.3	Floor	Vinyl Tiles		4	Presumed	18	-		

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block		Level 3	PRAC STORE	COMPRESSED SHEETING TO BENCHTOPS & SPLASHBACKS TO PRAC STORE ROOM BETWEEN ROOM B3.2 & B3.3	Furniture	Other (refer to description)	No asbestos detected (NAD)	1	Not Present(Testing)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block		Level 3	EXTERNAL	AC SOFFIT SHEETING	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRBB	25635013	B Block	B Block	Internal	Level 2	CLEANERS ROOM	VINYL TILES TO CLEANERS STORE ROOM B2.13	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Testing)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 1	CEILING PANELS	AC CEILING TILES TO GROUND FLOOR	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Testing)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block	Internal	Level 1	HALL	VINYL TILES FLOORING, FEATURE PATTERN - BLACK IN THE HALL	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	3	Confirmed	43	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 3	CEILING	AC CEILING TILES TO LEVEL 3	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 3	CLEANERS CUPBOA	VINYL FLOOR TILES USED AS SPLASHBACK TO CLEANERS SINK EASTERN END OF THE PLUMBERS WORKSHOP	Wall	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 3	EXTERNAL	SOFFIT SHEETING/POSSIBLY MASONITE	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 3	FIRE HOSE CUPBO	WALL SHEETING TO THE FIRE HOSE REEL CUPBOARD	Wall	Other (refer to description)	No asbestos detected (NAD)	1	Not Present(Testing)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 3	POLISHING ROOM	VINYL FLOOR TILE SPLASHBACK TO THE WASH BASIN IN THE POLISHING ROOM	Wall	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Testing)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 3	POLISHING ROOM	VINYL FLOOR TILES UNDER THE OLD POLISHING AND BUFFING MACHINE STANDS	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Testing)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 3	SERVICE CUPBOARD	AC FLUE PIPE ABOVE THE HOT WATER UNITS IN THE SERVICE CUPBOARD IN THE SHEET METAL WORKSHOP	Drains/Pipes/Floors	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 3	SERVICE CUPBOARD	MASTIC SEAL TO THE FLUE PIPE JOINS IN THE SERVICE CUPBOARD IN THE SHEET METAL WORKSHOP	Drains/Pipes/Floors	Other (refer to description)	No asbestos detected (NAD)	1	Not Present(Testing)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 3	SERVICE CUPBOARD	TEXTILE ROPE INSULATION AROUND HOT WATER PIPE IN SERVICE CUPBOARD BESIDE ELECT CUPBOARD	Drains/Pipes/Floors	Woven Textile	CHR - Chrysotile	2	Removed	59	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 3	SHEETMETAL WRKS	CEILING TILES TO LEVEL 3 OF BLOCK C	Ceiling	Other (refer to description)	No asbestos detected (NAD)	1	Not Present(Testing)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 3	SHEETMETAL WRKS	VINYL FLOOR TILES SPLASHBACK TO EYE WASH STATION WESTERN END OF OPEN SHEET METAL WORKSHOP	Wall	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Testing)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Various levels External	WINDOWS	WINDOW PUTTY TO ALL EXTERNAL METAL FRAMED WINDOWS	Wall	Other (refer to description)	No asbestos detected (NAD)	1	Not Present(Testing)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block	Internal	Level 1	CEILING PANELS	PERFORATED CEILING TILES TO ROOMS C1.05 - C1.08	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Testing)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 1	ENTRY	AC SHEETING TO ENTRY PANEL EASTERN SIDE	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 2	LADIES TOILET	VINYL FLOOR TILES USED AS A SPLASHBACK TO THE LADIES TOILET WASH BASIN	Wall	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 1	MALE W.C	VINYL TILES TO MALE TOILET WALLS	Wall	Polymer Bound		3	Presumed	25	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 3	C3.04	VILLABOARD COVER SHEET ABOUT GAS GAUGES	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 1	WELDING BAYS	COMPRESSED AC WALL PANELS TO WELDING BAYS	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 2	CEILING TILES	AC CLG TILES TO STUDENT & STAFF MALE T.LT.REST OF FLR TILES HAVE BEEN REPLACED BY CLIENT	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 2	CLEANERS ROOM	VINYL FLOOR TILES USED AS A SPLASHBACK TO THE CLEANERS SINK	Wall	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block	Internal	Level 1	HALL	VINYL TILES - FEATURE PATTERN IS WHITE	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	NA	Not Present(Testing)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 2	FLOOR	VINYL FLOOR TILES TO CLASS ROOMS & HALLWAY & CLEANERS ROOM C2.1	Floor	Vinyl Tiles		2	Presumed	34	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block	Internal	Level 1	HALL	VINYL TILES FLOORING (COLOUR - SALMON) IN HALL	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	3	Confirmed	43	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block	Internal	Level 1	ROOM C.2.5	VINYL TILES (GREY & WHITE) FLOORING, SMALL AREA IN FRONT OF BLACKBOARD	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	3	Confirmed	43	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block	Internal	Level 1	ROOM C.2.5	GREEN AND WHITE VINYL TILES (MAIN AREA) DIRECT STICK TO CONCRETE	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	3	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block	Internal	Level 1	ROOM C.2.2	VINYL TILES (WHITE) FLOORING, SMALL AREA TO LEFT AND RIGHT HAND SIDES OF BLACKBOARD AREA	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	3	Confirmed	43	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block	Internal	Level 1	ROOM C.2.2	RED AND WHITE VINYL TILES DIRECT STICK TO CONCRETE	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	NA	Not Present(Not Tested)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block	Internal	Level 1	HALL	VINYL TILES FLOORING, FEATURE PATTERN - RED IN THE HALL	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	3	Confirmed	43	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block	Internal	Level 1	ROOM C.2.7	GREEN AND WHITE VINYL TILES DIRECT STICK TO CONCRETE	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	NA	Not Present(Testing)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Level 1	ELECT/GOUGING	VILLABOARD WALL SHEETING TO ELECTRICS ROOM, ART GOUGING ROOM & WORK AREA & LECTURE ROOMS	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block		Roof Level 1	EXTERNAL	AC FLUE PIPE THROUGH THE ROOF LEVEL NORTHERN SIDE OF BLOCK C	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block	Internal	Level 1	ROOM C.2.6	GREEN AND WHITE VINYL TILES DIRECT STICK TO CONCRETE	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	NA	Not Present(Testing)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block	Internal	Level 1	STORE ROOM	VINYL TILES FLOORING IN STOREROOM	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	NA	Not Present(Testing)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRCC	25635012	C Block	C Block	Internal	Level 3	BOOTH5 WELDING	COMPRESSED AC PARTITIONS TO WELDING BOOTHS (RM C3.04)	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Testing)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block		Various levels Internal	WALL COATING	VERMICULITE WALL COATING TO UPPER WALLS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Testing)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Internal	Ground Floor	CLEANERS ROOM	VINYL TILES	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Internal	Level 2	MALE/FEM TOILET	CEILING TILES TO THE MALE AND FEMALE TOILET ON LEVEL 2	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Internal	Ground Floor	STOREROOM	VINYL TILES	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Internal	Level 3	ROOM D310	VINYL TILES	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	2	Confirmed	34	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Internal	Level 1	TOILETS	AC CEILING TILES TO MALE AND FEMALE TOILETS	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block		Various levels Internal	STAIRWELL	VINYL FLOOR TILES TO STAIRWELLS - EAST & WEST END ENTRY FOYERS	Floor	Vinyl Tiles	CHR - Chrysotile	3	Confirmed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Est	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Internal	Level 3	FLOOR TILES	VINYL FL TILES TO CLASSRM & HWAY, TOILET AIRLOCK & D3.05, D3.11, D3.12 & CLEANERS	Floor	Vinyl Tiles		3	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Ground Floor	ENTRY	COMPRESSED AC SHEETING TO ENTRY		Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Level 1	EXTERNAL	1 X DT SURROUND ON THE NORTHERN SIDE OF BLOCK D		Drains/Pipes/Floors	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Level 3	ROOM D302	VINYL FLOOR TILES UNDER THE NEW SHEET VINYL IN ROOM D302		Floor	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Various levels External	WALL COATING	VERMICULITE WALL COATING TO UPPER WALLS		Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Various levels External	WALL COATING	VERMICULITE WALL COATING TO UPPER WALLS		Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Tested)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Level 3	ROOM D303	MILBOARD LINING TO THE VINYL BACKING UNDER THE CARPET TO THE COMPUTER ROOM D303		Floor	Milboard	CHR - Chrysotile	2	Confirmed	69	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Level 1	EXTERNAL	1 X DT SURROUND ON THE SOUTHERN SIDE OF BLOCK D		Drains/Pipes/Floors	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Level 3	ROOM 309A	2 X FW DAVEY & CO PTY LTD SWITCH WITH ZELEMITE BACKING ON THE DISPLAY BENCH IN ROOM D309A		Plant, Equipment & Machinery	Polymer Based	CHR - Chrysotile	2	Removed	39	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Level 3	ROOM 308&08A	VINYL FLOOR TILES UNDER THE NEW SHEET VINYL IN ROOM D308, D308A AND D309B		Floor	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Level 3	MALE TOILETS	CEILING TILES TO THE MALE TOILETS AND AIR LOCK ON LEVEL 3		Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Level 3	EXTERNAL	AC SOFFIT SHEETING		Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Level 2	ROOM D201	VINYL FLOOR TILES UNDER THE CARPET TO ROOM D201		Floor	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRDD	25635011	D Block	D Block	Level 1	FLOOR TILES	VINYL FLOOR TILES TO THE ENTRY PASSAGEWAY		Floor	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Level 1	SOFFIT	AC CEILING SHEETS INCLUDING THE ENTRY AWNING		Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Level 1	E15	AC CEILING TILES		Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Level 1	E16	VINYL FLOOR TILES TO ROOM E16		Floor	Vinyl Tiles	CHR - Chrysotile	3	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Level 1	E14	VINYL FLOOR TILES		Floor	Vinyl Tiles		3	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Level 1	E14	AC CEILING SHEET		Ceiling	Cement Based	Mixed	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Roof Level 1	ROOF	CORRUGATED ROOF SHEETING (REPLACE DURING CHRISTMAS BREAK ONLY)		Roof Sheeting	Cement Based		2	Removed	34	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Internal	Level 1	E15A	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles		3	Removed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Level 1	ROOF	2 X AC VENT PIPES		Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Internal	Level 1	E15A	AC CEILING SHEETS TO E15A STAFF SHOWER	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Level 1	OPEN WORK AREA	ZELEMITE OR MILBOARD IN A 'BIRLEX MAJOR' POWER PLANT		Insulation/Fill	Milboard		4	Removed	64	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Level 1	OPEN WORK AREA	ZELEMITE BACKING BOARD TO THE SWITCHBOARD		Insulation/Fill	Polymer Based		4	Presumed	25	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Level 1	OPEN WORK AREA	TEXTILE LAGGING AROUND COOLING WATER HOSES ON FURNACE		Plant, Equipment & Machinery	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Level 1	OPEN WORK AREA	POSSIBLE TEXTILE GASKETS AROUND THE 'CUPOLA' FURNACE		Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Tested)		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Level 1	OPEN WORK AREA	COMPRESSED AC SHEET AROUND THE FURNACE		Plant, Equipment & Machinery	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Level 1	OPEN WORK AREA	500 DEGREES CENTIGRADE CASTING OVEN DOOR SEAL		Plant, Equipment & Machinery	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Level 1	E203	'TILUX' SPLASHBACK		Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Level 1	E16	AC CEILING TILES IN ROOM E16 AND E16A		Ceiling	Cement Based	Mixed	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Internal	Level 1	E15A	AC CEILING TILES SIM TO SAMPLE 62965/10-14	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Internal	Level 1	E15A	AC WALL SHEETING TO ROOM E15A	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Level 1	OPEN WORK AREA	500 DEGREES CENTIGRADE CASTING OVEN (GASKET MATERIAL ON SIDE WALL OF UNIT)		Plant, Equipment & Machinery	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Internal	Level 1	ENTRY FOYERS	AC CEILING	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Level 1	OPEN AREA	CEILING TILES TO THE OPEN AREA OUTSIDE THE ROOM		Ceiling	Cement Based	Mixed	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Internal	Level 1	OPEN AREA	WALL PANELS ABOVE ROLLER SHUTTER DOOR	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Level 1	E12	AC CEILING SHEETS		Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYREE	25635010	E Block	E Block	Level 1	E13 TOILETS	AC CEILING SHEETS		Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRFF	25635009	F Block	F Block	External	Roof Level 1	EXTERNAL WORKSHOP AREA	DEBRIS TO GUTTERING, EXTERNAL WORKSHOP AREA	Stormwater Plumbing	Cement Based	Mixed	2	Removed	34	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRFF	25635009	F Block	F Block	Internal	Roof Level 1	INTERNAL WORKSHOP AREA	DEBRIS TO GUTTERING, INTERNAL WORKSHOP AREA	Stormwater Plumbing	Cement Based	Mixed	2	Removed	34	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRFF	25635009	F Block	F Block	External	Roof Level 1	ROOF	SUPER SIX ROOF SHEET	Roof Sheeting	Cement Based	CHR - Chrysotile	2	Removed	34	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRFF	25635009	F Block	F Block	External	Level 1	EXTERNAL	WALL SHEETING INFILL PANEL BETWEEN THE LOUVRES OUTSIDE THE STAFFROOM	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRFF	25635009	F Block	F Block	External	Level 1	EXTERNAL	AC SOFFIT SHEET	Gable/Soffit/ascia	Cement Based	Mixed	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRFF	25635009	F Block	F Block	External	Level 1	EXTERNAL	3 LM OF AC VENT PIPE ON THE SOUTH EASTERN CORNER OF THE TOILETS	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRFF	25635009	F Block	F Block	Ground Floor	TOILETS	VARIOUS LEVELS		Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRFF	25635009	F Block	F Block	Internal	Ground Floor	OPEN AREA	AC CEILING PANELS	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRGG	25635008	G Block	G Block	Level 1	LECTURE ROOM	VINYL FLOOR TILES TO ROOM D1.15		Floor	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRGG	25635008	G Block	G Block	Level 1	AIRCONDITION RM	INSULATION AROUND HEATING BAYS IN AIR CONDITION FOUND NOT TO CONTAIN ASBESTOS		Heater Bank Insulation	Other (refer to description)		4	Presumed		-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRGG	25635008	G Block	G Block	Level 1	CANTEEN	AC CEILING SHEETS		Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRGG	25635008	G Block	G Block	Level 1	CANTEEN	AC WALL SHEETING ABOVE STOVES		Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRGG	25635008	G Block	G Block	Level 1	CANTEEN	VINYL FLOOR TILES TO HALL		Floor	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRGG	25635008	G Block	G Block	Level 1	G1.09 & 11	AC CEILING SHEETINGS IN ROOMS G1.09 & G1.11 & HALL		Ceiling	Cement Based		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Cat	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRG	25635008	G Block	G Block		Level 3	PLANT ROOM	PART PERFORATED WALL SHEETING TO THE PLANT ROOM ON LEVEL 3	Wall	Other (refer to description)	No asbestos detected (NAD)	1	Not Present(Tested)	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRG	25635008	G Block	G Block	External	Level 1	EXTERNAL	SOFFIT SHEETING TO THE NORTHERN SIDE OF THE CANTEN	Gable/Soffit/ascia	Cement Based	Mixed	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRG	25635008	G Block	G Block	External	Level 1	EXTERNAL	FIRE DOOR TO THE FIRE ESCAPE ON LEVEL 1 OPPOSITE THE BULK STORE	Fire Door	Other (refer to description)	No asbestos detected (NAD)	1	Not Present(Tested)	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRG	25635008	G Block	G Block		Mezzanine 2	GYM	AC SHEETING TO END WALL (INSIDE AND OUTSIDE)	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRG	25635008	G Block	G Block		Level 1	HALL	VINYL FLOOR TILES TO HALL	Floor	Vinyl Tiles		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRG	25635008	G Block	G Block		Mezzanine 1	PLANT ROOM	RED FIRE DOOR TO THE MEZZANINE PLANT ROOM	Fire Door	Cement Based	Mixed	3	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRG	25635008	G Block	G Block		Level 1	LECTURE ROOM	AC SHEETING TO CEILING IN D1.15	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRG	25635008	G Block	G Block		Level 3	PASSAGEWAY	FIRE DOOR TO STAIRWELL NO 3 OUTSIDE ROOM G3.13	Fire Door	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRG	25635008	G Block	G Block		Level 3	PASSAGEWAY	FIRE DOOR IN THE PASAGEWAY OUTSIDE ROOM G3.05 STAIRWELL NO 1	Fire Door	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRG	25635008	G Block	G Block		Level 2	PLANT ROOM	INSULATION IN HEATER BANKS FOUND NOT TO CONTAIN ASBESTOS. 9900 PLANNED REMOVAL PROGRAM	Heater Bank Insulation	Other (refer to description)		4	Presumed	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRG	25635008	G Block	G Block		Level 2	LIBRARY	FIRE DOOR IN THE MAIN LIBRARY BESIDE RECEPTION DOOR NO G2.13	Fire Door	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRG	25635008	G Block	G Block		Level 2	CEILING TILES	AC CEILING TILES ON SECOND FLOOR	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Tested)	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRG	25635008	G Block	G Block		Level 2	AUDITORIUM	FIRE DOOR IN G2.03 AUDITORIUM	Fire Door	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRG	25635008	G Block	G Block		Level 1	TOP PRINTING RM	COMPRESSED AC SHEETING ABOVE PRINTING ROOM	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRG	25635008	G Block	G Block		Mezzanine 1	PLANT ROOM	WALL SHEETING ABOVE THE EXHAUST FANS IN THE PLAN ROOM MEZZANINE	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRH	25635007	H Block	H Block	External		INFILL PANELS	FIBRE CEMENT INFILL PANELS TO THE SOUTH SIDE WINDOWS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Tested)	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRH	25635007	H Block	H Block	External	Level 1	EXTERNAL	COMPRESSED SHEET SUNHOODS ON THE NORTHERN ELEVATION OF BLOCK H	Sun Hood	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRH	25635007	H Block	H Block	External	Level 2	LEVEL 2 & 3 STAIRWELLS	AC INFILL PANELS BELOW THE WINDOWS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRI	25635006	I Block	I Block	Internal	Level 1	WALL PANELS	AC SHADOW LINE WALL SHEETING BELOW THE LOUVRE WINDOWS NORTHERN, SOUTHERN AND WESTERN SIDES	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRI	25635006	I Block	I Block	Internal	Level 2	FITTERS WORKSHOP	AC WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRI	25635006	I Block	I Block	Internal	Level 2	ELEC OFFICE	AC WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRI	25635006	I Block	I Block	Internal	Level 1	WALL PANELS	AC WALL SHEETING BELOW THE WINDOW	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRI	25635006	I Block	I Block	External	Level 1	EXTERNAL	AC SOFFIT SHEETS JOINING ONTO THE BULK STORE FROM THE OLD ENGINEERING WORKSHOPS	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRI	25635006	I Block	I Block	External	Ground Floor	WALLS	FIBRE CEMENT WALL CLADDING TO THE SOUTHERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRI	25635006	I Block	I Block	External	Ground Floor	SOFFIT	AC CEILING SHEETS TO SOFFIT	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRI	25635006	I Block	I Block	External	Ground Floor	LOADING DOCK	CEILING SHEETS TO THE LOADING DOCK OF THE MAIN STORE	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRI	25635006	I Block	I Block	External	Ground Floor	DISPATCH AREA	WALL SHEETING BELOW THE LOUVRE WINDOWS ON THE NORTH EASTERN SIDE OF THE DISPATCH AREA	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Tested)	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRI	25635006	I Block	I Block		Ground Floor	CEILING	AC CEILING TILES FOR TOILETS, OFFICE, MAIN SPACE, SECURE STORE	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRI	25635006	I Block	I Block	Internal	Level 1	WORKSHOP OFFICE	AC CEILING SHEETS TO THE WORKSHOP OFFICE 4 SQM	Ceiling	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRK	25635004	K Block	K Block		Ground Floor	PATTERN SHOP	TIMBER RACK AREA, 4 SQM METAL WORK ROOM	Gasket	Milboard	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRK	25635004	K Block	K Block	External	Level 1	EXTERNAL	MILBOARD GASKETS TO A HEAT EXTRACTOR DUCTWORK			No asbestos detected (NAD)	4	Not Present(Tested)	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRK	25635004	K Block	K Block		Ground Floor	HEAT ROOM	MARTIN WILD BARFIELD' ELECTRIC FURNACE	Plant, Equipment & Machinery	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRK	25635004	K Block	K Block		Ground Floor	HEAT ROOM	OLD CYANIDE FURNACE GASKETS	Plant, Equipment & Machinery	Milboard	CHR - Chrysotile	3	Removed	64	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRK	25635004	K Block	K Block		Ground Floor	PATTERN SHOP	MILBOARD BACKING TO THE INFARED LIGHTBANKS LOCATED IN THE SPRAY PAINTING BOOTH	Plant, Equipment & Machinery	Milboard	CHR - Chrysotile	2	Removed	69	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRK	25635004	K Block	K Block		Level 1	DRESSING ROOM	VINYL FLOOR TILES	Floor	Vinyl Tiles	No asbestos detected (NAD)	3	Not Present(Tested)	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRK	25635004	K Block	K Block		Level 2	K2.03/PASSAGEWAY	VINYL FLOOR TILES TO ROOM K2.03 AND PASSAGEWAY AND STAFFROOM	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Tested)	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRK	25635004	K Block	K Block	External	Ground Floor	DT SURROUND	1 X DT SURROUND	Drains/Pipes/Floors	Cement Based	Mixed	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRK	25635004	K Block	K Block	External	Level 1	FACIA	AC FASCIA SHEETS	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRK	25635004	K Block	K Block	Internal	Ground Floor	MALE TOILETS	AC CEILING LINING	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRK	25635004	K Block	K Block	Internal	Ground Floor	MALE TOILETS	AC WALL SHEETING	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRK	25635004	K Block	K Block	Internal	Ground Floor	MALE TOILETS	COMPRESSED AC WALL PARTITIONS	Wall	Cement Based	Mixed	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRK	25635004	K Block	K Block	Internal	Ground Floor	OPEN AREA	FIBRE CEMENT WALL PATITIONS AT THE WEST END OF THE OPEN AREA	Wall	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Tested)	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRK	25635004	K Block	K Block	Internal	Ground Floor	PLASTER W/SHOP	AC CEILING SHEETS	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRK	25635004	K Block	K Block		Various levels Internal	STAIRWELL	AC WALL SHEETING TO THE STAIRWELL, GABLE END	Wall	Cement Based		4	Presumed	18	-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRL		L Block Store	L Block Store											-	
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRL		L Block	L Block	Internal	Level 3	TOILETS	FIBRE CEMENT WALL LININGS TO MOCK UP TOILETS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Tested)	-		
Metropolitan South		YERONGA TAFE CAMPUS	YERONGA TAFE CAMPUS	JYRO		O Block	O Block											-	
Mount Isa		MOUNT ISA TAFE - TERRACE GARDENS - DUCHESS ROAD (VIC-49856)	MOUNT ISA TAFE - TERRACE GARDENS - DUCHESS ROAD (VIC-49856)	JYRS		S Block	S Block											-	
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VTC	49856000	-- Site Grounds	-- Site Grounds											-	
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS		26494008	Canteen	Canteen	Internal	Ground Floor	ROOM E105 CANTEN AREA	BACKING TO SHEET VINYL FLOORING	Floor Backing/Underlay	Milboard	CHR - Chrysotile	4	Confirmed	64	-	
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS		26494010	G Block 4 Bay Carport	G Block 4 Bay Carport	External	Ground Floor	HEAVY MACHINERY STORAGE	ROOF STORAGE AREA	Baffles/Lining	Other (refer to description)		3	Presumed	-		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMI	26494000	-- Site - Grounds	-- Site - Grounds											-	
										TAFes from BEMIR-TAFes									

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VM01		Shed - IETU	Shed - IETU												
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VM03		Shed - Gardener	Shed - Gardener												
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VM04		Auto Storage - Bunkers	Auto Storage - Bunkers												
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VM05		Auto Storage	Auto Storage												
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VM06		Fuel Store	Fuel Store												
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIA	26494005	A Block	A Block												
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIAA	26494005	A Block	A Block	Inter nal	Ground Floor	CORRIDOR/HALL	DUPLICATE ENTRY - SPRAYED ASBESTOS CEILING	Ceiling	Sprayed Coating	No asbestos detected (NAD)	4	Not Present(Tested)			
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIAA	26494005	A Block	A Block	Inter nal	Level 1	ROOM A7 WORKSHOP	WALL SHEETING	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)			
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIAA	26494005	A Block	A Block	Inter nal	Level 1	ROOM A7 WORKSHOP	VINYL TILE	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Tested)			
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIAA	26494005	A Block	A Block	Inter nal	Level 1	ROOM A7 WORKSHOP	SPRAYED ASBESTOS - STEEL GIRDERS	Ceiling	Sprayed Coating		4	Presumed	64		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIAA	26494005	A Block	A Block	Inter nal	Level 1	ROOM A7 WORKSHOP	DUPLICATE ENTRY - WALL SHEETING	Wall	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIAA	26494005	A Block	A Block	Inter nal	Level 1	ROOM A7 WORKSHOP	CEILING SHEETING	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)			
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIAA	26494005	A Block	A Block	Inter nal	Level 1	CORRIDOR/HALL	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIAA	26494005	A Block	A Block	Inter nal	Ground Floor	CORRIDOR/HALL	SPRAYED ASBESTOS - SUSPENDED CEILING PANELS	Ceiling	Sprayed Coating	No asbestos detected (NAD)	4	Not Present(Tested)			
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIAA	26494005	A Block	A Block	Exter nal	Level 1	SOFFITS	SOFFIT SHEETING	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIAA	26494005	A Block	A Block	Exter nal	Ground Floor	COVERED WALKWAY	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIAA	26494005	A Block	A Block	Inter nal	Ground Floor	ROOM A7 WORKSHOP	SPRAYED ASBESTOS - SUSPENDED PLASTER PANELS	Ceiling	Sprayed Coating		4	Presumed	64		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIAA	26494005	A Block	A Block	Inter nal	Ground Floor	STAIRWELL	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIAA	26494005	A Block	A Block	Inter nal	Ground Floor	STOREROOM	SPRAYED ON LAGGING - ELECTRICAL MAINS	Ceiling	Lagging	No asbestos detected (NAD)	4	Not Present(Tested)			
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIBB	26494003	B Block	B Block	Inter nal	Ground Floor	MACHINE SHOP	WALL SHEETING - WELDING BOOTHS	Wall	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIBB	26494003	B Block	B Block	Inter nal	Ground Floor	WORKSHOP	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIBB	26494003	B Block	B Block	Inter nal	Ground Floor	MACHINE SHOP	LAGGING AROUND PIPES	Other (refer to description)	Lagging		4	Presumed	64		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMICC	26494001	C Block	C Block	Inter nal	Ground Floor	FRONT ENTRANCE	WALL TRIMS	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)			
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMICC	26494001	C Block	C Block	Inter nal	Level 1	STAIRWELL TO GF	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMICC	26494001	C Block	C Block	Inter nal	Ground Floor	ROOM C-22 GENERAL OFFICE	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMICC	26494001	C Block	C Block	Inter nal	Ground Floor	ROOM C-19 GENERAL OFFICE	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMICC	26494001	C Block	C Block	Inter nal	Ground Floor	CORRIDOR/HALL	WALL SHEETING - RECEPTION OFFICE	Wall	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMICC	26494001	C Block	C Block	Inter nal	Ground Floor	CORRIDOR/HALL	SUSPENDED CEILING TILES	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMICC	26494001	C Block	C Block	Inter nal	Ground Floor	CORRIDOR/HALL	DUPLICATE ENTRY - SUSPENDED CEILING TILES	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMICC	26494001	C Block	C Block	Exter nal	Level 1	CORRIDOR/HALL	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMICC	26494001	C Block	C Block	Exter nal	Ground Floor	SOFFIT	SOFFIT SHEETING- WESTERN ELEVATION	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	4	Not Present(Tested)			
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMICC	26494001	C Block	C Block	Inter nal	Ground Floor	ROOM C-20 GENERAL OFFICE	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIDD	26494007	D Block	D Block	Inter nal	Ground Floor	DEMOUNTABLE D	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIDD	26494007	D Block	D Block	Inter nal	Ground Floor	OFFICE BLOCK D	WALL SHEETING	Wall	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Ground Floor	ROOM E103 CLASSROOM	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Exter nal	Ground Floor	COVERED WALKWAY	CEILING SHEETING - BLOCK E - BLOCK C	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Exter nal	Level 1	SOFFITS	SOFFIT SHEETING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Ground Floor	CORRIDOR/HALL	DUPLICATE ENTRY - CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Ground Floor	CORRIDOR/HALL	DUPLICATE ENTRY - SUSPENDED CEILING TILES	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Ground Floor	ROOM E120 STAFF ROOM	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Level 1	ROOM E209 STAFF ROOM	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Level 1	ROOM E208 STORE ROOM	CEILING SHEETING - CLEANERS	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Level 1	ROOM E208 STORE ROOM	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Level 1	ROOM E207 TOILETS MALE & FEMALE	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Level 1	ROOM E204 OFFICE(GENERAL)	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Level 1	ROOM E203 OFFICE(GENERAL)	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Level 1	ROOM E201 CONFERENCE ROOM	WALL SHEETING	Wall	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Ground Floor	CORRIDOR/HALL	SUSPENDED CEILING TILES	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Level 1	ROOM E 4	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Ground Floor	CORRIDOR/HALL	WALL SHEETING	Wall	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Ground Floor	ROOM E119 OFFICE(GENERAL)	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Ground Floor	ROOM E118 OFFICE(GENERAL)	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Ground Floor	ROOM E117 OFFICE(GENERAL)	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Ground Floor	ROOM E114 TOILETS MALE & FEMALE	CEILING SHEETING	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Ground Floor	ROOM E110 CONFERENCE ROOM	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Ground Floor	ROOM E106 STORE ROOM	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Ground Floor	ROOM E105 CANTEN	CEILING SHEETING	Ceiling	Cement Based		4	Not Present(Not Tested)			
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Level 1	STAIRWELL	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMIEE	26494006	E Block	E Block	Inter nal	Level 1	ROOM E 5	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18		

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Est	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMFF	26454004	F Block	F Block	Internal	Ground Floor	ROOM F36 WORKSHOP	WALL SHEETING - REAR	Wall	Cement Based		4	Presumed	18	-	
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMHH	26454011	H Block	H Block	External	Ground Floor	THROUGHOUT	TAFE BUILDING CONSTRUCTED AFTER 1980	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMJJ		J Block	J Block											-	
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMJJ		J Block	J Block											-	
Mount Isa		MOUNT ISA TAFE CAMPUS	MOUNT ISA TAFE CAMPUS	VMKK		K Block	K Block	External	Ground Floor	THROUGHOUT	TAFE BUILDING CONSTRUCTED AFTER 1990	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Mount Isa		NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)	NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)		31929003	C & J WORKSHOP	C & J WORKSHOP	External	Ground Floor	THROUGHOUT	TAFE BUILDINGS CONSTRUCTED AFTER 1990	Baffles/Lining	Other (refer to description)		4	Presumed	-	-	
Mount Isa		NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)	NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)		31929005	Flammables Store	Flammables Store	External	Ground Floor	FLAMMABLES STORE	FLAMMABLES STORE	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Mount Isa		NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)	NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)	VLG	31929000	" Site - Grounds	" Site - Grounds											-	
Mount Isa		NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)	NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)	VLG01		Kiln / Store	Kiln / Store											-	
Mount Isa		NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)	NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)	VLG02		Garden Shed	Garden Shed											-	
Mount Isa		NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)	NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)	VLG04	31929004	Carport	Carport											-	
Mount Isa		NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)	NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)	VLGAA		A Block	A Block	External	Ground Floor	BLOCK A	BLOCK A	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Mount Isa		NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)	NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)	VLGBB		B Block	B Block	External	Ground Floor	BLOCK B	BLOCK B	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Mount Isa		NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)	NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)	VLGCC		C Block	C Block	External	Ground Floor	BLOCK C	BLOCK C	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Mount Isa		NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)	NORMANTON TAFE CAMPUS (LOWER GULF) (WIC-31929)	VLGDD		D Block	D Block											-	
Skills Tech Australia		ACACIA RIDGE TAFE CAMPUS	ACACIA RIDGE TAFE CAMPUS	51659000	51659000	" Site Grounds	" Site Grounds											-	
Skills Tech Australia		ACACIA RIDGE TAFE CAMPUS	ACACIA RIDGE TAFE CAMPUS	JAR	48263000	" Site - Grounds	" Site - Grounds											-	
Skills Tech Australia		ACACIA RIDGE TAFE CAMPUS	ACACIA RIDGE TAFE CAMPUS	JAR01		Main Shed	Main Shed											-	
Skills Tech Australia		ACACIA RIDGE TAFE CAMPUS	ACACIA RIDGE TAFE CAMPUS	JAR03		Marketing	Marketing											-	
Skills Tech Australia		ACACIA RIDGE TAFE CAMPUS	ACACIA RIDGE TAFE CAMPUS	JARAA		A Block	A Block											-	
Skills Tech Australia		ACACIA RIDGE TAFE CAMPUS	ACACIA RIDGE TAFE CAMPUS	JARCC		C Block	C Block											-	
Skills Tech Australia		ACACIA RIDGE TAFE CAMPUS	ACACIA RIDGE TAFE CAMPUS	JARDD		D Block	D Block											-	
Skills Tech Australia		ACACIA RIDGE TAFE CAMPUS	ACACIA RIDGE TAFE CAMPUS	JAREE		E Block	E Block											-	
Skills Tech Australia		ACACIA RIDGE TAFE CAMPUS	ACACIA RIDGE TAFE CAMPUS	JARFF		F Block	F Block											-	
Skills Tech Australia		ACACIA RIDGE TAFE CAMPUS	ACACIA RIDGE TAFE CAMPUS	JARGG		G Block	G Block											-	
Skills Tech Australia		ACACIA RIDGE TAFE CAMPUS	ACACIA RIDGE TAFE CAMPUS	JARHH		H Block	H Block											-	
Skills Tech Australia		ACACIA RIDGE TAFE CAMPUS	ACACIA RIDGE TAFE CAMPUS	JARII		I Block	I Block											-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789003	23789003	WID CERAMICS STORE	WID CERAMICS STORE		Ground Floor	EXTERNAL	FIBRE CEMENT SHEET EAVES LINING TO BUILDING PERIMETER. SIM SAMPLE 1937	Cable/Goff/Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789003	23789003	WID CERAMICS STORE	WID CERAMICS STORE		Ground Floor	DRY STORE	INFILL PANELS IN PERIMETER WALLS OF NORTH DRY STORE	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789003	23789003	WID CERAMICS STORE	WID CERAMICS STORE		Ground Floor	DRY STORE	CEILING PANELS TO DRY STORE. SIM SAMPLE 1937	Ceiling	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789003	23789003	WID CERAMICS STORE	WID CERAMICS STORE		Ground Floor	CERAMICS STORE	UNUSED COMPRESSED SHEET MATERIAL ON GROUND ADJ N WALL OF BLDG. SIMILAR SAMPLE 1922	Stored Material	Cement Based		3	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789004	23789004	STORE SHED NO 1	STORE SHED NO 1	###		Room description not provided	NO ASBESTOS CONTAINING MATERIALS DETECTED IN STORE SHED NO.1							-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789007	23789007	MATERIAL STORE	MATERIAL STORE		Ground Floor	INTERNAL	CEILING AND INTERNAL WALL LININGS. SIM SAMPLE 1931	Ceiling	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789010	23789010	STORAGE	STORAGE		Ground Floor	EXTERNAL	FIBRE CEMENT SHEET EXTERNAL WALL CLADDING TO BUILDING. SIM SAMPLE 1937	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789018	23789018	LOCKSMITHS BLK E	LOCKSMITHS BLK E		Ground Floor	Room description not provided	EXTERNAL WALL CLADDING AND SOUTH SIDE AWNING (DAMAGE NOTED SOME WALLS) PHOTO 14	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789025	23789025	PLANT ROOM BLK I	PLANT ROOM BLK I		Ground Floor	Room description not provided	COMPRESSED SHEET EXTERNAL WALLPANELS OF BUILDING	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789027	23789027	GLAZING BLK P	GLAZING BLK P		Level 1	LECTURE ROOM	SPECKLED GREY VINYL FLOOR TILES, EAST HALF OF ROOM	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789027	23789027	GLAZING BLK P	GLAZING BLK P		Ground Floor	OLD STORE	CEILING PANELS TO OLD STORE ADJACENT TANKS SIM SAMPLE 1930 - CHR	Ceiling	Cement Based		3	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789027	23789027	GLAZING BLK P	GLAZING BLK P		Ground Floor	N/W ROOM	WALL PANELS TO NORTH WESTERN ROOM SIM SAMPLE 1937 - NAD	Wall	Cement Based		4	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789027	23789027	GLAZING BLK P	GLAZING BLK P		Ground Floor	OLD OFFICE	CEILING PANELS TO OLD OFFICE SIM SAMPLE 1937 - NAD	Ceiling	Cement Based		4	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789027	23789027	GLAZING BLK P	GLAZING BLK P		Ground Floor	REPROGRAPHICS	FIBRE CEMENT SHEET WALL LININGS OF TOILET SIM SAMPLE 1937 - NAD	Wall	Cement Based		4	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789027	23789027	GLAZING BLK P	GLAZING BLK P		Ground Floor	REPROGRAPHICS	COMPRESSED SHEET TOILET CUBICLE PARTITIONS SIMILAR SAMPLE 1942 - NAD	Wall	Cement Based		4	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789027	23789027	GLAZING BLK P	GLAZING BLK P		Ground Floor	REPROGRAPHICS	FIBRE CEMENT SHEET CEILING LINING OF TOILET SIM SAMPLE 1937 - NAD	Ceiling	Cement Based		4	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789027	23789027	GLAZING BLK P	GLAZING BLK P		Ground Floor	OLD OFFICE	INTERNAL AND EXTERNAL FIBRE CEMENT SHEET WALL LINING SIM SAMPLE 1937 - NAD	Wall	Cement Based		4	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789027	23789027	GLAZING BLK P	GLAZING BLK P		Ground Floor	OLD STORE	WALL PANELS TO OLD STORE ADJACENT TANKS SIM SAMPLE 1930 - CHR	Wall	Cement Based		3	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789027	23789027	GLAZING BLK P	GLAZING BLK P		Ground Floor	OLD OFFICE	FLOOR TILES TO OLD OFFICE	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789027	23789027	GLAZING BLK P	GLAZING BLK P		Ground Floor	REPROGRAPHICS	BROWN VINYL FLOOR TILES TO REPROGRAPHICS ROOM	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789027	23789027	GLAZING BLK P	GLAZING BLK P		Ground Floor	EXTERIOR - SHED	FIBRE CEMENT SHEET INTERNAL WALL LINING OF SHED AT E END OF S WALL. REFER SAMPLE 1937	Wall	Cement Based		4	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q	Internal	Ground Floor	ROOM Q104 -	ROOM Q104 - WESTERN END OF CLASS ROOM	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q	Internal	Ground Floor	STAFF ROOM - WESTERN END WALL OF STAFF ROOM	STAFF ROOM - WESTERN END WALL SHEETING	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q	Internal	Ground Floor	STAFF ROOM - NORTHERN WALL	STAFF ROOM - NORTHERN WALL	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q	Internal	Ground Floor	STAFF ROOM - EASTERN WALL	STAFF ROOM - EASTERN WALL SHEETING	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q	Internal	Ground Floor	ROOM Q102 - EASTERN WALL SHEETING	ROOM Q102 - EASTERN WALL SHEETING	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q		Ground Floor	ALL AREAS	WALL LININGS - PREDOMINANTLY AT BLDG PERIMETER (SOME APPEAR TO BE NEVER ASB FREE MATERIAL)	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q		Ground Floor	Room description not provided	FORMWORK AROUND DRAINS AT BASE OF DOWNPIPES - 5.50M EACH PHOTO NO. 31	Drains/Pipes/Floor	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q		Ground Floor	TOILETS	BLACK VINYL FLOOR TILES TO TOILETS	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q		Ground Floor	TUTORIAL ROOM	INSULATION TO ELECT HIBANK IN REDUNDANT SIA DUCT, CLG SPACE OVER N TUTORIAL ROOM. PHOTO 20	Heater Bank Insulation	Milboard	CHR - Chrysotile	2	Removed	69	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q		Level 1	WORKSHOP	CLUTCH PLATE STORED BROWN BUILD BOARD UNDER WBN	Stored Material	Polymer Bound	CHR - Chrysotile	4	Confirmed	25	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ed.	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q		Level 1	WORKSHOP	REMOVED BY CLIENT - GASKET TO TURBO UNIT MOUNTED EXHAUST MANIFOLD	Stored Material	Miliboard	CHR - Chrysotile	2	Removed	69	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q	Internal	Ground Floor	RADAR ROOM NORTHERN WALL	RADAR ROOM-NORTHERN WALL SHEETING	Cement Based	Cement Based	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q	Internal	Ground Floor	RADAR ROOM-SOUTHERN WALL	WALL SHEETING TO SOUTHERN WALL TO RADAR ROOM	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q	Internal	Ground Floor	ROOM Q104 -	WALL SHEETING TO EASTERN END OF CLASS ROOM	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q	Internal	Ground Floor	ROOM Q102 -	INTERNAL WALL SHEET OF CLASSROOM WESTERN END - WEST FACING WALL	Wall	Cement Based	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q	Internal	Ground Floor	ROOM Q104 -	WALL SHEETING SOUTHERN END OF CLASS ROOM	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q	Internal	Ground Floor	ROOM Q102 - NORTHERN WALL	ROOM Q102 - NORTHERN WALL	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q	Internal	Ground Floor	ROOM Q102 -SOUTHERN WALL SHEETING	ROOM Q102-SOUTHERN WALL SHEETING	Wall	Cement Based	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q	Internal	Ground Floor	ROOM Q104 -	INTERNAL WALL SHEET OF NORTH EAST CLASSROOM - NORTH FACING WALL	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789028	23789028	MARINE & FISH CTR BLK Q	MARINE & FISH CTR BLK Q	Internal	Ground Floor	RADAR ROOM WESTERN WALL	RADAR ROOM WESTERN WALL	Wall	Cement Based	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789029	23789029	ADMINISTRATION BLK A	ADMINISTRATION BLK A	Internal	###	Room description not provided	NO ASBESTOS CONTAINING MATERIALS DETECTED IN ADMINISTRATION BUILDING	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789030	23789030	SURFACE FIN SKILLS	SURFACE FIN SKILLS	Various levels	Internal Ground Floor	THROUGHOUT	PARTITION WALL TO METAL FABRICATION WORKSHOP	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789030	23789030	SURFACE FIN SKILLS	SURFACE FIN SKILLS	Internal Ground Floor		STORE ROOM	NO ACCESS TO STORE ROOM WEST CORNER OF MIDDLE WORKSHOP, NEXT TO SAFETY SHOWER	Wall	Other (refer to description)			Presumed	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789032	23789032	TRACTOR SHED BLK V	TRACTOR SHED BLK V		Ground Floor	EXTERNAL	STEEL STRUCTURE IRON ROOF				4	Presumed	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	23789033	23789033	PLUMBING TOWER	PLUMBING TOWER		Ground Floor	EXTERNAL					4	Presumed	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA	23789000	** Site - Grounds	** Site - Grounds		Site / Grounds	CAR PARK	SHEETING TO WORKBENCH NSIDE GREENHOUSE	Furniture	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA	23789000	** Site - Grounds	** Site - Grounds	External	Site / Grounds	EXTERNAL	1 X TELECOMMUNICATIONS PIT ON THE NORTHERN SIDE OF BLOCK C (SIM SAMPLE 6266508-01)	Preformed Moulded Product	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA	23789000	** Site - Grounds	** Site - Grounds	###	Room description not provided	PHOTOGRAPH OF CAMPUS - PHOTO NO. 1		Other (refer to description)				Presumed	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA	23789000	** Site - Grounds	** Site - Grounds		Site / Grounds	SANDSTONE HOLDING YARD	REMOVED BY CLIENT - MELTROID COATED BLK'S NORTH OF LAMETH WISHOP	Stored Material	Polymer Based	CHR - Chrysotile	2	Removed	39	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA	23789000	** Site - Grounds	** Site - Grounds	External	Site / Grounds	EXTERNAL	1 X SMALL TELECOMMUNICATIONS PIT SOUTH EAST CORNER OF BLOCK D	Preformed Moulded Product	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA	23789000	** Site - Grounds	** Site - Grounds	External	Site / Grounds	EXTERNAL	1 X TELECOMMUNICATION PIT NORTH WESTERN SIDE	Preformed Moulded Product	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA	23789000	** Site - Grounds	** Site - Grounds	External	Site / Grounds	EXTERNAL	1 X TELECOMMUNICATION PIT NE SIDE APRON ROADWAY	Preformed Moulded Product	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA	23789000	** Site - Grounds	** Site - Grounds	External	Site / Grounds	EXTERNAL	1 X SMALL TELECOMMUNICATION PIT SE CORNER BLOCK D	Preformed Moulded Product	Cement Based	Mixed	4	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA	23789000	** Site - Grounds	** Site - Grounds	External	Site / Grounds	EXTERNAL	1 X TELECOMMUNICATIONS PIT ON NORTHSIDE OF BLOCK D	Preformed Moulded Product	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA	23789000	** Site - Grounds	** Site - Grounds	External	Site / Grounds	EXTERNAL	1 X TELECOMMUNICATIONS PIT SWEST CNR WORK BLOCK	Preformed Moulded Product	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA	23789000	** Site - Grounds	** Site - Grounds	External	Site / Grounds	EXTERNAL	1 X TELECOMMUNICATION PIT SSIDE OF BLOCK F CAPRO	Preformed Moulded Product	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA01	23789005	FLAMMABLE STORE	FLAMMABLE STORE	###	Room description not provided	NO ASBESTOS CONTAINING MATERIALS DETECTED IN FLAMMABLE STORE						Not Present(Not Tested)	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA02	23789031	MARINE STORE BLK T	MARINE STORE BLK T	###	Room description not provided	NO ASBESTOS CONTAINING MATERIALS DETECTED IN MARINE STORE						Not Present(Not Tested)	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA03	23789011	GOODS RECEIVED BLK N	GOODS RECEIVED BLK N		Ground Floor	EXTERNAL	REMOVED BY CLIENT - FIBRE CEMENT SHEET DEBRIS ON GROUND AROUND BASE OF BUILDING	Stored Material	Cement Based		2	Removed	34	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA03	23789011	GOODS RECEIVED BLK N	GOODS RECEIVED BLK N		Ground Floor	EXTERNAL	FIBRE CEMENT SHEET EXTERNAL WALL CLADDING TO BUILDING, SIM SAMPLE 1937	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA04	23789006	GRAPHICS	GRAPHICS		Ground Floor	STORE ROOM	FIBRE CEMENT SHEET WALL AND CEILING LINING OF STORE ROOMS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA05		Storage Shed	Storage Shed										-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA06		Storage Shed - Carpark	Storage Shed - Carpark										-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA07		Storage Shed	Storage Shed										-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGA08		Shed	Shed										-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAAA		A Block	A Block										-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAB8	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B		Level 3	3.12 COMPUTER B	FIBRE CEMENT SHEET EAST WALL OF COMPUTER ROOM B, CONCEALED BEHIND PLASTERBOARD WALL LINING	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAB8	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B	Internal	Ground Floor	OFFICE	REMOVED BY CLIENT - DUST & DEBRIS FROM SOUTHERN SIDE OF OFFICE ON TOP OF CABINET	Debris	Cement Based	CHR - Chrysotile	2	Removed	34	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAB8	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B	Internal	Ground Floor	OFFICE	DUST & DEBRIS FROM PHOTOCOPIER IN CENTRE OF OFFICE	Debris	Cement Based	No asbestos detected (NAD)	2	Not Present(Not Tested)	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAB8	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B	Internal	Ground Floor	OFFICE	DUST & DEBRIS FROM NORTH WEST OF OFFICE ON TOP OF PIGEON HOLES	Debris	Cement Based	No asbestos detected (NAD)	2	Not Present(Not Tested)	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAB8	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B	Internal	Ground Floor	OFFICE	DUST & DEBRIS FROM NORTH EASTERN END ON TOP OF RAC	Debris	Cement Based	No asbestos detected (NAD)	2	Not Present(Not Tested)	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAB8	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B		Level 1	VARIOUS	CLOS TO STA BOOKSHOP, STUDENT SERVICES, HRM & RISK MANAGEMENT OFFICE, SIM SAMPLE 1916	Ceiling	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAB8	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B		Level 1	BG-1 FEMALE TLT	COMPRESSED SHEET WALL PANELS TO FEMALE TLT, BEHIND CERAMIC WALL TILES. SIMILAR SAMPLE 1910	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAB8	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B		Level 1	BG-2 MALE TLT	COMPRESSED SHEET WALL PANELS TO MALE TLT, BEHIND CERAMIC WALL TILES.	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Not Tested)	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAB8	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B		Level 1	CANTEEN/DINING	PERFORATED FIBRE CEMENT SHEET CEILING TILES TO CANTEEN DINING ROOM	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAB8	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B		Level 1	CLEANERS STORE	FLUE PIPE FROM TOP OF HW UNIT EXITS THROUGH CLG (EXTENT NOT DETERMINED) SIM SAMPLE 1912	Drains/Pipes/F	Cement Based		3	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAB8	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B		Level 1	KITCHEN	WALL PANELS BEHIND CERAMIC WALL TILES IN KITCHEN AREA OF CANTEEN, SIMILAR SAMPLE 1910	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAB8	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B		Level 1	MAIL ROOM	WALL PANELS TO MALE TOILET IN STUDENT COMMON RM, BEHIND WALL TILES, REFER SAMPLE 1910	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAB8	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B		Level 3	3.14 MALE TLT	ASBESTOS CEMENT SHEET PACKING MATERIAL ASSOCIATED WITH WALL BRACKETS WITHIN CEILING SPACE	Ceiling	Cement Based	CHR - Chrysotile	3	Confirmed	13	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAB8	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B		Level 1	OPEN AIR DINING	FIBRE CEMENT SHEET SOFFIT OF AWNING EXTENDING OUT FROM NORTH EXTERIOR WALL OF CANTEEN	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAB8	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B	Internal	Ground Floor	COMPUTER ROOM	CEILING TILE THROUGHOUT GROUND FLOOR	Ceiling	Cement Based	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAB8	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B		Level 2	2.11 & 2.13	NORTH WALL LININGS TO FEMALE TLT ENTRY FOYER & CLEANERS STORE, SIM SAMPLE 1913	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAB8	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B		Level 2	2.12	WALL PANELS THROUGHOUT FEMALE TOILET BEHIND CERAMIC WALL TILES SIMILAR SAMPLE 1910	Wall	Cement Based		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEHIM Score	Attention Required	Comments
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGABB	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B		Level 3	3.13 & 3.15	FIBRE CEMENT SHEET WALL LININGS TO MALE TOILET ENTRY FOYER AND CLEANERS STORE	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Testing)		-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGABB	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B		Level 3	3.16 COMPUTER 9	PACKING MATERIAL ABOVE EAVES, BWN STEEL BEAMS & CONCRETE BRACKETS	Ceiling	Cement Based		3	Presumed	13	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGABB	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B		Level 1	MALE & FEMALE TOILET	SHEETING BEHIND CERAMIC TILES TOILETS IN CANTEEN	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGABB	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B		Level 3	Room description not provided	FIBRE CEMENT SHEET EAVES LINING TO BUILDING PERIMETER PHOTO NO.4	Gable/Soffit/ascle	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGABB	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B		Level 3	3.15 CLEANERS	REDUNDANT FLUE PIPE IN SERVICE DUCT AT REAR OF CLEANERS STORE EXTENDS TO FLRS BELOW. PHOTO 3	Drains/Pipes/Flues	Cement Based	Mixed	2	Removed	34	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGABB	23789021	COMMERCIAL/CANTEEN BLK B	COMMERCIAL/CANTEEN N BLK B		Level 3	3.14 MALE TLT	WALL PANELS THOUT TLT. INCL. BULKHEAD OVER URINALS. (TILES COVER MOST WALL AREAS) PHOTO 2	Wall	Cement Based	CHR - Chrysotile	3	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C		Level 3	PROJECT STORE 3	LIGHT OLIVE GREEN VINYL FLOOR TILES TO PROJECT STORE 3 REFER SAMPLE 1921	Floor	Vinyl Tiles		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	External	Level 1	PANELS	INFILL PANELS LINING TO THE WEST ELEVATION	Wall	Cement Based		2	Removed	34	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	External	Ground Floor	EXTERNAL	INFILL PANELS -BASE OF MASONRY FLUE FROM HEAT TREATMENT ROOM SIM. SAMPLE 1920 PHOTO 10	Wall	Cement Based		3	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Various levels External		Room description not provided	HORIZONTAL SUNSHADES BETWEEN COLUMNS OF N & S WALLS, BELOW LOUVRE WINDOWS. PHOTO NO. 9	Sun Hood	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Various levels External		EXTERNAL	EXTERNAL INFILL PANELS BELOW PERIMETER WALL. WINDOWS SIM SAMPLE 1920. PHOTO 9	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Roof Level 1	EXTERNAL	FLUE PIPE EXTENDING ABOVE ROOFLINE. WESTERN END OF BUILDING PHOTO 6. SIM SAMPLE 1912 MIX	Drains/Pipes/Flues	Cement Based		3	Removed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Roof Level 1	DUST EXTRACTOR	COMPRESSED SHEET LOUVRES - N WALL DUST EXTRACTOR. ROOM OVER FIRE STAIRS. SIM. SMPL 1910	Sun Hood	Cement Based		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 3	W FIRE STAIRS	FLOOR TILES TO LANDING AT TOP OF STAIRS & LANDING BETWEEN L1 AND L2. REFER SAMPLE 1919	Floor	Vinyl Tiles		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 3	STORE ROOM 3	PERFORATED FIBRE CEMENT SHEET CEILING TILES TO STORE ROOM 3 SIM SAMPLE 1916	Ceiling	Cement Based		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Ground Floor	CG-7 & STORE	INT. & EXT. FIBRE CEMENT SHEETWALL LINING OF SOUTH WALL TO CG-7 CLASSROOM MATERIAL STORE	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Testing)		-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 3	ROOM 3.11	REMOVED BY CLIENT - BACKING BOARD STUDENT DISPLAY UNIT HEATING ELEMENT	Plant, Equipment & Machinery	Mitboard	Mixed	2	Removed	69	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 2	C2-16	FLOOR TILES TO ROOM C1-16 REFER SAMPLE 1921	Floor	Vinyl Tiles		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 3	MATERIAL STORE	FLOOR TILES TO MATERIAL STORE. SIM. TILES MAY BE UNDER CARPET OTHER L2 RMS. REFER SMPL 1921	Floor	Vinyl Tiles		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 3	E FIRE STAIRS	INSULATION PACKED BWN EXHAUST DUCT & CONCRETE PERIMETER WALL DUCT ON LANDING BWN L1 & L2	Insulation/Fill	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Testing)		-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 3	E FIRE STAIRS	GREY VINYL FLOOR TILES TO LANDING AT TOP OF EAST FIRE STAIRS & LANDING BWN L1 & L2	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Testing)		-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 3	C3-6	PERFORATED FIBRE CEMENT SHEET CEILING TILES TO ROOM C2-6 SIM SAMPLE 1916	Ceiling	Cement Based		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 3	C3-13	INTERNAL WALL LININGS AT SOUTH END OF ROOM C2-13, SURROUNDING WINDOW	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 3	C313	FLOOR TILES TO ROOM C2-13 REFER SAMPLE 1918	Floor	Vinyl Tiles		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 3	ALL AREAS	INTERNAL INFILL PANELS BELOW PERIMETER WALL WINDOWS. PHOTO NO. 7. SIM SAMPLE 1920	Wall	Cement Based		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 3	3-4 WORKSHOP	PERFORATED FIBRE CEMENT SHEET CEILING TILES TO EAST HALF OF WORKSHOP. SIM SAMPLE 1916	Ceiling	Cement Based		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 3	ROOM C3.12	REMOVED BY CLIENT - KLESTER SOLINGER HOT AIR GUN STORED ON SHELVING	Plant, Equipment & Machinery	Mitboard	CHR - Chrysotile	2	Removed	69	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 2	C2-7	VINYL FLOOR SHEETING TO DRAWING ROOM 2 SIM 1923	Floor	Vinyl Sheetling (includes backing)		4	Presumed	62	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 1	G1.01	STORTED SHEETING BEHIND THE SOLVENT BATH	Stored Material	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Testing)		-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Ground Floor	STORE ROOM	FLOOR TILES TO STORE ROOM BENEATH WEST FIRE STAIRS REFER SAMPLE 1921	Floor	Vinyl Tiles		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Ground Floor	STORE ROOM	FLOOR TILES TO STORE ROOM BELOW EAST FIRE STAIRS REFER SAMPLE 1921	Floor	Vinyl Tiles		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Ground Floor	ENTIRE FLOOR	INTERNAL INFILL PANELS BELOW N & S PERIMETER WALL WINDOWS SIM SAMPLE 1920	Wall	Cement Based		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Ground Floor	E&W FIRE STAIRS	FLOOR TILES TO EAST AND WEST FIRE STAIRS REFER SAMPLE 1919	Floor	Vinyl Tiles		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Ground Floor	CG-8	FLOOR TILES TO ROOM CG-8 REFER SAMPLE 1921	Floor	Vinyl Tiles		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 2	C2-18	FLOOR TILES TO CLASSROOM 2 REFER SAMPLE 1921	Floor	Vinyl Tiles		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 3	HW UNIT PLANTRM	FLUE PIPE EXTENDING UP FROM TOP OF HW UNIT TO ABOVE ROOF LINE. SIM SAMPLE 1912 - MIX	Drains/Pipes/Flues	Cement Based		3	Removed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Ground Floor	CG-4	WALLS AND CEILING OF WELDING BOOTH, N/E CORNER OF WORKSHOP SIMILAR SAMPLE 1922 - CHR	Wall	Cement Based	Mixed	3	Removed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 2	C2-8A	VINYL FLOOR SHEETING TO ROOM C1-8A SIM SAMPLE 1923	Floor	Vinyl Sheetling (includes backing)		4	Presumed	62	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 2	ROOM 2.22	BACKING TO SHEET VINYL	Floor	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Testing)		-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 2	CENTRL CORRIDOR	FLOOR TILES TO CENTRAL CORRIDOR REFER SAMPLE 1921	Floor	Vinyl Tiles		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 2	E&W FIRE STAIRS	VINYL FLOOR TILES ON L1 LANDINGS & LANDINGS BETWEEN L1 AND GF. REFER SAMPLE 1919	Floor	Vinyl Tiles		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 3	3-4 WORKSHOP	LIGHT OLIVE GREEN VINYL FLOOR TILES TO WORKSHOP 3-4	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Testing)		-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 2	ENTIRE FLOOR	FIBRE CEMENT SHEET INFILL PANELS BELOW PERIMETER WALL WINDOWS. SIM SAMPLE 1920	Wall	Cement Based		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 1	HEAT TREATMENT	GASKET AT SERVICE ENTRY POINT TO MUFFLER FURNANCE	Plant, Equipment & Machinery	Mitboard	CHR - Chrysotile	2	Removed	69	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 1	STORE ROOM	REMOVED BY CLIENT - ROLLS OF GASKET MATERIAL STORED IN CUPBOARD	Stored Material	Mitboard	CHR - Chrysotile	2	Removed	69	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 2	C2-17	FLOOR TILES TO ROOM C1-17 REFER SAMPLE 1921	Floor	Vinyl Tiles		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 2	C1-8	VINYL FLOOR SHEETING TO DRAWING ROOM 1	Floor	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Testing)		-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 1	HEAT TREATMENT	GASKET AT SERVICE ENTRY POINT TO MUFFLER FURNANCES	Plant, Equipment & Machinery	Mitboard	CHR - Chrysotile	2	Removed	69	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 2	C2-19	FLOOR TILES TO CLASSROOM 1 REFER SAMPLE 1921	Floor	Vinyl Tiles		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Ground Floor	CG-3	FIBRE CEMENT SHEET WALLS OF SOUTHERN FURNACE UNIT TO HEAT TREATMENT ROOM. PHOTO NO. 8	Plant, Equipment & Machinery	Cement Based	CHR - Chrysotile	3	Confirmed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Ground Floor	CG-7 & STORE	FLOOR TILES TO ROOM CG-7 AND MATERIAL STORE REFER SAMPLE 1921	Floor	Vinyl Tiles		4	Presumed	18	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGACC	23789020	FASHION BLK C	FASHION BLK C	Level 3	PROJECT STORE 3	INTERNAL WALL LINING AT NORTH END OF ROOM, SURROUNDING WINDOW. SIM SAMPLE 1920	Wall	Cement Based		4	Presumed	18	-		

TAFEs from BEHIM-TAFEs

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Level 1	D1-3, 4, 4A	VINYL FLOOR SHEETING - TO ROOMS D1-3, D1-4 AND D1-4A	Floor Finish/Coverin	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Presumed	62	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	External	Ground Floor	EXTERNAL	DECORATIVE VERMICULITE COATING TO SOFFIT E HALF OF FLR & SOMECSTNS W HALF.	Ceiling	Other (refer to description)	No asbestos detected (NAD)	NA	Not Present(Testing)	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	External	Ground Floor	EXTERNAL	FIBRE CEMENT SHEET CEILING TILES TO WEST HALF OF FLOOR	Ceiling	Cement Based	Mixed	4	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	External	Level 1	E&W FIRE STAIRS	DECORATIVE VERMICULITE COATING TO SOFFIT OF E & W STAIRWELL.	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Testing)	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	External	Level 2	EXTERNAL	SOFFIT SHEETING TO THE PERIMETER OF THE BUILDING	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	External	Roof Level 1	VENT PIPE	VENT PIPE ON THE ROOF WESTERN END OF BLOCK	Drains/Pipes/ascia	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Ground Floor	DG.1	REMOVED IN 2008 - FIBRE CEMENT SHEET CEILING TILES TO MALE TOILET	Ceiling	Cement Based		4	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Ground Floor	DG.4	VINYL FLOOR SHEETING TO ROOM DG-4	Floor Finish/Coverin	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Ground Floor	DG.8	WALLS TO WELDING BOOTHS IN WORKSHOP (SOME BOOTH WALLS ARE DAMAGED)	Wall	Cement Based	No asbestos detected (NAD)	3	Not Present(Testing)	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Ground Floor	E FIRE STAIRS	FLOOR TILES TO EASTERN FIRE STAIRS	Floor Finish/Coverin	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Testing)	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Level 2	ROOM D3.05	CEILING TILES (PERFORATED)	Ceiling	Low Density Board	CHR AMO - Chrysotile Amosite	1	Confirmed	73	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Level 1	CORRIDOR & VER ROOMS	VINYL FLOOR TILES (MOTTLED GREEN/WHITE) - OF CENTRAL CORRIDOR & WEST HALF OF BUILDING	Floor Finish/Coverin	Vinyl Tiles		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Level 1	D1.03	DISPLAY ACETYLENE BOTTLE .FLOOR REQUIRES ATTENTION	Stored Material	Loose Fill	CHR - Chrysotile	2	Removed	69	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Level 1	DG.7 AND DG.8	VINYL TILES - ROOMS DG-7 AND DG-8	Floor Finish/Coverin	Vinyl Tiles		4	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Level 1	FIRST AID ROOM	CEILING TILES (PERFORATED)	Ceiling	Low Density Board	CHR AMO - Chrysotile Amosite	2	Confirmed	69	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Level 1	ROOM D207	CEILING TILES (PERFORATED) - ROOM D207	Ceiling	Low Density Board	CHR AMO - Chrysotile Amosite	2	Confirmed	69	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Level 2	CLASSROOM	REMOVED BY CLIENT - MERCURY TRANSFORM FIXED TO WALL OF ONE CLASSROOM	Stored Material	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Level 2	D2.13	VINYL FLOOR SHEETING TO STAFF KITCHEN/COMMON ROOM SIM SAMPLE 1923 - NAD	Floor	Vinyl Sheeting (includes backing)		4	Removed	62	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Level 2	INTERNAL CEILINGS	CEILING TILES - PERFORATED (EXCLUDE ROOM D3.05)	Ceiling	Cement Based	Mixed	2	Confirmed	34	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Level 2	INTERNAL FLOOR COVERINGS	MOTTLED GREEN/WHITE VINYL FLOOR TILE THROUGHOUT MAJORITY OF THIS LEVEL	Floor	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Ground Floor	WESTERN STAIRS	FLOOR TILES TO WEST STAIRS REFER SAMPLE 62565/09-04	Floor Finish/Coverin	Vinyl Tiles		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Level 1	D2.9	DECORATIVE INFL PANELS IN TOILET CURBICLE DOORS - STUDENTS TOILETS	Furniture	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Level 3	ROOM D310	CEILING TILES (PERFORATED) - ROOM D310	Ceiling	Low Density Board	CHR AMO - Chrysotile Amosite	2	Confirmed	69	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Level 3	HW UNIT PLANTROOM	FLUE PIPES EXTEND FROM TOP OF HW UNITS TO ABOVE ROOFLINE PHOTO 12, SIM SAMPLE 1912	Drains/Pipes/F	Cement Based		3	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Level 2	STORE ROOM D3.02	REMOVED BY CLIENT - BACKING TO TWO ELECTRICAL TRAINING AIDS IN CBOARD	Stored Material	Miliboard	CHR - Chrysotile	2	Removed	89	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGADD	23789019	ELECT/METAL FAB BLK D	ELECT/METAL FAB BLK D	Internal	Level 2	STORE ROOM D3.02	ZELMITE TO TEACHING AID STORED IN CUPBOARD 2 OFF	Stored Material	Polymer Bound	CHR - Chrysotile	4	Confirmed	25	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAE		E Block	E Block												
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789017	S.MASONDRY CLEAN BLK FA	S.MASONDRY CLEAN BLK FA	External	Ground Floor	EAVES	LOWER LEVEL EAVES SOUTH END OF BUILDING (UPPER LEVEL EAVES ARE HARDBOARD)	Gable/Soffit/ascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Testing)	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789017	S.MASONDRY CLEAN BLK FA	S.MASONDRY CLEAN BLK FA		Ground Floor	DRY CLEANING RM	FIBRE CEMENT SHEET LINING TO NORTH WALL OF DRY CLEANING RM SIM SAMPLE 1931	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789017	S.MASONDRY CLEAN BLK FA	S.MASONDRY CLEAN BLK FA		Ground Floor	EXTERNAL	SEVERAL FIBRE CEMENT SHEET WALL PANELS ABOVE WINDOWS AND DOORWAYS, SIM SAMPLE 1920	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789017	S.MASONDRY CLEAN BLK FA	S.MASONDRY CLEAN BLK FA		Ground Floor	SAND BLAST	WALLS & CEILING OF SAND BLAST BOOTH IN N/E CNR OF WORKSHOP PHOTO 15, SIMILAR SAMPLE 1922	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789017	S.MASONDRY CLEAN BLK FA	S.MASONDRY CLEAN BLK FA		Ground Floor	SEMINAR ROOM	FIBRE CEMENT SHEET LINING TO NORTH WALL OF SEMINAR ROOM SIM SAMPLE 1931	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789017	S.MASONDRY CLEAN BLK FA	S.MASONDRY CLEAN BLK FA		Ground Floor	STORE	INFILL PANELS LINING SECTIONS OF S INTERNAL WALL OF MEZANINE STORE, SAMPLE 1920	Wall	Cement Based		3	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789002	ART/CERAMICS BLK F	ART/CERAMICS BLK F		Ground Floor	OPEN AREA	SHEETING TO BENCH TOPS/BACK OF SOME WBENCHES	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789002	ART/CERAMICS BLK F	ART/CERAMICS BLK F		Ground Floor	KILN AREA	CEILING PANELS - KILN AREA	Ceiling	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789002	ART/CERAMICS BLK F	ART/CERAMICS BLK F		Ground Floor	EXTERNAL	WALL - EASTERN ELEVATION - FLUE PIPE	Drains/Pipes/F	Cement Based		3	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789002	ART/CERAMICS BLK F	ART/CERAMICS BLK F		Ground Floor	EXTERNAL	SMALL COLLAR SECTION TO PVC FLUE PIPE EXTENDING UP S WALL	Drains/Pipes/F	Cement Based		3	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789002	ART/CERAMICS BLK F	ART/CERAMICS BLK F		Ground Floor	EXTERNAL	CEILING PANELS TO SPRAY BOOTHS, SIM SAMPLE 1937	Ceiling	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789002	ART/CERAMICS BLK F	ART/CERAMICS BLK F		Ground Floor	EXTERNAL	CORRUGATED ROOF SHEETING SEE PHOTO 16	Roof Sheeting	Cement Based		1	Removed	37	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789002	ART/CERAMICS BLK F	ART/CERAMICS BLK F		Ground Floor	PRINTING WISHOP	PARTITION WALL SURROUNDING N & E SIDES OF PAINTING AREA, SIM SAMPLE 1937	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789002	ART/CERAMICS BLK F	ART/CERAMICS BLK F	External	Roof Level 1	EXTERNAL	REMOVED AND REPLACED 05.02.11 - ARP T043 - CORRUGATED ROOF CLADDING	Roof Sheeting	Cement Based		1	Removed	37	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789002	ART/CERAMICS BLK F	ART/CERAMICS BLK F		Ground Floor	EXTERNAL	LOWER LEVEL EAVES, S END OF BLDG (UPPER LVL EAVES LINING HARDBOARD)	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789002	ART/CERAMICS BLK F	ART/CERAMICS BLK F		Ground Floor	STUDIO CLASSROOM	VINYL FLOOR TILES TO 2 C/ROOMS ON EAST SIDE OF BLK	Floor	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Testing)	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789002	ART/CERAMICS BLK F	ART/CERAMICS BLK F	Internal	Ground Floor	PRAC AREA	PARTITION WALL - BETWEEN PRAC AREA AND CLASSROOM (ASBESTOS FREE)	Wall	Cement Based	No asbestos detected (NAD)	3	Not Present(Testing)	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789002	ART/CERAMICS BLK F	ART/CERAMICS BLK F	Internal	Ground Floor	STAFFROOM	REMOVED BY CLIENT - INSULATION TO VULCAN PLATE OVEN KITCHEN BENCH	Plant, Equipment & Machinery	Miliboard	CHR - Chrysotile	2	Removed	69	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789002	ART/CERAMICS BLK F	ART/CERAMICS BLK F	External	Roof Level 1	EXTERNAL	ASBESTOS CEMENT FLUE PIPE COLLAR, SOUTH ELEVATION	Drains/Pipes/F	Cement Based	Mixed	3	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789002	ART/CERAMICS BLK F	ART/CERAMICS BLK F		Ground Floor	KILN AREA	WALLS - SOUTH WEST ELEVATION - SMALL KILN	Furniture	Cement Based	Mixed	3	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAF	23789002	ART/CERAMICS BLK F	ART/CERAMICS BLK F		Ground Floor	STAFF KITCHEN	FLOOR TILES TO STAFF KITCHEN	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Testing)	-		
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAG	23789016	COMPUTER/TEACH/ART BLK G	COMPUTER/TEACH/ART BLK G		Roof Level 1	EXTERNAL	CORRUGATED SHEET ROOF CLADDING PHOTO 16, SIM SAMPLE 1939	Roof Sheeting	Cement Based		1	Presumed	37	-	

TAFES from BEMIR-TAFES

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAGG	23789016	COMPUTER/TEACH/ART BLK G	COMPUTER/TEACH/ART BLK G		Ground Floor	OPEN AREA	REMOVED BY CLIENT - OUTER SKIN TO SUI KILM STORE IN OPEN AREA BLOCK G	Plant, Equipment & Machinery	Millboard	Mixed	2	Removed	69	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAGG	23789016	COMPUTER/TEACH/ART BLK G	COMPUTER/TEACH/ART BLK G		Ground Floor	PLANT ROOM	2 X GASKETS TO THE RADAC HEAT EXCHANGE	Plant, Equipment & Machinery	Millboard	CHR - Chrysotile	3	Removed	64	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAGG	23789016	COMPUTER/TEACH/ART BLK G	COMPUTER/TEACH/ART BLK G		Ground Floor	W SIDE ENTRANCE	SOFFIT OF AWNING OVER MAIN ENTRANCE AT BASE OF STAIRWELL. SIM SAMPLE 1930	Ceiling	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAGG	23789016	COMPUTER/TEACH/ART BLK G	COMPUTER/TEACH/ART BLK G		Level 1	ALL AREAS	PITCHED FIBRE CEMENT SHEET CLG ABOVE LOWER SUSPENDED CEILING PHOTO 17. SIM SAMPLE 1930	Ceiling	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAGG	23789016	COMPUTER/TEACH/ART BLK G	COMPUTER/TEACH/ART BLK G		Level 1	S CLASSROOM	INSULATION TO A/C HEATER BANK IN CLG SPACE, N CLASSROOM HAS SAME HEATER BANK IN CLG	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Testing)		-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAGG	23789016	COMPUTER/TEACH/ART BLK G	COMPUTER/TEACH/ART BLK G		Various levels External	EXTERNAL	FLUE PIPE EXTENDING UP S WALL (BASE OF PIPE IS CAST IRON) PHOTO 18. SIM SAMPLE 1912	Drains/Pipes/Furniture	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAGG	23789016	COMPUTER/TEACH/ART BLK G	COMPUTER/TEACH/ART BLK G	External	Level 1	EXTERNAL	FIBRE ASBESTOS BOARD AWING LINING TO THE MAIN ENTRANCE SIM SAMPLE 926809-11	Gable/Soffit/Facade	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAGG	23789016	COMPUTER/TEACH/ART BLK G	COMPUTER/TEACH/ART BLK G	External	Level 1	EXTERNAL	FIBRE CEMENT SHEET EAVES LINING TO BUILDING SIM SAMPLE 1930 - CHR	Gable/Soffit/Facade	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Various levels External	EXTERNAL	FIBRE CEMENT SHEET EAVES AROUND BUILDING PERIMETER	Gable/Soffit/Facade	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Testing)		-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H	External	Roof Level 1	EXTERNAL	CORRUGATED SHEET ROOF CLADDING	Roof Sheeting	Cement Based	CHR - Chrysotile	1	Confirmed	37	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H	Internal	Level 1	TOOLS STORE ROOM H104 STORE ROOM COUNTER	GREEN SHEET VINYL ON COUNTER	Furniture	Vinyl Sheeting (includes backing)		4	Not Present(Testing)		-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H	Internal	Ground Floor	INTERNAL	REMOVED IN 2008 - ASBESTOS CEMENT WALL, PANELS TO THE WELDING BOOTHS	Wall	Cement Based		2	Removed	34	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	SHEET METAL	FIBRE CEMENT SHEET LINING N END OF E WALL OF SHEET METAL STORE. SIM SAMPLE 1930	Wall	Cement Based		3	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	W ENTRY FOYER	CEILING PANELS TO WEST SIDE ENTRY FOYER. SIM SAMPLE 1937	Ceiling	Cement Based		3	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	STORE ROOM	FIBRE CEMENT SHEET CEILING TILES TO STORE ROOM	Ceiling	Cement Based	CHR - Chrysotile	3	Confirmed	19	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	STORE ROOM	BLUE VINYL FLOOR TILES TO STORE ROOM	Floor	Vinyl Tiles	CHR - Chrysotile	3	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H	Internal	Ground Floor	INTERNAL	ASBESTOS CEMENT WALL, PANELS TO THE WEST END FOYER & ADJACENT ROOM	Wall	Cement Based	Mixed	4	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	STORE ROOM	BACKING TO SHEET VINYL ON TOP SERVERY SHELF	Furniture	Vinyl Sheeting (includes backing)		NA	Not Present(Testing)		-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	N/E CLASSROOM	MOTTLED GREY VINYL FLOOR TILES TO N/E CLASSROOM	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Testing)		-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	W ENTRY FOYER	NORTH, SOUTH AND EAST WALLS OF WEST SIDE ENTRY FOYER. SIM SAMPLE 1930	Wall	Cement Based		3	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	HQ-7	WALL PANELS TO MALE TOILET, ADJACENT WEST SIDE ENTRY FOYER. SIM SAMPLE 1930	Wall	Cement Based		3	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	EXTERNAL	1 X D T SURROUND TO DRAIN NORTH END OF H BLOCK	Drains/Pipes/Furniture	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	S END OFFICE	VINYL FLOOR SHEETING TO SOUTH END OFFICE	Floor	Polymer Based	No asbestos detected (NAD)	4	Not Present(Testing)		-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	NW OFFICE	FLOOR TILES TO NW OFFICE REFER SAMPLE 1936	Floor	Vinyl Tiles		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	ELECTRICIAN ROOM	300 X 300 MM FLOOR TILES IN THE ELECTRICIAN ROOM	Floor	Vinyl Tiles		3	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	HQ-16	WALL PANELS TO ACETYLENE STORE, WEST SIDE OF BUILDING. SIM SAMPLE 1930	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	JOB STORE	BROWN VINYL FLOOR TILES TO JOBSTORE	Floor	Vinyl Tiles	CHR - Chrysotile	3	Removed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	CLEANERS STORE	WALL PANELS TO CLEANERS STORE ADJ TO ACETYLENE STORE, W SIDE OF BLDG. SIM SAMPLE 1930	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	CLEANERS STORE	FLOOR TILES TO CLEANERS STORE ADJ TO ACETYLENE STORE, W SIDE OF BLDG. SIM SAMPLE 1938	Floor	Vinyl Tiles		3	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	JOB STORE	WALL PANELS TO JOB STORE. SIM SAMPLE 1930	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	LPG STORE	CEILING PANELS TO LPG CYLINDER STORE, S/W CORNER OF BUILDING. SIM SAMPLE 1930	Ceiling	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	MAIN WORKSHOP	24 WELDING BOOTHS-COMPRESSED SHEET & ASBESTOS CEMENT. (SDMEDAMG02)	Furniture	Cement Based		24	Removed	34	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	NW CLASSROOM	LIGHT GREEN VINYL FLOOR TILES TO NW CLASSROOM	Floor	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Testing)		-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAHH	23789015	SHEET METAL WORK BLK H	SHEET METAL WORK BLK H		Ground Floor	HQ-16	CEILING PANELS TO ACETYLENE STORE, WEST SIDE OF BUILDING. SIM SAMPLE 1930	Ceiling	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAKK	23789026	PLUMBING/TEACH BLK K	PLUMBING/TEACH BLK K		Level 1	GAS FITTING	REMOVED BY CLIENT - SEAL TO GAS HEAT UNIT TRAINING AID	Plant, Equipment & Machinery	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAKK	23789026	PLUMBING/TEACH BLK K	PLUMBING/TEACH BLK K		Level 1	BOILER AREA	SEAL TO CREMATING UNIT BESIDE THE GAS BOILER	Plant, Equipment & Machinery	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAKK	23789026	PLUMBING/TEACH BLK K	PLUMBING/TEACH BLK K		Level 1	HOT WATER SECTION	REMOVED BY CLIENT - LINING TO GREEN HOT STEAM DISPLAY HWATER UNIT	Plant, Equipment & Machinery	Millboard	CHR - Chrysotile	2	Removed	69	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAKK	23789026	PLUMBING/TEACH BLK K	PLUMBING/TEACH BLK K		Level 1	EXTERNAL	1 X D T SURROUND ON THE NORTHERN ELEVATION	Drains/Pipes/Furniture	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAKK	23789026	PLUMBING/TEACH BLK K	PLUMBING/TEACH BLK K		Ground Floor	TOILETS	COMPRESSED SHEET TOILET CUBICLE PARTITIONS SIMILAR SAMPLE 1942 - NAD	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAKK	23789026	PLUMBING/TEACH BLK K	PLUMBING/TEACH BLK K		Ground Floor	HQ-4	FASCIA PANNELLING AT TOP OF EXTERIOR WALLS OF STORE ROOM SIM SAMPLE 1937	Gable/Soffit/Facade	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAKK	23789026	PLUMBING/TEACH BLK K	PLUMBING/TEACH BLK K		Ground Floor	HQ-4	CEILING PANELS TO STORE ROOM SOUTH WEST CORNER OF WORKSHOP SIM SAMPLE 1937	Ceiling	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAKK	23789026	PLUMBING/TEACH BLK K	PLUMBING/TEACH BLK K		Ground Floor	E END ROOMS	FIBRE CEMENT SHEET WALLS TO TOILETS, CORRIDOR AND STAFF ROOM. SIM SAMPLE 1937 - NAD	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAKK	23789026	PLUMBING/TEACH BLK K	PLUMBING/TEACH BLK K		Ground Floor	E END ROOMS	FIBRE CEMENT SHEET CEILINGS TO TOILETS, CORRIDOR AND STAFFROOM. SIM SAMPLE 1937	Ceiling	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAKK	23789026	PLUMBING/TEACH BLK K	PLUMBING/TEACH BLK K		Ground Floor	E END ROOMS	BROWN VINYL FLOOR TILES TO CORRIDOR, KITCHEN & SECTION OF CLASSROOM. REFER SAMPLE 1944	Floor	Vinyl Tiles		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAKK	23789026	PLUMBING/TEACH BLK K	PLUMBING/TEACH BLK K	Mezzanine # 1	MEZZANINE	MEZZANINE	SHEETING STORED ON MEZZA. LEVEL ABOVE STORE	Stored Material	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGALL	23788024	BOAT WORKSHOP BLK L	BOAT WORKSHOP BLK L		Ground Floor	L1-03 & L1-06	CUBICLE PARTITIONS TO MALE AND FEMALE TOILETS SIMILAR SAMPLE 1942	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGALL	23788024	BOAT WORKSHOP BLK L	BOAT WORKSHOP BLK L		Ground Floor	L1-03, 05, 06	FIBRE CEMENT SHEET CEILINGS TO MALE, FEMALE AND HANDICAPPED TOILETS. SIM SAMPLE 1937	Ceiling	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGALL	23788024	BOAT WORKSHOP BLK L	BOAT WORKSHOP BLK L		Various levels Internal	MOST ROOMS	WALL LININGS TO STORE ROOMS, CLASSROOM AND STAFF ROOM SIM SAMPLE 1937	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAMM		M Block	M Block		Ground Floor	VARIOUS AREAS	INFILL PANELS ATTACHED TO TIMBER FRAMEWORK IN SEVERAL AREAS OF THE CEILING	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Testing)		-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAOO	23789023	LIBRARY BLK O	LIBRARY BLK O		Level 1	EXTERNAL	1 X D T SURROUND ON THE SOUTHERN ELEVATION	Drains/Pipes/Furniture	Cement Based	Mixed	4	Confirmed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAOO	23789023	LIBRARY BLK O	LIBRARY BLK O		Roof Level 1	ATRIUM	SHEETING TO THE ATRIUM CEILING	Ceiling	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAOO	23789023	LIBRARY BLK O	LIBRARY BLK O		Ground Floor	L	SUSPECTED MILLBOARD LINING TO 4 A/C HEATER BANKS (CONDITION UNKNOWN-NOT ACCESSIBLE)PHOTO22	Heater Bank Insulation	Millboard		4	Removed	64	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAOO	23789023	LIBRARY BLK O	LIBRARY BLK O		Ground Floor	Room description not provided	FIBRE CEMENT SHEET SOFFIT OF AWNING/COVERED WALKWAY - PERIMETER OF BLDG. PHOTO 23	Gable/Soffit Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAOO	23789023	LIBRARY BLK O	LIBRARY BLK O		Ground Floor	CONFERENCE ROOM	FIBRE CEMENT SHEET CEILING TILES OF TOILET, OFF CONFERENCE ROOM	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAOO	23789023	LIBRARY BLK O	LIBRARY BLK O		Ground Floor	CONFERENCE ROOM	FIBRE CEMENT SHEET PARTITION WALL OF TOILET, OFF CONFERENCE ROOM. SIM SAMPLE 1952	Wall	Cement Based		4	Presumed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAOO	23789023	LIBRARY BLK O	LIBRARY BLK O		Ground Floor	M & F TOILETS	COMPRESSED SHEET CURBICLE PARTITIONS TO MALE AND FEMALE TOILETS. PHOTO NO. 24	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAPP		P Block	P Block											-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGAQQ		Q Block	Q Block											-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JGASS		S Block	S Block											-	
Skills Tech Australia		EAGLE FARM TAFE CAMPUS	EAGLE FARM TAFE CAMPUS	JOATT		T Block	T Block											-	
Skills Tech Australia		SALISBURY TAFE CAMPUS	SALISBURY TAFE CAMPUS	JSL	49551000	* Site - Grounds	* Site - Grounds											-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694000	25694000	SITE GROUNDS	SITE GROUNDS		External	Ground Floor	HAND RADIO DEMOUNT EXTERIOR	Wall	Other (refer to description)	No asbestos detected	4	Removed		-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694000	25694000	SITE GROUNDS	SITE GROUNDS		Internal	Ground Floor	FERN HOUSE	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694000	25694000	SITE GROUNDS	SITE GROUNDS		Internal	Ground Floor	HAND RADIO DEMOUNT INTERIOR	Wall	Cement Based		4	Removed	18	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 1	STAIRWELL 1	Fire Door	Cement Based		4	Removed	18	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 1	ROOM 1.08 STUDENT	Ceiling	Sprayed Coating		4	Removed	64	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 1	ROOM 1.09 KITCHEN	Wall	Other (refer to description)	No asbestos detected	4	Removed		-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 1	ROOM 1.11 DRY STORE	Wall	Cement Based		4	Removed	18	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 1	ROOM 1.15 AUDIO CONT	Floor Finish/Covering	Vinyl Tiles	No asbestos detected	4	Removed	18	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 1	ROOM 1.07 STUDENT	Ceiling	Other (refer to description)	No asbestos detected	4	Removed		-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 1	ROOM 1.17 CONTROL RM	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Removed	62	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Ground Floor	THE BUILDING	Floor Finish/Covering	Cement Based		4	Removed	18	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 1	STD COUNCELLOR	Ceiling	Sprayed Coating		4	Removed	64	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 1	ROOM 1.16 CONTROL RM	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Removed	62	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 1	ROOM 1.05 STUDENT	Ceiling	Sprayed Coating		4	Removed	64	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 1	ROOM 1.04 STUDENT	Ceiling	Sprayed Coating		4	Removed	64	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 1	ROOM 1.02 PASSAGE	Ceiling	Sprayed Coating		4	Removed	64	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 1	STUDENT EMPLOY	Ceiling	Sprayed Coating		4	Removed	64	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Basement 1	STAIRWELL 1	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Basement 1	FIRE PUMP ENCL	Gasket	Polymer Bound		4	Removed	25	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Basement 1	FIRE PUMP ENCL	Gasket	Polymer Bound		4	Removed	25	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Basement 1	CAR PARK BASEMENT 1	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Basement 1	CAR PARK BASEMENT 1	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 2	ROOM 2.38 PASSAGE	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Removed	62	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 1	ROOM 1.03 ADMIN RECP	Ceiling	Sprayed Coating		4	Removed	64	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 7	LIFT MOTOR RM	Plant, Equipment & Machinery	Polymer Bound	CHR - Chrysotile	4	Removed	25	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 1	STUDENT LOUNGE	Ceiling	Sprayed Coating		4	Removed	64	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 2	ROOM 2.25 MALE	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Removed	52	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 7	STAIRWELL 1	Fire Door	Cement Based		4	Removed	18	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 6	STAIRWELL 1	Fire Door	Cement Based		4	Removed	18	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 6	PLANT ROOM	Heater Bank Insulation	Millboard		4	Removed	64	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 5	STAIRWELL 1	Fire Door	Cement Based		4	Removed	18	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 5	PLANT ROOM	Heater Bank Insulation	Millboard		4	Removed	64	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 4	STAIRWELL 1	Fire Door	Cement Based		4	Removed	18	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 4	PLANT ROOM	Heater Bank Insulation	Millboard		4	Removed	64	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 3	STAIRWELL 1	Fire Door	Cement Based		4	Removed	18	-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 3	PLANT ROOM	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 2	TAPES ROOM	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
Southbank		ACACIA RIDGE SKILLS TECH	STH BRIS SBI TAFE	25694002	25694002	STH BRIS COTAFE BLK F	STH BRIS COTAFE BLK F		Internal	Level 2	ROOM 2.18 KITCHEN	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Removed	62	-	

TAFEs from BEMIR-TAFEs

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Southbank		ACACIA RIDGE SKILLS TECH	5TH BRIS SBI TAFE	25694002	25694002	5TH BRIS COTAFE BLK F	5TH BRIS COTAFE BLK F	Internal	Level 2	ROOM 2.36 PRINT RM	BROWN PATTERNED VINYL SHEETING SIMILAR TO SAMPLE 2585 (NAD)	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Removed	62	-	
Southbank		ACACIA RIDGE SKILLS TECH	5TH BRIS SBI TAFE	25694002	25694002	5TH BRIS COTAFE BLK F	5TH BRIS COTAFE BLK F	Internal	Level 1	SUPPORT OFFICER	VERMICULITE TO UNDERSIDE OF CONCRETE FLOOR ABOVE SIMILAR TO SAMPLE 2586 (NAD)	Ceiling	Sprayed Coating		4	Removed	64	-	
Southbank		ACACIA RIDGE SKILLS TECH	5TH BRIS SBI TAFE	25694002	25694002	5TH BRIS COTAFE BLK F	5TH BRIS COTAFE BLK F	Internal	Level 2	ROOM 2.28 MASTR CONT	BROWN PATTERNED VINYL SHEETING SIMILAR TO SAMPLE 2585 (NAD)	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Removed	62	-	
Southbank		ACACIA RIDGE SKILLS TECH	5TH BRIS SBI TAFE	25694002	25694002	5TH BRIS COTAFE BLK F	5TH BRIS COTAFE BLK F	Internal	Level 2	PLANT ROOM	INTERNAL LINING TO HEATERBANKS X 8	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
Southbank		ACACIA RIDGE SKILLS TECH	5TH BRIS SBI TAFE	25694002	25694002	5TH BRIS COTAFE BLK F	5TH BRIS COTAFE BLK F	Internal	Level 2	ROOM 2.24 DRESSING	BROWN PATTERNED VINYL SHEETING SIMILAR TO SAMPLE 2585 (NAD)	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Removed	62	-	
Southbank		ACACIA RIDGE SKILLS TECH	5TH BRIS SBI TAFE	25694002	25694002	5TH BRIS COTAFE BLK F	5TH BRIS COTAFE BLK F	Internal	Level 2	ROOM 2.23 FEMALE	BROWN PATTERNED VINYL SHEETING SIMILAR TO SAMPLE 2585 (NAD)	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Removed	62	-	
Southbank		ACACIA RIDGE SKILLS TECH	5TH BRIS SBI TAFE	25694002	25694002	5TH BRIS COTAFE BLK F	5TH BRIS COTAFE BLK F	Internal	Level 2	ROOM 2.22 LIBRARY	BROWN PATTERNED VINYL SHEETING SIMILAR TO SAMPLE 2585 (NAD)	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Removed	62	-	
Southbank		ACACIA RIDGE SKILLS TECH	5TH BRIS SBI TAFE	25694002	25694002	5TH BRIS COTAFE BLK F	5TH BRIS COTAFE BLK F	Internal	Level 2	ROOM 2.20 2 LIBRARY	BROWN PATTERNED VINYL SHEETING MORE TESTS REQUIRED TO VERIFY PRESENCE OF ASBESTOS	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
Southbank		ACACIA RIDGE SKILLS TECH	5TH BRIS SBI TAFE	25694002	25694002	5TH BRIS COTAFE BLK F	5TH BRIS COTAFE BLK F	Internal	Level 2	STAIRWELL 1	INTERNAL LINING TO EXIT FIRE DOORS (TYPICAL ENTIRE LEVEL) SIMILAR TO SAMPLE 2585 (NAD)	Fire Door	Cement Based		4	Removed	16	-	
Southbank		ACACIA RIDGE TAFE CAMPUS	5th Bris COTAH	29912002	29912002	BLOCK D	BLOCK D												-
Southbank		ACACIA RIDGE TAFE CAMPUS	5TH BRIS SBI TAFE	25694013	25694013	BLOCK A	BLOCK A												-
Southbank		KANGAROO PT TAFE ANNEXE	KANGAROO PT TAFE ANNEXE	31882000	31882000	" Site - Grounds	" Site - Grounds												-
Southbank		MORNINGSIDE	MORNINGSIDE	AMS	25700000	" Site Grounds	" Site Grounds												-
Southbank		5TH BRIS CONTEMP MUSIC	5TH BRIS CONTEMP MUSIC	31073000	31073000	" Site - Grounds	" Site - Grounds												-
Southern Queensland		CHARLEVILLE TAFE CAMPUS	CHARLEVILLE TAFE CAMPUS	NCVAA	29448001	A Block	A Block	External	Whole Building (asbestos free)	A BLOCK	BUILT AFTER 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		CHARLEVILLE TAFE CAMPUS	CHARLEVILLE TAFE CAMPUS	NCVBB	29448002	G BLOCK (AMENITIES)	G BLOCK (AMENITIES)												-
Southern Queensland		CHINCHILLA TAFE CAMPUS	CHINCHILLA TAFE CAMPUS	NCC	37745000	" Site - Grounds	" Site - Grounds												-
Southern Queensland		CHINCHILLA TAFE CAMPUS	CHINCHILLA TAFE CAMPUS	NCCAA	37745001	A Block	A Block												-
Southern Queensland		DALBY TAFE CAMPUS	DALBY TAFE CAMPUS	NDA	20287000	" Site - Grounds	" Site - Grounds												-
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKI	23933000	SITE	SITE	Internal	Ground Floor	SMOKO SHED	ALL VINYL FLOOR TILES CONTAINS NIL ASBESTOS	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKI	23933000	SITE	SITE	External	Ground Floor	SMOKO SHED EXTERNAL	WALL SHEETING	Wall	Cement Based	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKI	23933000	SITE	SITE	External	Site / Grounds	DUPLICATE ENTRY - SMOKO SHED EXTERNAL									-
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKI	23933000	SITE	SITE	External	Ground Floor	SMOKO SHED EXTERNAL	SOFFIT SHEETING	Gable/Soffit Based	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKI	23933000	SITE	SITE	Internal	Ground Floor	SMOKO SHED	ALL FIBROUS WALL SHEETINGS ARE SUSPECTED ACM - SIM SAMPLE 0532 - NIL ASBESTOS DETECTED	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKI	23933000	SITE	SITE	Internal	Ground Floor	SMOKO SHED	ALL FIBROUS CEILING SHEETINGS ARE SUSPECTED ACM - SIM SAMPLE 0532 - NIL ASBESTOS DETECTED	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK081		Engine Testing - C Block	Engine Testing - C Block												-
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK082	23933010	Flammable Store	Flammable Store												-
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK084	23933018	Grounds Shed	Grounds Shed	External	Ground Floor	GARDEN SHED EXTERNAL	ALL FIBROUS SOFFIT SHEETINGS ARE SUSPECTED ACM	Gable/Soffit Based	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK084	23933018	Grounds Shed	Grounds Shed	Internal	Ground Floor	GARDEN SHED	ALL FIBROUS BENCH TOP COMPRESSED AC IS SUSPECTED ACM	Furniture	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK084	23933018	Grounds Shed	Grounds Shed	Internal	Ground Floor	GARDEN SHED	ALL FIBROUS CEILING SHEETING ARE SUSPECTED ACM	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK084	23933018	Grounds Shed	Grounds Shed	Internal	Ground Floor	GARDEN SHED	ALL FIBROUS CEILING SHEETING ARE SUSPECTED ACM	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK084	23933018	Grounds Shed	Grounds Shed	Internal	Ground Floor	GARDEN SHED	ALL FIBROUS WALL SHEETINGS ARE SUSPECTED ACM	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK085	23933004	Pump House	Pump House												-
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK086		Machinery Shed	Machinery Shed												-
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK087	23933020	Hay Shed	Hay Shed												-
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK088		Igloo	Igloo												-
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK089		Storage Shed/Classroom	Storage Shed/Classroom												-
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK110		Storage/Toilet	Storage/Toilet												-
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK1AA	23933006	A Block	A Block	Internal	Ground Floor	TAABINGA ROOM	ALL SHEET VINYL IN BAR AREA SIM SAMPLE 0529 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK1AA	23933006	A Block	A Block	Internal	Ground Floor	ROOM A1.20 STORE	ALL FIBROUS CEILING SHEETING ARE SUSPECTED ACM	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK1AA	23933006	A Block	A Block	Internal	Ground Floor	ROOM A1.20 STORE	ALL FIBROUS WALL SHEETING ARE SUSPECTED ACM	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK1AA	23933006	A Block	A Block	Internal	Level 1	SW END STAIRWELL	ALL SHEET VINYL FLOOR COVERINGS	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK1AA	23933006	A Block	A Block	Internal	Ground Floor	ROOM A1.23	ALL FIBROUS CEILING SHEETING - SIM SAMPLE 0530 - NIL ASBESTOS DETECTED	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK1AA	23933006	A Block	A Block	Internal	Ground Floor	ROOM A1.22	ALL FIBROUS CEILING SHEETING IS SUSPECTED OF ACM	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK1AA	23933006	A Block	A Block	Internal	Ground Floor	STAFF MEN'S TOILETS	ALL VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK1AA	23933006	A Block	A Block	Internal	Ground Floor	ROOM A1.20 KITCHEN	ALL FIBROUS WALL SHEETING BEHIND WALL TILES ARE SUSPECTED ACM	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK1AA	23933006	A Block	A Block	Internal	Ground Floor	TAABINGA ROOM	ALL VINYL FLOOR TILES ARE SIM SAMPLE 0526 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK1AA	23933006	A Block	A Block	Internal	Level 1	ROOM A2.09	ALL SHEET VINYL FLOOR COVERING SIM SAMPLES 0529 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK1AA	23933006	A Block	A Block	Internal	Ground Floor	STAFF MEN'S TOILETS	ALL FIBROUS CEILING SHEET SIM SAMPLE 0530 - NIL ASBESTOS DETECTED	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK1AA	23933006	A Block	A Block	Internal	Ground Floor	TOILET	ALL CEILING SHEETING HANDICAPPED TOILET - SIM SAMPLE 0530 - NIL ASBESTOS DETECTED	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK1AA	23933006	A Block	A Block	Internal	Ground Floor	ROOM A1.12	ALL VINYL FLOOR TILES - SIM SAMPLE 0526 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NK1AA	23933006	A Block	A Block	Internal	Ground Floor	ROOM A1.11	ALL VINYL FLOOR TILES ARE - SIM SAMPLE 0526 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIAA	23933006	A Block	A Block	Internal	Ground Floor	ROOM A1.04	ALL VINYL FLOOR TILES ARE - SIM SAMPLE 0526 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIAA	23933006	A Block	A Block	Internal	Ground Floor	ROOM A1.03	ALL VINYL FLOOR TILES ARE - SIM SAMPLE 0526 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIAA	23933006	A Block	A Block	Internal	Ground Floor	KITCHEN DINING	ALL VINYL FLOOR TILES SIM SAMPLE 0526 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIAA	23933006	A Block	A Block	Internal	Ground Floor	HALLWAY RECEPTION	ALL VINYL FLOOR TILES ARE - SIM SAMPLE 0526 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIAA	23933006	A Block	A Block	Internal	Ground Floor	FEMALE STAFF TOILETS	ALL FIBROUS CEILING SHEET IS SUSPECTED ACM (FEMALE STAFF TOILETS)	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIAA	23933006	A Block	A Block	Internal	Ground Floor	FASHION STUDIES	ALL VINYL FLOOR TILES ARE - SIM SAMPLE 0526 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIAA	23933006	A Block	A Block	External	Ground Floor	SOFFIT	ALL FIBROUS SOFFIT SHEETING IS SUSPECTED ACM	Cable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIAA	23933006	A Block	A Block	External	Ground Floor	EXTERNAL WALLS	ALL FIBROUS EXTERNAL WALL SHEET IS - SIM SAMPLE 0528 - NIL ASBESTOS DETECTED	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIAA	23933006	A Block	A Block	Internal	Ground Floor	SW STAIRWELL FOYER	ALL VINYL FLOOR TILES SIM SAMPLE 0526 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIAA	23933006	A Block	A Block	Internal	Ground Floor	ROOM A1.20 KITCHEN	ALL FIBROUS CEILING SHEETING SIM SAMPLE 0530 - NIL ASBESTOS DETECTED	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIBB	23933021	B Block	B Block	Internal	Ground Floor	ROOM B1.03	ALL SHEET VINYL FLOOR COVERINGS SIM SAMPLE 0529	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIBB	23933021	B Block	B Block	Internal	Ground Floor	ROOM B1.06	ALL SHEET VINYL FLOOR COVERINGS SIM SAMPLE 0529 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIBB	23933021	B Block	B Block	Internal	Ground Floor	ROOM B1.02	SHEET VINYL IN FRONT OF SINK - SIM SAMPLE 0529	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.03 MALE TOILET	ALL FIBROUS CEILING SHEETING IN MALE TOILET IS ASBESTOS FREE	Ceiling	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.19	ALL FIBROUS PERFORATED CEILING SHEETING - SIM SAMPLE 0527	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.09	ALL SHEET VINYL FLOOR COVERINGS SIM SAMPLE 0529	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.10	ALL PERFORATED CEILING SHEETING IS ASBESTOS FREE	Ceiling	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.10 WELDING ROOM	ALL PERFORATED & FLAT WALL SHEETING IN WELDING ROOM IS ASBESTOS FREE	Wall	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.15	ALL FIBROUS PERFORATED CEILING SHEETING ASBESTOS FREE	Ceiling	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.15	ALL FIBROUS WALL SHEETING IS ASBESTOS FREE	Wall	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.05	ALL PERFORATED CEILING SHEETING CONTAINS NIL ASBESTOS	Ceiling	Other (refer to description)		4	Presumed	-	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.16	ALL FIBROUS FLAT AND PERFORATED SHEETING IS ASBESTOS FREE	Wall	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.16	ALL PERFORATED CEILING SHEETING IS ASBESTOS FREE	Ceiling	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.17	ALL SHEET VINYL FLOOR COVERINGS SIM SAMPLE 0527	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.18	ALL SHEET VINYL FLOOR COVERINGS SIM SAMPLE 0527	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.19	ALL FIBROUS FLAT & PERFORATED WALL SHEETING - SIM SAMPLE 0527	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.08	ALL SHEET VINYL FLOOR COVERINGS SIM SAMPLE 0529	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.20 STORE	ALL FIBROUS CEILING SHEETING SIM SAMPLE 0527	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.22 OFFICE	ALL FIBROUS WALL SHEETING SIM SAMPLE 0527	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.22 STORE	ALL FIBROUS PERFORATED CEILING SHEETING - SIM SAMPLE 0527	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.22 STORE	ALL FIBROUS WALL SHEETINGS SIM SAMPLE 0527	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.23	ALL PERFORATED CEILING & WALL SHEETING - SIM SAMPLE 0527	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.24	ALL PERFORATED FIBROUS CEILING SHEETING - SIM SAMPLE 0527	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.26	NO ASBESTOS MATERIALS WERE FOUND AT TIME OF AUDIT	Wall	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.04 STAF	ALL FIBROUS CEILING SHEETING IS ASBESTOS FREE	Ceiling	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.02 FEMALE TOILET	ALL FIBROUS CEILING SHEETING IN FEMALE TOILET IS ASBESTOS FREE	Ceiling	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.01	ALL FIBROUS CEILING SHEETING INCLUDING SKYLIGHTS ARE ASBESTOS FREE	Ceiling	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	INTERIOR WALL	ALL PERFORATED AND FLAT WALL SHEETING IS ASBESTOS FREE	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	External	Ground Floor	SOFFIT	ALL FIBROUS SOFFIT SHEETING IS ASBESTOS FREE	Cable/Soffit/Fascia	Cement Based		4	Not Present(Not Tested)	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.04 STAF	ALL SHEET VINYL FLOOR COVERINGS ARE ASBESTOS FREE	Floor Finish/Covering	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKICC	23933009	C Block	C Block	Internal	Ground Floor	ROOM C1.04 STAF	ALL FIBROUS WALL SHEETINGS ARE ASBESTOS FREE	Wall	Other (refer to description)		4	Not Present(Not Tested)	-	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMR Score	Assessment Required	Comments
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.25	ALL SHEET VINYL - SIM SAMPLE 0529	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.03	ALL SHEET VINYL FLOOR COVERINGS SIM SAMPLE 0529 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.11	ALL FIBROUS FLAT & PERFORATED WALL SHEETING - SIM SAMPLE 0527	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.11	ALL FIBROUS CEILING SHEETING SIM SAMPLE 0527 - NIL ASBESTOS DETECTED	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.09	ALL SHEET VINYL FLOOR COVERINGS SIM SAMPLE 0529 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.09	ALL FIBROUS FLAT & PERFORATED WALL SHEETING - SIM SAMPLE 0527	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.09	ALL FIBROUS CEILING SHEETING SIM SAMPLE 0527 - NIL ASBESTOS DETECTED	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.08	ALL SHEET VINYL FLOOR COVERINGS SIM SAMPLE 0529 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.07	ALL SHEET VINYL FLOOR COVERINGS SIM SAMPLE 0529 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.05	ALL SHEET VINYL FLOOR COVERINGS SIM SAMPLE 0529 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.26	ALL FIBROUS SHEETING ON WORK BENCHES IS NA	Wall	Other (refer to description)		4	Presumed		-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.05	ALL FIBROUS CEILING SHEETING SIM SAMPLE 0527 - NIL ASBESTOS DETECTED	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.13	ALL FIBROUS FLAT & PERFORATED SHEETING - SIM SAMPLE 0527	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.03	ALL FIBROUS CEILING SHEETING CONTAINS NIL ASBESTOS	Ceiling	Other (refer to description)		4	Presumed		-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.02 MALE TOILET	ALL FIBROUS CEILING SHEETING SIM SAMPLE 0527 - NIL ASBESTOS DETECTED	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.01 LADIES	ALL FIBROUS CEILING SHEETING SIM SAMPLE 0527 - NIL ASBESTOS DETECTED	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	QOLN ROOM	ALL SHEET VINYL FLOOR COVERINGS SIM SAMPLE 0529 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	QOLN ROOM	ALL FIBROUS WALL SHEETING SIM SAMPLE 0527	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	QOLN ROOM	ALL FIBROUS CEILING SHEETING SIM SAMPLE 0527 - NIL ASBESTOS DETECTED	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	CLEANERS ROOM	ALL FIBROUS CEILING SHEETING IS SUSPECTED ACM	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	External	Ground Floor	SOFFIT	ALL FIBROUS SOFFIT SHEETING IS SUSPECTED ACM	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	External	Ground Floor	ROOM D1.05 CHIMNEY	CHIMNEY IS SUSPECTED ACM	Drains/Pipes/Roof	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.05	ALL FIBROUS FLAT & PERFORATED WALL SHEETING - SIM SAMPLE 0527	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.26	ALL FIBROUS CEILING PERFORATED SHEETING - SIM SAMPLE 0527	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.11	ALL SHEET VINYL FLOOR COVERINGS SIM SAMPLE 0529 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.26	ALL FLAT & PERFORATED WALL SHEETING - SIM SAMPLE 0527	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.13	ALL FIBROUS CEILING SHEETING SIM SAMPLE 0527 - NIL ASBESTOS DETECTED	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.24	ALL SHEET VINYL - SIM SAMPLE 0529	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.20	ALL FIBROUS PERFORATED CEILING SHEETING - SIM SAMPLE 0527 - NIL ASBESTOS DETECTED	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.18	ALL FIBROUS FLAT & PERFORATED SHEETING - SIM SAMPLE 0527	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.18	ALL FIBROUS CEILING SHEETING SIM SAMPLE 0527 - NIL ASBESTOS DETECTED	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.17	ALL SHEET VINYL FLOOR COVERINGS SIM SAMPLE 0529 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.16	ALL SHEET VINYL FLOOR COVERINGS SIM SAMPLE 0529 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIDD	23933008	D Block	D Block	Internal	Ground Floor	ROOM D1.20	ALL FIBROUS FLAT & PERFORATED WALL SHEETING - SIM SAMPLE 0527	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIEE	23933015	E Block	E Block	Internal	Ground Floor	ROOM E1.02	ALL FIBROUS WALL SHEETING ARE SUSPECTED ACM	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIEE	23933015	E Block	E Block	External	Site / Grounds	SITE PIPEWORK	ALL PIPES ON EXTERNAL FENCE ON BLOCK E ON SE BOUNDARY ARE SUSPECTED ACM	Drains/Pipes/Fittings	Cement Based		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIEE	23933015	E Block	E Block	Internal	Ground Floor	ROOM E1.02	ALL FLOOR TILES SIM SAMPLE 0532 - NIL ASBESTOS DETECTED	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Southern Queensland		KINGAROY TAFE CAMPUS	KINGAROY TAFE CAMPUS	NKIEE	23933015	E Block	E Block	Internal	Ground Floor	ROOM E1.04	ALL FIBROUS WALL SHEETINGS ARE SUSPECTED ACM	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		NURUNDERI CHERBOURG TAFE	NURUNDERI CHERBOURG TAFE	NNR	30957000	"Site Grounds"	"Site Grounds"	Internal	Ground Floor									-	
Southern Queensland		NURUNDERI CHERBOURG TAFE	NURUNDERI CHERBOURG TAFE	NNR01		Shed	Shed											-	
Southern Queensland		NURUNDERI CHERBOURG TAFE	NURUNDERI CHERBOURG TAFE	NNRAA	30957001	A Block	A Block											-	
Southern Queensland		NURUNDERI CHERBOURG TAFE	NURUNDERI CHERBOURG TAFE	NNRB2		Kiln	Kiln											-	
Southern Queensland		NURUNDERI CHERBOURG TAFE	NURUNDERI CHERBOURG TAFE	NNRB0	30957002	B Block	B Block											-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS		22350003	SPORTS FIELD/TOILET	SPORTS FIELD/TOILET	External	Ground Floor	PERIMETER	WALL SHEETING - BOXING FOR FOUNDATIONS	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS		22390018	TENNIS COURTS	TENNIS COURTS	External	Whole Building (asbestos free)	CONSTRUCTED POST 1990	DUPLICATE ENTRY - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		3	Not Present(Not Tested)		-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS		22350020	MAINTENANCE/CARPENTER BLOC	MAINTENANCE/CARPENTER ER BLOC	Internal	Whole Building (asbestos free)	BUILT POST 1990	BUILT AFTER 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		3	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350006	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	TOILETS	COMPRESSED SHEETING TO CEILING & SKYLIGHTS IN MALE & FEMALE TOILETS & CLEANERS ROOM	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	WELDING STORE	PLY CEILING SHEETING	Ceiling	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	STAFFROOM	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	STAFFROOM	BLOCKWORK WALL SHEETING - EASTERN, SOUTHERN & WESTERN ELEVATION	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	STAFF STOREROOM	WALL SHEETING - SOUTHERN ELEVATION	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	STAFF STOREROOM	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350006	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	STAFFROOM	WALL SHEETING - NORTHERN ELEVATION	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	TOILETS	WALLS & PARTITIONS TO MALE & FEMALE TOILET/CLEANER ROOM- SIM SAMPLE D02838	Wall	Cement Based		4	Removed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	WELDING BAY	WALL SHEETING - WELDING BOOTH	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	WELDING BAY 1	CEILING SHEETING - BAY 1	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	WELDING BAY 1	WALL SHEETING - BAY 1	Wall	Cement Based		3	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	WELDING BAY 2	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	STAFF STOREROOM	BLOCKWORK WALL SHEETING - NORTHERN, EASTERN & WESTERN ELEVATIONS	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	WELDING BAY 1	HEAT MATTING	Other (refer to description)	Woven Textile		3	Presumed	80	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	WOODWORK ROOM	PLY WALL SHEETING	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	WELDING STORE	PLY WALL SHEETING	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	WELDING BAY 2	HEAT MATTING	Other (refer to description)	Woven Textile		3	Presumed	80	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	EXT. WALLS	SHEETING TO SOUTHERN END WALL OF TOILET BLOCK	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	WELDING BAY 2	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	S/E DOUBLE TEACHING ROOM	PLY WALL SHEETING	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	External	Ground Floor	AUTOMOTIVE STORE	WALL SHEETS EACH SIDE OF GATES TO EXT. MOTOR STORE ROOM NORTHERN END	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	External	Ground Floor	PERIMETER	CEILING SHEETING - NORTHERN ELEVATION - FLAMMABLE GAS STORE	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	AUTOMOTIVE SEC.	CEILING SHEETING - ABOVE FIRE HOSE REEL	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	AUTOMOTIVE SEC.	PLY WALL SHEETING - SOUTHERN ELEVATION - ABOVE I BEAM	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	AUTOMOTIVE SEC.	PLY WALL SHEETING - WESTERN ELEVATION	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	AUTOMOTIVE SEC.	WALL SHEETING	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	AUTOMOTIVE SEC.	WALL SHEETING - EASTERN ELEVATION	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	AUTOMOTIVE STORE ROOM	INTERNAL WALLS TO STORE ROOM TO SOUTHERN END OF TOILET BLOCK (SW SAMPLE D02839)	Wall	Cement Based		4	Removed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	AUTOMOTIVE STORE ROOM	PLY WALL SHEETING	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	FAN ROOM	PLY WALL SHEETING	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350006	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	FITTING STORE	PLY CEILING SHEETING	Ceiling	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350006	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	FITTING STORE	PLY WALL SHEETING	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	MACHINE ROOM	PLY WALL SHEETING	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	METAL FAB ROOM	DOOR SEAL - OVEN FOR WELDING RODS	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	S/E DOUBLE TEACHING ROOM	CREAM FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	S/E DOUBLE TEACHING ROOM	GYPROCK CEILING SHEETING	Ceiling	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350005	22350005	BLOCK C - TECHNOLOGY CENTRE	BLOCK C - TECHNOLOGY CENTRE	Internal	Ground Floor	AUTOMOTIVE SEC.	WALL SHEETING - SOUTHERN ELEVATION	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350014	22350014	BLOCK L - FLAMMABLE STORE	BLOCK L - FLAMMABLE STORE	External	Whole Building (asbestos free)	BUILT POST 1990	Duplicate Entry - Built After 1990 - Asbestos Free	Other (refer to description)	Other (refer to description)		3	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350015	22350015	BLOCK K - CAMPUS STORE	BLOCK K - CAMPUS STORE	External	Whole Building (asbestos free)	BUILT POST 1990	Duplicate Entry - Built After 1990 - Asbestos Free	Other (refer to description)	Other (refer to description)		3	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350016	22350016	BLOCK B - HOSPITALITY	BLOCK B - HOSPITALITY	External	Whole Building (asbestos free)	BUILT POST 1990	Duplicate Entry - Built After 1990 - Asbestos Free	Other (refer to description)	Other (refer to description)		3	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350019	22350019	STORE/UNISEX TOILET	STORE/UNISEX TOILET	Internal	Ground Floor	STORE ROOM	WALL SHEETING - SOUTHERN ELEVATION	Wall	Cement Based		4	Presumed	18	-	MOVED FROM BLK C TO UNISEX TOILETS.
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350019	22350019	STORE/UNISEX TOILET	STORE/UNISEX TOILET	External	Ground Floor	UNISEX TOILETS	Duplicate Entry - Built After 1990 - Asbestos Free	Other (refer to description)	Other (refer to description)		3	Not Present(Not Tested)		-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350019	22350019	STORE/UNISEX TOILET	STORE/UNISEX TOILET	Inter nal	Ground Floor	AMENITIES STOREROOM	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350019	22350019	STORE/UNISEX TOILET	STORE/UNISEX TOILET	Inter nal	Ground Floor	AMENITIES STOREROOM	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350019	22350019	STORE/UNISEX TOILET	STORE/UNISEX TOILET	Inter nal	Ground Floor	CLEANERS ROOM	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350019	22350019	STORE/UNISEX TOILET	STORE/UNISEX TOILET	Inter nal	Ground Floor	CLEANERS ROOM	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350019	22350019	STORE/UNISEX TOILET	STORE/UNISEX TOILET	Inter nal	Ground Floor	FEMALE STAFF	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350019	22350019	STORE/UNISEX TOILET	STORE/UNISEX TOILET	Inter nal	Ground Floor	FEMALE TOILETS	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350019	22350019	STORE/UNISEX TOILET	STORE/UNISEX TOILET	Inter nal	Ground Floor	FEMALE TOILETS	WALL PARTITION SHEETING	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350019	22350019	STORE/UNISEX TOILET	STORE/UNISEX TOILET	Inter nal	Ground Floor	MALE TOILETS	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350019	22350019	STORE/UNISEX TOILET	STORE/UNISEX TOILET	Inter nal	Ground Floor	MALE TOILETS	WALL PARTITION SHEETING	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350019	22350019	STORE/UNISEX TOILET	STORE/UNISEX TOILET	Inter nal	Ground Floor	MALE TOILETS	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	MOVED FROM C BLK TO UNISEX TOILETS
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	22350019	22350019	STORE/UNISEX TOILET	STORE/UNISEX TOILET	Inter nal	Ground Floor	PERIMETER	WALL SHEETING - SOUTHERN ELEVATION	Wall	Other (refer to description)		4	Presumed	18	-	MOVED TO UNISEX TOILET FROM C BLK. RESULT: TESTED NOT PRESENT
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-000	22350001	BLOCK D - RESOURCE CTR EDUC	BLOCK D - RESOURCE CTR EDUC	Inter nal	Ground Floor	OFFICE/NRTH SID	BROWN TILES - UNDER CARPET	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-000	22350001	BLOCK D - RESOURCE CTR EDUC	BLOCK D - RESOURCE CTR EDUC	Inter nal	Ground Floor	ENTRANCE	CEILING SHEETING - NORTHWESTERN ELEVATION	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-000	22350001	BLOCK D - RESOURCE CTR EDUC	BLOCK D - RESOURCE CTR EDUC	Inter nal	Ground Floor	WITHDRAWAL AREA	WALL PANEL - UNDER FIXED GLASS TO PARTITION - EASTERN ELEVATION	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-000	22350001	BLOCK D - RESOURCE CTR EDUC	BLOCK D - RESOURCE CTR EDUC	Inter nal	Ground Floor	THROUGHOUT	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-000	22350001	BLOCK D - RESOURCE CTR EDUC	BLOCK D - RESOURCE CTR EDUC	Exter nal	Ground Floor	PERIMETER	SHEETING - UNDERSIDE OF SUNHOOD - SOUTHERN ELEVATION	Sun Hood	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-000	22350001	BLOCK D - RESOURCE CTR EDUC	BLOCK D - RESOURCE CTR EDUC	Exter nal	Ground Floor	PERIMETER	VENT PIPE - NORTHERN ELEVATION	Drains/Pipes/Fittings	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-000	22350001	BLOCK D - RESOURCE CTR EDUC	BLOCK D - RESOURCE CTR EDUC	Exter nal	Level 1	DUPLICATE ENTRY - SUNHOOD								-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-001	22350009	BLOCK F - JUBILEE HALL EDUC	BLOCK F - JUBILEE HALL EDUC	Inter nal	Ground Floor	FEMALE TOILETS	VILLABOARD WALL SHEETING	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-001	22350009	BLOCK F - JUBILEE HALL EDUC	BLOCK F - JUBILEE HALL EDUC	Inter nal	Level 1	LIGHTING STAGE	WALL PARTITIONS SHEETING - LIGHTING BALCONY & STAIRWELL - NORTHERN ELEVATION	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-001	22350009	BLOCK F - JUBILEE HALL EDUC	BLOCK F - JUBILEE HALL EDUC	Inter nal	Ground Floor	THROUGHOUT	VILLABOARD WALL SHEETING - FRONT FOYER & CANTEN	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-001	22350009	BLOCK F - JUBILEE HALL EDUC	BLOCK F - JUBILEE HALL EDUC	Inter nal	Ground Floor	MALE TOILETS	WALL PARTITION SHEETING	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-001	22350009	BLOCK F - JUBILEE HALL EDUC	BLOCK F - JUBILEE HALL EDUC	Inter nal	Ground Floor	MALE TOILETS	VILLABOARD WALL SHEETING	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-001	22350009	BLOCK F - JUBILEE HALL EDUC	BLOCK F - JUBILEE HALL EDUC	Inter nal	Ground Floor	MALE TOILETS	CEILING SHEETING	Ceiling	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-001	22350009	BLOCK F - JUBILEE HALL EDUC	BLOCK F - JUBILEE HALL EDUC	Inter nal	Ground Floor	MAIN HALL	CORRUGATED WALL SHEETING - ABOVE WINDOWS - BOTH SIDES	Wall	Cement Based	Mixed	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-001	22350009	BLOCK F - JUBILEE HALL EDUC	BLOCK F - JUBILEE HALL EDUC	Inter nal	Other (refer to description)	FOYER/HALL	CEILING TILES	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-001	22350009	BLOCK F - JUBILEE HALL EDUC	BLOCK F - JUBILEE HALL EDUC	Inter nal	Ground Floor	FEMALE TOILETS	WALL PARTITION SHEETING	Wall	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-001	22350009	BLOCK F - JUBILEE HALL EDUC	BLOCK F - JUBILEE HALL EDUC	Exter nal	Ground Floor	RAINWATER PIPES	TOPS TO RAINWATER PIPE EXCLUDE ONE AT SOUTH EAST END (FIVE ONLY)	Stormwater Plumbing	Cement Based	CHR - Chrysotile	4	Removed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-001	22350009	BLOCK F - JUBILEE HALL EDUC	BLOCK F - JUBILEE HALL EDUC	Exter nal	Ground Floor	RAINWATER PIPES	6 RAINWATER PIPES - EAST & WEST SIDES (300MM) PIPES NEED NEW JOINT PUTTY BETWEEN PIPE & TAP	Stormwater Plumbing	Cement Based	Mixed	4	Removed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-001	22350009	BLOCK F - JUBILEE HALL EDUC	BLOCK F - JUBILEE HALL EDUC	Exter nal	Ground Floor	PERIMETER	SOFFIT SHEETING - SOUTHERN ELEVATION	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-001	22350009	BLOCK F - JUBILEE HALL EDUC	BLOCK F - JUBILEE HALL EDUC	Exter nal	Ground Floor	PERIMETER	SOFFIT SHEETING - NORTHERN ELEVATION	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-001	22350009	BLOCK F - JUBILEE HALL EDUC	BLOCK F - JUBILEE HALL EDUC	Exter nal	Ground Floor	PERIMETER	SOFFIT SHEETING - EASTERN ELEVATION	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-001	22350009	BLOCK F - JUBILEE HALL EDUC	BLOCK F - JUBILEE HALL EDUC	Inter nal	Ground Floor	FEMALE TOILETS	CEILING SHEETING	Ceiling	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-001	22350009	BLOCK F - JUBILEE HALL EDUC	BLOCK F - JUBILEE HALL EDUC	Inter nal	Basement 1	STORE ROOM	CEILING SHEETING - UNDERSIDE OF STAGE FLOOR AROUND MAIN SUPPORTS & POSTS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-001	22350009	BLOCK F - JUBILEE HALL EDUC	BLOCK F - JUBILEE HALL EDUC	Inter nal	Ground Floor	HALLWAY OUTSIDE TOILETS	CEILING SHEETING	Ceiling	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-002	22350010	BLOCK E - SCIENCE EDUC	BLOCK E - SCIENCE EDUC	Exter nal	Level 1	PERIMETER	SOFFIT SHEETING - UNDER WALKWAY	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-002	22350010	BLOCK E - SCIENCE EDUC	BLOCK E - SCIENCE EDUC	Exter nal	Ground Floor	PERIMETER	CEILING SHEETING - UNDERNEATH TOP FLOOR & ABOVE LOUVERS - NORTHERN & SOUTHERN ELEVATIONS	Ceiling	Cement Based	Mixed	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-002	22350010	BLOCK E - SCIENCE EDUC	BLOCK E - SCIENCE EDUC	Exter nal	Ground Floor	PERIMETER	SHADOW LINE SOFFIT SHEETING - SOUTHERN ELEVATION - NEAR EXTERNAL STAIRS	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-002	22350010	BLOCK E - SCIENCE EDUC	BLOCK E - SCIENCE EDUC	Exter nal	Ground Floor	WALKWAY	WALL PANEL FROM WALKWAY UP TO BUILDING NORTH ELEVATION	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-002	22350010	BLOCK E - SCIENCE EDUC	BLOCK E - SCIENCE EDUC	Exter nal	Level 1	NORTHERN SIDE STAIR	SOFFIT SHEETING - ABOVE STAIRS - NORTHERN ELEVATION	Gable/Soffit/Fascia	Cement Based		3	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-002	22350010	BLOCK E - SCIENCE EDUC	BLOCK E - SCIENCE EDUC	Exter nal	Ground Floor	TANK STAND/FERN	WALL SHEETS TO FERN HOUSE UNDER TANKSTAND	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Removed		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-002	22350010	BLOCK E - SCIENCE EDUC	BLOCK E - SCIENCE EDUC	Inter nal	Ground Floor	TOILETS	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-002	22350010	BLOCK E - SCIENCE EDUC	BLOCK E - SCIENCE EDUC	Inter nal	Ground Floor	TOILETS	WALL PARTITION SHEETING	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-002	22350010	BLOCK E - SCIENCE EDUC	BLOCK E - SCIENCE EDUC	Inter nal	Level 1	LABORATORY A	GAUZE BUNSEN BURNER MATTS	Furniture	Other (refer to description)	Mixed	2	Removed		-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-002	22350010	BLOCK E - SCIENCE EDUC	BLOCK E - SCIENCE EDUC	Inter nal	Level 1	LABORATORY A	INTERNAL DOOR LINING TO TOWN ROOM & MERCER INSULATOR ED NO. 289793	Furniture	Medium Board	CHR - Chrysotile	2	Removed	69	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-002	22350010	BLOCK E - SCIENCE EDUC	BLOCK E - SCIENCE EDUC	Inter nal	Level 1	LABORATORY A	LINING BEHIND WALLS OF TOWNSON & MERCER INCUBATOR	Furniture	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-002	22350010	BLOCK E - SCIENCE EDUC	BLOCK E - SCIENCE EDUC	Inter nal	Whole Building (asbestos free)	FIRE ESCAPES - BUILT POST 1993	DUPLICATE ENTRY - FIRE ESCAPES - BUILT 1993 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)		-	TOP FLOOR REBUILT AFTER FIRE INCLUDES SHEETS TO THE 2 EXT.
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-002	22350010	BLOCK E - SCIENCE EDUC	BLOCK E - SCIENCE EDUC	Exter nal	Level 1	NORTHERN SIDE STAIR	CEILING SHEETING - ABOVE STAIRS - NORTHERN ELEVATION	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	CLASSROOM - 2.03	CEILING SHEETING	Ceiling	Cement Based	CHR AMO - Chrysotile Amosite	3	Confirmed	40	-	CEILING MOUNTED FANS NOTED IN ROOM

TAFes from BEMIR-TAFes

Current as at 10-May-11

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Est	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	CLASSROOM - 207	CEILING SHEETING	Ceiling	Cement Based	CHR AMO - Chrysotile Amosite	3	Confirmed	40	-	CEILING MOUNTED FANS
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Ground Floor	STOREROOM - 1.06	WALL UPPER INFILL PANELS DIRECTLY BELOW CEILING LINING - SOUTHERN ELEVATION	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	LOWER WALL MADE OF BRICK
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	CLASSROOM 2.05	WALL SHEETING - SOUTHSIDE - WESTERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Testing)	-	-	ADJACENT WALL MADE OF MASONITE
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	CLASSROOM 2.05	WALL INFILL PANELS AROUND A/C UNITS - SOUTHERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Testing)	-	-	3 X INFILL PANELS. ADJACENT INFILL PANELS MADE OF TIMBER. LOWER WALL MADE OF MASONITE
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	CLASSROOM 2.05	VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	OLIVE VINYL TILES ATTACHED TO MASONITE
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	CLASSROOM 2.05	CEILING SHEETING	Ceiling	Cement Based	CHR AMO - Chrysotile Amosite	3	Confirmed	40	-	CEILING MOUNTED FAN'S NOTED IN ROOM
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	CLASSROOM 2.05	CEILING ACCESS PANEL	Ceiling Access Panel	Cement Based	Mixed	4	Confirmed	37	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	J1 STAFF	CREAM/BROWN FLOOR SHEETING - WET AREAS & UNDER CARPET	Floor Finish/Covering	Vinyl Sheetting (includes backing)	No asbestos detected (NAD)	4	Not Present(Testing)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	CLASSROOM - 207	INFILL PANELS AROUND A/C UNIT ON SOUTHERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Testing)	-	-	2 X INFILL PANELS. ADJACENT INFILL PANELS MADE OF TIMBER. LOWER WALL MADE OF MASONITE
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	J1 STAFF	DUPLICATE ENTRY - CREAM/BROWN FLOOR SHEETING - WET AREAS & UNDER CARPET	Floor	Vinyl Sheetting (includes backing)		4	Presumed	62	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	CLASSROOM - 207	ACCESS TO CEILING SPACE ABOVE EAST SIDE OF ROOM	Ceiling	Cement Based	CHR AMO - Chrysotile Amosite	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	CLASSROOM - 2.03	WALL INFILL PANELS BELOW WINDOWS - NORTHERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Testing)	-	-	SURROUNDING WALL MADE OF MASONITE
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	CLASSROOM - 2.03	WALL INFILL PANELS AROUND A/C UNIT - SOUTHERN ELEVATION	Wall	Cement Based		NA	Presumed	-	-	2 X INFILL PANELS. ADJACENT INFILL PANELS MADE OF TIMBER. LOWER WALL MADE OF MASONITE
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	CLASSROOM - 2.03	ACCESS TO CEILING SPACE ABOVE EASTERN ELEVATION	Ceiling	Cement Based	CHR AMO - Chrysotile Amosite	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	2ND ROOM FROM EAST END	CEILING ACCESS PANEL	Ceiling Access Panel	Cement Based	Mixed	4	Confirmed	37	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	2.01	CEILING ACCESS PANEL	Ceiling Access Panel	Cement Based	CHR - Chrysotile	4	Confirmed	37	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Ground Floor	WALKWAY	WALKWAY	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	CLASSROOM 2.05	ACCESS TO CEILING SPACE ABOVE WESTERN ELEVATION	Ceiling	Cement Based	CHR AMO - Chrysotile Amosite	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	OFFICE - 2.06	WALL INFILL PANEL AROUND A/C UNIT - SOUTHERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Testing)	-	-	1 X INFILL PANEL. ADJACENT INFILL PANELS MADE OF TIMBER. LOWER WALL MADE OF MASONITE
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	THROUGHOUT	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	STOREROOM - 2.04	WALL INFILL PANEL AROUND A/C UNIT - NORTHERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Testing)	-	-	SURROUNDING WALL MADE OF MASONITE
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	STOREROOM - 2.04	CEILING SHEETING	Ceiling	Cement Based	CHR AMO - Chrysotile Amosite	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	STAIRWELL	CEILING SHEETING	Ceiling	Cement Based	CHR AMO - Chrysotile Amosite	3	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	STAFFROOM	WALL INFILL PANEL AROUND A/C UNIT - SOUTHERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Testing)	-	-	1 X INFILL PANELS. ADJACENT INFILL PANELS MADE OF TIMBER. LOWER WALL MADE OF MASONITE
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	STAFFROOM	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheetting (includes backing)	No asbestos detected (NAD)	NA	Not Present(Testing)	-	-	MOTTLE BEIGE VINYL FLOOR SHEETING ATTACHED TO MASONITE
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	DUPLICATE ENTRY - J5 STORE ROOM	DUPLICATE ENTRY - GREEN FLOOR TILES UNDER CARPET TO RM J5 STORE ROOM	Wall	Cement Based		3	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	STAFFROOM	ACCESS TO CEILING SPACE ABOVE EASTERN ELEVATION	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	KITCHEN	VINYL FLOOR SHEETING - MOTTLE BEIGE	Floor Finish/Covering	Vinyl Sheetting (includes backing)	No asbestos detected (NAD)	NA	Not Present(Testing)	-	-	VINYL FLOOR SHEETING ATTACHED TO MASONITE. VINYL SHEETING EXTENDS BENEATH CARPET
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	OFFICE - 2.06	CEILING SHEETING	Ceiling	Cement Based	CHR AMO - Chrysotile Amosite	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	3RD ROOM FROM EAST END	CEILING ACCESS PANEL	Ceiling Access Panel	Cement Based	Mixed	4	Confirmed	37	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	OFFICE - 2.06	ACCESS TO CEILING SPACE ABOVE EASTERN ELEVATION	Ceiling	Cement Based	CHR AMO - Chrysotile Amosite	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	External	Ground Floor	DUPLICATE ENTRY - SUNROOMS	DUPLICATE ENTRY -	Ground Floor						-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	KITCHEN	CEILING SHEETING	Ceiling	Cement Based	CHR AMO - Chrysotile Amosite	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	J5	WALL SHEETING - AROUND CONNECTING DOORWAY & AROUND AIRCONDITIONING	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	J5	GREEN FLOOR TILES - UNDER CARPET & SMALL ROOM OFF	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Testing)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	STAFFROOM	CEILING SHEETING	Ceiling	Cement Based	CHR AMO - Chrysotile Amosite	3	Confirmed	40	-	CEILING MOUNTED FAN'S NOTED IN ROOM
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	External	Level 1	VERANDAH	INSIDE LINING TO THE 'DOALL DILLY KILM' AT EASTERN END OF VERANDAH	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	4	Removed	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Ground Floor	CLASSROOM - 1.09	WALL INFILL PANEL AROUND A/C UNIT - SOUTHERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Testing)	-	-	1 X INFILL PANEL. ADJACENT INFILL PANELS MADE OF TIMBER. LOWER WALL MADE OF MASONITE
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Ground Floor	CLASSROOM - 1.09	UPPER INFILL PANEL DIRECTLY BELOW CEILING LINING - SOUTHERN ELEVATION	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	4 x infill panels. lower wall made of concrete
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Inter nal	Level 1	OFFICE - 2.06	CEILING ACCESS PANEL (S/W ROOM BESIDE UPPER EASTERN ROOM)	Ceiling Access Panel	Cement Based	Mixed	4	Confirmed	37	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	External	Vertical Rise (external)	PERIMETER	FLAT WALL SHEETING - INCLUDING PANELS WHERE WALKWAY MEETS BUILDING	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	External	Vertical Rise (external)	PERIMETER	DUPLICATE ENTRY - EXTERNAL WALL PANELS WHERE WALKWAY MEETS BUILDING	Wall	Cement Based		3	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	External	Various levels External	VENT PIPES	2 ONLY 100MM VENT PIPES TO EAST & WESTERN ENDS	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Est.	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEIMR Score	Attention Required	Comments
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	CLASSROOM - 1.06	WALL INFILL PANELS - CEILING LINING ABOVE NORTH-WEST ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Not Tested)	-	-	3 X INFILL PANELS
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	External	Level 1	VERANDAH	OUTSIDE LINING TO THE 'DOALL DILLY KILM' AT EASTERN END OF VERANDAH	Plant, Equipment & Machinery	Cement Based	Mixed	4	Removed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	CLASSROOM - 1.09	VINYL FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheetting (includes backing)		4	Presumed	37	-	OLIVE VINYL TILES SHEETING ATTACHED TO CONCRETE
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	External	Level 1	VERANDAH	CEILING SHEETING - INCLUDING INTERNAL STARWAY	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	External	Ground Floor	VERANDAH	FLAT CEILING SHEETS - OPEN AREA - UNDER BUILDING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	External	Ground Floor	UNDER BUILDING	WALL PANEL SHEETING - BETWEEN I BEAMS BOTH SIDES OF BUILDING INCLUDE ABOVE WINDOWS NRTH/STH	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	External	Ground Floor	PERIMETER	SHEETING - SUNHOOD - SOUTHERN ELEVATION	Sun Hood	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	External	Ground Floor	PERIMETER	SHADOW LINE CEILING LINING - UNDERSIDE OF VERANDAH FLOOR - NORTHERN ELEVATION	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	GYM	WALL SHEETING - WESTERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	STOREROOM - 1.06	WALL UPPER INFILL PANELS DIRECTLY BELOW CEILING LINING - NORTHERN ELEVATION	Wall	Cement Based	CHR AMO - Chrysotile Amosite	4	Confirmed	18	-	LOWER WALL MADE OF BRICK
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	External	Level 1	VERANDAH	SHEETING - UNDER FIXED GLASS ALONG VERANDAH & IMPRESS PANEL IN ROOM JS-NEAST CORNER	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	GYM - 1.08	WALL UPPER INFILL PANELS DIRECTLY BELOW CEILING LINING - SOUTHERN ELEVATION	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	STOREROOM - 1.06	CEILING SHEETING	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	STAIRWELL - 1.07	FLOOR SHEETING	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	BEIGE AND GREEN VINYL TILES ATTACHED TO CONCRETE
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	STAIRWELL	CREAM/GREEN FLOOR TILES - BOTTOM STAIRWELL	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	J9	GREY FLOOR TILES - UNDER CARPET	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	CLASSROOM - 1.09	CEILING SHEETING	Ceiling	Cement Based	CHR AMO - Chrysotile Amosite	3	Confirmed	40	-	CEILING MOUNTED FAN'S NOTED IN ROOM
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	J6	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	CLASSROOM - 1.09	WALL INFILL PANELS ADJACENT TO A/C UNITS - SOUTHERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Not Tested)	-	-	4 X INFILL PANELS. LOWER WALL MADE OF CONCRETE
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	GYM - 1.08	WALL UPPER INFILL PANELS DIRECTLY BELOW CEILING LINING - NORTHERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Not Tested)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	GYM - 1.08	WALL UPPER INFILL PANEL - WEST SIDE - SOUTHERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Not Tested)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	GYM - 1.08	WALL INFILL PANEL BELOW METAL VENTILATION LOUVRES - WEST SIDE - NORTHERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Not Tested)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	GYM - 1.08	WALL LOWER INFILL PANELS - CENTRAL AND EAST SIDES - NORTHERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Not Tested)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	GYM - 1.08	WALL LOWER INFILL PANEL - WEST SIDE - NORTHERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Not Tested)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	GYM - 1.08	WALL INFILL PANELS AROUND A/C UNITS - SOUTHERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Not Tested)	-	-	4 X INFILL PANELS
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	GYM - 1.08	WALL INFILL PANEL ON LOWER SOUTH SIDE - WESTERN ELEVATION (ADJACENT TO COUNTER)	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Not Tested)	-	-	1 X INFILL PANEL
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	GYM - 1.08	WALL INFILL PANEL BELOW WINDOW - CENTRAL WEST ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Not Tested)	-	-	1 X INFILL PANEL
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	GYM	WALL PANEL SHEETING - TOPS OF WALLS ABOVE WINDOWS - WESTERN ELEVATION	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	GYM - 1.08	WALL SHEETING NORTH AND SOUTH SIDES - WESTERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	NA	Not Present(Not Tested)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-003	22350013	BLOCK J - LECTURE ROOMS EDUC	BLOCK J - LECTURE ROOMS EDUC	Internal	Ground Floor	J9	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-004	22350002	COVERED WALKWAYS EDUC	COVERED WALKWAYS EDUC	External	Whole Building (asbestos free)	CONSTRUCTED POST 1990	DUPLICATE ENTRY - ASBESTOS FREE	Other (refer to description)	Other (refer to description)	3	Not Present(Not Tested)	-	-		
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-005	22350004	STORE - GROUNDSMAN EDUC	STORE - GROUNDSMAN EDUC	Internal	Ground Floor	METER BOARD	BACKING BOARD - ELECTRICAL METERS	Insulation/Fill	Polymer Based	CHR - Chrysotile	4	Confirmed	25	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-005	22350004	STORE - GROUNDSMAN EDUC	STORE - GROUNDSMAN EDUC	External	Site / Grounds	STORE COMPOUND	1 MTR LENGTH OF 300MM AC PIPE STORED IN GROUNDSMAN'S COMPOUND SOUTH WEST CORNER	Stored Material	Cement Based		4	Removed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-006	22350007	BLOCK T - RELOCATABLE GEN LEARN	BLOCK T - RELOCATABLE GEN LEARN	Internal	Ground Floor	ROOM 2	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-006	22350007	BLOCK T - RELOCATABLE GEN LEARN	BLOCK T - RELOCATABLE GEN LEARN	Internal	Ground Floor	ROOM 2	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-006	22350007	BLOCK T - RELOCATABLE GEN LEARN	BLOCK T - RELOCATABLE GEN LEARN	External	Ground Floor	PERIMETER	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-006	22350007	BLOCK T - RELOCATABLE GEN LEARN	BLOCK T - RELOCATABLE GEN LEARN	Internal	Ground Floor	ROOM 1	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-006	22350007	BLOCK T - RELOCATABLE GEN LEARN	BLOCK T - RELOCATABLE GEN LEARN	External	Ground Floor	PERIMETER	SOFFIT SHEETING - NORTHERN & SOUTHERN ELEVATIONS	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-006	22350007	BLOCK T - RELOCATABLE GEN LEARN	BLOCK T - RELOCATABLE GEN LEARN	External	Ground Floor	BAG RACKS	BAG RACKS - NORTHERN VERANDAH	Furniture	Cement Based	Mixed	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-006	22350007	BLOCK T - RELOCATABLE GEN LEARN	BLOCK T - RELOCATABLE GEN LEARN	External	Roof Level 1	DUPLICATE ENTRY - SOFFIT							-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-006	22350007	BLOCK T - RELOCATABLE GEN LEARN	BLOCK T - RELOCATABLE GEN LEARN	Internal	Ground Floor	ROOM 1	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-007	22350008	BLOCK H - CANTEN EDUC	BLOCK H - CANTEN EDUC	External	Ground Floor	PERIMETER	SHEETING - SUNHOODS	Sun Hood	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-007	22350008	BLOCK H - CANTEN EDUC	BLOCK H - CANTEN EDUC	Internal	Ground Floor	CANTEEN	GREY FLOOR SHEETING - INCLUDING STOREROOMS	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-007	22350008	BLOCK H - CANTEN EDUC	BLOCK H - CANTEN EDUC	External	Ground Floor	PERIMETER	4 PANELS - UNDER WINDOWS - NORTHERN & SOUTHERN ELEVATIONS	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-007	22350008	BLOCK H - CANTEN EDUC	BLOCK H - CANTEN EDUC	External	Ground Floor	FENCE	SHEETING - PALING FENCE - NORTHWESTERN CORNER	Fencing	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-007	22350008	BLOCK H - CANTEN EDUC	BLOCK H - CANTEN EDUC	External	Ground Floor	FENCE	SHEETING - BELOW PALING FENCE - WESTERN ELEVATION	Fencing	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-007	22350008	BLOCK H - CANTEN EDUC	BLOCK H - CANTEN EDUC	External	Ground Floor	DUPLICATE ENTRY - SUNHOODS							-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	34S-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Level 1	THROUGHOUT	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Ground Floor	G19	CREAM/BROWN FLOOR SHEETING - UNDER CARPET - INCLUDING HALLWAY	Floor	Vinyl Sheeting (includes backing)		3	Presumed	62	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Ground Floor	G18	CREAM/BROWN FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Ground Floor	G16	WALL SHEETING - REAR	Wall	Cement Based		3	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Ground Floor	G17, 20 & 21	GREY FLOOR TILES - UNDER CARPET	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Ground Floor	G15	GREY FLOOR SHEETING	Floor Finish/Covering	Other (refer to description)		4	Not Present(Not Tested)	-	-	LAID POST 1990
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Ground Floor	THROUGHOUT	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Level 1	G3	PLASTERBOARD CEILING ACCESS PANEL	Ceiling Access Panel	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Level 1	G4	CEILING ACCESS PANEL (	Ceiling Access Panel	Low Density Board	CHR AMO - Chrysotile Amosite	4	Confirmed	64	-	Form of ACM changed from CB to LD
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Ground Floor	G15	GREEN FLOOR TILES	Floor	Vinyl Tiles		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Level 1	G8 - EASTERN STAFF ROOM	CEILING ACCESS PANEL - EASTERN ELEVATION OF STAIRWELL	Ceiling Access Panel	Low Density Board	CHR AMO - Chrysotile Amosite	4	Confirmed	64	-	Form of ACM changed from AA to LD
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Ground Floor	G12	CEILING SHEETING	Ceiling	Cement Based		3	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Level 1	THROUGHOUT	VARIOUS WALLS THROUGHOUT COVER STRIPS MISSING ON WALLS	Wall	Cement Based		4	Removed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Level 1	THROUGHOUT	WALL SHEETING	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Level 1	G5	PLASTERBOARD CEILING ACCESS PANEL	Ceiling Access Panel	Other (refer to description)		3	Not Present(Not Tested)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	External	Vertical Rise (external)	PERIMETER	WALL SHEETING - SOUTH ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	External	Ground Floor	PERIMETER	BLACK FLOOR TILES - OUTSIDE ROOM G15 - UNDER CARPET	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	External	Ground Floor	PERIMETER	FIBROLITE CORRUGATED CEILING SHEETING - UNDERSIDE OF VERANDAH	Ceiling	Cement Based	Mixed	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	External	Ground Floor	PERIMETER	WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	External	Level 1	PERIMETER	SOFFIT SHEETING - INCLUDING STAIRWAY - WESTERN ELEVATION	Gable/Soffit/ascia Floor	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Ground Floor	G14	BLACK FLOOR TILES	Floor	Vinyl Tiles		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	External	Vertical Rise (external)	PERIMETER	WALL PANEL SHEETING - INCLUDING WINDOW HEADS BELOW SUNHOOD - SOUTHERN ELEVATION	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Ground Floor	G15	CEILING SHEETING	Ceiling	Cement Based		3	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Ground Floor	DUPLICATE ENTRY - G10 - RADIO ROOM	DUPLICATE ENTRY - BLACK FLOOR TILES TO RADIO ROOM (G10)	Floor	Vinyl Tiles		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Ground Floor	DUPLICATE ENTRY - G10 - RADIO ROOM	DUPLICATE ENTRY - CEILINGS TO RADIO ROOM	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Ground Floor	DUPLICATE ENTRY - G10 - RADIO ROOM	DUPLICATE ENTRY - GREEN FLOOR TILES TO RADIO ROOM	Floor	Vinyl Tiles		3	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Ground Floor	G13	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Ground Floor	G14	CEILING SHEETING	Ceiling	Cement Based		3	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	Internal	Ground Floor	G14	GREEN FLOOR TILES	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-008	22350011	BLOCK G - LECTURE ROOMS EDUC	BLOCK G - LECTURE ROOMS EDUC	External	Level 1	VERANDAH	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L - LECTURE ROOMS EDUC	BLOCK I L - LECTURE ROOMS EDUC	External	Level 1	VERANDAH	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L - LECTURE ROOMS EDUC	BLOCK I L - LECTURE ROOMS EDUC	Internal	Ground Floor	STAIRWELL	BLACK FLOOR TILES - BOTTOM - STAIRWELL	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L - LECTURE ROOMS EDUC	BLOCK I L - LECTURE ROOMS EDUC	Internal	Other (refer to description)	I11 - LAUNDRY	VENT PIPE	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L - LECTURE ROOMS EDUC	BLOCK I L - LECTURE ROOMS EDUC	Internal	Level 1	THROUGHOUT	WALL PANELS - WITH AIR CONDITIONERS MOUNTED IN	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L - LECTURE ROOMS EDUC	BLOCK I L - LECTURE ROOMS EDUC	Internal	Level 1	THROUGHOUT	CEILING SHEETING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L - LECTURE ROOMS EDUC	BLOCK I L - LECTURE ROOMS EDUC	Internal	Level 1	I6	CEILING ACCESS PANEL	Ceiling Access Panel	Low Density Board	Mixed	4	Confirmed	73	-	Form of ACM updated from CB to LD.
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L - LECTURE ROOMS EDUC	BLOCK I L - LECTURE ROOMS EDUC	Internal	Level 1	I5	GREY FLOOR SHEETING - SWITCHBOARD ROOM	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L - LECTURE ROOMS EDUC	BLOCK I L - LECTURE ROOMS EDUC	Internal	Level 1	I3 - STOREROOMS	GREY FLOOR SHEETING	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L - LECTURE ROOMS EDUC	BLOCK I L - LECTURE ROOMS EDUC	Internal	Level 1	I3	CEILING ACCESS PANEL	Ceiling Access Panel	Cement Based	CHR - Chrysotile	4	Confirmed	37	-	Form of ACM updated from CB to LD.
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L - LECTURE ROOMS EDUC	BLOCK I L - LECTURE ROOMS EDUC	Internal	Level 1	I2	CEILING ACCESS PANEL	Ceiling Access Panel	Low Density Board	Mixed	4	Confirmed	73	-	Form of ACM changed from CB to LD.
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L - LECTURE ROOMS EDUC	BLOCK I L - LECTURE ROOMS EDUC	Internal	Level 1	I1	CEILING ACCESS PANEL	Ceiling Access Panel	Low Density Board	Mixed	4	Confirmed	73	-	Form of ACM changed from CB to LD
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L - LECTURE ROOMS EDUC	BLOCK I L - LECTURE ROOMS EDUC	Internal	Level 1	EASTERN UPPER CLASSROOM	CEILING ACCESS PANEL	Ceiling Access Panel	Low Density Board	Mixed	3	Confirmed	80	-	Form of ACM changed from CB to LD
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L - LECTURE ROOMS EDUC	BLOCK I L - LECTURE ROOMS EDUC	Internal	Level 1	COOKING ROOM	FLOOR SHEETING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Not Tested)	62	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L - LECTURE ROOMS EDUC	BLOCK I L - LECTURE ROOMS EDUC	External	Ground Floor	PERIMETER	WALL SHEETING - SAMPLED 10TH SHEET FROM WEST END - NORTHERN ELEVATION	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L - LECTURE ROOMS EDUC	BLOCK I L - LECTURE ROOMS EDUC	External	Ground Floor	STAIRWELL	GREY FLOOR TILES - BOTTOM STAIRS	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L - LECTURE ROOMS EDUC	BLOCK I L - LECTURE ROOMS EDUC	External	Ground Floor	DUPLICATE ENTRY - EXT BUILDING	Sun Hood	Cement Based		4	Presumed	18	-		
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L - LECTURE ROOMS EDUC	BLOCK I L - LECTURE ROOMS EDUC	External	Level 1	PERIMETER	SHEETING - SUNHOODS - SOUTHERN ELEVATION	Sun Hood	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L - LECTURE ROOMS EDUC	BLOCK I L - LECTURE ROOMS EDUC	External	Ground Floor	PERIMETER	CEILINGS SHEETING - OPEN AREA UNDER THE BUILDING	Ceiling	Cement Based		4	Presumed	18	-	

TAFES from BEMR-TAFES

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L- LECTURE ROOMS EDUC	BLOCK I - LECTURE ROOMS EDUC	Exter nal	Ground Floor	PERIMETER	SOFFIT SHEETING	Cable/Soffit/F ascia	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L- LECTURE ROOMS EDUC	BLOCK I - LECTURE ROOMS EDUC	Exter nal	Ground Floor	PERIMETER	WALL SHEETING	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	ACM was inaccessible by the surveyor during the survey on 18/02/2011.
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L- LECTURE ROOMS EDUC	BLOCK I - LECTURE ROOMS EDUC	Inter nal	Ground Floor	STOREROOM 208	CEILING PANEL OFF EAST WALL - SAMPLED MIDDLE SHEET	Ceiling	Low Density Board	CHR AMO - Chrysotile Amosite	4	Confirmed	64	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L- LECTURE ROOMS EDUC	BLOCK I - LECTURE ROOMS EDUC	Exter nal	Ground Floor	PERIMETER	WALL SHEETING - BEAMS BETWEEN COLUMN TO PERIMETER OF BUILDING & PANEL FROM WALKWAY TO SUNHOOD	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L- LECTURE ROOMS EDUC	BLOCK I - LECTURE ROOMS EDUC	Inter nal	Ground Floor	H14	WALL SHEETING	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L- LECTURE ROOMS EDUC	BLOCK I - LECTURE ROOMS EDUC	Exter nal	Level 1	VERANDAH	WALL PANELS - UNDER WINDOWS ALONG VERANDAH - INCL EASTERN ELEVATION & BAG RACKS	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L- LECTURE ROOMS EDUC	BLOCK I - LECTURE ROOMS EDUC	Exter nal	Level 1	WESTERN STAIRWELL	CEILING ACCESS PANEL	Ceiling Access Panel	Low Density Board	Mixed	4	Confirmed	64	-	Form of ACM changed from CB to LD
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L- LECTURE ROOMS EDUC	BLOCK I - LECTURE ROOMS EDUC	Exter nal	Other (refer to description)		Duplicate ENTRY - EXT WALLS							-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L- LECTURE ROOMS EDUC	BLOCK I - LECTURE ROOMS EDUC	Exter nal	Roof Level 1		Duplicate ENTRY - SOFFITS							-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L- LECTURE ROOMS EDUC	BLOCK I - LECTURE ROOMS EDUC	Inter nal	Ground Floor	ART ROOM	WALL PARTITION WITH AIR CON BETWEEN ART ROOM & STOREROOM	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L- LECTURE ROOMS EDUC	BLOCK I - LECTURE ROOMS EDUC	Inter nal	Ground Floor	DARK ROOM	CEILING SHEETING - WESTERN ELEVATION	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L- LECTURE ROOMS EDUC	BLOCK I - LECTURE ROOMS EDUC	Inter nal	Ground Floor	DARK ROOM	Duplicate ENTRY - VENT PIPE IN DARK ROOM	Drains/Pipes/F lues	Cement Based		3	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L- LECTURE ROOMS EDUC	BLOCK I - LECTURE ROOMS EDUC	Inter nal	Ground Floor		Duplicate ENTRY - STAIRWAY							-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-009	22350012	BLOCK I L- LECTURE ROOMS EDUC	BLOCK I - LECTURE ROOMS EDUC	Exter nal	Ground Floor	PERIMETER	WALL SHEETING - ABOVE & BELOW WINDOWS	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-011	22350021	SHADE STRUCTURE 1 - NORTH EDUC	SHADE STRUCTURE 1 - NORTH EDUC	Exter nal	Ground Floor									-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-012	22350022	SHADE STRUCTURE 2 - SOUTH EDUC	SHADE STRUCTURE 2 - SOUTH EDUC	Exter nal	Ground Floor									-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	345-5668-013	22350023	RELOCATABLE - SEU EDUC	RELOCATABLE - SEU EDUC	Exter nal	Whole Building (asbestos free)	BUILT POST 1990	BUILT POST 1990 - ASBESTOS FREE.	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)	-	-	Building built post 1990
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	NSW	22350000	SITE	SITE	Inter nal	Ground Floor	PUMP SHED	BACKING BOARD - ELECTRICAL METRE - WATER PUMPS BESIDE SPORTS FIELD TOILETS	Insulation/Fill	Polymer Board	CHR - Chrysotile	4	Confirmed	25	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	NSW	22350000	SITE	SITE	Exter nal	Site / Grounds	WATER PUMP	2 DUCKS - ACCESS TAPE - BETWEEN WATER METERS & WATER PUMPS BELOW SPORTS FIELD TOILETS	Drains/Pipes/F lues	Cement Based	Mixed	4	Confirmed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	NSW	22350000	SITE	SITE	Exter nal	Whole Building (asbestos free)	SUN SHELTER	Duplicate ENTRY - 2 ONLY SHADE COVERS TO OVAL - BUILT AFTER 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		3	Not Present(Not Tested)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	NSW	22350000	SITE	SITE	Exter nal	Site / Grounds	BESIDE FLAMMABLE STORE	STORED SHEETING	Stored Material	Cement Based		4	Presumed	18	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	NSW/03		Toilets	Toilets	Exter nal	Whole Building (asbestos free)	BUILT POST 1990	Duplicate ENTRY - BUILT AFTER 1990	Other (refer to description)	Other (refer to description)		NA	Not Present(Not Tested)	-	-	
Southern Queensland		ROMA TAFE CAMPUS	ROMA TAFE CAMPUS	NSWAA	22350017	BLOCK A - B.A.G.S. BLD EDUC	BLOCK A - B.A.G.S. BLD EDUC	Exter nal	Whole Building (asbestos free)	BUILT POST 1990	Duplicate ENTRY - BUILT AFTER 1990	Other (refer to description)	Other (refer to description)					-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET		25601006	DINING COURT YARD	DINING COURT YARD	Exter nal	Whole Building (asbestos free)	DINING/COURT	CONSTRUCTED AFTER 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET		25601016	BORE PUMP SHED	BORE PUMP SHED	Exter nal	Whole Building (asbestos free)	BORE/PUMP SHED	METAL CONSTRUCTION - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	25601017	25601017	TRADE O/DOOR WK/SH	TRADE O/DOOR WK/SH											-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	25601018	25601018	BK J COMPRESSOR RM	BK J COMPRESSOR											-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	25601019	25601019	BLK J PLANT ROOM	BLK J PLANT ROOM											-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	25601020	25601020	BL J BRICKIES STR	BL J BRICKIES STR											-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	25601022	25601022	BL K GAS BOTTLE ST	BL K GAS BOTTLE ST											-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	25601023	25601023	BL K GALL BOTTLE S	BL K GALL BOTTLE S											-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	25601025	25601025	HORTICULTURAL BLOCK	HORTICULTURAL BLOCK											-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	25601026	25601026	PROPAGATING SHED	PROPAGATING SHED											-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	25601027	25601027	GREEN HOUSE	GREEN HOUSE											-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	25601028	25601028	COVERED WALKWAYS	COVERED WALKWAYS											-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	25601029	25601029	CARPENTERS STORE	CARPENTERS STORE											-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	25601030	25601030	TIMBER STORE	TIMBER STORE											-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	25601031	25601031	METALWORK STORE	METALWORK STORE											-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	25601032	25601032	STAFF OFFICE MODUL	STAFF OFFICE MODUL											-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	25601033	25601033	BLOCK B	BLOCK B	Exter nal	Whole Building (asbestos free)	BLOCK B	BUILDING CONSTRUCTED POST 1990 OCS PRESUMED ASBESTOS FREE	Other (refer to description)	Other (refer to description)		NA	Not Present(Not Tested)	-	-	Building built post 1990
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTB	25601000	** Site - Grounds	** Site - Grounds	Exter nal	Whole Building (asbestos free)	SITE	CONSTRUCTED POST 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		3	Presumed	-	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTB01	25601005	Electrical Sub Station	Electrical Sub Station	Exter nal	Ground Floor	ELECTRICAL SUB	NIL ASBESTOS IDENTIFIED	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTB02	25601002	GRIMAN-FLAME STORE	GRIMAN-FLAME STORE	Exter nal	Roof Level 1	WEST SIDE	SHEETING TO THE SOFFIT ABOVE THE ROLLER DOOR	Cable/Soffit/F ascia	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTB02	25601002	GRIMAN-FLAME STORE	GRIMAN-FLAME STORE	Inter nal	Ground Floor	OFFICE	SHEETING TO THE DIVIDING PARTITION BETWEEN THE OFFICE AND WORKSHOP AREA	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTB03	25601014	WORKSHOP/STORE BLK	WORKSHOP/STORE BLK	Exter nal	Whole Building (asbestos free)	WORKSHOP/STORE	CONSTRUCTED AFTER 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTB04	25601015	Garden Shed	Garden Shed	Exter nal	Whole Building (asbestos free)	STORAGE SHED	ZINCALUME CONSTRUCTION - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTB05		Green House - Maintenance	Green House - Maintenance											-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BMIR Score	Attention Required	Comments
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTB07		Green House 1 - Horticult	Green House 1 - Horticult	Inter nal	Ground Floor										
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTB08		Green House 2 - Horticult	Green House 2 - Horticult	Inter nal	Ground Floor										
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTB09		Green House 3 - Horticult	Green House 3 - Horticult	Inter nal	Ground Floor										
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Level 1	ROOM 1.93 MALE & FEMALE TOILET	COMPRESSED SHEETING TO THE MALE AND FEMALE TOILETS	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Level 1	ROOM 2.6 MALE & FEMALE TOILET	COMPRESSED SHEETING TO THE MALE AND FEMALE TOILET PARTITIONS	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Level 1	ROOM 2.56 STAFF ROOM	COMPRESSED SHEETING TO THE MALE AND FEMALE TOILET PARTITIONS ROOMS 2.56	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Level 1	ROOM 2.54 STAFF ROOM	COMPRESSED SHEETING TO THE MALE AND FEMALE TOILET PARTITIONS ROOMS 2.54	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Level 1	ROOM 2.29 MALE & FEMALE TOILET	COMPRESSED SHEETING TO THE MALE AND FEMALE TOILET PARTITIONS	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Level 1	ROOM 2.26 MALE & FEMALE TOILET	COMPRESSED SHEETING TO THE MALE AND FEMALE TOILET PARTITIONS	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Ground Floor	STORE ROOM	WALL SHEETING TO THE KITCHEN STORE ROOM EASTERN END	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Ground Floor	ROOM 1.94 MALE & FEMALE TOILET	COMPRESSED SHEETING TO THE MALE AND FEMALE TOILETS	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Ground Floor	ROOM 1.47 MALE & FEMALE TOILET	COMPRESSED SHEETING TO THE MALE AND FEMALE TOILET PARTITIONS	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Ground Floor	ROOM 1.07 MALE & FEMALE TOILET	COMPRESSED SHEETING TO THE MALE AND FEMALE TOILET PARTITIONS	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Ground Floor	PLANT ROOM	INSULATION TO HEATER BANKS UNDER LECTURE THEATRE REPRESENTATIVE THROUGHOUT	Hester Bank Insulation	Milboard		4	Removed	64	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Ground Floor	PLANT ROOM	INSULATION TO INSIDE AIR CONDITIONING DUCTS REPRESENTATIVE	Insulation/Fill	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Ground Floor	ROOM 1.44 OFFICE	SHEETING TO THE OFFICE CEILING	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Ground Floor	ROOM 1.32 BULK STORES	CEMENT SHEETING TO INTERNAL WALLS - ROOMS BULK STORES	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Ground Floor	ROOM 1.32 BULK STORES	CEILING SHEETING ROOM 1.32	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Ground Floor	ROOM 1.28	CEMENT SHEETING TO INTERNAL WALLS ROOM 1.28	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Ground Floor	ROOM 1.27	CEMENT SHEETING TO INTERNAL WALLS ROOM 1.27	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Ground Floor	ROOM 1.08 MALE & FEMALE TOILET	COMPRESSED SHEETING TO THE MALE AND FEMALE TOILET PARTITIONS	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Ground Floor	ROOM 1.48 MALE & FEMALE TOILET	COMPRESSED SHEETING TO THE MALE AND FEMALE TOILET PARTITIONS	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBAA	25601001	BLOCK A BUS STUD	BLOCK A BUS STUD	Inter nal	Ground Floor	ROOM 1.91 OFFICE	SHEETING TO THE OFFICE CEILING	Ceiling	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBBB		B Block	B Block	Exter nal	Whole Building (asbestos free)	BLOCK B	BUILT AFTER 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		3	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBDD	25601007	ELECTRICAL TRADES	ELECTRICAL TRADES	Exter nal	Whole Building (asbestos free)	BLOCK D	CONSTRUCTED AFTER 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBEE	25601008	MECHANICAL TRADES	MECHANICAL TRADES	Exter nal	Whole Building (asbestos free)	BLOCK E	CONSTRUCTED AFTER 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBFF	25601009	CAM CAD ROOMS	CAM CAD ROOMS	Exter nal	Ground Floor	BLOCK F	CONSTRUCTED AFTER 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBHH	25601010	DRAWING ROOMS	DRAWING ROOMS	Exter nal	Whole Building (asbestos free)	BLOCK H	CONSTRUCTED AFTER 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBJJ	25601011	WOODWORK/MASONRY	WOODWORK/MASONRY	Exter nal	Whole Building (asbestos free)	BLOCK J	CONSTRUCTED AFTER 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBK1	25601021	BLK K FLAMMLIQ STR	BLK K FLAMMLIQ STR	Exter nal	Ground Floor	BLOCK K	CONSTRUCTED AFTER 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBKK	25601012	METALWORK/PLUMBING	METALWORK/PLUMBING	Exter nal	Ground Floor	BLOCK K	CONSTRUCTED AFTER 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBLL	25601013	STAFF OFFICES	STAFF OFFICES	Exter nal	Whole Building (asbestos free)	BLOCK L	CONSTRUCTED AFTER 1990 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBMM		M Block	M Block												
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBNN		N Block	N Block												
Southern Queensland		TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	TOOWOOMBA TAFE CAMPUS - BRIDGE STREET	NTBTT		T Block	T Block												
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTB	31805000	** Site - Grounds	** Site - Grounds												
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTH01		Dyno Shed	Dyno Shed												
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTH02		Wood Store	Wood Store												
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHEE	31805001	E Block	E Block	Inter nal	Ground Floor	ROOM E2-03	VERMICULITE CEILINGS TO CLASS ROOMS AND WORKROOMS	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHEE	31805001	E Block	E Block	Inter nal	Ground Floor	ROOM E2-04	CEILING SHEETS TO ROOM E2-04	Ceiling	Cement Based		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHEE	31805001	E Block	E Block	Inter nal	Ground Floor	ROOM E2-10	INTERNAL WALL SHEETING TO RMS E2-10	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHEE	31805001	E Block	E Block	Inter nal	Ground Floor	WAITING AREA FOR OFFICES E1-10 & E1-11	INTERNAL WALL SHEETING TO WAITING AREA FOR OFFICES E1-10 & E1-11	Wall	Other (refer to description)		4	Presumed		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHEE	31805001	E Block	E Block	Inter nal	Level 1	RM E2-11 TOILETS	CEILING SHEETS TO ROOM E2-11	Ceiling	Cement Based		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHEE	31805001	E Block	E Block	Inter nal	Level 1	RM E2-11 TOILETS	INTERNAL WALL SHEETING TO FEMALE TOILET & HANDICAPPED TOILET BESIDE	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHEE	31805001	E Block	E Block	Inter nal	Level 1	ROOM E2-02	CEILING SHEETS TO ROOM E2-02	Ceiling	Cement Based		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHEE	31805001	E Block	E Block	Inter nal	Level 1	ROOM E2-02	GREEN VINYL FLOOR TILES UNDER CARPET TO ROOM E2-02	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHEE	31805001	E Block	E Block	Inter nal	Level 1	ROOM E2-09 STAFF STORE ROOM - ADJACENT TO ENTRANCE DOORS	INTERNAL WALL SHEETING TO STAFF STORE ROOM - ADJACENT TO ENTRANCE DOORS	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHEE	31805001	E Block	E Block	Inter nal	Level 1	STAIRWELL CORRIDOR	BROWN VINYL FLR TILES TO HALLWAY BESIDE STAIRWELL - OUTSIDE ROOM E2-03.	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Level 1	STAIRWELL	INTERNAL WALL SHEETING AROUND & BESIDE ENTRANCE DOORS TO RM E2-49 INSTALLED 1994 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		4	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Level 2	E BLOCK - LEVEL 02	CREAM SHEET VINYL FLOOR COVERINGS TO E BLK - LEVEL 02	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Level 2	E BLOCK - LEVEL 02	INFILL PANELS ABOVE THE DOOR LEADING TO ROOM E209	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Various levels Internal	INTERNAL	PUTTY TO STEEL FRAMED WINDOWS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Level 1	ROOM E2-09	VERMICULITE CEILINGS TO RMS E2-09	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Ground Floor	PAINT STUDIO	WALL LINING OUT SIDE THE PAINT STUDIO	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Ground Floor	ROOM E2-03	CEILING SHEETS TO ROOM E2-03	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Level 2	E BLOCK - LEVEL 02	CEILING SHEETS TO E BLK - LEVEL 02 INCL HALLWAYS & STAIRWELL	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	External	Ground Floor	EXTERNAL	TILUX CEILING SHEETS TO FLAMMABLE LIQUID STORES - WESTERN SIDE	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	External	Ground Floor	WALKWAY	GROUND FLOOR WALKWAY BETWEEN BLOCKS E & F.	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	External	Roof Level 1	EXTERNAL	CORRUGATED ROOF SHEETING	Roof Sheeting	Cement Based		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Ground Floor	MALE TOILET	SUSPENDED CEILING SHEETS TO MALE TOILET (RM E1-13)	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Ground Floor	PAINT STUDIO	WALL LINING TO GROUND FLOOR STUDIO ACCESS LOBBY	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Ground Floor	RECEPTION	BROWN VINYL FLOOR TILES TO RECEPTION AREA INCL STAIRWELL	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Ground Floor	ROOM E1-01	GREEN VINYL FLOOR TILES UNDER CARPET TO E1-01	Floor	Vinyl Tiles		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Ground Floor	ROOM E1-02	GREEN VINYL FLOOR TILES UNDER CARPET TO E1-02	Floor	Vinyl Tiles		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Ground Floor	ROOM E1-06	GREEN VINYL FLOOR TILES TO ROOM E1-06	Floor Finish/Covering	Vinyl Tiles		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Ground Floor	ROOM E1-06	GREEN VINYL FLOOR TILES UNDER CARPET TO E1-06	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Ground Floor	ROOM E1-11	BLUE VINYL FLOOR TILES UNDER CARPET TO ROOM E1-11	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Ground Floor	ROOM E2-01	CEILING SHEETS TO ROOM E2-01	Ceiling	Cement Based		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Ground Floor	ROOM E2-01	GREEN VINYL FLOOR TILES UNDER CARPET TO ROOM E2-01	Floor	Vinyl Tiles		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHHE	31805001	E Block	E Block	Internal	Ground Floor	LIFT LOBBY	VINYL FLOOR SHEETING TO THE LIFT LOBBY	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHFF	31805002	F Block	F Block	Internal	Level 1	F BLOCK - LEVEL 01	CREAM SHEET VINYL FLOOR COVERING TO BLK F - LEVEL 1	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHFF	31805002	F Block	F Block	Internal	Ground Floor	ROOM F1-03	CLUTCH PLATE STORED ON THE DISPLAY SHELF	Plant, Equipment & Machinery	Polymer Based	CHR - Chrysotile	4	Confirmed	25	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHFF	31805002	F Block	F Block	Internal	Level 1	HALLWAY	INTERNAL WALL SHEETING TO HALLWAY OUTSIDE ROOM F2-12	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHFF	31805002	F Block	F Block	Internal	Level 1	F BLOCK - LEVEL 01	CEILING SHEETS TO F BLK - LEVEL 01 - INCL STAIRWELLS	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHFF	31805002	F Block	F Block	Internal	Ground Floor	ROOM F1-03	CREAM SHEET VINYL FLOOR COVERING TO ROOM F1-03	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHFF	31805002	F Block	F Block	Internal	Ground Floor	F BLOCK - GROUND FLOOR	CEILING SHEETS TO BLK F - GROUND FLOOR	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHFF	31805002	F Block	F Block	External	Various levels External	EXTERNAL	PUTTY TO STEEL FRAMED WINDOWS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHFF	31805002	F Block	F Block	External	Various levels External	EXTERNAL	EXT WALL SHEETING UNDER WINDOW ON SIDE RM F1-03 & TO UPPER LVL MID SECTS INCL GABLE ENDS	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHFF	31805002	F Block	F Block	External	Ground Floor	SWOEB SUB STN	SWOEB SUB STN - ACCESS UNAVAILABLE NOT GOVERNMENT OWNED - SUSPECT METERBOARD BACKINGS	Insulation/Fill	Polymer Based		4	Presumed	25	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHFF	31805002	F Block	F Block	External	Roof Level 1	SOFFIT	SOFFIT SHEETS TO NORTH, SOUTH, EAST & WEST SIDES OF BUILDING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHFF	31805002	F Block	F Block	External	Roof Level 1	EXTERNAL	CORRUGATED ROOF SHEETING INCL MOULDINGS	Roof Sheeting	Cement Based		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHFF	31805002	F Block	F Block	Internal	Ground Floor	MACHINE SHOP	INFILL PANELS BOTH SIDES OF THE ENTRANCE TO THE MACHINE SHOP	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Level 1	STAFF ROOM	SHEET VINYL FLOOR COVERINGS	Floor	Vinyl Sheeting (includes backing)		3	Presumed	62	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Level 1	G BLOCK - LEVEL 01	INT WALL SHEETING ABOVE HIP HEIGHT TO LEVEL 01 ROOMS INCL SECTION OF WALKWAY	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Level 1	RM G2-02	CEILING SHEETS TO ROOM G2-02	Ceiling	Cement Based		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Level 1	RM G2-02	CREAM SHEET VINYL FLOOR COVERINGS	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Level 1	RM G2-02	INTERNAL WALL SHEETING TO ROOM G2-02	Wall	Cement Based		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Level 1	ROOM G2-01	CREAM SHEET VINYL FLOOR COVERINGS	Floor Finish/Covering	Vinyl Sheeting (includes backing)		3	Presumed	62	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Ground Floor	WEST INT	GREY VINYL FLOOR TILES TO ENTRANCE AREA INC UNDER CARPET TO RM G1-05	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	4	Confirmed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Level 1	STAFF ROOM	INTERNAL WALL SHEETING TO STAFFROOM	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Ground Floor	RM-06	CEILING SHEETS TO G1-06	Ceiling	Cement Based		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Level 2	WALKWAY TO F BLOCK	WALL LINING TO THE WALKWAY FROM G BLOCK TO F BLOCK	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Level 1	STAFF ROOM	CEILING SHEETS TO STAFFROOM	Ceiling	Cement Based		4	Presumed	18	-	

TAFEs from BEMIR-TAFEs

Current as at 10-May-11

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Ground Floor	WEST INT	BLACK VINYL FLR TILES TO ENTRANCE AREA INC UNDER CARPET TO RM G1-05	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	External	Level 1	SOFFIT	SOFFIT SHEETS TO NORTHERN & SOUTHERN SIDES	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Ground Floor	RM-06	INTERNAL WALL SHEETING TO RM G1-08	Ceiling	Cement Based		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Ground Floor	RM G1-10	CEILING SHEETS TO G1-10	Ceiling	Cement Based		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Ground Floor	RM G1-09	INTERNAL WALL SHEETING TO G1-09	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Ground Floor	RM G1-09	CEILING SHEETS TO G1-09	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Ground Floor	RM G1-07	INTERNAL WALL SHEETING TO RMS G1-07	Ceiling	Cement Based		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Ground Floor	RM G1-07	CEILING SHEETS TO G1-07	Ceiling	Cement Based		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Ground Floor	RM G1-02	CEILING SHEETS TO G1-02	Ceiling	Cement Based		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31806003	G Block	G Block	External	Various levels	EXTERNAL	PUTTY TO STEEL FRAMED WINDOWS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	External	Various levels	EXTERNAL	EXT WALL SHEETING ABOVE EAST W'SHOP ENTRY DOOR & TO WINDOWS INFILLS WESTERN SIDE	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHGG	31805003	G Block	G Block	Internal	Ground Floor	ROOM G1-03	INTERNAL WALL SHEETING TO MAINTENANCE WORKROOM	Wall	Cement Based	Mixed	4	Confirmed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHJJ	31805006	J Block	J Block	Internal	Ground Floor	ROOM J1-04	INTERNAL WALL SHEETING AROUND OFFICE AREA (ROOM J1-04)	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHJJ	31805006	J Block	J Block	Internal	Level 1	WELDING BOOTHS	WALL SHEETING TO THE WELDING BOOTHS - CLASS 302	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHJJ	31805006	J Block	J Block	External	Ground Floor	DOCUMENT ROOM	VINYL SHEET FLOOR COVERING TO THE DOCUMENT ROOM	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHJJ	31805006	J Block	J Block	External	Ground Floor	EXTERNAL WALLS	CORRUGATED AC WALL SHEETING TO PERIMETER OF BUILDING	Wall	Cement Based		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHJJ	31805006	J Block	J Block	External	Ground Floor	EXTERNAL WALLS	EXTERNAL WALL SHEETING BETWEEN WINDOWS	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHJJ	31805006	J Block	J Block	External	Roof Level 1	ROOF	CORRUGATED ROOF SHEETING INCL FIBROLITE GABLE ENDS AND SKY LIGHT WALLS	Roof Sheeting	Cement Based		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHKK	31805007	K Block	K Block	Internal	Level 1	INTERNAL	GREEN VINYL FLOOR TILES UNDER CARPET TO LEVEL 01	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHKK	31805007	K Block	K Block	Internal	Level 2	STAIRWELLS	CEILING SHEETS ABOVE TMBER LATTICE WORK TO STAIRWELLS	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHKK	31805007	K Block	K Block	Internal	Level 2	ROOM K3-02	WALL SHEETING ABOVE K3-02 ENTRANCE DOORS EASTERN END	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHKK	31805007	K Block	K Block	Internal	Level 2	INTERNAL	SUSPENDED CEILING SHEETS TO LEVEL 02 INCLUDING ROOM K3-01	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHKK	31805007	K Block	K Block	Internal	Level 2	INTERNAL	COMPRESSED WALL SHEETING BEHIND SINK - BESIDE ROOM K3-02 ENTRANCE	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHKK	31805007	K Block	K Block	Internal	Level 1	RM K2-01	FLAT CEILING SHEETS TO K2-01	Ceiling	Cement Based		3	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHKK	31805007	K Block	K Block	Internal	Level 1	HALLWAYS	SHEET VINYL FLOOR COVERINGS HALLWAYS	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHKK	31805007	K Block	K Block	Internal	Ground Floor	WORKSHOP	VERMICULITE CEILINGS TO WORKSHOP AREA	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHKK	31805007	K Block	K Block	Internal	Ground Floor	WORKSHOP	SUSPECTED DISC BRAKE PADS TO DISPLAY BOARD	Plant, Equipment & Machinery	Polymer Based		4	Presumed	25	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHKK	31805007	K Block	K Block	Internal	Ground Floor	TOILET	SUSPENDED CEILING SHEETS TO WESTERN TOILET SECTION	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHKK	31805007	K Block	K Block	Internal	Ground Floor	TOILET	SUSPENDED CEILING SHEETS TO TOILETS	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHKK	31805007	K Block	K Block	Internal	Ground Floor	ROOM K1-09	GREEN VINYL FLOOR TILES TO RM K1-09 AND ADJACENT HALL WAY	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHKK	31805007	K Block	K Block	Internal	Ground Floor	DOCUMENT HOLDING AREA	WALL SHEETING TO CLASS DOCUMENT HOLDING AREA	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHKK	31805007	K Block	K Block	Internal	Ground Floor	DOCUMENT HOLDING AREA	CEILING SHEETS TO CLASS DOCUMENT HOLDING AREA	Ceiling	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHKK	31805007	K Block	K Block	External	Ground Floor	EXTERNAL	EXT WALL SHEETING ABOVE ALUM WINDOWS TO NW CNR	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		TOOWOOMBA TAFE CAMPUS - HUME STREET	TOOWOOMBA TAFE CAMPUS - HUME STREET	NTHKK	31805007	K Block	K Block	Internal	Level 1	RM K2-15	FLAT CEILING SHEETS TO K2-15	Ceiling	Cement Based		3	Presumed	18	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	26360010	J Block - Covered Ways	J Block - Covered Ways	J Block - Covered Ways	External	Ground Floor	COVERED WAYS	NIL ASBESTOS IDENTIFIED	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	26360013	M Block - Covered Area	M Block - Covered Area	M Block - Covered Area	External	Ground Floor	COVERED AREA	NIL ASBESTOS IDENTIFIED	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWW	26360000	** Site - Grounds	** Site - Grounds	External	Ground Floor	FLAMMABLE STORE	NIL ASBESTOS IDENTIFIED	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWW01	26360009	Fuel Store	Fuel Store	External	Ground Floor	FLAMMABLE STORE	NIL ASBESTOS IDENTIFIED	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWW02	26360011	Mobile Amenities	Mobile Amenities	Internal	Ground Floor	TOILETS	NIL ASBESTOS IDENTIFIED	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWW03	26360001	Stock Shed	Stock Shed	External	Ground Floor	BULL SHED	NIL ASBESTOS IDENTIFIED	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWW04	26360012	Hay Shed	Hay Shed	External	Ground Floor	HAY SHED	NIL ASBESTOS IDENTIFIED	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWW05	26360015	Bore Pump House	Bore Pump House	External	Ground Floor	EAST WALL	1 HEATER BANKS TO AIR CONDIT. UNIT EXT. ENTRANCE EAST WALL-3 UNIT R BLOCK 2 TO STH-1 TOWST	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWWAA	26360008	A Block	A Block	External	Roof Level 1	SOFFITS	SOFFITS TO PERIMETER OF BUILDING	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWWAA	26360008	A Block	A Block	Internal	Ground Floor	TOILETS	COMPRESSED SHEETS TO PARTITION OF FEMALE TOILETS	Wall	Cement Based		3	Presumed	18	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWWAA	26360008	A Block	A Block	Internal	Ground Floor	TOILETS	COMPRESSED SHEETS TO PARTITION OF MALE TOILETS	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWWBB	26360007	B Block	B Block	External	Roof Level 1	SOFFITS	SOFFIT TO NORTH, SOUTH, EAST & WEST SIDES OF BUILDING	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWWBB	26360007	B Block	B Block	Internal	Ground Floor	TOILETS	COMPRESSED PARTITIONS TO TOILETS	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWWGC	26360006	C Block	C Block	Internal	Ground Floor	STAFF TOILETS	COMPRESSED SHEETS TO TOILET PARTITIONS- FEMALE STAFF	Wall	Cement Based		3	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWWCC	26360006	C Block	C Block	Internal	Ground Floor	STAFF TOILETS	COMPRESSED SHEETS TO TOILET PARTITIONS-MALE STAFF	Wall	Cement Based		4	Presumed	18	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWWCC	26360006	C Block	C Block	External	Roof Level 1	SOFFIT	SOFFIT TO NORTH, SOUTH, EAST & WEST SIDES OF BUILDING	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWDD	26360005	D Block	D Block	Internal	Ground Floor	ROOM/OFFICE NEAST	COMPRESSED TAPS AND SHELVES TO WORK BENCHES NEAST CORNER	Furniture	Cement Based		4	Presumed	18	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWDD	26360005	D Block	D Block	External	Roof Level 1	SOFFITS	MARKED MANUFACTURED WITHOUT ASBESTOS	Gable/Soffit/Fascia	Other (refer to description)		4	Presumed		-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWEE	26360004	E Block	E Block	External	Ground Floor	TELECOM PIT	FIBRE CEMENT TELECOM PIT PROFILE NEXT TO BLOCK E BETWEEN BLOCK D	Preformed Molded Product	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWEE	26360004	E Block	E Block	Internal	Ground Floor	ROOM E13 WELDING ROOMS	2 SHEETS HARDFLEX H2 STORED WITH SHEET METAL NORTH EAST CORNER OF ROOM	Stored Material	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWEE	26360004	E Block	E Block	Internal	Ground Floor	ROOM E13 WELDING ROOMS	COMPRESSED SHEETING TO WELDING BOOTH PARTITIONS AND OXY. BENCHES (E13)	Furniture	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWEE	26360004	E Block	E Block	Internal	Ground Floor	ROOM E25 B CLASSROOM	CLUTCH PLATES STORED ON SHELVES ON NORTHERN WALL OF CLASSROOMS E 25 B	Stored Material	Polymer Bound	CHR - Chrysotile	4	Confirmed	25	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWEE	26360004	E Block	E Block	Internal	Ground Floor	ROOM E5 WELDING ROOMS	COMPRESSED SHEETING TO WELDING BOOTH PARTITIONS AND OXY. BENCHES (E5)	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWFF	26360003	F Block	F Block	External	Ground Floor	SUN HOODS	SUNHOOD TO WESTERN WALL COMPRESSED SHEET	Sun Hood	Cement Based		4	Presumed	18	-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWWGG	26360002	G Block	G Block	External	Ground Floor	NEXT SHEEP PENS	SHEET TO END OF WASH BASIN NEXT TO SHEEP PENS - NORTH SIDE	Furniture	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Southern Queensland		WARWICK TAFE CAMPUS	WARWICK TAFE CAMPUS	NWWGG	26360002	G Block	G Block	Internal	Ground Floor	WEST END ROOMS	ROOMS AT WEST END OF WOOL SHED -BUILT IN 1985 - ASBESTOS FREE	Other (refer to description)	Other (refer to description)		3	Not Present(Not Tested)		-	
Sunshine Coast		MAROOCHYDORE TAFE CAMPUS - 108 PARKER STREET	MAROOCHYDORE TAFE CAMPUS - 108 PARKER STREET	51779000	51779000	** Site - Grounds	** Site - Grounds											-	
Sunshine Coast		MAROOCHYDORE TAFE CAMPUS - 108 PARKER STREET	MAROOCHYDORE TAFE CAMPUS - 108 PARKER STREET	51779001	51779001	OFFICE ACCOMM	OFFICE ACCOMM											-	
Sunshine Coast		MAROOCHYDORE TAFE CAMPUS - 170 HORTON PARADE	MAROOCHYDORE TAFE CAMPUS - 170 HORTON PARADE	32668802	32668802	CAR ACCOMODATION	CAR ACCOMODATION											-	
Sunshine Coast		MAROOCHYDORE TAFE CAMPUS - 170 HORTON PARADE	MAROOCHYDORE TAFE CAMPUS - 170 HORTON PARADE	RMD	32668000	Site/Grounds	Site/Grounds	External	Ground Floor	CAMPUS	ASBESTOS FREE	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
Sunshine Coast		MAROOCHYDORE TAFE CAMPUS - 170 HORTON PARADE	MAROOCHYDORE TAFE CAMPUS - 170 HORTON PARADE	RMD01		Garage	Garage											-	
Sunshine Coast		MAROOCHYDORE TAFE CAMPUS - 170 HORTON PARADE	MAROOCHYDORE TAFE CAMPUS - 170 HORTON PARADE	RMDAA	32668001	A Block	A Block											-	
Sunshine Coast		MOOLOOLABA TAFE CAMPUS	MOOLOOLABA TAFE CAMPUS	28946001		SALON/ELECT ROOM	SALON/ELECT ROOM	Internal	Ground Floor	B BLOCK STORE ROOM	VINYL FLOORING, Sample 23615.	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	Sample 23615 taken for asbestos testing.
Sunshine Coast		MOOLOOLABA TAFE CAMPUS	MOOLOOLABA TAFE CAMPUS	28946001		SALON/ELECT ROOM	SALON/ELECT ROOM	Internal	Ground Floor	B BLOCK OLD BAR AREA	VINYL FLOORING, Sample 23614.	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	Sample 23614 taken for asbestos test.
Sunshine Coast		MOOLOOLABA TAFE CAMPUS	MOOLOOLABA TAFE CAMPUS	28946001		SALON/ELECT ROOM	SALON/ELECT ROOM	Internal	Ground Floor	B BLOCK ELECTRICAL SOUTH ROOM	VINYL FLOOR, Sample 23613.	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	Sample 23613 taken for asbestos test.
Sunshine Coast		MOOLOOLABA TAFE CAMPUS	MOOLOOLABA TAFE CAMPUS	28946001		SALON/ELECT ROOM	SALON/ELECT ROOM	External	Other (refer to description)	SOUTH END OF B BLOCK	SOFFIT, Sample 23616.	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	Sample 23616 taken for asbestos testing.
Sunshine Coast		MOOLOOLABA TAFE CAMPUS	MOOLOOLABA TAFE CAMPUS	28946001		SALON/ELECT ROOM	SALON/ELECT ROOM	External	Ground Floor	VERANDAH	SHEETING TO CEILING TO VERANDAH	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Sunshine Coast		MOOLOOLABA TAFE CAMPUS	MOOLOOLABA TAFE CAMPUS	28946001		SALON/ELECT ROOM	SALON/ELECT ROOM	External	Ground Floor	NORTH END OF B BLOCK	SOFFIT, Sample 23612.	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	Sample 23612 taken for asbestos test.
Sunshine Coast		MOOLOOLABA TAFE CAMPUS	MOOLOOLABA TAFE CAMPUS	28946001		SALON/ELECT ROOM	SALON/ELECT ROOM	Internal	Ground Floor	ELECT MAINS ROOM	VINYL SHEETING TO FLOOR TO ELECTRICAL MAINS ROOM OFF ROOM B	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Sunshine Coast		MOOLOOLABA TAFE CAMPUS	MOOLOOLABA TAFE CAMPUS	RML	28946000	** Site - Grounds	** Site - Grounds											-	
Sunshine Coast		MOOLOOLABA TAFE CAMPUS	MOOLOOLABA TAFE CAMPUS	RMLAA	28946010	A Block	A Block											-	
Sunshine Coast		MOOLOOLABA TAFE CAMPUS	MOOLOOLABA TAFE CAMPUS	RMLBB		B Block	B Block											-	
Sunshine Coast		MOOLOOLABA TAFE CAMPUS	MOOLOOLABA TAFE CAMPUS	RMLCC		C Block	C Block											-	
Sunshine Coast		MOOLOOLABA TAFE CAMPUS	MOOLOOLABA TAFE CAMPUS	RMLDD		D Block	D Block											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	25174000	25174000	** Site - Grounds	** Site - Grounds											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	25174010	25174010	LUNCH ROOM	LUNCH ROOM	External	Level 1	SOFFITS		Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	25174010	25174010	LUNCH ROOM	LUNCH ROOM	Internal	Level 1	THROUGHOUT	INTERNAL SHEETING TO WALLS	Wall	Cement Based		4	Presumed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	25174010	25174010	LUNCH ROOM	LUNCH ROOM	Internal	Level 1	ROOM	SHEETING TO CEILING TO ROOM	Ceiling	Cement Based		4	Presumed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	25174010	25174010	LUNCH ROOM	LUNCH ROOM	Internal	Level 1	ROOM	SHEETING TO FLOOR TILES TO ROOM	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	25174020	25174020	GROUNDSTAFF SHED	GROUNDSTAFF SHED											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	25174021	25174021	PRINT ROOM / STORE SHED	PRINT ROOM / STORE SHED											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	25174023	25174023	RENEWABLE ENERGY CLASSROOM	RENEWABLE ENERGY CLASSROOM											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	25174031	25174031	RENEWABLE ENERGY TOILET BLOCK	RENEWABLE ENERGY TOILET BLOCK											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	25174032	25174032	RENEWABLE ENERGY FIELD SHED	RENEWABLE ENERGY FIELD SHED											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	25174033	25174033	COVERED WALKWAY	COVERED WALKWAY											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNM01		Storage Shed	Storage Shed											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNM02		Lunch Room	Lunch Room											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNM03		Storage Shed	Storage Shed											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNM04	25174009	Plumbing Pit	Plumbing Pit											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNM06	25174003	Flammable Liquids Lab	Flammable Liquids Lab											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNM09		Aquaculture	Aquaculture											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNM10	25174022													-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNM11	25174009	FIRE BOOSTER CONTROL BUILDING	FIRE BOOSTER CONTROL BUILDING	Internal	Ground Floor	PUMP SHED	SHEETING TO WALLS TO PUMP SHED	Wall	Cement Based		4	Presumed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNM12		Storage Shed	Storage Shed											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNM13		Storage Shed	Storage Shed											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNM14		Greenhouse	Greenhouse											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNM15	25174019	Fertilizer Shed	Fertilizer Shed											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNM16		Greenhouse	Greenhouse											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNM17		Office	Office											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNM18		Lunch Room	Lunch Room											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNM19	25174017	PLASTERERS WORK SHED	PLASTERERS WORK SHED											-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNM20		Demountable	Demountable											-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Floor	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEIMR Score	Attention Required	Comments
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMAA	25174008	A Block	A Block	Inter nal Level 1	ROOM A1.17 CANTEN & STORE	SHEETING TO CEILING TO CANTEN AND STORE ROOMS	Ceiling	Cement Based		4	Presumed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMAA	25174008	A Block	A Block	Exter nal Level 3	SOFFITS	SHEETING TO SOFFITS	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMAA	25174008	A Block	A Block	Exter nal Level 3	VERANDAH A3.25	SHEETING TO CEILING TO VERANDAH	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMAA	25174008	A Block	A Block	Inter nal Level 1	CANTEN	SHEETING TO CEILING IN OPEN EATING AREA ONLY	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMAA	25174008	A Block	A Block	Inter nal Level 3	ROOM A3.13 TOILETS - FEMALE	SHEETING TO WALL PARTITIONS TO TOILETS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMAA	25174008	A Block	A Block	Inter nal Level 1	ROOM A1.17 CANTEN & STORE	SHEETING TO WALLS TO CANTEN AND STORE ROOMS	Wall	Cement Based		4	Presumed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMAA	25174008	A Block	A Block	Inter nal Level 1	ROOM A1.60 TOILETS - MALE	SHEETING TO WALL PARTITIONS TO TOILETS	Wall	Cement Based		4	Presumed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMAA	25174008	A Block	A Block	Inter nal Level 1	ROOM A1.60 TOILETS - FEMALE	SHEETING TO WALL PARTITIONS TO TOILETS	Wall	Cement Based		4	Presumed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMAA	25174008	A Block	A Block	Inter nal Level 2	HALLWAY	CEILING TILES TO HALLWAY TO LEVEL 2	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMAA	25174008	A Block	A Block	Inter nal Level 2	ROOM A2.60 TOILETS - MALE	SHEETING TO WALL PARTITIONS TO TOILETS	Wall	Cement Based		4	Presumed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMAA	25174008	A Block	A Block	Inter nal Level 2	ROOM A2.80 TOILETS - FEMALE	SHEETING TO WALL PARTITIONS TO TOILETS	Wall	Cement Based		4	Presumed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMAA	25174008	A Block	A Block	Inter nal Level 2	ROOM A204	SHEETING TO CEILING TO ROOM A204	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMAA	25174008	A Block	A Block	Inter nal Level 3	ROOM A3.06 OFFICE	SPRAYED ON TO MAIN BEAM INSIDE CEILING TO OFFICE	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMAA	25174008	A Block	A Block	Inter nal Level 3	ROOM A3.11 TOILETS - MALE	SHEETING TO WALL PARTITIONS TO TOILETS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMAA	25174008	A Block	A Block	Exter nal Roof Level 1	FASCIA	SHEETING TO FASCIAS TO WALLS	Gable/Soffit/F ascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB A	25174004	BA Block	BA Block	Inter nal Ground Floor	STORAGE	PANEL TO WALL BESIDE AIR CONDITIONER	Wall	Cement Based		4	Presumed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB A	25174004	BA Block	BA Block	Inter nal Ground Floor	STORAGE	SHEETING TO FIRE DOORS	Fire Door	Mitlbord		4	Presumed	64	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB A	25174004	BA Block	BA Block	Inter nal Ground Floor	STORAGE	PERFORATED SHEETING TO CEILING	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.13A WORKSHOP STORE	FIBRE CEMENT CEILING SHEETING - SAMPLE SU-026014	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.14-1.13	SHEETING TO CEILINGS TO ROOMS 1.14 TO 1.13	Ceiling	Cement Based		4	Presumed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.15	PERFORATED SHEETING TO CEILING TO ROOM 1.15 - SAMPLE SU-02608	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.15 AUTO WORKSHOP	EASTERN WALL ABOVE 2.7M HIGH BLACK WINDOW RAIL - SU-02609	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.15 AUTO WORKSHOP	PERFORATED CEILING SHEETING - SAMPLE SU-02608	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.15 AUTO WORKSHOP	SOUTHERN WALL ABOVE 2.7M HIGH BLACK WINDOW RAIL - SAMPLE SU-02607	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.15 AUTO WORKSHOP	WESTERN WALL ABOVE 2.7M HIGH BLACK WINDOW RAIL - SAMPLE SU-02610	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.16 FIT/TURNING	EASTERN WALL ABOVE 2.7M HIGH BLACK WINDOW RAIL - SAMPLE SU-02617	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.30 TIMBER WORKSHOPS	FIBRE CEMENT SHEETING ON EASTERN WALL - SAMPLE SU-02649	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.16 FIT/TURNING	PERFORATED CEILING SHEETING - SAMPLE SU-02615	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.09 MAIN WORKSHOP	WESTERN WALL ABOVE 2.7M HIGH BLACK WINDOW RAIL - SAMPLE SU-02604	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.16 FIT/TURNING	SHEETING TO WALLS ABOVE 3 METRES TO FITTING & TURNING	Wall	Cement Based		4	Presumed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.16 FIT/TURNING	SOUTHERN WALL ABOVE 2.7M HIGH BLACK WINDOW RAIL - SAMPLE SU-02619	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.16 FIT/TURNING	WESTERN WALL ABOVE 2.7M HIGH BLACK WINDOW RAIL - SAMPLE SU-02618	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.20 FIRST AID ROOM	SHEETING TO CEILING AND WALL PANEL TO FIRST AID ROOM	Ceiling	Cement Based		4	Presumed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.21 CLEANER/STORE & TOILETS	SHEETING TO CEILING TO CLEANER/STORE AND TOILETS	Ceiling	Cement Based		4	Presumed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.28 CLASSROOM	FIBRE CEMENT CEILING SHEETING - SAMPLE SU-02629	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.28 CLASSROOM	FIBRE CEMENT CEILING SHEETING INSIDE NEW AIR CON ROOM - SAMPLE SU-02630	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.28 CLASSROOM	WESTERN WALL SHEETING - SAMPLE SU-02631	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Exter nal Ground Floor	SOFFIT SHEETING	EASTERN SIDE OF BUILDING OUTSIDE ROOM 1.16 - SAMPLE SU-02621	Gable/Soffit/F ascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.16 FIT/TURNING	NORTHERN WALL ABOVE 2.7M HIGH BLACK WINDOW RAIL - SAMPLE SU-02616	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.08 ELECTRICAL	SHEETING TO PARTITION WALLS TO ELECTRICAL ROOM	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Exter nal Ground Floor	SOFFIT SHEETING	FIBRE CEMENT SOFFIT SHEETING OUTSIDE ROOM 1.30 - SAMPLE SU-02650	Gable/Soffit/F ascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Exter nal Ground Floor	SOFFIT SHEETING	FIBRE CEMENT SOFFIT SHEETING TO NORTH EASTERN SIDE OF ROOM 1.47 - SAMPLE SU-02654	Gable/Soffit/F ascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Exter nal Ground Floor	SOFFIT SHEETING	NORTH EASTERN SIDE OF BUILDING OUTSIDE ROOM 1.09 - SAMPLE SU-02620	Gable/Soffit/F ascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Exter nal Ground Floor	SOFFIT SHEETING	SOFFIT OUTSIDE MALE STUDENT TOILET - SAMPLE SU-02628	Gable/Soffit/F ascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Exter nal Ground Floor	SOFFIT SHEETING	WESTERN SIDE OF BUILDING OUTSIDE ROOM 1.07 - SAMPLE SU-02623	Gable/Soffit/F ascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Exter nal Ground Floor	SOFFIT SHEETING	WESTERN SIDE OF BUILDING OUTSIDE ROOM 1.16B - SAMPLE SU-02622	Gable/Soffit/F ascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	VERANDAH	SHEETING TO CEILINGS TO VERANDAHS TO BOTH SIDES OF BUILDING	Ceiling	Cement Based		4	Presumed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	FEMALE STUDENT TOILET	GENERAL AREA CEILING SHEETING - SAMPLE SU-02626	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.10 CLASSROOM	PERFORATED SHEETING TO CEILING AND SKYLIGHTS TO CLASSROOM & ROOMS 1.12 & 1.10	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	MALE STUDENT TOILET	URINAL AREA CEILING - SAMPLE SU-02625	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.10 CLASSROOM	PERFORATED CEILING SHEETING - SAMPLE SU-02613	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.08 ELECTRICAL	SHEETING TO WALLS ABOVE 3 METRES	Wall	Cement Based		4	Presumed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.09 MAIN WORKSHOP	EASTERN WALL ABOVE 2.7M HIGH BLACK WINDOW RAIL - SAMPLE SU-02603	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Sunshine Coast		NAMBOUR TAFE CAMPUS	NAMBOUR TAFE CAMPUS	RNMB B	25174007	B Block	B Block	Inter nal Ground Floor	ROOM 1.09 MAIN WORKSHOP	NORTHERN WALL OF ROOM ABOVE 2.7M HIGH BLACK WINDOW RAIL - SAMPLE SU-02601	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	

TAFes from BEIMR-TAFes

TAFEs from BEMIR-TAFEs

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Sunshine Coast		NOOSA TEWANTIN TAFE CAMPUS	NOOSA TEWANTIN TAFE CAMPUS	RNAAA		A Block	A Block												
Sunshine Coast		NOOSA TEWANTIN TAFE CAMPUS	NOOSA TEWANTIN TAFE CAMPUS	RNABR		C Block	C Block											-	
Sunshine Coast		NOOSA TEWANTIN TAFE CAMPUS	NOOSA TEWANTIN TAFE CAMPUS	RNACC		C Block	C Block											-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS		24305001	STORE SHED	STORE SHED	Internal	Ground Floor	STORE SHED	STORE/SHED CONSTRUCTED 1990 - THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS		24305002	CRICKET OVAL SHED	CRICKET OVAL SHED	Internal	Ground Floor	CRICKET OVAL SHED	CONSTRUCTED OF NON-ASBESTOS MATERIALS - METAL ROOF, TIMBER WALLS AND FLOOR	Baffles/Lining	Other (refer to description)		3	Presumed		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS		24305018	COVERED LINK	COVERED LINK	External	Ground Floor	COVERED LINK	BUILDING CONSTRUCTED POST - 1990 THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS		24305019	AUDITORIUM COVER	AUDITORIUM COVER	External	Ground Floor	AUDITORIUM COVER	BUILDING CONSTRUCTED POST - 1990 THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS		24305027	PERGOLA	PERGOLA	External	Ground Floor	PERGOLA	BUILDING CONSTRUCTED POST - 1990 THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS		24305035	COVERED AREA	COVERED AREA	External	Ground Floor	COVERED AREA	BUILDING CONSTRUCTED POST - 1990 THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS		24305035	COVERED AREA	COVERED AREA	External	Ground Floor	COVERED AREA	BUILDING CONSTRUCTED POST - 1990 THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS		24305035	COVERED AREA	COVERED AREA	External	Ground Floor	COVERED AREA	BUILDING CONSTRUCTED POST - 1990 THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS		24305035	COVERED AREA	COVERED AREA	External	Ground Floor	COVERED AREA	BUILT POST 1990	Baffles/Lining	Other (refer to description)		3	Presumed		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS		24305035	COVERED AREA	COVERED AREA	External	Site / Grounds	EXTERNAL	TIMBER FRAME STRUCTURE WITH METAL CLADDING	Baffles/Lining	Other (refer to description)		3	Presumed		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS		24305036	SHADE SAILS	SHADE SAILS	External	Site / Grounds	SHADE SAILS	STEEL SHADE CLOTH STRUCTURE	Baffles/Lining	Other (refer to description)		3	Presumed		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN	24305000	SITE	SITE	External	Site / Grounds	BAR-B-QUE	SHEETING AS FORM WORK UNDER BENCH TOPS BBQ SITES 2 BRICK	Wall	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN	24305000	SITE	SITE	Internal	Other (refer to description)	STORED MATERIAL (INTERNAL OR EXTERNAL)								-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN	24305000	SITE	SITE	External	Site / Grounds	BEHIND GATE VALVES/SERV ENTRY DOOR	SHEETING BEHIND GATE VALVES OUTSIDE SERVICE TUNNEL	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN	24305000	SITE	SITE	External	Site / Grounds	EXTERNAL	SHEET DEBRIS IN PATHWAY APPROX 90MM WEST DAY CARE	Debris	Cement Based	CHR - Chrysotile	2	Confirmed	34	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN	24305000	SITE	SITE	External	Site / Grounds	GARDEN BED	DEBRIS IN GARDEN BED STHN OF THE WORK SHED	Debris	Cement Based	Mixed	2	Confirmed	34	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN	24305000	SITE	SITE	External	Site / Grounds	NORTHERN BOUNDARY	SHEETING PIPE DEBRIS ON NURSERY SIDE OF SITE	Debris	Cement Based	CHR - Chrysotile	2	Confirmed	34	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN	24305000	SITE	SITE	External	Site / Grounds	TANK STAND	3 X SHEETS ROOF SHEETING UNDER TANK STAND TRACTOR SHED - PORTABLE ITEM	Stored Material	Cement Based	CHR - Chrysotile	2	Confirmed	34	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN	24305000	SITE	SITE	External	Site / Grounds	TELECOMMUNICATION PITS	2 X TELECOMMUNICATIONS PIT IN STAFF CAR PARK VINE YARD	Drains/Pipes/F	Cement Based	CHR - Chrysotile	4	Confirmed	15	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN	24305000	SITE	SITE	External	Site / Grounds	TELECOMMUNICATION PITS	TELECOMMUNICATIONS PIT THROUGHOUT CAR PARKS UNDER LIGHT POLE	Drains/Pipes/F	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN	24305000	SITE	SITE	Internal	Basement 1	SERVICE TUNNEL	PACKING MATERIAL UNDER THE PIPE SUPPORT BRACKET - PORTABLE ITEM	Stored Material	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN	24305000	SITE	SITE	Internal	Basement 1	SERVICE TUNNEL PIPES	APPROX 6 PIPES ACCESS THROUGH CONCRETE WALL	Drains/Pipes/F	Cement Based	Mixed	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN	24305000	SITE	SITE	Internal	Other (refer to description)	STORED MATERIAL (INTERNAL OR EXTERNAL)	PIECE OF COMPRESSED SHEET STORED AT WHLS OFFICE SUPPLIED BY BRONWYN ROULSTONE	Stored Material	Cement Based	No asbestos detected (NAD)	1	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN	24305000	SITE	SITE	External	Basement 1	SERVICE TUNNEL UNDER BLK B	SEALS TO GATE VALVES UNDER BLOCK B IN SERVICE TUNNELS VALVES STUFFING BOXES APPROX. 8 UNITS - PORTA	Stored Material	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN	24305000	SITE	SITE	Internal	Site / Grounds	DRIVEWAY	SHEET PIPE IN DOORWAYS AND THROUGHOUT THE NURSERY	Debris	Cement Based	Mixed	2	Confirmed	34	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN01		Hort - Shade Structure (N	Hort - Shade Structure (N												
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN02	24305022	Hort - Machinery Shed (Ne	Hort - Machinery Shed (Ne	Internal	Ground Floor	OFFICE/STORE SHED	BUILDING CONSTRUCTED POST - 1990 THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN04		Hort - Pot Shed (West of	Hort - Pot Shed (West of												
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN05	24305025	Hort - Propagation Tunnel	Hort - Propagation Tunnel	External	Ground Floor	MISTING SHED	BUILDING CONSTRUCTED POST - 1990 THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN06	24305022	Hort - Shade House (Large	Hort - Shade House (Large	External	Ground Floor	GREENHOUSE NO 1	BUILDING CONSTRUCTED POST - 1990 THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN07	24305020	Hort - Potting Shed 1	Hort - Potting Shed 1	Internal	Ground Floor	WORK SHED BENCHES	2 X POTTING WORK BENCHES IN THE WORK SHED	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN07	24305020	Hort - Potting Shed 1	Hort - Potting Shed 1	External	Ground Floor	WORK SHED	BUILDING CONSTRUCTED POST - 1990 THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN08	24305021	Hort - Potting Shed 2	Hort - Potting Shed 2	External	Ground Floor	POTTING SHED	BUILDING CONSTRUCTED POST - 1990 THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN09	24305023	Hort - Shade House (West	Hort - Shade House (West	External	Ground Floor	GREENHOUSE NO 2	BUILDING CONSTRUCTED POST - 1990 THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN10	24305024	Hort - Shade House (East	Hort - Shade House (East	External	Ground Floor	GREENHOUSE NO 3	BUILDING CONSTRUCTED POST - 1990 THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN11	24305028	Hort - Amenities	Hort - Amenities	Internal	Ground Floor	INTERNAL	SHEETING TO WALL ABOVE BLOCK WORK	Wall	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN11	24305028	Hort - Amenities	Hort - Amenities	External	Roof Level 1	EXTERNAL	SHEETING TO WALL BETWEEN ROOF LEVELS	Wall	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN13		Shed (South West of B Blo	Shed (South West of B Blo												
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN15	24305013	Shed (South East of B Blo	Shed (South East of B Blo	External	Ground Floor	STORAGE SHED	BUILDING CONSTRUCTED POST - 1990 THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN19		Shed - Small (East of Hou	Shed - Small (East of Hou												
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBN20		Shed - Large (East of Hou	Shed - Large (East of Hou												

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEIR Score	Attention Required	Comments
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBN21	24305031	Hort - Chemical Storage S	Hort - Chemical Storage S	External	Ground Floor	CHEMICAL SHED	BUILDING CONSTRUCTED POST - 1990 THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)	-		
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBN22	24305026	Hort - Storage Shed (Near	Hort - Storage Shed (Near	External	Ground Floor	TOOL SHED	BUILDING CONSTRUCTED POST - 1990 THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)	-		
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBN23		Hort - Machinery Storage	Hort - Machinery Storage											-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBN24	24305030	Hort - Tractor Storage Sh	Hort - Tractor Storage Sh	External	Ground Floor	STORE SHED	BUILDING CONSTRUCTED POST - 1990 THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)		3	Not Present(Not Tested)	-		
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBN25		Childcare - Storage Shed	Childcare - Storage Shed											-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBN26		Childcare - Storage Shed	Childcare - Storage Shed											-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBN27		Childcare - Storage Shed	Childcare - Storage Shed											-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBN28		Storage Shed	Storage Shed											-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNAA	24305007	A Block	A Block	External	Ground Floor	FASCIA	SHEETING TO FASCIA BOARD	Gable/Soffit/Fascia	Cement Based	No asbestos detected (NAD)	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNAA	24305007	A Block	A Block	Internal	Ground Floor	ROOM 1.01 CLASSROOM	VINYL SHEETING TO FLOOR AREA OF CLASSROOM. REFER BMP SECTION 3.3	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNAA	24305007	A Block	A Block	External	Ground Floor	SOFFITS	SHEETING TO SOFFITS	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOM B2-05	WELDING BAY 3 BENCH TOPS	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	16	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 5	ROOM B5-11	FIRE DOOR TO SERVICE DUCT IN ROOM B5.11 (REMOVED & REPLACED WITH NON ASBESTOS)	Fire Door	Cement Based	Mixed	2	Removed	34	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOM B2-17	COMPRESSED SHEETING ON FLOOR BELOW FIRE ALARM BOX	Floor Finish/Covering	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOM B2-05	COMPRESSED SHEETING TO WALLS OF WELDING BOOTHS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOM B2-05	ASBESTOS SEAL TO ELECTRODE DRYING OVEN IN ROOM B2-05 (REMOVED & REPLACED WITH NON ASBESTOS)	Furniture	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOM B203 WALL SHEET ADJACENT TO CAGE AREA	WALL SHEET ADJ TO CAGE AREA	Wall	Cement Based	No asbestos detected (NAD)	3	Not Present(Not Tested)	-		
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOM B2-05	WELDING BAY 8 BENCH TOP	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOM B2-05	WELDING BAY 7 BENCH TOP	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 4	SERVICE DUCT	FIRE DOOR TO SERVICE DUCT BETWEEN RMS B4.04 & B4.02 (REMOVED & REPLACED WITH NON ASBESTOS)	Fire Door	Cement Based	Mixed	2	Removed	34	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOM B2-05	WELDING BAY 4 BENCH TOPS	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 4	ROOM B5-08	VENT PIPES IN TWO CORNERS OF ROOM B5-08	Drains/Pipes/Furniture	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOM B2-05	WELDING BAY 2 BENCH TOPS	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOM B2-05	WELDING BAY 12 BENCH TOP	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOM B2-05	WELDING BAY 11 BENCH TOP	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOM B2-05	DEMONSTRATION WELDING BAY BENCH TOP	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOM 2.13 AUTOMOTIVE	GASKETS IN ALL THE AUTOMOTIVE SECTION TEST MOTORS & OLD LAWN MOWER & MOTORS - PORTABLE ITEM	Stored Material	Polymer Based		4	Presumed	25	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOM 2.13 AUTOMOTIVE	CLUTCH HOUSING/PLATE STORED UNDER THE WORKBENCH - PORTABLE ITEM	Stored Material	Polymer Based	CHR - Chrysotile	3	Confirmed	25	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOM 2.05 MAIN SWITCHBOARD	ZELEMITE BACKBOARD TO ENERGY MANAGEMENT SYSTEMS	Insulation/Fill	Polymer Based	CHR - Chrysotile	4	Removed	25	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	PASSAGEWAYS	VINYL SHEETING TO FLOOR OF PASSAGEWAYS. REFER BMP SECTION 3.3	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOM B2-05	WELDING BAY 6 BENCH TOP	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Various levels Internal	STAIRWELLS	FIRE DOORS IN STAIRWELLS ON EACH SIDE OF COURTYARD	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 3	SERVICE DUCT	FIRE DOOR TO SERVICE DUCT BETWEEN RMS B3.18 & B3.20	Fire Door	Cement Based	Mixed	2	Removed	34	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 3	SERVICE DUCT	FIRE DOOR TO SERVICE DUCT BESIDE ROOM B3.82	Fire Door	Cement Based	Mixed	2	Removed	34	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 3	ROOM B3-06	ZELEMITE BOARDS STORED BESIDE DOOR BELOW LIGHT SWITCH & ALONG WALL & ON WORK BENCH	Stored Material	Polymer Based	CHR - Chrysotile	4	Removed	25	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 3	ROOM B3-03	SHEETING TO PARTITION WALLS IN ROOM B3-03	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOM B3-08	VINYL SHEETING TO FLOOR AREA OF B3-08	Floor Finish/Covering	Virgin Sheeting (includes backing)		4	Presumed	62	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 3	PASSAGEWAY	VERMICULITE TO THE PASSAGE WAY ON LEVEL 3	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOMS B2-02 & 03	COMPRESSED SHEETING TO WALLS OF WELDING BOOTHS	Wall	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	ROOM B2-17	FIBRO SHEETING ON WALL NEAR LIGHT SWITCH	Wall	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 2	WALL SHEET TO CAGED AREA	WALL SHEET TO CAGED AREA	Wall	Cement Based	No asbestos detected (NAD)	3	Not Present(Not Tested)	-		
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 4	ENTRY FOYER	VERMICULITE COATING TO ENTRY FOYER CEILING	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Various levels Internal	SERVICE DUCT	STORMWATER PIPE IN SERVICE DUCT BETWEEN RMS B5.03 & B5.02	Stormwater Plumbing	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 5	SERVICE DUCT	FIRE DOOR TO SERVICE DUCT BETWEEN RMS B5.03 & B5.02	Fire Door	Cement Based	Mixed	2	Removed	34	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Various levels Internal	ROOM B5-11	STORMWATER PIPE IN SERVICE DUCT IN ROOM B5.11	Stormwater Plumbing	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 6	ROOM 6.04 LIFT PLANT ROOM	1 X SET BRAKE SHOES TO LIFT MOTOR FLY WHEEL	Plant, Equipment & Machinery	Polymer Based		3	Presumed	25	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 1	ROOMS B2-02 & 03	SHEETING TO WALLS ADJACENT TO ROLLER DOOR AND WALLS THROUGH TO CAGED AREA	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 5	PLANT ROOM STAIRWELLS	COMPRESSED SHEETING TO BOARDS AT FOOT OF DOORS TO ROOF IN PLANT RM STAIRWELLS	Floor	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 4	SERVICE DUCT	FIRE DOOR TO SERVICE DUCT BETWEEN RMS B4.12 & B4.10 (REMOVED & REPLACED WITH NON ASBESTOS)	Fire Door	Cement Based	Mixed	2	Removed	34	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 4	ROOM R5-08	SHEETING TO CEILING OF INTERNAL MARKETING PUBLICITY AND PROMOTIONS ROOM	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Various levels Internal	TOILETS	SHEETING BEHIND TILES TO ALL TOILETS TOUT BLOCK	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Level 2	EXTERNAL	DRAIN SURROUNDS TO VENT PIPES IN COURTYARD AND ON SOUTH-EAST CORNER OF BLDG	Drains/Pipes/Floors	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Various levels External	EXTERNAL	VENT PIPE ON WALLS IN COURTYARD	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	Internal	Level 3	PASSAGEWAY	VINYL FLOOR SHEETING TO CORRIDORS ON LEVEL 3	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Level 2	BARGE BOARD	COMPRESSED SHEETING TO BARGE BOARD PANELS	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Ground Floor	ADJ CAR RAMP	COMPRESSED SHEETING TO BENCH ADJACENT TO CAR RAMP	Furniture	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Level 2	EXTERNAL	VENT PIPE ON WALL FACING BLOCK C	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Level 2	EXTERNAL	WASTE PIPES OUTSIDE COURTYARD ON EAST WALL	Drains/Pipes/Floors	Cement Based	Mixed	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Level 2	OPP DETACHED CLASSROOM	COMPRESSED SHEETING TO WALL OPPOSITE DETACHED CLASSROOM	Wall	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Level 2	ROOM B2-17 PIPES	COMPRESSED PIPES IN GROUND UNDER COMPRESSED SHEET BELOW FIRE ALARM BOX	Drains/Pipes/Floors	Cement Based	Mixed	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Level 2	SOFFITS	DECORVENT SHEETING TO SOFFITS	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Level 3	CAR BAYS & BRICKLAYING	SHEETING TO CEILING ABOVE CAR BAYS AND BRICKLAYING AREA ON LEVEL 2	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Roof Level 1	SOFFIT	SOFFIT SHEET BEHIND VENTILATION BLADES IN MIDDLE OF ROOF EACH SIDE OF C/YARD	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Level 3	SOFFIT	COMPRESSED SHEETING TO SMALL SOFFIT UNDER BARGE BOARD PANELS	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Various levels External	BARGE BOARD	COMPRESSED SHEETING TO BARGE BOARD PANELS	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Roof Level 1	EXTERNAL	SHEETING TO THE TOPS OF THE PARAPET WALLS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Roof Level 1	EXTERNAL	COMPRESSED SHEETING TO WALLS AT EACH END OF ROOF	Wall	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Roof Level 1	BARGE BOARD	COMPRESSED SHEETING TO BARGE CAPPING IN CENTRE OF ROOFS ON EACH SIDE OF C/YARD	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Level 4	SOFFITS	DECORVENT SHEETING TO SOFFITS	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Level 4	SOFFIT	COMPRESSED SHEETING TO SMALL SOFFIT DIRECTLY UNDER BARGE BOARDS	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Level 4	BARGE BOARD	COMPRESSED SHEETING TO BARGE BOARD PANELS	Gable/Soffit/Fascia	Cement Based	Mixed	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBB	24305011	B Block	B Block	External	Level 3	SOFFITS	DECORVENT AND PLAIN SHEETING TO SOFFITS	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBH	24305004	Brick House	Brick House	Internal	Various levels Internal	STAIRWELL	SHEETING TO WALLS OF STAIRWELL	Wall	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBH	24305004	Brick House	Brick House	Internal	Ground Floor	STAIRWELL	SHEETING TO UNDERNEATH AREA OF STAIRS	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBH	24305004	Brick House	Brick House	External	Ground Floor	SWITCHBOARD	ZELEMIT BACKING TO THE ELECTRICAL BOARD	Insulation/Fill	Polymer Bound	CHR - Chrysotile	3	Removed	25	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBH	24305004	Brick House	Brick House	External	Level 1	EXTERNAL	SHEETING TO SOFFITS	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBH	24305004	Brick House	Brick House	External	Level 1	PATIO	SHEETING TO PATIO CEILING	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBH	24305004	Brick House	Brick House	Internal	Ground Floor	EMERGENCY SHOWER/CHEMICAL STORE	SHEETING TO WALLS OF EMERGENCY SHOWER/CHEMICAL STORE	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBH	24305004	Brick House	Brick House	Internal	Ground Floor	RM1-01	FIBRO SHEETING TO WALL ABOVE AND TO LEFT HAND SIDE OF DOOR BESIDE FIRE EXTINGUISHER	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBH	24305004	Brick House	Brick House	External	Ground Floor	EXTERNAL METER BOX	ZELEMIT BACKING TO FUSE SECTION OF METER BOX	Insulation/Fill	Polymer Bound		4	Presumed	25	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBH	24305004	Brick House	Brick House	Internal	Level 1	BATHROOM	SHEETING TO CEILING OF BATHROOM	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBH	24305004	Brick House	Brick House	Internal	Level 1	BATHROOM	SHEETING TO WALLS OF BATHROOM	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBH	24305004	Brick House	Brick House	Internal	Level 1	TOILET	SHEETING TO CEILING OF TOILET	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBH	24305004	Brick House	Brick House	External	Ground Floor	DT SURROUNDS	DRAIN SURROUNDS TO WASTE AND VENT PIPES AT REAR OF BUILDING	Drains/Pipes/Floors	Cement Based	Mixed	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBH	24305004	Brick House	Brick House	Internal	Various levels Internal	STAIRWELL	SHEETING TO CEILING OF STAIRWELL	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBH	24305004	Brick House	Brick House	Internal	Various levels Internal	STAIRWELL	VINYL TILES TO LANDING BETWEEN FLIGHT OF STAIRS	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBH	24305004	Brick House	Brick House	External	Ground Floor	ENTRY	SHEETING TO ENTRY CEILING OUTSIDE DOOR E1-01	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNBH	24305004	Brick House	Brick House	Internal	Level 1	TOILET	SHEETING TO WALLS OF TOILET	Wall	Cement Based		4	Presumed	18	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNCC	24305010	C Block	C Block	External	Level 4	PLANT ROOM	SEAL TO HB EXT. SEAL BANK NO 4 FROM AC UNIT 1	Heater Bank Insulation	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNCC	24305010	C Block	C Block	External	Level 4	PLANT ROOM	INSULATION TO HB NO 8 EXTERNAL BOX AC UNIT NO 2	Heater Bank Insulation	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 3	FIRE ESCAPE WESTERN	SEALS TO HB IN CEILING SPACE ABOVE WEST FESC OPP	Heater Bank Insulation	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 4	PLANT ROOM	SEAL TO EXTERNAL SECT. HEATER BANK NO 3 FROM AC UNIT 1	Heater Bank Insulation	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 1	ROOM 1.34 BATTERY ROOM	1 X FIRE DOORS TO THE BATTERY ROOM C111	Fire Door	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 4	ROOM C3.18 PLANT ROOM	1 SET OF DOUBLE FIRE DOORS IN PLANT ROOM C3.18 ENTRY	Fire Door	Cement Based	Mixed	2	Removed	34	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 4	PLANT ROOM (THEATRETTE)	HB TO THEATRETTE PLANT ROOM ROOF C3.18 ENTRY TO PL R	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 4	PLANT ROOM (COOLING TOWER AREA)	ONE SET OF FIRE DOORS TO THE COOLING TOWER AREA	Fire Door	Cement Based	Mixed	2	Removed	34	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 4	PLANT ROOM	LINING TO INSIDE HEATER BANK NO 9 OF AC UNIT NO 2	Heater Bank Insulation	Milboard	CHR - Chrysotile	2	Removed	69	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 4	PLANT ROOM	LINING TO INSIDE HEATER BANK NO 4 OF AC UNIT NO 2	Heater Bank Insulation	Milboard	CHR - Chrysotile	2	Removed	69	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 4	PLANT ROOM	LINING TO INSIDE HEATER BANK NO 4 FROM AC UNIT NO 1	Heater Bank Insulation	Milboard	CHR - Chrysotile	2	Removed	69	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 4	PLANT ROOM	LINING TO HEATER BANK NO 5 FROM AC UNIT NO 1	Heater Bank Insulation	Milboard	CHR - Chrysotile	2	Removed	69	-	
The Bremer		BUNDAMBA TAFE CAMPUS	BUNDAMBA TAFE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 4	PLANT ROOM	LINING INSIDE OF HB NO 3 FROM AC UNIT NO 1	Heater Bank Insulation	Milboard	CHR - Chrysotile	2	Removed	69	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEIR Score	Attention Required	Comments
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 3	FIRE ESCAPE SOUTHERN	SEALS TO HB CEILING SPACE ABOVE FIRE EXIT STAIRS OS LIB	Heater Bank Insulation	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 3	PLANT ROOM ENTRY	FIRE DOOR TO THE ENTRY STAIRS IN THE PLANT ROOM	Fire Door	Cement Based	Mixed	2	Removed	34	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNCC	24305010	C Block	C Block	External	Level 4	ROOF	SHEET DEBRIS ON TOP OF THE COOLING TOWER PORTABLE ITEM	Debris	Cement Based	Mixed	2	Confirmed	34	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 3	FIRE ESCAPE WESTERN	LINING TO HB ABOVE FIRE ESCAPE OUTSIDE BOARD ROOM	Heater Bank Insulation	Millboard	CHR - Chrysotile	2	Removed	69	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNCC	24305010	C Block	C Block	External	Level 4	PLANT ROOM	INSULATION TO HB EXTERNAL BOX NO 9 OF AC UNIT 2	Heater Bank Insulation	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 3	FIRE ESCAPE SOUTHERN	LINING TO HB IN DUCTWORK ABOVE STAIRS OS LIBRARY	Heater Bank Insulation	Millboard	CHR - Chrysotile	2	Removed	69	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 2	FOYER	WOVEN MATERIAL PACKING TO H.W. PIPES IN SERVICE DUCT ADJ. TO DOOR C3-02 FEM. TOILET	Insulation/Fill	Woven Textile	CHR - Chrysotile	4	Removed	64	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 2	FOYER	SHEETING TO CEILING AREA OF FOYER	Ceiling	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 1	ROOM C.104 PLANT ROOM	1 X FIRE DOORS TO PLANT ROOM C.104 DOUBLE SET	Fire Door	Cement Based	Mixed	2	Removed	34	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 1	FOYER	WOVEN MATERIAL PACKING TO H.W. PIPES IN SERVICE DUCT ADJ TO DOOR C2-03 IN FOYER	Insulation/Fill	Woven Textile	CHR - Chrysotile	4	Removed	64	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNCC	24305010	C Block	C Block	External	Various levels External	ROOF AWNINGS	STORMWATER SPITTERS ON ROOF AWNINGS ALL CON PADS OMI	Stormwater Plumbing	Cement Based	Mixed	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 4	CEILING SPACE	POSSIBLE MORE HB IN CEILING SPACE UNABLE ACCESS C1.17 RM	Heater Bank Insulation	Millboard	CHR - Chrysotile	3	Removed	64	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNCC	24305010	C Block	C Block	External	Level 2	SOFFIT	SHEETING TO SMALL SOFFIT AREA UNDER FASCIA BOARD	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNCC	24305010	C Block	C Block	External	Level 2	FASCIA	COMPRESSED SHEETING TO FASCIA BOARD ON MAIN BUILDING AND COVERED LINK TO BLOCKS B & D	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNCC	24305010	C Block	C Block	External	Level 2	EASTERN STAIRCASE	SHEETING TO CEILING OF STAIRCASE ON EAST ELEVATION OF BUILDING FACING BLOCK B	Ceiling	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNCC	24305010	C Block	C Block	External	Level 4	PLANT ROOM	INSULATION TO EXTERNAL SECTIONS OF HEATER BANKS	Heater Bank Insulation	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNCC	24305010	C Block	C Block	Internal	Level 1	STORE - ROOM C1-26	REMOVED - FIRE DOOR	Fire Door	Cement Based	CHR AMO - Chrysotile Amosite	3	Removed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNCH	24305012	Childcare	Childcare	External	Ground Floor	CHILD CARE CENTRE	BUILDING CONSTRUCTED POST - 1990 THEREFORE ASSUMED TO BE ASBESTOS FREE CONSTRUCTION	Baffles/Lining	Other (refer to description)	CHR - Chrysotile	3	Not Present(Not Tested)	-	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBND	24306009	D Block	D Block	Internal	Level 2	FIRE ESCAPE STAIRWELL	FIRE DOOR AT TOP OF FIRE ESCAPE STAIRWELL ON SOUTH-WEST ELEV. OF BLDG (IDENTIFIED NAD 20405 PROGRA	Fire Door	Other (refer to description)	CHR - Chrysotile	4	Not Present(Not Tested)	-	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBND	24306009	D Block	D Block	Internal	Level 1	FIRE ESCAPE STAIRWELL	PACKING IN FIRE DOOR ON SOUTH-WEST ELEVATION OF BLDG	Fire Door	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)	-	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBND	24306009	D Block	D Block	Internal	Various levels Internal	FIRE ESCAPE STAIRWELL	PACKING IN FIRE DOORS AT ENTRANCE TO FIRE ESCAPE STAIRWELL ON NW ELEV OF BLDG (IDENTIFIED NAD 2004/	Fire Door	Other (refer to description)	CHR - Chrysotile	4	Not Present(Not Tested)	-	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBND	24306009	D Block	D Block	External	Ground Floor	FASCIA	COMPRESSED SHEETING TO FASCIA BOARD	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBND	24306009	D Block	D Block	Internal	Ground Floor	ROOM D1-06 PLANT	LINING TO HEATER BANKS IN AIR-CONDITIONING DUCTS	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNHC	24305029	Hort - Classrooms	Hort - Classrooms	Internal	Ground Floor	ROOMS H1-01 & 02 HORTICULTURE ROOMS	SHEETING TO CEILINGS OF HORTICULTURE ROOMS H1-01 AND H1-02	Ceiling	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNHC	24305029	Hort - Classrooms	Hort - Classrooms	External	Ground Floor	SOUTHERN SIDE	1 X POTTING WORKBENCH SOUTHERN SIDE OF CLASSROOM BLOCK	Furniture	Cement Based	CHR - Chrysotile	3	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNHD	24305034	Hort - Demountable	Hort - Demountable	Internal	Ground Floor	HORT. MODULAR	BUILT POST 1990	Baffles/Lining	Other (refer to description)	CHR - Chrysotile	3	Presumed	-	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNWH	24306005	White House (Timber House)	White House (Timber House)	External	Ground Floor	ENCL. VERANDAH	SHEETING TO CEILING OF ENCLOSED VERANDAH	Ceiling	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNWH	24306005	White House (Timber House)	White House (Timber House)	External	Ground Floor	ENCL. VERANDAH	SHEETING TO WALL OF ENCLOSED VERANDAH	Wall	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNWH	24306005	White House (Timber House)	White House (Timber House)	External	Ground Floor	EXTERNAL	DRAIN SURROUND TO WASTE PIPE OUTSIDE KITCHEN	Drains/Pipes/Floors	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNWH	24306005	White House (Timber House)	White House (Timber House)	External	Ground Floor	EXTERNAL	SHEETING TO WALL ADJACENT TO FRONT DOOR	Wall	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNWH	24306005	White House (Timber House)	White House (Timber House)	Internal	Ground Floor	ENCL. VERANDAH	VINYL SHEETING TO FLOOR IN ENCLOSED VERANDAH	Floor Finish/Covering	Vinyl Sheeting (includes backing)	CHR - Chrysotile	4	Confirmed	62	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNWH	24306005	White House (Timber House)	White House (Timber House)	External	Ground Floor	EXTERNAL	SHEETING TO SOFFITS	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNWH	24306005	White House (Timber House)	White House (Timber House)	Internal	Ground Floor	GARAGE	SHEETING TO CEILING OF GARAGE	Ceiling	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNWH	24306005	White House (Timber House)	White House (Timber House)	Internal	Ground Floor	GARAGE	SHEETING TO WALL ABOVE TILT-A-DOOR IN GARAGE	Wall	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNWH	24306005	White House (Timber House)	White House (Timber House)	Internal	Ground Floor	INTERNAL	VINYL SHEETING UNDER CARPET IN OFFICE STOREROOM & SMALL PASSAGE BETWEEN THEM	Floor Backing/Underlay	Vinyl Sheeting (includes backing)	CHR - Chrysotile	4	Confirmed	62	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNWH	24306005	White House (Timber House)	White House (Timber House)	Internal	Ground Floor	KITCHEN	SHEETING TO CEILING OF KITCHEN	Ceiling	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNWH	24306005	White House (Timber House)	White House (Timber House)	Internal	Ground Floor	KITCHEN	SHEETING TO WALLS OF KITCHEN	Wall	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNWH	24306005	White House (Timber House)	White House (Timber House)	Internal	Ground Floor	KITCHEN	VINYL SHEETING TO THE FLOOR OF THE LARGE KITCHEN	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNWH	24306005	White House (Timber House)	White House (Timber House)	Internal	Ground Floor	OFFICE	SHEETING TO WALLS BEHIND WALLPAPER IN OFFICE	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNWH	24306005	White House (Timber House)	White House (Timber House)	Internal	Ground Floor	STAT. STORE RM	SHEETING TO WALLS BEHIND WALLPAPER & ON ALCOVE WALLS IN STATIONARY STORE ROOM	Wall	Cement Based	Mixed	4	Confirmed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNWH	24306005	White House (Timber House)	White House (Timber House)	Internal	Ground Floor	TOILET	SHEETING TO CEILING OF TOILET	Ceiling	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNWH	24306005	White House (Timber House)	White House (Timber House)	Internal	Ground Floor	TOILET	SHEETING TO WALLS OF TOILET	Wall	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNWH	24306005	White House (Timber House)	White House (Timber House)	Internal	Ground Floor	CLASSROOMS/OFFICES	SHEETING TO CEILINGS OF CLASSROOMS AND OFFICES	Ceiling	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		BUNDAMBA TAPE CAMPUS	BUNDAMBA TAPE CAMPUS	MBNWH	24306005	White House (Timber House)	White House (Timber House)	External	Various levels External	AJD TO LANDING	VENT PIPE ON REAR WALL ADJACENT TO LANDING	Drains/Pipes/Floors	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		INALA TAPE CAMPUS - TBI	INALA TAPE CAMPUS - TBI	MIN	43925000	-- Site - Grounds	-- Site - Grounds	Internal	Ground Floor	STORE	CEILING	Ceiling	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		INALA TAPE CAMPUS - TBI	INALA TAPE CAMPUS - TBI	MINAA	43929001	A Block	A Block	Internal	Ground Floor	STORE	CEILING	Ceiling	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		IPSWICH TAPE CAMPUS	IPSWICH TAPE CAMPUS	24306004	24306004	AUTOMOTIVE STORE	AUTOMOTIVE STORE	Internal	Ground Floor	STORE	CEILING	Ceiling	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		IPSWICH TAPE CAMPUS	IPSWICH TAPE CAMPUS	24306004	24306004	STAFF STORAGE	STAFF STORAGE	Internal	Ground Floor	STAFFROOM SW	CEILING IN STAFFROOM	Ceiling	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		IPSWICH TAPE CAMPUS	IPSWICH TAPE CAMPUS	24306004	24306004	STAFF STORAGE	STAFF STORAGE	Internal	Ground Floor	ROOM SW	WALLS IN STORE GABLE END	Wall	Cement Based	CHR - Chrysotile	4	Presumed	18	-	
The Bremer		IPSWICH TAPE CAMPUS	IPSWICH TAPE CAMPUS	24306004	24306004	STAFF STORAGE	STAFF STORAGE	Internal	Ground Floor	ROOM SW	WALLS IN STAFFROOM	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
The Bremer		IPSWICH TAPE CAMPUS	IPSWICH TAPE CAMPUS	24306004	24306004	STAFF STORAGE	STAFF STORAGE	External	Roof Level 1	ROOM SW ROOF	ROOF (REPLACED WITH NEW)	Roof Sheeting	Cement Based	CHR - Chrysotile	2	Removed	34	-	

TAFes from BEIR-TAFes

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	24306005	24306005	ADMINISTRATION	G - C.A.T. BLK A	Internal	Ground Floor	ENTRY	CEILING OF MAIN ENTRY	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	24306005	24306005	ADMINISTRATION	G - C.A.T. BLK A	Internal	Ground Floor	ENTRY	CEILING OF MAIN ENTRY	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	24306005	24306005	ADMINISTRATION	G - C.A.T. BLK A	External	Roof Level 1	ROOF	BLOCK E END UNPAINTED	Roof Sheeting	Cement Based		3	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	24306005	24306005	ADMINISTRATION	G - C.A.T. BLK A	Internal	Ground Floor	OFFICE	2 PANELS IN DIVING WALL	Wall	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	24306005	24306005	ADMINISTRATION	G - C.A.T. BLK A	Internal	Ground Floor	OFFICE	CEILING IN OFFICE	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	24306005	24306005	ADMINISTRATION	G - C.A.T. BLK A	Internal	Ground Floor	OFFICE	CEILING IN PHOTOCOPY ROOM	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	24306005	24306005	ADMINISTRATION	G - C.A.T. BLK A	Internal	Ground Floor	ROOM 2E OFFICE	CEILING IN OFFICE - ROOM 2E	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	24306005	24306005	ADMINISTRATION	G - C.A.T. BLK A	Internal	Ground Floor	ROOM 2W STAFF ROOM	CEILING IN STAFFROOM	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	24306005	24306005	ADMINISTRATION	G - C.A.T. BLK A	Internal	Ground Floor	ROOM 4E CLASSROOM	CEILING IN CLASSROOM 4E	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	24306005	24306005	ADMINISTRATION	G - C.A.T. BLK A	Internal	Ground Floor	ROOM 4M CONFERENCE	CEILING IN CONFERENCE ROOM	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	24306005	24306005	ADMINISTRATION	G - C.A.T. BLK A	Internal	Ground Floor	ROOM 4W CLASSROOM	CEILING IN CLASSROOM 4W	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	24306005	24306005	ADMINISTRATION	G - C.A.T. BLK A	Internal	Ground Floor	ENTRY	CEILING IN ENTRANCE	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIP	24306000	Site - Grounds	Site - Grounds												
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIP01	24306012	Toilets - Female (H Block)	Toilets - Female (H Block)	External	Ground Floor	EXTERNAL	SOFFIT	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIP01	24306012	Toilets - Female (H Block)	Toilets - Female (H Block)	Internal	Ground Floor	FEMALE TOILET	CEILING IN FEMALE TOILET	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIP01	24306012	Toilets - Female (H Block)	Toilets - Female (H Block)	External	Ground Floor	EXTERNAL	EXTERNAL CEILING PANELS TO THE ENTRANCE	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIP01	24306012	Toilets - Female (H Block)	Toilets - Female (H Block)	Internal	Ground Floor	FEMALE TOILET	CUBICLE PARTITIONS COMPRESSED	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIP02	24306013	Toilets - Male (I Block)	Toilets - Male (I Block)	External	Ground Floor	EXTERNAL	EXTERNAL CEILING PANEL TO THE ENTRANCE	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIP02	24306013	Toilets - Male (I Block)	Toilets - Male (I Block)	External	Ground Floor	EXTERNAL	SOFFIT	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIP02	24306013	Toilets - Male (I Block)	Toilets - Male (I Block)	Internal	Ground Floor	MALE TOILET	CEILING IN MALE TOILET	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIP02	24306013	Toilets - Male (I Block)	Toilets - Male (I Block)	Internal	Ground Floor	MALE TOILET	CUBICLE PARTITIONS AS FOR FEMALE TOILET COMPRESSED	Wall	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIP02	24306013	Toilets - Male (I Block)	Toilets - Male (I Block)	Internal	Ground Floor	MALE TOILET	WALL	Wall	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIP02	24306013	Toilets - Male (I Block)	Toilets - Male (I Block)	Internal	Ground Floor	MALE TOILET	PRIVACY SCREEN COMPRESSED	Wall	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIP03	24306019	Toilets - Disabled (G Block)	Toilets - Disabled (G Block)	External	Ground Floor	SOFFIT	SOFFIT TO THE DISABLED TOILET BLOCK	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIP04	24306001	Toilets - Male / Female (TOILET BLOCK)	TOILET BLOCK	Internal	Ground Floor	TOILETS	CEILING IN SKETCH 01	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIP05		Store - Facilities (F Block)	Store - Facilities (F Block)												
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPAA	24306018	A Block	A Block	Internal	Level 1	STAIRS	MAIN STAIRS 01 - 02 FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPAA	24306018	A Block	A Block	Internal	Level 1	REAR ENTRY	FLOOR TO THE REAR ENTRY	Floor Finish/Covering	Vinyl Sheeting (includes backing)	CHR - Chrysotile	4	Confirmed	62	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPAA	24306018	A Block	A Block	Internal	Level 2	ROOM A204 WASH ROOM	FLOOR TO THE WASH ROOM	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPAA	24306018	A Block	A Block	Internal	Level 1	ROOM A206	STAFFROOM AND ENTRY VINYL TILES	Floor Finish/Covering	Vinyl Tiles		3	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPAA	24306018	A Block	A Block	Internal	Ground Floor	ROOM A103 STORE	CEILING IN STORAGE AREA	Ceiling	Cement Based		3	Presumed	16	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPAA	24306018	A Block	A Block	Internal	Ground Floor	ROOM A105 STORE	LARGE FIXED KILN (NOT IN USE)	Plant, Equipment & Machinery	Woven Textile	CHR - Chrysotile	3	Confirmed	64	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPAA	24306018	A Block	A Block	Internal	Ground Floor	ROOM A105 KILN ROOM	1 PAIR OF TEXTILE GLOVES	Stored Material	Woven Textile	CHR - Chrysotile	2	Removed	69	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPAA	24306018	A Block	A Block	Internal	Ground Floor	ROOM A103 STORE (KILN)	SMALL KILN (NOT IN USE)	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPAA	24306018	A Block	A Block	Internal	Ground Floor	ROOM A102 QUIET ROOM	QUIET ROOM SIMILAR LEVEL 02 SHEET VINYL	Floor Finish/Covering	Vinyl Sheeting (includes backing)	CHR - Chrysotile	3	Removed	62	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPAA	24306018	A Block	A Block	Internal	Level 2	ROOM A305	SHEETING THROUGHOUT LEVEL 02 SHEET VINYL UNDERLAY	Floor Backing/Underlay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPAA	24306018	A Block	A Block	Internal	Ground Floor	ROOM A105 STORE	LARGE KILN FIRE BRICK	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPBB	24306017	B Block	B Block	Internal	Level 2	ROOM B305 CLASSROOM & STOREROOM	CEILING IN CLASS AND STOREROOM	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPBB	24306017	B Block	B Block	Internal	Level 2	ROOM B304 STOREROOM	CEILING IN STOREROOM	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPBB	24306017	B Block	B Block	Internal	Level 2	ROOM B303	CEILING	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPBB	24306017	B Block	B Block	Internal	Level 2	ROOM B301 OFFICE	CEILING IN OFFICE	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPBB	24306017	B Block	B Block	Internal	Level 1	STORE	STOREROOM ADJACENT D204 HALF PAINTED	Wall	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPBB	24306017	B Block	B Block	Internal	Level 1	ROOM B205 CLASSROOM	CEILING IN CLASSROOM	Ceiling	Cement Based		4	Presumed	16	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPBB	24306017	B Block	B Block	Internal	Level 1	ROOM B204 CLASSROOM	CEILING IN CLASSROOM	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPBB	24306017	B Block	B Block	External	Roof Level 1	ROOF	ROOF OVER STOREROOM ADJACENT D204	Roof Sheeting	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPBB	24306017	B Block	B Block	Internal	Level 2	ROOM B302 CLASSROOM	CEILING IN CLASSROOM	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPBB	24306017	B Block	B Block	Internal	Level 1	ROOM B202 OFFICES	CEILING IN OFFICES	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPBB	24306017	B Block	B Block	Internal	Level 2	STORES	CEILING IN 2 STOREROOMS	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPBB	24306017	B Block	B Block	Internal	Ground Floor	ROOM B101 CLASSROOM	CEILING IN CLASSROOM	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPBB	24306017	B Block	B Block	Internal	Ground Floor	ROOM B102 LIBRARY	CEILING IN LIBRARY	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPBB	24306017	B Block	B Block	Internal	Ground Floor	ROOM B103 CLASSROOM	CEILING IN CLASSROOM	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPBB	24306017	B Block	B Block	Internal	Level 1	ENTRY	CEILING IN FOYER ADJ B204	Ceiling	Cement Based		4	Presumed	18	-	

TAFes from BEMIR-TAFes

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPBB	24306017	B Block	B Block	Internal	Level 1	ROOM 201 COUNCILLOR	CEILING IN PHOTOCOPY ROOM	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPBB	24306017	B Block	B Block	Internal	Level 1	ROOM B102 LIBRARY	LIBRARY SHEET VINYL	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPCC	24306016	C Block	C Block	Internal	Ground Floor	POTTERY ROOM	CEILING IN POTTERY ROOM	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPCC	24306016	C Block	C Block	Internal	Level 2	ROOM C303	SCREEN WALL	Wall	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPCC	24306016	C Block	C Block	Internal	Level 2	ROOM C304	FLOOR TILES C304 AND C306	Floor Finish/Covering	Vinyl Tiles	CHR - Chrysotile	3	Confirmed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPCC	24306016	C Block	C Block	External	Ground Floor	STEPS	AC LINING TO CONCRETE BLOCK STEPS	Floor	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPDD	24306015	D Block	D Block	Internal	Level 2	STORE	AC WALL SHEETING TO STORE ROOM ADJACENT TO ROOM D 201	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPDD	24306015	D Block	D Block	Internal	Ground Floor	ROOM D101 CANTEN	FLOOR TO THE CANTEN SERVRY	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPDD	24306015	D Block	D Block	Internal	Ground Floor	ROOM D101 CANTEN	WALL OVER CANTEN SIDE ENTRY	Wall	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPDD	24306015	D Block	D Block	Internal	Ground Floor	ROOM D102 CANTEN KITCHEN	FLOOR TO THE CANTEN KITCHEN	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPDD	24306015	D Block	D Block	Internal	Level 1	ROOM D204 (KILN)	1 X 'SELAS' GAS & ENGINEERING BRAND KILN. MATERIAL AROUND DOOR SEAL	Plant, Equipment & Machinery	Millboard	Mixed	2	Removed	69	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPDD	24306015	D Block	D Block	Internal	Level 1	ROOM D204 (KILN)	SELAS KILN. (Same kiln as other entry). LINING AROUND THE INTERIA OF KILN	Plant, Equipment & Machinery	Millboard	CHR - Chrysotile	2	Removed	69	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPDD	24306015	D Block	D Block	Internal	Level 2	ROOM D204	FLOOR TO ROOM D204	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPDD	24306015	D Block	D Block	Internal	Level 2	FLOOR	SHEET VINYL FLOOR TO ROOM D201	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPEE	24306008	BLOCK E	BLOCK E	Internal	Ground Floor	39417	WELDING BENCHES AND ENCLOSURE BAYS	Furniture	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPEE	24306008	BLOCK E	BLOCK E	External	Ground Floor	ROOM 3E	TOTAL EXTERIOR WALLS SHEETMETAL/WELDING UNPAINTED	Wall	Cement Based		3	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPEE	24306008	BLOCK E	BLOCK E	Internal	Ground Floor	13-14	WELDING BENCHES AND ENCLOSURE BAYS COMPRESSED	Furniture	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPEE	24306008	BLOCK E	BLOCK E	External	Ground Floor	ROOF	SHEET METAL/WELDING	Roof Sheeting	Cement Based		3	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPLL	24306009	L Block	AUTO SCHOOL BLK L	Internal	Ground Floor	CORRIDOR	CEILINGS IN CORRIDOR AND AMENITIES	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPLL	24306009	L Block	AUTO SCHOOL BLK L	Internal	Ground Floor	ROOM	CAR ELECTRICS AREA VINYL FLOOR TILES THROUGHOUT GROUND FLOOR & 01	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	3	Not Present(Not Tested)	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPLL	24306009	L Block	AUTO SCHOOL BLK L	External	Level 1	SOFFIT	SOFFIT AND FASCIA COMPRESSED	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPMM	24306007	BLOCK M	BLOCK M	External	Ground Floor	ROOF	MACHINE SHOP UNPAINTED	Roof Sheeting	Cement Based		3	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPMM	24306007	BLOCK M	BLOCK M	External	Ground Floor	ROOM 6 MACHINE SHOP	TOTAL EXTERIOR WALLS MACHINE SHOP UNPAINTED	Wall	Cement Based		3	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPMM	24306007	BLOCK M	BLOCK M	External	Ground Floor	VERANDAH	BETWEEN M & E COVERED WALKWAY UNPAINTED	Roof Sheeting	Cement Based		3	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPMM	24306007	BLOCK M	BLOCK M	External	Ground Floor	VERANDAH	BETWEEN M & W COVERED WALKWAY	Roof Sheeting	Cement Based		3	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPPP	24306002	BLOCK P	BLOCK P	Internal	Roof Level 1	ROOM 1	WALL	Wall	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPPP	24306002	BLOCK P	BLOCK P	Internal	Roof Level 1	ROOM 4	WALL	Wall	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPPP	24306002	BLOCK P	BLOCK P	Internal	Roof Level 1	ROOM 3	WALLS	Wall	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPPP	24306002	BLOCK P	BLOCK P	Internal	Roof Level 1	ROOM 2, 3 & 4	ROOMS 2 3 AND 4 FLOOR TILES	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	3	Not Present(Not Tested)	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPPP	24306002	BLOCK P	BLOCK P	Internal	Roof Level 1	ROOM 2	CEILING	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPPP	24306002	BLOCK P	BLOCK P	Internal	Roof Level 1	OFFICE	CEILING	Ceiling	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPPP	24306002	BLOCK P	BLOCK P	Internal	Roof Level 1	COMMON ROOM	COMMON ROOM WALL	Wall	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPPP	24306002	BLOCK P	BLOCK P	Internal	Ground Floor	STORE	SMALL ENGINES STORE	Wall	Cement Based		3	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPPP	24306002	BLOCK P	BLOCK P	Internal	Ground Floor	STORE	2 SHEETS BROKEN	Wall	Cement Based		2	Removed	34	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPPP	24306002	BLOCK P	BLOCK P	External	Roof Level 1	EXTERNAL WALLS	TOTAL EXTERIOR WALLS GROUND AND 1ST FLOORS	Wall	Cement Based		3	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPPP	24306002	BLOCK P	BLOCK P	Internal	Roof Level 1	OFFICE	WALL	Wall	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPPP	24306002	BLOCK P	BLOCK P	Internal	Roof Level 1	ROOM 2	WALL	Wall	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPSS		S Block	S Block												
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPWW	24306006	BLOCK W	BLOCK W	External	Ground Floor	EXTERNAL NORTH	EXTERIOR WALL SHEETING UNPAINTED	Wall	Cement Based		3	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPWW	24306006	BLOCK W	BLOCK W	External	Ground Floor	SOUTH	FIBREGLOSS/WOODWORK 3 PANELS UNPAINTED	Wall	Cement Based		4	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPWW	24306006	BLOCK W	BLOCK W	External	Ground Floor	ROOF	ROOF UNPAINTED	Roof Sheeting	Cement Based		3	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPWW	24306006	BLOCK W	BLOCK W	External	Ground Floor	NORTH	BUILT APPROX 1946 FIBREGLASS/ WOODWORK	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPWW	24306006	BLOCK W	BLOCK W	External	Ground Floor	EXTERNAL WEST	EXTERIOR WALL SHEETING UNPAINTED	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPWW	24306006	BLOCK W	BLOCK W	External	Ground Floor	EXTERNAL WEST	EXTERIOR WALL SHEETING UNPAINTED	Wall	Cement Based		3	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPWW	24306006	BLOCK W	BLOCK W	External	Ground Floor	EXTERNAL SOUTH	EXTERIOR WALL SHEETING UNPAINTED	Wall	Cement Based		3	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPWW	24306006	BLOCK W	BLOCK W	External	Ground Floor	EXTERNAL EAST	GABLE END UNPAINTED	Wall	Cement Based		3	Presumed	18	-	
The Bremer		IPSWICH TAFE CAMPUS	IPSWICH TAFE CAMPUS	MIPWW	24306006	BLOCK W	BLOCK W	External	Ground Floor	EXTERNAL WEST	EXTERIOR WALL SHEETING UNPAINTED	Wall	Cement Based		3	Presumed	18	-	
Tropical North Queensland		BAMAGA TAFE CAMPUS (WIC-31486)	BAMAGA TAFE CAMPUS (WIC-31486)	XBA	31486000	** Site - Grounds	** Site - Grounds												
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA	25954000	XCA00 - SITE GROUNDS - CAIRNS TAFE CAMPUS	SITE	Internal	Site / Grounds	NORTHEAST BLOCK J	NORTH EAST CORNER J BLOCK TELECOM PIT LOCATED SAMPLE 74	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA01		XCA01 - SERVICES/STORE	Services/ Store												
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA02		XCA02 - SUBSTATION	Substation												

TAFEs from BEMIR-TAFEs

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA04		XCA04 - SHED	Shed											-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA07		XCA07 - OPEN CARPORT	Open Carport											-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA09		XCA09 - CHEMICAL STORAGE	Chemical Storage											-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA10		XCA10 - SMALL/MEDIUM SHED	Small/Med Shed											-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA13		XCA13 - HORTICULTURAL SHED	Hort Shed											-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA14		XCA14 - HORTICULTURAL SHED	Hort Shed											-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA15		XCA15 - HORTICULTURAL SHED	Hort Shed											-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA16		XCA16 - HORTICULTURAL SHED	Hort Shed											-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA17		XCA17 - HORTICULTURAL SHED	Hort Shed											-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA18	25954038	XCA18 - JENNY LIND BOAT	JENNY LIND - BOAT	Internal	Ground Floor	TOILET	SHOWER TOILET FLOOR VINYL FLOOR TILES REFER SAMPLE 98	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA18	25954039	XCA18 - JENNY LIND BOAT	JENNY LIND - BOAT	External	Ground Floor	ENGINE	T.A.F.E. 16.76M BOAT EXHAUST LAGGING SAMPLE 97	Pipe Installation	Lagging	CHR - Chrysotile	3	Confirmed	64	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA18	25954039	XCA18 - JENNY LIND BOAT	JENNY LIND - BOAT	Internal	Ground Floor	ENGINE CEILING SPACE	ENGINE ROOM INSULATION IN ROOF SAMPLE 99	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA18	25954039	XCA18 - JENNY LIND BOAT	JENNY LIND - BOAT	Internal	Ground Floor	GALLEY	GALLEY BEIGE VINYL FLOOR TILES SAMPLE 98	Floor Finish/Covering	Vinyl Tiles		4	Not Present(Not Tested)	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA18	25954039	XCA18 - JENNY LIND BOAT	JENNY LIND - BOAT	Internal	Ground Floor	ENGINE SWITCHBOARD	SWITCHBOARD MOUNTING PLATE BLACK HARDBOARD SAMPLE 100 (CELEMIT)	Insulation/Fill	Polymer Bound	CHR - Chrysotile	4	Confirmed	25	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA19	25954025	XCA19 - WALKWAYS	WALKWAYS	External	Ground Floor	WALKWAY	COVERED WALKWAY A TO I I TO F F TO C	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA19	25954025	XCA19 - WALKWAYS	WALKWAYS	External	Ground Floor	WALKWAY	COVERED WALKWAY D TO G BARGE & SOFFIT LININGS	Gable/Soffit/Fascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCA19	25954025	XCA19 - WALKWAYS	WALKWAYS	Internal	Ground Floor	WALKWAY	WALKWAY D TO G INTERNAL SHEET LINING SAMPLE 95	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	ROOM A110 PRNT ROOM	PRINT ROOM DIVIDER WALL SAMPLE 69	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	PASSAGE	FIBRE CEMENT PARTITION WALL ADJACENT TO ROOM A1 125	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	PASSAGE	FIBRE CEMENT NOTICE BOARD OPPOSITE THE OFFICE A1.25	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	PASSAGE	AC INFILL PANELS ABOVE THE WINDOWS	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	OFFICE	HUMAN RESOURCE MANAGEMENT OFFICE REFER SAMPLE 66	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Level 1	ROOM A214	GREY VINYL FLOOR TILES REFER SAMPLE 65	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	ROOM 110 AGE	VINYL FLOOR SHEET SIM SAMPLE 70	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Level 1	ROOM A207 SECURITY	UNDER CARPET IN SECURITY/OF ROOM VINYL FLOOR TILES REFER SAMPLE 66	Floor Backing/Underlay	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	ROOM A115	GREY VINYL FLOOR TILES REFER SAMPLE 66	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	ROOM A119	DIVIDER WALL SHEET	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	ROOM A119	OFFICE VINYL TILES REFER SAMPLE 66	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	ROOM A125	BETWEEN A125 & SMALL OFFICE DIVIDER WALL SAMPLE 68	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	PASSAGE	TOILET ACCESS PASSAGE CEILING SHEETS SIM SAMPLE 67	Ceiling	Cement Based		4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	STORE	PRINT ROOM STORE GREY VINYL FLOOR TILES REFER SAMPLE 66	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Level 1	ROOM A105 STAFF ROOM	STAFF ROOM VINYL FLOOR TILES REFER SAMPLE 66	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	PASSAGE	PASSAGE VINYL FLOOR SHEET SAMPLE TO 3-2	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Level 1	ROOM A206 STORE ROOM	STORE ROOM VINYL FLOOR TILES REFER SAMPLE 66	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	ROOM A114	GREY VINYL FLOOR TILES REFER SAMPLE 66	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Level 1	ROOM A211	GREY VINYL FLOOR TILES REFER SAMPLE 66	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Level 1	ROOM A212	GREY VINYL FLOOR TILES SAMPLE 66	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Level 1	ROOM A213	GREY VINYL FLOOR TILES REFER SAMPLE 66	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	PASSAGE	PASSAGE BEIGE VINYL FLOOR SHEET	Floor Finish/Covering	Vinyl Sheeting (includes backing)	CHR - Chrysotile	4	Confirmed	62	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	External	Roof Level 1	FASCIA	AROUND CENTRAL GARDEN SHEET TO FACE OF FASCIA SIM SAMPLE 67	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	FOYER	FOYER CEILING SHEET SIM SAMPLE 67	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	ROOM A1 23	GREY VINYL FLOOR TILES	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	ROOM A103 TOILET	TOILET COMPRESSED SHEET PARTITIONS SIM SAMPLE 33	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Level 1	ROOM A205	OFFICE AREA CEILING SHEET SIM SAMPLE 67	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	DARK ROOM	DARK ROOM OF PRINT ROOM GREY VINYL FLOOR TILES REFER SAMPLE 66	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	External	Roof Level 1	FASCIA	AROUND ENTIRE BUILDING COMPRESSED AC SHEET FASCIA PAN SIM SAMPLE 33	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	External	Roof Level 1	EAVES	AROUND BUILDING EAVES SOFFIT LINING SIM SAMPLE 67	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	External	Level 1	VERANDAH	ALL VERANDAH AREA AC CEILING SHEET SAMPLE 67	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	External	Various levels External	VENT	EAST END OF BLOCK A TWO VENT PIPES FROM TOILETS SIM SAMPLE 45	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAAA	25954011	XCAAA - BLOCK A	A Block	Internal	Ground Floor	DARK ROOM	DARK ROOM SHEET WALL SIM SAMPLE 69	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B127	FIRE BLANKET NO 16	Plant, Equipment & Machinery	Other (refer to description)		4	Presumed		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOMS B101 & B102	ROOM B101 & B102 VINYL FLOOR TILES BEIGE SAMPLE 30	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B128	WEBBING/LAGGING AROUND PIPE ON MOTORENGINE STAND SIMILAR TO SAMPLE 19107	Pipe Insulation	Woven Textile		2	Removed	69	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B128	WEBBING/LAGGING AROUND PIPE FROM INTAKE - EXHAUST MANIFOLD ON MTR/STAND 12	Pipe Insulation	Woven Textile	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B128	INSULATION TO EXHAUST PIPE OF LRG STATIONARY MOTOR NTH END OF ROOM	Pipe Insulation	Other (refer to description)		3	Presumed		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B128	DISC BRAKE PADS END OF MOTOR T/A0030 SIMILAR TO SAMPLE 19114	Plant, Equipment & Machinery	Polymer Bound		3	Presumed	25	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B128	CLUTCH PLATES CONNECTED TO MOTORS ON ENGINE STANDS 12,11,9 & 6 SIMILAR TO SAMPLE 19114	Plant, Equipment & Machinery	Polymer Bound		4	Presumed	25	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B128	BRAKE SHOES CONNECTED TO MOBILE STAND	Plant, Equipment & Machinery	Other (refer to description)		4	Presumed		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B127	ROLL OF GASKET MATERIAL 1C10 & 1C21	Gasket	Polymer Bound		4	Presumed	25	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B127	GASKET ON SHELF D OF BAY 5	Gasket	Polymer Bound		4	Presumed	25	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	SHED	OPEN STORE SHED INSULATION AROUND EXHAUST PIPE SAMPLE 31	Pipe Insulation	Woven Textile	CHR - Chrysotile	3	Confirmed	64	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B127	GASKET ON BOTTOM SHELF OF BAY T	Gasket	Polymer Bound		4	Presumed	25	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Level 1	ROOM B202	ROOM B202 VINYL FLOOR TILES REFER SAMPLE 30	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B127	CLUTCH PLATES IN BOX 1ST SHELF MIDDLE OF ROOM SML CLUTCH PLATE	Plant, Equipment & Machinery	Polymer Bound		3	Presumed	25	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B127	CLUTCH PLATES IN BOX 1ST SHELF MIDDLE OF ROOM LGE CLUTCH PLATE	Plant, Equipment & Machinery	Other (refer to description)		3	Presumed		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B127	BRAKE SHOES BOTTOM SHELF - SML BRAKE SHOE	Plant, Equipment & Machinery	Polymer Bound		4	Presumed	25	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B127	BRAKE SHOES BOTTOM SHELF - LGE BRAKE SHOE	Plant, Equipment & Machinery	Polymer Bound		4	Presumed	25	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B127	GASKET ON SHELF D OF BAY 5	Gasket	Polymer Bound		4	Presumed	25	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Level 1	ROOM B203 TEST ROOM	SECTION TEST ROOM- WEST WALL BELOW WINDOWS - COMPRESSES AC SHEET - SIM SAMPLE 33	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Level 1	ROOM B208 STORE ROOM	STORE ROOM WALL SHEET SIM SAMPLE 35	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Level 1	ROOM B208 STORE ROOM	STORE ROOM VINYL FLOOR TILES REFER SAMPLE 30	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Level 1	ROOM B205 GEARBOX ROOM	GEARBOX ROOM VINYL FLOOR TILES REFER SAMPLE 30	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Level 1	ROOM B205 GEARBOX ROOM	GEARBOX ROOM- NTH STNTH & EA WALL SHEET SIM SAMPLE 35	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Level 1	ROOM B205 GEARBOX ROOM	GEARBOX ROOM - UNDER WINDOWS COMPRESSED AC SHEET SIM SAMPLE 33	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Level 1	ROOM B204	UNDER WINDOWS COMPRESSED AC SHEET SIM SAMPLE 33	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	WORKSHOP	BRAKE LINING AND CLUTCH PLATES IN VARIOUS STAGES OF DISREPAIR	Plant, Equipment & Machinery	Polymer Bound		3	Presumed	25	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Level 1	ROOM B204	NORTH SOUTH & EAST WALL SHEETING SIM SAMPLE 35	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	SHED	OPEN STORE SHED INSULATION AROUND EXHAUST PIPE SAMPLE 32	Pipe Insulation	Woven Textile	CHR - Chrysotile	2	Confirmed	69	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Level 1	ROOM B203 TEST ROOM	SECTION TEST ROOM- WEST WALL AC SHEET SAMPLE 35	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Level 1	ROOM B203 TEST ROOM	SECTION TEST ROOM VINYL FLOOR TILES REFER SAMPLE 30	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Level 1	ROOM B203 TEST ROOM	SECTION TEST ROOM- NORTH WALL SIM SAMPLE 35	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Level 1	ROOM B203 TEST ROOM	SECTION TEST ROOM- EAST WALL SHEET SIM SAMPLE 35	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B127	GASKET IN CARDBOARD BOX ON SHELF D BAY 15	Gasket	Polymer Bound		4	Presumed	25	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Level 1	FOYER	FOYER - WALL SHEETING ON OFFICE SIDE SIM SAMPLE 35	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B126	GAS HEATING UNITS FOR SOLDERING IRONS - TWO UNITS. Re Inspected July 2001 found removed	Plant, Equipment & Machinery	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Level 1	ROOM B204	OFFICE AREA VINYL FLOOR TILES REFER SAMPLE 30	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B106	HIGH TENSION LEAD PLIERS SIMILAR TO SAMPLE 19104	Plant, Equipment & Machinery	Polymer Bound		4	Presumed	25	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B124	EA WALL- WASH BAY GLANDPACKING AC VENT PIPE	Drains/Pipes/Floors	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B127	GASKET ON SHELF C BAY 5	Gasket	Polymer Bound		4	Presumed	25	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	External	Level 1	ROOM B201 PLANT	PLANT ROOM EXTERIOR COMPRESSED AC SHEET SAMPLE 33	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	External	Roof Level 1	WEST, NORTH & SOUTHERN SIDES	WEST NORTH & SOUTH SIDE FASCIA AROUND ROOF SIM SAMPLE 33	Gable/Soffit/ascia	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Internal	Ground Floor	ROOM B102 LIBRARY	ROOM B102 - NORTH END AC SHEET	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Inter nal	Ground Floor	ROOM B104 TEACHER	ROOM B104 - TEACHER ROOM CA7 VINYL FLOOR TILES REFER SAMPLE 30	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Exter nal	Level 1	ROOM B201 PLANT	EXTERNAL WALL - FAN AREA AC SHEET SAMPLE 34	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Inter nal	Ground Floor	ROOM B106 MALE TOILET	MALE TOILET COMPRESSED PARTITIONS	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Inter nal	Ground Floor	ROOM B114	ROOM B114 VINYL FLOOR TILES REFER SAMPLE 30	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Inter nal	Ground Floor	ROOM B115 TYRE	ROOM B115 - TYRE ROOM VINYL FLOOR TILES REFER SAMPLE 30	Floor Finish/Coverin g	Vinyl Tiles		3	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Inter nal	Ground Floor	ROOM B118	FRONT INSULATING PANEL ON ITEM T62 IN BOTTOM SHELF	Plant, Equipment & Machinery	Other (refer to description)		4	Presumed	-	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Inter nal	Ground Floor	ROOM B118	FRONT INSULATING PANEL ON ITEM T63 & T64 IN BOTTOM SHELF	Plant, Equipment & Machinery	Polymer Based		4	Presumed	25	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Inter nal	Ground Floor	ROOM B119 ELECTRICS	ROOM B119 - ELECTRICS VINYL FLOOR TILES REFER SAMPLE 30	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Inter nal	Ground Floor	ROOM B123 OUTBOARD MOTOR ROOM	OUTBOARD MOTOR ROOM COMPRESSED PLANKING ON FLOOR SAMPLE 36	Floor Finish/Coverin g	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCABB	25954001	XCABB - BLOCK B	B Block	Inter nal	Ground Floor	ROOM B103 FIRST AID	ROOM B103 - FIRST AID VINYL FLOOR TILES REFER SAMPLE 30	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCACC	25954004	XCACC - BLOCK C	C Block	Inter nal	Ground Floor	ROOM C101	SAW TOOTH CENTRE SHEETING BOTH SIDES SIM SAMPLE 41	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCACC	25954004	XCACC - BLOCK C	C Block	Inter nal	Ground Floor	ROOM C101	OXY WELDING BAYS COMPRESSED AC SHEET 12MM SAMPLE 43	Wall	Cement Based	Mixed	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCACC	25954004	XCACC - BLOCK C	C Block	Inter nal	Ground Floor	ROOM C108 STORE ROOM	STORE ROOM VINYL FLOOR TILES REFER SAMPLE 42	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCACC	25954004	XCACC - BLOCK C	C Block	Inter nal	Ground Floor	ROOM C101	SEAL TO DOOR OF OVEN (IN FRONT OF ROOM C106)	Plant, Equipment & Machinery	Other (refer to description)		4	Presumed	-	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCACC	25954004	XCACC - BLOCK C	C Block	Inter nal	Ground Floor	ROOM C101	WELDING BOOTHS - 2 DOUBLE BAY COMPRESSED AC 12MM THICK SAMPLE 39	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCACC	25954004	XCACC - BLOCK C	C Block	Inter nal	Ground Floor	ROOM C105 PLANT ROOM	PLANT ROOM BEHIND STEEL PERFORATED PLATE - INSULATION SAMPLE 38	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCACC	25954004	XCACC - BLOCK C	C Block	Inter nal	Ground Floor	ROOM C106 OFFICE	OFFICE VINYL FLOOR TILES	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCACC	25954004	XCACC - BLOCK C	C Block	Inter nal	Ground Floor	ROOM C109 STAFF ROOM	STAFF ROOM VINYL FLOOR TILES SAMPLE 42	Floor Finish/Coverin g	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCACC	25954004	XCACC - BLOCK C	C Block	Inter nal	Ground Floor	ROOM C114 EQUIPMENT STORE	EQUIPMENT STORE VINYL FLOOR TILES	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCACC	25954004	XCACC - BLOCK C	C Block	Exter nal	Roof Level 1	ROOF VENT PIPE	BLOCK C - VENT PIPE TO ROOF SIM SAMPLE 45	Drains/Pipes/F loes	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCACC	25954004	XCACC - BLOCK C	C Block	Inter nal	Ground Floor	ROOM C101	NW CORNER - WELDING BOOTHS COMPRESSED AC 20MM THICK SAMPLE 37	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCACC	25954004	XCACC - BLOCK C	C Block	Inter nal	Ground Floor	ROOM C101	METAL WORK AREA PERFORATED CEILING SHEETS SAMPLE 40	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCACC	25954004	XCACC - BLOCK C	C Block	Inter nal	Ground Floor	ROOM C101	NORTH WALL SHEETING SIM SAMPLE 41	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCACC	25954004	XCACC - BLOCK C	C Block	Exter nal	Ground Floor	ROOM C112	HOT WATER HEATER FLUE PIPE TO ROOF SAMPLE 45	Drains/Pipes/F loes	Cement Based	Mixed	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCACC	25954004	XCACC - BLOCK C	C Block	Exter nal	Ground Floor	VERANDAH	VERANDAH SOUTH & EAST SIDE CEILING SHEET SAMPLE 44	Ceiling	Cement Based	Mixed	4	Confirmed	16	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCACC	25954004	XCACC - BLOCK C	C Block	Exter nal	Ground Floor	VERANDAH	BLOCK C GABLE EAST END SHEET SIM SAMPLE 43	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCACC	25954004	XCACC - BLOCK C	C Block	Inter nal	Ground Floor	ROOM C101	METAL WORK AREA - CEILING AC CEILING SHEET SAMPLE 41	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCADD	25954008	XCADD - BLOCK D	D Block	Inter nal	Ground Floor	ROOM D118	COMPRESSED SHEET BENCHTOP ALONG 5TH WALL	Furniture	Cement Based		3	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCADD	25954008	XCADD - BLOCK D	D Block	Inter nal	Ground Floor	ROOM D118	COMPRESSED SHEET SPLASHBACK ALONG 5TH WALL	Furniture	Cement Based		3	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCADD	25954008	XCADD - BLOCK D	D Block	Inter nal	Ground Floor	ROOM D118	COMPRESSED SHEET BENCH TOP TO BAY 5	Furniture	Cement Based		3	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCADD	25954008	XCADD - BLOCK D	D Block	Inter nal	Ground Floor	ROOM D115	WELDING BAY 14 DIVIDING WALL (COMPRESSED SHEET)	Furniture	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCADD	25954008	XCADD - BLOCK D	D Block	Inter nal	Ground Floor	ROOM D115	COMPRESSED SHEET DIVIDING WALLS TO WELDING BAYS 1 -16	Furniture	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCADD	25954008	XCADD - BLOCK D	D Block	Inter nal	Ground Floor	ROOM D101	COMPRESSED SHEET BENCHTOP IN FRONT OF OFFICE SIMILAR TO SAMPLE 19100	Furniture	Cement Based		3	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCADD	25954008	XCADD - BLOCK D	D Block	Inter nal	Ground Floor	ROOM D118	WOVEN TEXTILE SEAL TO DOOR OF OVEN IN BAY 2	Plant, Equipment & Machinery	Other (refer to description)		4	Presumed	-	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAEE	25954010	XCAEE - BLOCK E	E Block	Inter nal	Ground Floor	ROOM E104 TIMBER STORE	TIMBER STORE E104 CEILING LINING SIM SAMPLE 41	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAEE	25954010	XCAEE - BLOCK E	E Block	Inter nal	Ground Floor	ROOM E117 STORE ROOM	STORE ROOM E117 VINYL FLOOR TILES REFER SAMPLE 42	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAEE	25954010	XCAEE - BLOCK E	E Block	Inter nal	Ground Floor	ROOM E116	ROOM E116 WALL SHEETING SIM SAMPLE 41	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAEE	25954010	XCAEE - BLOCK E	E Block	Inter nal	Ground Floor	ROOM E116	PERFORATED CEILING SHEET TO 66% OF AREA SIM SAMPLE 40	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAEE	25954010	XCAEE - BLOCK E	E Block	Inter nal	Ground Floor	ROOM E114	ROOM E114 VINYL FLOOR TILES REFER SAMPLE 42	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAEE	25954010	XCAEE - BLOCK E	E Block	Inter nal	Ground Floor	ROOM E109 STORE ROOM	STORE ROOM SHEET ON WALLS SIM SAMPLE 41	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAEE	25954010	XCAEE - BLOCK E	E Block	Inter nal	Ground Floor	STORE ROOM E109 STORE ROOM	STORE ROOM AC SHEET ON CEILING REFER SAMPLE 41	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAEE	25954010	XCAEE - BLOCK E	E Block	Inter nal	Ground Floor	ROOM E108 FEMALE TOILETS	FEMALE TOILETS E108 VINYL FLOOR TILES REFER SAMPLE 42	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAEE	25954010	XCAEE - BLOCK E	E Block	Inter nal	Ground Floor	ROOM E105 STAFF ROOM	STAFF ROOM E105 VINYL FLOOR TILES REFER SAMPLE 42	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAEE	25954010	XCAEE - BLOCK E	E Block	Inter nal	Ground Floor	OFFICE	OFFICE - SOUTHERN END CEILING LINING SIM SAMPLE 41	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAEE	25954010	XCAEE - BLOCK E	E Block	Inter nal	Ground Floor	OFFICE	OFFICE - DIVIDER WALL AC SHEET LINING SAMPLE 49	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAEE	25954010	XCAEE - BLOCK E	E Block	Exter nal	Roof Level 1	ROOF	VENT PIPE ON HOT WATER SYSTEM E107 THROUGH ROOF SIM SAMPLE 45	Drains/Pipes/F loes	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAEE	25954010	XCAEE - BLOCK E	E Block	Exter nal	Roof Level 1	EAVES	EAVES LINING ON EASTERN SIDE OF BLOCK E. SIM SAMPLE 44	Gables/Soffits	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAEE	25954010	XCAEE - BLOCK E	E Block	Exter nal	Ground Floor	VERANDAH	VERANDAH CEILING LINING SIM SAMPLE 44	Ceiling	Cement Based		4	Presumed	18	-	

TAFes from BEMIR-TAFes

Current as at 10-May-11

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Est	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAEE	25954010	XCAEE - BLOCK E	E Block	Inter nal	Ground Floor	ROOM E103 STORE ROOM	STORE ROOM VINYL FLOOR TILES REFER SAMPLE 42	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAEE	25954010	XCAEE - BLOCK E	E Block	Inter nal	Ground Floor	ROOM E107 STORE ROOM	STORE ROOM E107 SHEET ON CEILING SIM SAMPLE 41	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAEE	25954010	XCAEE - BLOCK E	E Block	Inter nal	Ground Floor	ROOM E116	CEILING SHEET TO 33% OF AREA SIM SAMPLE 41	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAFF	25954002	XCAFF - BLOCK F	F Block	Inter nal	Ground Floor	ROOM F 101	SHEETING ON CEILING TO 33% OF AREA, SIM SAMPLE 41	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAFF	25954002	XCAFF - BLOCK F	F Block	Inter nal	Ground Floor	WALL PARTITIONS	PARTITION WALLING TO THE WELDING AREA	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAFF	25954002	XCAFF - BLOCK F	F Block	Inter nal	Ground Floor	VERANDAH NORTH SIDE	CLUTCH PLATE ON BENCH NORTH SIDE BLOCK F, SAMPLE 50	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAFF	25954002	XCAFF - BLOCK F	F Block	Inter nal	Ground Floor	ROOM F104	CLUTCH PLATES - SIMILAR TO SAMPLES 19114 & 19113	Friction Product	Polymer Bound		4	Presumed	25	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAFF	25954002	XCAFF - BLOCK F	F Block	Inter nal	Ground Floor	ROOM F 119 STAFF ROOM	VINYL TILES IN STAFF ROOM REFER SAMPLE 42	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAFF	25954002	XCAFF - BLOCK F	F Block	Inter nal	Ground Floor	ROOM F 110 STORE ROOM	VINYL TILES IN STORE ROOM F 110, REFER SAMPLE 42	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAFF	25954002	XCAFF - BLOCK F	F Block	Inter nal	Ground Floor	ROOM F 107	VINYL TILES IN ROOM F 107,REFER SAMPLE 42	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAFF	25954002	XCAFF - BLOCK F	F Block	Inter nal	Ground Floor	ROOM F 101	WALL LININGS IN WORKSHOP F 101.	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAFF	25954002	XCAFF - BLOCK F	F Block	Inter nal	Ground Floor	ROOM F 101	PERFORATED CEILING SHEET TO 56% OF AREA, SIM SAMPLE 40	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAFF	25954002	XCAFF - BLOCK F	F Block	Exter nal	Level 1	VENT PIPES	AC VENT PIPES X 2 TO THE ROOF LEVEL	Drains/Pipes/F lues	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAFF	25954002	XCAFF - BLOCK F	F Block	Exter nal	Ground Floor	VERANDAH SWITCHBOARD	SWITCHBOARD, LOCATED NORTH EAST CORNER ON BLOCK F VERANDAH, SAMPLE 51	Insulation/Fill	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAFF	25954002	XCAFF - BLOCK F	F Block	Exter nal	Ground Floor	VERANDAH	VERANDAH CEILING LKING SIM SAMPLE 44	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAFF	25954002	XCAFF - BLOCK F	F Block	Exter nal	Ground Floor	EAVES	EAVES LINING WESTERN SIDE OF BUILDING, SIM SAMPLE 44	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAFF	25954002	XCAFF - BLOCK F	F Block	Inter nal	Ground Floor	ROOM F 102	VINYL TILES IN ROOM F 102,REFER SAMPLE 42	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAGG	25954009	XCAGG - BLOCK G	G Block	Inter nal	Level 1	FOYER	FOYER AREA VINYL FLOOR SHEET	Floor Finish/Coverin g	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAGG	25954009	XCAGG - BLOCK G	G Block	Exter nal	Roof Level 1	FASCIA	FASCIA VERTICAL & HORIZONTAL AROUND ENTIRE BUILDING SIM SAMPLE 63	Gable/Soffit/F ascia	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAGG	25954009	XCAGG - BLOCK G	G Block	Exter nal	Roof Level 1	ROOF AREA	CENTRE ROOF AREA SIDE PANELS OF ROOF VENT'LATION SIM SAMPLE 53	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAGG	25954009	XCAGG - BLOCK G	G Block	Inter nal	Ground Floor	ROOM G119	INSULATION BLOCK ON TOP OF DAVEY MOTOR ON 5TH BENCH SERIAL NO. 1146	Plant, Equipment & Machinery	Polymer Bound		3	Presumed	25	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAGG	25954009	XCAGG - BLOCK G	G Block	Inter nal	Ground Floor	ROOM G119	SWITCHBOARD BACKING PANEL ON EASTERN BENCH	Plant, Equipment & Machinery	Other (refer to description)		3	Presumed	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAGG	25954009	XCAGG - BLOCK G	G Block	Inter nal	Ground Floor	ROOM G123	BACKING PANEL TO SWITCHBOARD ON MOBILE CHALKBOARD SIMILAR TO SAMPLE 19097	Plant, Equipment & Machinery	Polymer Bound		3	Presumed	25	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAGG	25954009	XCAGG - BLOCK G	G Block	Inter nal	Ground Floor	ROOM G124	BACKING PANELS TO S/S A6,B8,B9,A10,B10,A11,B11,A12,B12,A13,B13,A14 & B14 SIMILAR TO SAMPLE 19096	Plant, Equipment & Machinery	Polymer Bound		3	Presumed	25	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAGG	25954009	XCAGG - BLOCK G	G Block	Inter nal	Ground Floor	ROOM G124	S/BOARD BACKING PANEL TO S/BOARD ON STUD WALLS SIMILAR TO SAMPLE 19097	Plant, Equipment & Machinery	Polymer Bound		3	Presumed	25	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAGG	25954009	XCAGG - BLOCK G	G Block	Inter nal	Ground Floor	TOILETS	FIBRE CEMENT CUBICALE WALL PARTITIONS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAGG	25954009	XCAGG - BLOCK G	G Block	Exter nal	Level 1	SUN HOODS	WINDOW SUN HOODS COMPRESSED SHEET SAMPLE 63	Sun Hood	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAGG	25954009	XCAGG - BLOCK G	G Block	Inter nal	Ground Floor	ROOM G124	SWITCHBOARD BACKING PANEL, (BOARD A9)	Plant, Equipment & Machinery	Other (refer to description)		3	Presumed	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Inter nal	Level 3	PLANT ROOM	PLANT ROOM HEATER BANKS SAMPLE 89	Heater Bank Insulation	Millboard	CHR - Chrysotile	2	Confirmed	86	-	It was noted upon inspection that ACM is in a deteriorated condition,fraying.
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Inter nal	Ground Floor	ROOM G 122 CLASSROOM	VINYL FLOOR TILES IN CLASS ROOM, REFER SAMPLE 56	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Inter nal	Ground Floor	ROOM G 122 CLASS S/BOARD	ZELEMIT BACKING TO SWITCHBOARD PANELS IN CLASSROOM, SIM SAMPLE 51	Insulation/Fill	Polymer Bound		4	Removed	25	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Inter nal	Ground Floor	ROOM G 121 CLASSROOM	VINYL FLOOR IN CLASS ROOM NORTH & SOUTH ENDS, SIM SAMPLE 53	Floor Finish/Coverin g	Vinyl Sheetin g (includes backing)		4	Presumed	62	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Inter nal	Ground Floor	ROOM G 119 CLASSROOM	WEST WALL OF CLASS ROOM SAMPLE 54	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Inter nal	Ground Floor	ROOM G 119 CLASSROOM	VINYL FLOOR SHEETING IN CLASS ROOM, SAMPLE 53	Floor Finish/Coverin g	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Inter nal	Ground Floor	ROOM G 119 CLASSROOM	CAPACITOR FROM ELECTRICAL EQUIPMENT, SAMPLE 52	Plant, Equipment & Machinery	Millboard	CHR - Chrysotile	3	Confirmed	64	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Inter nal	Ground Floor	ROOM G 108	VINYL FLOOR TILES REFER SAMPLE 56	Floor Finish/Coverin g	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Inter nal	Ground Floor	ROOM G 107 HORTICULTURE	WALL SHEETING EAST SIDE OF HORTICULTURE ROOM, SIM SAMPLE 51	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Inter nal	Level 1	ROOM G 219	FIRE DAMAGED ROOM VINYL FLOOR SHEET	Floor Finish/Coverin g	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Inter nal	Ground Floor	ROOM H130	WOVEN TEXTILE SEAL TO DOOR OF PIZZA OVEN NO.SLR642	Gasket	Other (refer to description)		3	Presumed	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Inter nal	Ground Floor	ROOM H130	WOVEN TEXTILE SEAL TO DOOR OF OVEN NO.5033968 SIMILAR TO SAMPLE 19102	Gasket	Woven Textile		3	Presumed	64	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Inter nal	Ground Floor	ROOM H 125 TOILET & SHOWER	TOILETS & SHOWER PARTITIONS COMPRESSED AC SHEET	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Inter nal	Ground Floor	ROOM H 124 TOILET & SHOWER	TOILETS & SHOWER PARTITIONS COMPRESSED AC SHEET	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Inter nal	Ground Floor	ROOM H 101	ABOVE FOLDER DOOR, DOUBLE SIDE SAC SHEET DIVIDER WALL	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Inter nal	Ground Floor	STORE	MISCOUTE BOARD STORED IN STORE, SAMPLE 60	Stored Material	Polymer Bound	CHR - Chrysotile	4	Confirmed	25	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Inter nal	Ground Floor	ROOM G 124 GENERATOR SETS	ZELEMIT ON GENERATOR SETS IN TRAINING ROOM, SAMPLE 59	Insulation/Fill	Polymer Bound	CHR - Chrysotile	3	Confirmed	25	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Ground Floor	SWITCH ROOM	SHEET VINYL FLOOR TO ROOM H1.11	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Level 3	PLANT ROOM AREA	WALL LININGS ADJACENT TO THE DOOR TO THE PLANT ROOM	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Level 1	ROOM G 218	ROOM G218 VINYL FLOOR SHEET SIM SAMPLE 53	Floor Finish/Covering	Vinyl Sheetting (includes backing)		4	Presumed	62	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Ground Floor	ROOM H130	WOVEN TEXTILE SEAL TO DOOR OF PIZZA OVEN NO.3LR042	Gasket	Woven Textile		3	Presumed	84	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Level 1	ROOM G 210	NORTH WALL SHEETING SIM SAMPLE 61	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Ground Floor	ROOM G 124	INSULATION AROUND 'BRAEMARE' HOT WATER SYSTEM UNIT. SAMPLE 55	Insulation/Fill	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Level 1	ROOM G 210A	SOUTH & EAST WALLS WALL SHEETING SIM SAMPLE 61	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Ground Floor	ROOM G 106 COMPUTER	WALL SHEETING EAST SIDE OF COMPUTER ROOM. SAMPLE 61	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Level 1	ROOM G 2100 OFFICE	STHNEAST WALL OFFICE WALL SHEETING SIM SAMPLE 61	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Level 1	TV STUDIO	SOUND PROOFING BATTS ON NTH WALL	Battles/Lining	Other (refer to description)		3	Presumed	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Level 3	PLANT ROOM	MASTIC TO AC DUCT	Membrane	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Level 3	PLANT ROOM	PLANT ROOM AC SHEET AROUND ALL WALLS SAMPLE T3	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Ground Floor	VARIOUS	VINYL FLOOR COVERING IN ROOMS G 115 G 114 G 113. SAMPLE 52	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954008	XCAHH - BLOCK H	H Block	Internal	Ground Floor	ROOM G 106 COMPUTER	VINYL FLOOR COVERING IN COMPUTER ROOM. SIM SAMPLE 53	Floor Finish/Covering	Vinyl Sheetting (includes backing)		4	Presumed	62	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Ground Floor	ROOM G 105 STORE ROOM	VINYL FLOOR SHEET IN STORE ROOM. SIM SAMPLE 53	Floor Finish/Covering	Vinyl Sheetting (includes backing)		4	Presumed	62	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Ground Floor	PASSAGE	VINYL FLOOR TILES IN PASSAGE WAY. SAMPLE 58	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954006	XCAHH - BLOCK H	H Block	Internal	Ground Floor	OFFICE	STUDENT ASS. ROOMS DIVIDER WALLS SAMPLE 72	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Ground Floor	OFFICE	FNQ TAPE STUDENT ASS. BEIGE VINYL FLOOR TILES SAMPLE 71	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Ground Floor	MALE TOILET	COMPRESSED 20MM SHEET TOILET PARTITIONS IN G 110	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Ground Floor	FEMALE TOILET	COMPRESSED 20MM SHEET IN FEMALE TOILET PARTITIONS. G 109	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	External	Ground Floor	ROOM G 124	150MM PIPE RUNNING UNDER BUILDING. SIM SAMPLE 58	Drains/Pipes/Furniture	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	External	Ground Floor	ROOM G 124	150MM PIPE RUNNING UNDER BUILDING. SIM SAMPLE 58	Drains/Pipes/Furniture	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAHH	25954005	XCAHH - BLOCK H	H Block	Internal	Ground Floor	ROOM G 124 R.A.C.	INSULATION IN R.A.C. ON BENCH. SAMPLE 57	Furniture	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAII	25954007	XCAII - BLOCK I	I Block	External	Ground Floor	STORE	VERANDA/EXTERNAL EAVES SOFFIT LINING SIM SAMPLE 65	Cables/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAII	25954007	XCAII - BLOCK I	I Block	Internal	Ground Floor	ROOM I101	BOTH SIDES AC LINED DIVIDER WALL SAMPLE 64	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAII	25954007	XCAII - BLOCK I	I Block	Internal	Ground Floor	ROOM I101	EAST END ABOVE BRICKWORK WALL SHEET SIM SAMPLE 65	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAII	25954007	XCAII - BLOCK I	I Block	Internal	Ground Floor	ROOM I101	EASTERN WALL LINING AC SHEET SAMPLE 65	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAII	25954007	XCAII - BLOCK I	I Block	Internal	Ground Floor	ROOM I101	STORE AREA CEILING SHEET SIM SAMPLE 65	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAII	25954007	XCAII - BLOCK I	I Block	Internal	Ground Floor	ROOM I101	SWITCHBOARD ROOM CEILING SHEET SIM SAMPLE 65	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM D103	CEILING PERFORATED CEILING SHEET SIM SAMPLE 40	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM D108 EQUIPMENT STORE	EQUIPMENT STORE VINYL FLOOR TILES REFER SAMPLE 42	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM 3113 CLASSROOM	CLASS ROOM PINK VINYL SHEET FLOOR SIM SAMPLE 76	Floor Finish/Covering	Vinyl Sheetting (includes backing)		4	Presumed	62	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM D101	CEILING SHEET TO 33% OF AREA SIM SAMPLE 41	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM D101	OXY WELDING AREA COMPRESSED AC SHEET 12MM SIM SAMPLE 39	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM D101	PERFORATED CEILING SHEET TO 66% OF AREA SIM SAMPLE 40	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM D101	WORKBENCH PLUMBING AREA 20MM COMPRESSED AC SHEET REFER SAMPLE 37	Plant, Equipment & Machinery	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM D101 STERILIZER	INSULATION AROUND STERILIZER SAMPLE 48	Insulation/Fill	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM D101	CABINET GAS BOTTLE SAMPLE 96 FULLY ENCAPSULATED NOT DISTURBED, NEED FOR EDUCATION PURPOSE	Plant, Equipment & Machinery	Loose Fill	CHR - Chrysotile	4	Confirmed	64	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM D113	NORTH WALL D113 LINED SIM SAMPLE 41	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Site / Grounds	VARIOUS ROOMS	SALONS 1 & 2 & STORE VINYL FLOOR COVERINGS IN ROOMS SIM SAMPLE 75	Floor Finish/Covering	Vinyl Sheetting (includes backing)		4	Presumed	62	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Site / Grounds	VARIOUS ROOMS	J125 126 128 129 130 VINYL FLOOR COVERINGS IN ROOMS SIM SAMPLE 75	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Site / Grounds	VARIOUS ROOMS	J121 122 123 124 VINYL FLOOR COVERINGS IN ROOMS SIM SAMPLE 75	Floor Finish/Covering	Vinyl Sheetting (includes backing)		4	Presumed	62	-	
Tropical North Queensland		CAIRNS TAPE CAMPUS (WIC-25954)	CAIRNS TAPE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Roof Level 1	ROOF	INSULATION AIR CONDITIONER. HEATER BANKS SAMPLE 101	Heater Bank Insulation	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	VARIOUS ROOMS	ROOMS J115 & 116 VINYL FLOOR COVERINGS IN ROOMS SIM SAMPLE 75	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM J107	WOVEN TEXTILE SEAL TO DOOR OF PIZZA OVEN	Gasket	Other (refer to description)		3	Presumed		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM D105 STORE ROOM	STORE ROOM CEILING SHEET SIM SAMPLE 41	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM D115	WELDING BOOTHS COMPRESSED AC SHEET SIM SAMPLE 42	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM D103	NORTH EAST & WEST WALLS SHEET WALL LINING SIM SAMPLE 41	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM D112 STAFF ROOM	STAFFROOM VINYL FLOOR TILES REFER SAMPLE 42	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM D109 STOREROOM	STOREROOM VINYL FLOOR TILES REFER SAMPLE 42	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	External	Ground Floor	CLASSROOM EXTERNAL	EXTERNAL WALL LINING AC SHAFFER BOARD SAMPLE 46	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM D106 STORE ROOM	STORE ROOM CEILING SHEET SIM SAMPLE 41	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	CLEANERS ROOM	VINYL FLOOR TILES TO THE CLEANERS ROOM	Floor Finish/Covering	Vinyl Tiles	CMR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM D103	PLUMBING TRAINING AREA SHEET CEILING SIM SAMPLE 41	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	ROOM D117 OFFICE OF PLUMBING WORKSHOP	OFFICE OF PLUMBING WORKSHOP VINYL FLOOR TILES REFER SAMPLE 42	Floor Finish/Covering	Vinyl Tiles		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	CLASSROOM	CEILING OF CLASSROOM CEILING LINING SIM SAMPLE 44	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	External	Roof Level 1	ROOF VENT PIPE	VENT PIPE ON ROOF SIM SAMPLE 45	Drains/Pipes/Fixtures	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	External	Ground Floor	VERANDA	VERANDA CEILING LINING SIM SAMPLE 44	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	External	Roof Level 1	FASCIA	FASCIAS & GABLES COMPRESSED SHEETING SIM SAMPLE 76	Gables/Soffits/Fascia	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAJJ	25954003	XCAJJ - BLOCK J	J Block	Internal	Ground Floor	CLASSROOM	INTERNAL WALL LINING AC SHEET SAMPLE 47	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAKK	25954006	XCAKK - BLOCK K	K Block	External	Level 1	PLANT ROOM	PLANT ROOM EXTERNAL STAIRWELL'S COMPRESSED AC WALL LINING SIM SAMPLE 80	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAKK	25954006	XCAKK - BLOCK K	K Block	Internal	Ground Floor	ROOMS 1-421-43	BLUE VINYL FLOOR COVERING SIM SAMPLE 79	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAKK	25954006	XCAKK - BLOCK K	K Block	Internal	Ground Floor	VARIOUS	CORRIDOR AND VARIOUS ROOMS BLUE VINYL FLOOR COVERING SAMPLE 79	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAKK	25954006	XCAKK - BLOCK K	K Block	Internal	Level 1	VARIOUS	CORRIDOR AND VARIOUS ROOMS BLUE VINYL FLOOR COVERING SIM SAMPLE 79	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Presumed	62	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAKK	25954006	XCAKK - BLOCK K	K Block	External	Roof Level 1	GABLE	BLOCK K WING A LINING ON EXTERNAL GABLE SIM SAMPLE 79	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAKK	25954006	XCAKK - BLOCK K	K Block	Internal	Ground Floor	ROOM 1497 GYM	GYM GREEN VINYL FLOOR COVERING SAMPLE 81	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAKK	25954006	XCAKK - BLOCK K	K Block	External	Level 1	EXTERNAL STAIRS	EAST & WEST EXTERNAL STAIR WELL SAC WALL LINING SAMPLE 80	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Internal	Ground Floor	KILN	KILN LOCATED IN KILN ROOM SAMPLE 84	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	External	Ground Floor	GABLE	EXTERNAL SHEETING TO GABLES AND BARGE SAMPLE 87	Gables/Soffits/Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Internal	Ground Floor	ROOM L108	LINING OF INTERNAL WALL OF KILN NO. 5017535	Plant, Equipment & Machinery	Other (refer to description)		3	Presumed		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Internal	Ground Floor	ROOM L104	INTERNAL LINING OF WOVEN TEXTILE GLOVE	Plant, Equipment & Machinery	Other (refer to description)		3	Presumed		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Internal	Ground Floor	KILN	KILN ROOM OLD SMALL KILN SAMPLE 86	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Internal	Ground Floor	PERGOLA	LINING TO THE EXHAUST DUCT ABOVE OVEN STYLE KLIN.	Drains/Pipes/Fixtures	Insulation Board	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Internal	Ground Floor	PERGOLA	INSULATION TO KILN DOOR KILN NO FA230528 - PERGOLA - L BLOCK.	Plant, Equipment & Machinery	Insulation Board	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	CY8808 R.Hammer 21/12/2010
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Internal	Ground Floor	PERGOLA	LINING TO DRUM STYLE KILN - PERGOLA - L BLOCK.	Plant, Equipment & Machinery	Insulation Board	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	CY-8806 R.Hammer 21/12/2010
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Internal	Ground Floor	PERGOLA	LINING TO OVEN STYLE KILN - PERGOLA - L BLOCK.	Plant, Equipment & Machinery	Insulation Board	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	CY-8805 R.Hammer 21/12/2010
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Internal	Ground Floor	ROOM L101	COMPRESSED SHEET TOP TO ORANGE STEEL FRAMED TABLE	Furniture	Other (refer to description)		3	Presumed		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Internal	Ground Floor	ROOM L101	COMPRESSED SHEET TOPS ON BLUE FRAMED TABLES	Furniture	Other (refer to description)		3	Presumed		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Internal	Ground Floor	ROOM L102	COMPRESSED SHEET TOPS ON BLUE FRAMED TABLES SIMILAR TO SAMPLE 19084	Furniture	Cement Based		3	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Internal	Ground Floor	ROOM L110	EXHAUST DUCT ABOVE KILN SIMILAR TO SAMPLE 19086	Drains/Pipes/Fixtures	Insulation Board		2	Presumed	34	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Internal	Ground Floor	ROOM L104	EXTERNAL SKIN OF WOVEN TEXTILE GLOVE	Plant, Equipment & Machinery	Other (refer to description)		3	Presumed		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Internal	Ground Floor	KILN	KILN ROOM LARGE KILN SAMPLE 85	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Internal	Ground Floor	ROOM L104	ROLL OF TEXTILE CORD ON SHELF	Plant, Equipment & Machinery	Other (refer to description)		3	Presumed		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Internal	Ground Floor	ROOM L104	WOVEN TEXTILE GLOVE	Plant, Equipment & Machinery	Woven Textile		3	Presumed	64	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Internal	Ground Floor	ROOM L106	COMPRESSED SHEET BENCHTOPS & SPLASHBACKS SIMILAR TO SAMPLE 19084	Furniture	Cement Based		3	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Internal	Ground Floor	ROOM L106	COMPRESSED SHEET BENCHTOPS & SPLASHBACKS SIMILAR TO SAMPLE 19084	Furniture	Cement Based		3	Presumed	18	-	

TAFEs from BEMIR-TAFEs

Current as at 10-May-11

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Est	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Inter nal	Ground Floor	ROOM L108	LINING INTERNAL WALLS OF KILN NO. EQ0028975, EQ0949555, EQ0517823, X06339 AND BLUE KILN	Plant, Equipment & Machinery	Insulation Board		3	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Inter nal	Ground Floor	ROOM L110	COMPRESSED SHEET BENCHTOPS & SPLASHBACK SIMILAR TO SAMPLE 19084	Furniture	Cement Based		3	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25854019	XCALL - BLOCK L	L Block	Inter nal	Ground Floor	ROOM L110	INSULATION TO KILN DOOR (KILN NO. FA250528)	Plant, Equipment & Machinery	Other (refer to description)		2	Presumed		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCALL	25954019	XCALL - BLOCK L	L Block	Inter nal	Ground Floor	ROOM L104	EXTERNAL SKIN OF WOVEN TEXTILE GLOVE	Plant, Equipment & Machinery	Other (refer to description)		3	Presumed		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAMM	25954014	XCAMM - BLOCK M	M Block	Inter nal	Ground Floor	ARTS	ARTS BUILDING THROUGHOUT CEILING SHEETS REFER SAMPLE 90	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAMM	25854014	XCAMM - BLOCK M	M Block	Exter nal	Ground Floor	ATSI ARTS	ATSI ARTS INTERNAL & EXTERNAL DEMOUNTABLE WALL SHEETING SAMPLE 90	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCANN	25954018	XCANN - BLOCK N	N Block	Exter nal	Ground Floor	ARTS	THROUGHOUT INTERNAL & EXTERNAL WALL SHEETING REFER SAMPLE 88	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCANN	25954018	XCANN - BLOCK N	N Block	Inter nal	Ground Floor	ATSI ARTS	ATSI ARTS THROUGHOUT DEMOUNTABLE CEILING LINING SAMPLE 88	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCARR	25954027	XCARR - BLOCK R	R Block	Inter nal	Ground Floor									-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCASS	25954030	XCASS - BLOCK S	S Block	Inter nal	Level 2	KITCHEN 3	DOOR SEALS TO MOFFAT 2-DOOR OVENS ON MOBILE TROLLEY, SIMILAR TO SAMPLE 19091	Gasket	Woven Textile		4	Presumed	64	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCASS	25954030	XCASS - BLOCK S	S Block	Inter nal	Ground Floor	ARTS	ATSI ARTS THROUGHOUT DEMOUNTABLE CEILING SHEET SAMPLE 92	Ceiling	Cement Based	Mixed	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCATT	25954020	XCATT - BLOCK T	T Block	Exter nal	Roof Level 1	GABLES	GABLE ENDS ON ROOF SHEET LINING SIM SAMPLE 83	Roof Sheeting	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCATT	25954020	XCATT - BLOCK T	T Block	Exter nal	Ground Floor	VERANDAH	VERANDA ON BLOCK T AC SHEETING ON CEILING SAMPLE 83	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCATT	25954020	XCATT - BLOCK T	T Block	Exter nal	Ground Floor	SHED/FRONT VERANDAH	FRONT VERANDAH ENTRY TO SHED SHEET LINING SIM SAMPLE 83	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAUJ	25954021	XCAUJ - BLOCK U	U Block	Inter nal	Ground Floor	STAIR EXITS	FIRE DOOR LOCATED AT STAIR EXITS SAMPLE 82	Fire Door	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAVV	25954022	XCAVV - BLOCK V	V BLOCK	Inter nal	Ground Floor	COVERED AREA	LAGGING TO COPPER PIPES INSIDE STEAM GENERATOR SERIAL NO.790	Pipe Insulation	Other (refer to description)		3	Presumed		-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAWW	25954023	XCAWW - BLOCK W	W Block	Exter nal	Ground Floor	ARTS INT & EXT	ARTS EXTERNAL & INTERNAL DEMOUNTABLE WALL SHEETS SAMPLE 91	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAWW	25954023	XCAWW - BLOCK W	W Block	Inter nal	Ground Floor	ARTS	ARTS BUILDING REFER SAMPLE 91	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		CAIRNS TAFE CAMPUS (WIC-25954)	CAIRNS TAFE CAMPUS (WIC-25954)	XCAYY	25954040	XCAYY - BLOCK Y	Y Block	Inter nal	Ground Floor									-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27524002	CRECHE NO 6	CRECHE NO 6	Exter nal	Ground Floor	EXTERNAL	SHADOWLINE EXTERNAL WALL SHEETING SAMPLE 1767	Wall	Cement Based	Mixed	2	Confirmed	43	-	SHEETING IS CRACKED AND DAMAGED.
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27524002	CRECHE NO 6	CRECHE NO 6	Inter nal	Ground Floor	LAUNDRY & TOILET	FLAT WALL SHEETING IN THE TOILET AND LAUNDRY AREA (CLEANERS ROOM)	Wall	Cement Based	CHR - Chrysotile	2	Confirmed	43	-	CRACKED AND HOLED WALL CLADDING.
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27524002	CRECHE NO 6	CRECHE NO 6	Inter nal	Ground Floor	LAUNDRY & TOILET	FLAT CEILING SHEETING IN TOILET AREA ABOVE THE LAUNDRY SINK AREA SIM SAMPLE 6250521-03	Ceiling	Cement Based		3	Presumed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27524002	CRECHE NO 6	CRECHE NO 6	Inter nal	Ground Floor	INTERNAL/TOILET	VINYL FLOOR TILES IN TOILETS SAMPLE 1770	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27524002	CRECHE NO 6	CRECHE NO 6	Inter nal	Ground Floor	INTERNAL	SHADOWLINE INTERNAL WALL SHEETING SIMILAR SAMPLE 1767	Wall	Cement Based		3	Presumed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27524002	CRECHE NO 6	CRECHE NO 6	Exter nal	Roof Level 1	ROOF	CORRUGATED ROOF SHEETING SAMPLE 1768	Roof Sheeting	Cement Based	CHR - Chrysotile	2	Confirmed	43	-	SHEETING HAS DETEIORATED, IT IS FRAYING.
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27524002	CRECHE NO 6	CRECHE NO 6	Inter nal	Ground Floor	INTERNAL	INTERNAL WALL SHEETING SAMPLE 1769	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27524004	SHED NO 8	SHED NO 8	Inter nal	Ground Floor	SHED NO 8	SHED NO 8 ASBESTOS FREE STRUCTURE	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)		-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27524005	BLDG NO 7	BLDG NO 7	Exter nal	Roof Level 1	ROOF	CORRUGATED SHEETING ON ROOF OF BLDG NO 7	Roof Sheeting	Cement Based		2	Presumed	43	-	SHEETING IS IN A DETEIORATED CONDITION - FRAYING.
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27524005	BLDG NO 7	BLDG NO 7	Exter nal	Ground Floor	EXTERNAL	SHADOWLINE SHEETING ON EXTERNAL WALLS SAMPLE 1772	Wall	Cement Based	Mixed	3	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27524005	BLDG NO 7	BLDG NO 7	Inter nal	Ground Floor	SWITCHBOARD	ZELEMITE SWITCHBOARD FACE SHEET BLDG NO 7 SAMPLE 1771	Insulation/Fill	Polymer Bound	CHR - Chrysotile	4	Removed	25	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27524006	TOBACCO SHED	TOBACCO SHED	Exter nal	Ground Floor	GABLES	FC SHEETING TO GABLE ENDS OF SHED SAMPLE 1794	Wall	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27524006	TOBACCO SHED	TOBACCO SHED	Inter nal	Site / Grounds	TOBACCO SHED	NO ASBESTOS DETECTED IN TOBACCO SHED	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)		-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27524008	MAIN STORE NO 12	MAIN STORE NO 12	Inter nal	Ground Floor	OFFICE	SHEETING ON WALLS OF OFFICE SAMPLE 1790	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27524008	MAIN STORE NO 12	MAIN STORE NO 12	Exter nal	Ground Floor	SWITCHBOARD	ZELEMITE SWITCHBOARD FACE SHEET SIMILAR SAMPLE 1771	Insulation/Fill	Polymer Bound		4	Removed	25	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27524011	NURSERY NO 3	NURSERY NO 3	Exter nal	Ground Floor	EXTERNAL WALLS	EXTERNAL WALL SHEETING NURSERY NO 3 SAMPLE 1776	Wall	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27524011	NURSERY NO 3	NURSERY NO 3	Inter nal	Ground Floor	DOOR PUTTY	PUTTY AROUND GLASS PANEL DOOR NURSERY NO 3 SAMPLE 1777	Insulation/Fill	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)		-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27583001	RESIDENCE NO 056	RESIDENCE NO 056	Exter nal	Ground Floor	EXTERNAL	FIBRE CEMENT MOULDED PROFILE TO DRAIN	Prnformed Moulded Product	Cement Based		4	Presumed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27583001	RESIDENCE NO 056	RESIDENCE NO 056	Exter nal	Ground Floor	VERANDAH	AC SHEETING ON VERANDAH OF RESIDENCE NO 56 SIMILAR SAMPLE 1798	Ceiling	Cement Based		4	Presumed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27583001	RESIDENCE NO 056	RESIDENCE NO 056	Exter nal	Ground Floor	EXTERNAL	AC SHEETING ON EXTERIOR OF RESIDENCE NO 56 SAMPLE 1798	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27583001	RESIDENCE NO 056	RESIDENCE NO 056	Inter nal	Ground Floor	KITCHEN	CEILING SHEETING IN KITCHEN OF RES 56 SAMPLE 1799	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27583001	RESIDENCE NO 056	RESIDENCE NO 056	Exter nal	Ground Floor	TANK STAND	COMPRESSED SHEET FLOORING ON TANK STAND OF RES 56	Floor	Cement Based		4	Presumed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27583001	RESIDENCE NO 056	RESIDENCE NO 056	Inter nal	Ground Floor	KITCHEN	VINYL FLOOR SHEETING WITH FRIABLE UNDERLAY	Floor Finish/Covering	Vinyl Sheeting (includes backing)	CHR - Chrysotile	4	Confirmed	62	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27583001	RESIDENCE NO 056	RESIDENCE NO 056	Inter nal	Ground Floor	KITCHEN	WALL SHEETING IN KITCHEN OF RESIDENCE 56 SIMILAR SAMPLE 1798	Wall	Cement Based		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ed	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27583001	RESIDENCE NO 056	RESIDENCE NO 056	External	Ground Floor	EXTERNAL	ZELEMITE SWITCHBOARD ADJACENT TO THIS RESIDENCE	Plant, Equipment & Machinery	Polymer Bound		3	Presumed	25	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27583001	RESIDENCE NO 056	RESIDENCE NO 056	External	Ground Floor	EAVES	SOFFIT SHEETING ON RESIDENCE 56 SIMILAR SAMPLE 1708	Gable/Soffit/ascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27583001	RESIDENCE NO 056	RESIDENCE NO 056	Internal	Ground Floor	INTERNAL	SHEETING BEHIND LAMINATE MATERIAL	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27584001	MAREEBA RESIDENCE NO 057	MAREEBA RESIDENCE NO 057	Internal	Ground Floor	KITCHEN	SHEET VINYL FLOOR COVERING WITH FIBROUS UNDERLAY	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27584001	MAREEBA RESIDENCE NO 057	MAREEBA RESIDENCE NO 057	Internal	Ground Floor	RESIDENCE	SHEETING TO INTERNAL WALLS/ RESIDENCE 57. SAMPLE 1795	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27584001	MAREEBA RESIDENCE NO 057	MAREEBA RESIDENCE NO 057	External	Ground Floor	EAVES	SHEETING TO SOFFITS ON RESIDENCE 57 SAMPLE 1797	Gable/Soffit/ascia	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)		27584001	MAREEBA RESIDENCE NO 057	MAREEBA RESIDENCE NO 057	Internal	Ground Floor	RESIDENCE	SHEETING TO INTERNAL CEILINGS RESIDENCE 57 SAMPLE 1796	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XHOUSE1		Residence 1	Residence 1											-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XHOUSE2		Residence 2	Residence 2											-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMA	27524000	Site - Grounds	Site - Grounds	Internal	Ground Floor	KILN DOOR	INSULATION ON REAR OF KILN DOOR SAMPLE 1778	Fire Door	Other (refer to description)	No asbestos detected (NAD)	2	Not Present(Not Tested)		-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMA	27524000	Site - Grounds	Site - Grounds	Internal	Ground Floor	KILN	VENT PIPE LYING DOWN ON KILN ROOF.	Pipe Insulation	Cement Based		2	Presumed	43	-	Vent pipe noted to be in a deteriorated condition, fraying.
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMA	27524000	Site - Grounds	Site - Grounds	External	Site / Grounds	GROUPS	CORRUGATED ROOF SHEET PIECES ON GROUND SAMPLE 1793	Roof Sheeting	Cement Based	CHR - Chrysotile	2	Removed	34	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMA	27524000	Site - Grounds	Site - Grounds	Internal	Grounds	KILN	ZELEMITE SHEET HOUSED BESIDE CANTEN SAMPLE 1779	Stomd Material	Polymer Bound	CHR - Chrysotile	2	Removed	39	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMA	27524000	Site - Grounds	Site - Grounds	External	Site / Grounds	TENNIS COURT	NO ASBESTOS DETECTED ON TENNIS COURT	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)		-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMA01		Horticulture	Horticulture											-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMA02		Green House	Green House											-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMA03	27524010	Hort Shed	Hort Shed	External	Ground Floor	EXTERNAL WORK BENCH	WORK BENCH TOP COMPRESSED SHEET SAMPLE 1775	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMA07		Store	Store											-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMA08		Irrigation Shed	Irrigation Shed											-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMA09		Fuel Shed	Fuel Shed											-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMA11		Store (condemned)	Store (condemned)											-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMA12		Tractor Shed	Tractor Shed											-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMA13		Old Barn	Old Barn											-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMA14	27524018	Hay Store	Hay Store											-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMA15		Irrigation Shed	Irrigation Shed											-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMA17	27524016	Chemical Store	Chemical Store											-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	External	Ground Floor	RAMP WEST SIDE	SHADOW LINE SHEETING STORED BELOW RAMP WESTSIDE ADMIN BLOC SAMPLE 1756	Stored Material	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	External	Level 1	VERANDAH	COMPRESSED SHEET FLOORING ON VERANDAH OF ADMIN BLOCK SAMPLE 1754	Floor Finish/Covering	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	Internal	Level 1	ROOM 202	VINYL TILES IN NTH/EAST CORNER OF ROOM 202 SAMPLE 1762	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	Internal	Level 1	INTERNAL	SHEETING TO INTERNAL WALLS OF ADMIN BLOCK SAMPLE 1769	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	Internal	Ground Floor	TOILETS/SHOWERS	VINYL FLOOR SHEETING WITH FRIABLE BACKING	Floor Finish/Covering	Vinyl Sheeting (includes backing)	CHR - Chrysotile	3	Confirmed	62	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	Internal	Level 1	ROOM 202	VINYL TILE UNDERLAY IN ROOM 202 SAMPLE 1763	Floor Backing/Underlay	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	Internal	Ground Floor	TOILETS/SHOWERS	COMPRESSED SHEET WALLS AND PARTITIONS TO THE FEMALE TOILETS	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	Internal	Ground Floor	STAFFROOM	SHEETING TO WALLS OF STAFF ROOM/ADMIN BLOCK SAMPLE 1752	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	External	Ground Floor	BULKHEAD	SHEETING TO BULKHEADS ABOVE WINDOWS SAMPLE 1753	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	External	Roof Level 1	ROOF	CORRUGATED ROOF SHEETING SAMPLE 1765	Roof Sheeting	Cement Based	Mixed	2	Confirmed	43	-	Noted by R.Hawmer upon inspection on 21/01/2011, Physical condition reduced to 2; attention recommended.
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	External	Level 1	SOFFIT	SOUTHERN SOFFIT TO BUILDING ONE - A BLOCK.	Gable/Soffit/ascia	Cement Based		2	Presumed	43	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	External	Level 1	NORTHERN SIDE	FASCIA BOARD SHEETING NTH SIDE OF BUILDING SAMPLE 1766	Gable/Soffit/ascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)		-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	External	Ground Floor	SEWER PIPE & DT	ORG SURROUND ON SEWER PIPE AND DISCONNECTOR TRAP SAMPLE 1758	Drains/Pipes/F lues	Cement Based	Mixed	4	Confirmed	18	-	

TAFEs from BEMIR-TAFEs

Current as at 10-May-11

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BSMR Score	Attention Required	Comments
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	External	Ground Floor	SEWER PIPE	JOINTING COMPOUND IN SEWER PIPE COLLARS SAMPLE 1757	Drains/Pipes/F	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	External	Ground Floor	RAMP WEST SIDE	CORRUGATED SHEETING STORED BELOW RAMP WEST SIDE OF BLDG SAMPLE 1755	Storm Material	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	External	Ground Floor	BULKHEAD	BULKHEAD SHEETING ABOVE WINDOWS IN ADMIN BLOCK SAMPLE 1759	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	Internal	Level 1	MALE/FEMALE SHOWERS	TILUX SHEETING IN MALE & FEMALE SHOWERS SAMPLE 1764	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	Internal	Level 1	INTERNAL	VILLBOARD CEILING SHEETS IN ADMIN BLOCK SAMPLE 1761	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAAA	27524001	A Block	A Block	Internal	Ground Floor	FEMALE TOILETS	COMPRESSED SHEET TOILET PARTITIONS/FEMALE TOILETS	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMABB	27524013	B Block	B Block	Internal	Ground Floor	CLASSROOMS	SHEETING ON INTERNAL WALLS SIMILAR SAMPLE 1785	Wall	Cement Based		4	Presumed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMABB	27524013	B Block	B Block	External	Ground Floor	EAVES	SHEETING ON SOFFITS SAMPLE 1785	Gable/Soffit/ascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMABB	27524013	B Block	B Block	External	Ground Floor	EXTERNAL	SHEETING ON EXTERNAL WALLS SAMPLE 1784	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMACC	27524012	C Block	C Block	External	Roof Level 1	ROOF	CORRUGATED ROOF SHEETING SAMPLE 1781	Roof Sheeting	Cement Based	Mixed	2	Confirmed	43	-	Noted upon inspection 21/01/2011, sheeting deteriorated, fraying, needs attention.
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMACC	27524012	C Block	C Block	Internal	Ground Floor	CANTEEN	CEILING SHEETS ON INTERNAL WALLS OF CANTEEN SAMPLE 1782	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMACC	27524012	C Block	C Block	External	Ground Floor	CANTEEN EXTERNAL	SHEETING ON EXTERNAL WALLS SAMPLE 1780	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMACC	27524012	C Block	C Block	Internal	Ground Floor	CANTEEN	WALL SHEETING ON INTERNAL WALLS SAMPLE 1783	Wall	Cement Based	Mixed	4	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMADD		D Block	D Block												
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAEE	27524009	E Block	E Block	Internal	Ground Floor	WELDING BAY	SHEETING ON WELDING BAY SCREENS AND WELDING BAY WALLS	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAEE	27524009	E Block	E Block	Internal	Ground Floor	TOILETS	PIPE JOINT COMPOUND IN PIPE IN TOILETS	Drains/Pipes/F	Polymer Bound		4	Presumed	25	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAEE	27524009	E Block	E Block	Internal	Ground Floor	TOILETS OF WORKSHOP	FC SHEET TO TOILETS OF WORKSHOP SAMPLE 1789	Wall	Cement Based	Mixed	4	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAEE	27524009	E Block	E Block	External	Roof Level 1	ROOF	CORRUGATED AC ROOF SHEETING SAMPLE 1788	Roof Sheeting	Cement Based	CHR - Chrysotile	3	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAEE	27524009	E Block	E Block	External	Ground Floor	EXTERNAL	COMPOUND SHEET SURROUNDS AT BASE OF WASTE PIPE FROM TOILET	Drains/Pipes/F	Cement Based		4	Presumed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAEE	27524009	E Block	E Block	External	Ground Floor	EAVES	SOFFIT SHEETING TO EAVES IN WOODWORK BLDG SAMPLE 1792	Gable/Soffit/ascia	Cement Based	Mixed	4	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAEE	27524009	E Block	E Block	External	Ground Floor	GAS BOTTLE ENCLOSURE	SHEETING ON GAS BOTTLE ENCLOSURE SAMPLE 1787	Wall	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	MAREEBA TAFE CAMPUS - 186 TINAROO CREEK (WIC-27524)	XMAFF	27524007	F Block	F Block	Internal	Ground Floor	WOODWORK	FC SHEETING TO CEILING IN WOODWORK BUILDING SAMPLE 1781	Ceiling	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Tropical North Queensland		MOSSMAN TAFE CAMPUS (WIC-30397)	MOSSMAN TAFE CAMPUS (WIC-30397)	XDO	30397000	" Site - Grounds	" Site - Grounds											-	
Tropical North Queensland		TULLY CAMPUS TROPICAL NORTH INSTITUTE	TULLY CAMPUS TROPICAL NORTH INSTITUTE	51942000	51942000	" Site - Grounds	" Site - Grounds											-	
Tropical North Queensland		TULLY TAFE CAMPUS - 6 STILL STREET (WIC-36818)	TULLY TAFE CAMPUS - 6 STILL STREET (WIC-36818)	XTU	36818000	" Site - Grounds	" Site - Grounds											-	
Tropical North Queensland		WELPA TAFE CAMPUS (WIC-30409)	WELPA TAFE CAMPUS (WIC-30409)	XWE	30409000	" Site - Grounds	" Site - Grounds											-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWS	27865000	" Site - Grounds	" Site - Grounds											-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWS01		Storage Shed	Storage Shed											-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWS02		Storage Shed	Storage Shed											-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWS03		Greenhouse	Greenhouse											-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWS04		Greenhouse	Greenhouse											-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWS05		Greenhouse	Greenhouse											-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWS06		Nursery	Nursery											-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWS07		Shade House	Shade House											-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWSAA	27865006	A Block	A Block	Internal	Ground Floor	TOILETS MALE/FEMALE	TOILET CEILINGS - ADMIN BLOCK 1	Ceiling	Cement Based		4	Presumed	18	-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWSAA	27865006	A Block	A Block	Internal	Level 1	STAIRWELL	EAST END STAIRWELL - ADMIN BLOCK 1	Ceiling	Cement Based		4	Presumed	18	-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWSAA	27865006	A Block	A Block	Internal	Ground Floor	ROOM 1.01 DINING ROOM	CEILING CAFETERIA - ADMIN BLOCK 1	Ceiling	Sprayed Coating		4	Presumed	64	-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWSAA	27865006	A Block	A Block	Internal	Ground Floor	CORRIDOR/HALL	CEILING FOYER - MAIN ENTRY ADMIN BLOCK 1	Ceiling	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWSAA	27865006	A Block	A Block	External	Ground Floor	EXTERNAL	EXTERNAL WALLS OF THE BUILDING ARE AC SHEET - ADMIN BLOCK 1	Wall	Cement Based		4	Presumed	18	-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWSAA	27865006	A Block	A Block	Internal	Level 1	STAIRWELL	STAIRWELL CEILING - ADMIN BLOCK 1	Ceiling	Cement Based		4	Presumed	18	-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWSBB	27865002	B Block	B Block	External	Ground Floor	WALKWAYS	CEILINGS OF COVERED WALKWAYS BETWEEN BLOCKS A, B, C, D, & E	Ceiling	Cement Based	Mixed	4	Confirmed	18	-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWSBB	27865002	B Block	B Block	Internal	Level 1	STAIRWELL	WALL PANEL SHEETING - UNDER WINDOW - MID FLIGHT OF STAIRWELL	Wall	Cement Based	CHR AMO - Chrysotile Amosite	4	Confirmed	18	-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWSBB	27865002	B Block	B Block	Internal	Level 1	STAIRWELL	CEILING OF STAIRWELLS 2 STAIRWELLS ONE EACH END OF THE BUILDING	Ceiling	Cement Based		4	Presumed	18	-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWSBB	27865002	B Block	B Block	Internal	Level 1	CORRIDOR/HALL	CEILING OF CORRIDOR/HALL	Ceiling	Cement Based		4	Presumed	18	-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWSBB	27865002	B Block	B Block	Internal	Ground Floor	ROOM 1.01 WORKSHOP	CEILING OF AUTOMOTIVE WORKSHOP	Ceiling	Sprayed Coating		4	Presumed	64	-	
Wike Bay		BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	BUNDABERG TAFE CAMPUS - 118 WALKER STREET (27865)	WWSBB	27865002	B Block	B Block	Internal	Level 1	AUDITORIUM STAIRS	WALLS OF THE AUDITORIUM STAIRWELL	Wall	Cement Based		4	Presumed	18	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description of ACM	Item of ACM	Form of ACM	Analysis Result	Physical Status	Status of ACM	BEMIR Score	Attention Required	Comments
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSCC	27865003	C Block	C Block	Internal	Level 1	STAIRWELL	STAIRWELL CEILING	Ceiling	Cement Based		4	Presumed	18	-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSCC	27865003	C Block	C Block	External	Ground Floor	SUN HOODS	WINDOW HOODS ON ALL BUILDINGS (BLOCK A B C D & E)	Sun Hood	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSCC	27865003	C Block	C Block	Internal	Ground Floor	WORKSHOP	WORKSHOP CEILING IS SPRAYER ON ASBESTOS	Ceiling	Sprayed Coating		4	Presumed	64	-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSCC	27865003	C Block	C Block	Internal	Ground Floor	WORKSHOP	FURNACE GASKET AND FIREBOX LINING	Plant, Equipment & Machinery	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSCC	27865003	C Block	C Block	External	Ground Floor	FASCIA	FASCIA IDENTICAL ON BLOCKS A B C & D CONNECTING WALKWAYS	Gable/Soffit/Fascia	Cement Based		4	Presumed	18	-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSDD	27865004	D Block	D Block	Internal	Basement 1	MANUAL ARTS ROOM	WALLS ARE AC SHEET	Wall	Cement Based		4	Presumed	18	-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSDD	27865004	D Block	D Block	Internal	Ground Floor	WORKSHOP	WELDING BOOTHS (BLACK) NO.16	Plant, Equipment & Machinery	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSDD	27865004	D Block	D Block	Internal	Ground Floor	WORKSHOP	WELDING BOOTHS (GREY) NO.8	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSDD	27865004	D Block	D Block	Internal	Level 1	MANUAL ARTS ROOM	PLUMBING BENCHES IN THE PLUMBING WORKSHOP	Furniture	Cement Based		4	Presumed	18	-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSDD	27865004	D Block	D Block	Internal	Level 1	STAIRWELL	STAIRWELL CEILING	Ceiling	Cement Based		4	Presumed	18	-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSEE	27865005	E Block	E Block	External	Ground Floor	EXTERNAL	ALL EXTERNAL WALLS ARE AC SHEETING	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSEE	27865005	E Block	E Block	Internal	Ground Floor	THEATRE FORECOURT	FLOOR TILES - DUCT COVER - SHEETING	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSFF		F Block	F Block											-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSGG	27865001	G Block	G Block	Internal	Ground Floor	PLANT ROOM	2 HEATER BANKS - NO ACCESS AVAILABLE, RE INSPECTION LATE 99 NO ASBESTOS MATERIAL FOUND	Heater Bank Insulation	Other (refer to description)		3	Not Present(Not Tested)	-	-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSGG	27865001	G Block	G Block	Internal	Ground Floor	PLANT ROOM	SHEETING TO ROOF & SIDES OF AIR COMPRESSOR/ GAS BOTTLE ENCLOSURE ON WEST END	Roof/Sheeting	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSGG	27865001	G Block	G Block	External	Ground Floor	SOFFITS	SOFFITS AROUND THE BUILDING NO AC SHEETING USED BUILT 1985	Gable/Soffit/Fascia	Other (refer to description)		4	Presumed	-	-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSII		I Block	I Block											-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSJJ		J Block	J Block											-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSKK		K Block	K Block											-	
Wide Bay		BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	BUNDABERG TAPE CAMPUS - 116 WALKER STREET (27865)	WWSLL		L Block	L Block											-	
Wide Bay		BUNDABERG TAPE CAMPUS - GOODWOOD ROAD (WIC-29851)	BUNDABERG TAPE CAMPUS - GOODWOOD ROAD (WIC-29851)		29851005	HAY SHED	HAY SHED	Internal	Site / Grounds	STORE SHED	SHED WAS ENTERED WITH NO SUSPECT ASBESTOS MATERIALS DETECTED	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Wide Bay		BUNDABERG TAPE CAMPUS - GOODWOOD ROAD (WIC-29851)	BUNDABERG TAPE CAMPUS - GOODWOOD ROAD (WIC-29851)		29851000	"" Site - Grounds	"" Site - Grounds											-	
Wide Bay		BUNDABERG TAPE CAMPUS - GOODWOOD ROAD (WIC-29851)	BUNDABERG TAPE CAMPUS - GOODWOOD ROAD (WIC-29851)	WGWO1	29851004	Square Shed	Square Shed	Internal	Site / Grounds	STORE SHED	SHED WAS ENTERED WITH NO SUSPECT ASBESTOS MATERIALS DETECTED	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Wide Bay		BUNDABERG TAPE CAMPUS - GOODWOOD ROAD (WIC-29851)	BUNDABERG TAPE CAMPUS - GOODWOOD ROAD (WIC-29851)	WGWO2	29851002	Shed	Shed	Internal	Ground Floor	PUMP STORE AREA	STORED MATERIAL IN PUMP STORAGE SHED. DOES NOT CONTAIN ASBESTOS	Stored Material	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		BUNDABERG TAPE CAMPUS - GOODWOOD ROAD (WIC-29851)	BUNDABERG TAPE CAMPUS - GOODWOOD ROAD (WIC-29851)	WGWO3	29851003	Fuel Store	Fuel Store	Internal	Ground Floor	IMPLEMENT SHED	COMPRESSED SHEETING TO VARIOUS BENCHES AROUND SHED. DOES NOT CONTAIN ASBESTOS	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		BUNDABERG TAPE CAMPUS - GOODWOOD ROAD (WIC-29851)	BUNDABERG TAPE CAMPUS - GOODWOOD ROAD (WIC-29851)	WGWO4	29851006	Pump Shed	Pump Shed	External	Various levels	PUMP SHED	PANEL TO ELECTRICAL SWITCHBOARD DOES NOT CONTAIN ASBESTOS	Insulation/Fill	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		BUNDABERG TAPE CAMPUS - GOODWOOD ROAD (WIC-29851)	BUNDABERG TAPE CAMPUS - GOODWOOD ROAD (WIC-29851)	WGWOA	29851001	A BLOCK	A BLOCK	Internal	Ground Floor	VARIOUS ROOMS	COMPRESSED SHEET TO VARIOUS BENCH TOPS AROUND BUILDING DOES NOT CONTAIN ASBESTOS	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		GAYNDAH TAPE CAMPUS - PINAPPLE STREET (WIC-29197)	GAYNDAH TAPE CAMPUS - PINAPPLE STREET (WIC-29197)	WGDA	29197001	A Block	A Block	External	Various levels	PARTITIONS/WALL	F.C. SHEETING TO PARTITIONS & WALLS OF TAPE CENTRE NO ASBESTOS DETECTED	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		GAYNDAH TAPE CAMPUS - PINAPPLE STREET (WIC-29197)	GAYNDAH TAPE CAMPUS - PINAPPLE STREET (WIC-29197)	WGDA	29197001	A Block	A Block	External	Various levels	SOFFITS/AWNING	A.C. SHEETING TO SOFFITS & AWNING ON EXTERNAL PERIMETER OF TAPE BUILDING	Ceiling	Cement Based		4	Presumed	18	-	
Wide Bay		GAYNDAH TAPE CAMPUS - PINAPPLE STREET (WIC-29197)	GAYNDAH TAPE CAMPUS - PINAPPLE STREET (WIC-29197)	WGDA	29197001	A Block	A Block	Internal	Ground Floor	CLASSROOM	FLOOR COVERINGS TO CLASSROOM GROUND FLOOR TAPE CENTRE NO ASBESTOS DETECTED	Floor Finish/Covering	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		GAYNDAH TAPE CAMPUS - PINAPPLE STREET (WIC-29197)	GAYNDAH TAPE CAMPUS - PINAPPLE STREET (WIC-29197)	WGDA	29197001	A Block	A Block	External	Various levels	FUEL STORE	F.C. SHEETING TO FASCIAS OF FUEL STORE N/E END OF TAPE NO ASBESTOS DETECTED	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)		29378003	C Block	C Block	External	Ground Floor	SOFFITS	EXTERNAL SOFFITS ARE ASBESTOS FREE	Gable/Soffit/Fascia	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Wide Bay		GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)		29378003	C Block	C Block	Internal	Ground Floor	INTERNAL	INTERNAL WALL SHEETING - SIM SAMPLE WB2280	Wall	Cement Based		4	Presumed	18	-	
Wide Bay		GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)		29378003	C Block	C Block	Internal	Level 1	FIRE BOOSTER PUMP	CLUTCH ON ANCILLARY MOTOR	Plant, Equipment & Machinery	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Wide Bay		GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)		29378006	Glasshouse	Glasshouse	External	Ground Floor	GLASSHOUSE	GLASSHOUSE	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Wide Bay		GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)		29378007	COVERED LINK	COVERED LINK	External	Ground Floor	COVERED WALKWAY	ALL COVERED LINKS ARE ASBESTOS FREE	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Wide Bay		GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)		29378008	GLASSHOUSE	GLASSHOUSE	External	Ground Floor	GLASSHOUSE	GLASSHOUSE	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Wide Bay		GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)		29378011	GAZEBO	GAZEBO	External	Ground Floor	SHADE STRUCTURE	GAZEBO	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Wide Bay		GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)		29378011	GAZEBO	GAZEBO	External	Ground Floor	SHADE STRUCTURE	GAZEBO	Baffles/Lining	Other (refer to description)		3	Presumed	-	-	
Wide Bay		GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)		29378013	J Block	J Block	External	Ground Floor	SOFFITS	EXTERNAL SOFFIT SHEETING IS ASBESTOS FREE	Gable/Soffit/Fascia	Cement Based		4	Not Present(Not Tested)	18	-	
Wide Bay		GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)		29378013	J Block	J Block	Internal	Ground Floor	SHELVING	FIBROUS SHELVING IS ASBESTOS FREE	Furniture	Cement Based		4	Not Present(Not Tested)	18	-	
Wide Bay		GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAPE CAMPUS - CARTWRIGHT ROAD (WIC-29378)		29378013	J Block	J Block	External	Ground Floor	EXTERNAL	EXTERNAL WALL SHEETING IS ASBESTOS FREE	Wall	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int. Ext.	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGY	29378000	-- Site - Grounds	-- Site - Grounds												
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYAA	29378001	A Block	A Block	Internal	Level 1	PIPE WORK	PIPE WORK IN AIR CONDITIONING ROOM IS ASBESTOS FREE	Drains/Pipes/Floors	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYAA	29378001	A Block	A Block	External	Level 1	SUN HOODS	FIBROUS SUN HOODS TO PERIMETER OF BUILDING ARE ASBESTOS FREE	Sun Hood	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-		
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYAA	29378001	A Block	A Block	Internal	Ground Floor	CANTEEN	FIBROUS SHEETING TO BULK HEAD OVER SERVERY IS ASBESTOS FREE	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYAA	29378001	A Block	A Block	Internal	Ground Floor	INTERNAL	INTERNAL CEILING SHEETING IS ASBESTOS FREE	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-		
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYAA	29378001	A Block	A Block	Internal	Ground Floor	INTERNAL	SHEET VINYL FLOOR COVERINGS THROUGHOUT	Floor Finish/Covering	Vinyl Tiles	No asbestos detected (NAD)	4	Not Present(Not Tested)	18	-	
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYAA	29378001	A Block	A Block	Internal	Ground Floor	MALE & FEMALE TOILETS	COMPRESSED FIBROUS SHEET BENEATH LOCKERS IS ASBESTOS FREE	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYAA	29378001	A Block	A Block	Internal	Ground Floor	TOILETS	FIBROUS PARTITIONS TO TOILETS MALE AND FEMALE ARE ASBESTOS FREE	Wall	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-		
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYAA	29378001	A Block	A Block	Internal	Level 1	ROOM 2.04	FIBROUS WALL SHEETING TO END WALL IS ASBESTOS FREE	Wall	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-		
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYAA	29378001	A Block	A Block	Internal	Level 1	ROOM 2.05	FIBROUS WALL SHEETING TO END WALL - SIM SAMPLE WB2279	Wall	Cement Based		4	Presumed	18	-	
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYAA	29378001	A Block	A Block	External	Level 1	SOFFIT	EXTERNAL FIBROUS SOFFIT SHEETING IS ASBESTOS FREE	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-		
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYAA	29378001	A Block	A Block	Internal	Ground Floor	ROOM 1.27	COMPRESSED FIBROUS SHEET FOOD STORAGE SHELVING IS ASBESTOS FREE	Furniture	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYBB	29378002	B Block	B Block	External	Ground Floor	EXTERNAL	EXTERNAL FIBROUS WALL SHEETING IS ASBESTOS FREE	Wall	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-		
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYBB	29378002	B Block	B Block	Internal	Ground Floor	INTERNAL	INTERNAL FLOOR SHEETING IS ASBESTOS FREE	Floor Finish/Covering	Vinyl Sheeting (includes backing)		4	Not Present(Not Tested)	62	-	
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYBB	29378002	B Block	B Block	External	Ground Floor	SOFFIT	EXTERNAL FIBROUS SOFFIT SHEETING IS ASBESTOS FREE	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYBB	29378002	B Block	B Block	Internal	Ground Floor	INTERNAL	INTERNAL FIBROUS WALL SHEETING	Wall	Cement Based		4	Presumed	18	-	
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYFF	29378004	F Block	F Block	External	Ground Floor	EXTERNAL	EXTERNAL CLADDING TO BLOCK F IS ASBESTOS FREE	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYFF	29378004	F Block	F Block	External	Ground Floor	EXTERNAL	EXTERNAL WALL SHEETING - SIM SAMPLE WB2282	Wall	Cement Based		4	Presumed	18	-	
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYFF	29378004	F Block	F Block	External	Ground Floor	SOFFIT	EXTERNAL SOFFIT SHEETING IS ASBESTOS FREE	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-		
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYFF	29378004	F Block	F Block	Internal	Ground Floor	INTERNAL	INTERNAL CEILING SHEETING SIM SAMPLE WB2282	Ceiling	Cement Based		4	Presumed	18	-	
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYFF	29378004	F Block	F Block	Internal	Ground Floor	INTERNAL	INTERNAL WALL SHEETING - SIM SAMPLE WB2282	Wall	Cement Based		4	Presumed	18	-	
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYFF	29378004	F Block	F Block	Internal	Ground Floor	WELDING BAYS	COMPRESSED FIBROUS SHEETING TO WELDING BAYS IS ASBESTOS FREE	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYGG	29378005	G Block	G Block	External	Ground Floor	EXTERNAL	FIBROUS WALL SHEETING SIM SAMPLE WB2281	Wall	Cement Based		4	Presumed	18	-	
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYGG	29378005	G Block	G Block	External	Ground Floor	SOFFIT	FIBROUS SOFFIT SHEETING IS ASBESTOS FREE	Gable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-		
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYKK	29378010	K Block	K Block	External	Ground Floor	STORE	STORE	Baffles/Lining	Other (refer to description)		3	Presumed	-		
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYLL	29378009	L Block	L Block	External	Ground Floor	WORKSHOP	WORKSHOP	Baffles/Lining	Other (refer to description)		3	Presumed	-		
Wide Bay		GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	GYMPIE TAFE CAMPUS - CARTWRIGHT ROAD (WIC-29378)	WGYMM		M Block	M Block												
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	20930001		COVERED LINKS	COVERED LINKS	External	Ground Floor	COVERED LINKS	COVERED LINKS ARE ASBESTOS FREE	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-		
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	20930018		S Block	S Block	Internal	Ground Floor	RURAL STUDIES	RURAL STUDIES SHED IS ASBESTOS FREE	Wall	Other (refer to description)		4	Not Present(Not Tested)	-		
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	20930026		BORE PUMP SHED	BORE PUMP SHED	Internal	Ground Floor	STORAGE	STORAGE SHED IS ASBESTOS FREE	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-		
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	20930028		SHELTER SHED	SHELTER SHED	External	Ground Floor	SHELTER	SHELTER SHED IS ASBESTOS FREE	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-		
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	20930029		STORAGE SHED	STORAGE SHED	Internal	Ground Floor	SHED	STORAGE SHED IS ASBESTOS FREE	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-		
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	WHB	20930000	-- Site - Grounds	-- Site - Grounds												
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	WHB01	20930034	Shadehouse	Shadehouse	External	Ground Floor	SHADE STRUCTURE	SHADE STRUCTURE WAS ASBESTOS FREE AT TIME OF AUDIT	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-		
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	WHB02	20930035	Shadehouse	Shadehouse	External	Ground Floor	SHADE STRUCTURE	SHADE STRUCTURE IS ASBESTOS FREE	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-		
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	WHB03	20930023	Store	Store	Internal	Ground Floor	POISON STORE	POISON STORE IS ASBESTOS FREE	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-		
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	WHB04	20930024	Store	Store	Internal	Ground Floor	CAMP GEAR STORE	CAMP GEAR STORAGE SHED IS ASBESTOS FREE	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-		
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	WHB05	20930022	Store	Store	Internal	Ground Floor	TIMBER RACKS	Sheeting	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-		
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	WHB06	20930025	Pump Shed	Pump Shed	Internal	Ground Floor	PUMP SHED	PUMP SHED IS ASBESTOS FREE	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-		

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Est	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHB07	20930017	Transformer	Transformer	Inter nal	Ground Floor	MAIN SWITCHBOARD ROOM	MAIN SWITCH ROOM WAS ASBESTOS FREE AT TIME OF AUDIT	Wall	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHB08	20930010	Fuel Store	Fuel Store	Inter nal	Ground Floor	STORAGE	FLAMMABLE STORE WAS ASBESTOS FREE AT TIME OF AUDIT	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHB10	20930027	Sport Store	Sport Store	Inter nal	Ground Floor	STORAGE SHED	FIBROUS WINDOW PANEL ON STORAGE SHED IS ASBESTOS FREE - REFER SAMPLE 1662	Wall	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHB11	20930030	Kiln Shed	Kiln Shed	Inter nal	Ground Floor	INTERNAL	FIBROUS SHEETING TO CEILING AND WALLS OF PROJECT SHED ARE ASBESTOS FREE	Wall	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBAA	20930002	A Block	A Block	Inter nal	Ground Floor	INTERNAL	ALL FIBROUS SHEETING THROUGHOUT IS ASBESTOS FREE	Wall	Other (refer to description)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBBB	20930003	B Block	B Block	Inter nal	Ground Floor	INTERNAL	BLOCK B WAS ASBESTOS FREE AT TIME OF AUDIT	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBCC	20930004	C Block	C Block	Inter nal	Ground Floor	THROUGHOUT	BLOCK C WAS ASBESTOS FREE AT TIME OF AUDIT FREE	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBDD	20930005	D Block	D Block	Inter nal	Ground Floor	Training Restaurant	Sheeting - Western Side of Room under Carpet	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBDD	20930005	D Block	D Block	Inter nal	Ground Floor	Canteen	Sheeting - Dining Room - Northern Side	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBDD	20930005	D Block	D Block	Inter nal	Ground Floor	Canteen	Sheeting - Kitchen - Western Side	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBDD	20930005	D Block	D Block	Inter nal	Ground Floor	Canteen	Sheeting - Scullery - Southern Doorway to Hallway	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBDD	20930005	D Block	D Block	Inter nal	Ground Floor	Canteen	Sheeting - Servary - Sheet Join to Centre of Room	Floor Finish/Covering	Vinyl Sheeting (includes backing)	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBDD	20930005	D Block	D Block	Inter nal	Ground Floor	DUPLICATE ENTRY							-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBDD	20930005	D Block	D Block	Inter nal	Ground Floor	INTERNAL	ALL FIBROUS SHEETING THROUGHOUT IS ASBESTOS FREE	Wall	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBEE	20930006	E Block	E Block	Inter nal	Ground Floor	THROUGHOUT	BLOCK E IS ASBESTOS FREE	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBFF	20930007	F Block	F Block	Inter nal	Ground Floor	THROUGHOUT	BLOCK F IS ASBESTOS FREE	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBGG	20930008	G Block	G Block	Inter nal	Ground Floor	THROUGHOUT	BLOCK G WAS ASBESTOS FREE AT TIME OF AUDIT	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBHH	20930009	H Block	H Block	Inter nal	Ground Floor	THROUGHOUT	BLOCK H WAS ASBESTOS FREE AT TIME OF AUDIT	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBJJ	20930011	J Block	J Block	Inter nal	Ground Floor	TOILETS	FIBROUS WALL AND CEILING SHEETING IS ASBESTOS FREE	Wall	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBKK	20930012	K Block	K Block	Inter nal	Ground Floor	THROUGHOUT	BLOCK K IS ASBESTOS FREE	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBLL	20930013	L Block	L Block	Inter nal	Ground Floor	THROUGHOUT	BLOCK L WAS ASBESTOS FREE AT TIME OF AUDIT	Wall	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBMM	20930014	M Block	M Block	Inter nal	Ground Floor	THROUGHOUT	BLOCK M WAS ASBESTOS FREE AT TIME OF AUDIT FREE	Wall	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBNN	20930015	N Block	N Block	Exter nal	Ground Floor	EXTERNAL	ALL EXTERNAL FIBROUS SHEETING TO BLOCK N IS ASBESTOS FREE	Wall	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBNN	20930015	N Block	N Block	Inter nal	Ground Floor	INTERNAL	ALL INTERNAL FIBROUS SHEETING TO BLOCK N IS ASBESTOS FREE	Wall	Cement Based		4	Not Present(Not Tested)	18	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBNN	20930015	N Block	N Block	Inter nal	Ground Floor	STORED MATERIAL	STORED FIBROUS SHEETING AT REAR OF N BLOCK IS ASBESTOS FREE	Stored Material	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBPP	20930016	P Block	P Block	Exter nal	Ground Floor	EXTERNAL	EXTERNAL FIBROUS CEILING SHEETING IS ASBESTOS FREE	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBPP	20930016	P Block	P Block	Inter nal	Ground Floor	INTERNAL	ALL FIBROUS CEILING SHEETING THROUGHOUT IS ASBESTOS FREE	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBPP	20930016	P Block	P Block	Inter nal	Ground Floor	INTERNAL	INTERNAL FIBROUS SHEETING IS ASBESTOS FREE	Wall	Cement Based		4	Not Present(Not Tested)	18	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBPP	20930016	P Block	P Block	Inter nal	Ground Floor	WELDING BAY	FIBROUS PED BOARD TO WELDING BAYS IS ASBESTOS FREE	Wall	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBRR	20930019	R Block	R Block	Inter nal	Ground Floor	INTERNAL	Sheeting	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBRR	20930019	R Block	R Block	Exter nal	Ground Floor	EXTERNAL	Sheeting	Wall	Cement Based	No asbestos detected (NAD)	4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBRR	20930019	R Block	R Block	Exter nal	Ground Floor	SOFFIT	EXTERNAL FIBROUS SOFFIT SHEETING IS ASBESTOS FREE	Cable/Soffit/Fascia	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBRR	20930019	R Block	R Block	Inter nal	Ground Floor	INTERNAL	INTERIOR FIBROUS CEILING SHEETING IS ASBESTOS FREE	Ceiling	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBS1	20930020	Facilities	Facilities	Inter nal	Ground Floor	OFFICES	FACILITIES OFFICE WAS ASBESTOS FREE AT TIME OF AUDIT	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBS2	20930031	Workshop	Workshop	Inter nal	Ground Floor	STORAGE SHED	FIBROUS WALL SHEETING TO BOTH ENDS OF SHED	Wall	Other (refer to description)	No asbestos detected (NAD)	3	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBS3	20930036	Workshop	Workshop	Inter nal	Ground Floor	STORAGE SHED	STORAGE SHED (36) WAS ASBESTOS FREE AT TIME OF AUDIT	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)	-	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBS4	20930021	Marine Studies	Marine Studies	Inter nal	Ground Floor	CLASSROOMS	FIBROUS SHEETING THROUGHOUT ALL OF BUILDING IS ASBESTOS FREE	Wall	Cement Based		4	Not Present(Not Tested)	18	-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWREEN ROAD (WIC-20930)	WHBS5		Store	Store										-	-	

Region	District	Facility Name	Site Name	Agency Ref No	Other Ref No	Improvement	Improvement Other Name	Int Ext	Floor Level	Specific Location	Description Of ACM	Item of ACM	Form of ACM	Analysis Result	Physical State	Status of ACM	BEMIR Score	Attention Required	Comments
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	WHBUU	20930041	U Block	U Block											-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	WHBVV	20930038	V Block	V Block	Internal	Ground Floor	THROUGHOUT	BLOCK V IS ASBESTOS FREE	Baffles/Lining	Other (refer to description)		4	Not Present(Not Tested)		-	
Wide Bay		HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	HERVEY BAY TAFE CAMPUS - URRAWEEN ROAD (WIC-20930)	WHBWW		W Block	W Block											-	
Wide Bay		MARYBOROUGH CoTAFE	MARYBOROUGH CoTAFE	23982000	23982000	** Site - Grounds	** Site - Grounds	External	Site / Grounds	EVACUATION SITE	LOOSE DEBRIS - NORTH WESTERN ELEVATION	Debris	Cement Based		2	Removed	58	-	CLEAN AREA
Wide Bay		MARYBOROUGH CoTAFE	MARYBOROUGH CoTAFE	23982000	23982000	** Site - Grounds	** Site - Grounds	External	Site / Grounds	Garden Seat	Garden Seat beside Covered Links, East Side Block T	Furniture	Cement Based		4	Presumed	18	-	
Wide Bay		MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	30377000	30377000	** Site - Grounds	** Site - Grounds											-	
Wide Bay		MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	WMB01		Greenhouse	Greenhouse											-	
Wide Bay		MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	WMB02		Greenhouse	Greenhouse											-	
Wide Bay		MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	WMB03		Greenhouse	Greenhouse											-	
Wide Bay		MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	WMB04		Greenhouse	Greenhouse											-	
Wide Bay		MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	WMB05		Greenhouse	Greenhouse											-	
Wide Bay		MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	WMB08		Chemical Store	Chemical Store											-	
Wide Bay		MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	WMB09		Pump/ Fire Shed	Pump/ Fire Shed	External	Ground Floor	FIRE BOOSTER PUMP ENCLOSURE	CLUTCH PUMP = BOOSTER PUMP	Plant, Equipment & Machinery	Cement Based	CHR - Chrysotile	4	Confirmed	18	-	
Wide Bay		MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	WMB10		Fuel Store	Fuel Store											-	
Wide Bay		MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	WMBAA	30377001	A Block	A Block											-	
Wide Bay		MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	WMBB9	30377002	B Block	B Block											-	
Wide Bay		MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	WMBCC	30377003	C Block	C Block											-	
Wide Bay		MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	WMBDD	30377004	D Block	D Block											-	
Wide Bay		MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	WMBEE	30377005	E Block	E Block											-	
Wide Bay		MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	WMBFF	30377008	F Block	F Block											-	
Wide Bay		MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	MARYBOROUGH TAFE CAMPUS - NAGEL ST (WIC-30377)	WMBHH	30377026	H Block	H Block											-	

Warning Notice:

Do not rely solely on the completeness of this Asbestos Register as all asbestos containing material may not be identified and listed, particularly in inaccessible locations and other areas not readily accessed e.g. wall cavities and ceiling spaces. If there is any doubt, presume the material contains asbestos and take appropriate precautions prior to undertaking work. Please read the information contained in the Legends at the end of the Asbestos Register.

LEGENDS**BEMIR Score**

- 1 - 25:** Can be managed in-situ. Negligible hazard potential. Safe work procedures required if disturbed.
- 26 - 50:** Can be managed in-situ. Low hazard potential. Seek advice from competent person if disturbed.
- 51 - 75:** May need attention. Moderate hazard potential. Seek advice from competent person if disturbed.
- 76 - 100:** Needs attention. Hazardous. Special precautions are required if disturbed.

Physical state of ACM

- 5:** intact and stable, good condition
- 4:** intact and stable, only minor wear
- 3:** intact and stable, slight damage
- 2:** reduced stability, degrading
- 1:** unstable, severely deteriorated or major damage

The BEMIR score provides a guide to the safe management of the ACM. It is an assessment of risk that takes into consideration the form of the ACM, the condition of the ACM, and the likelihood of disturbance of the ACM. The risk assessment is conducted on the date of the asbestos survey/inspection noted in the Asbestos Register

Form of ACM

AA – Whole Building (asbestos free)

AD – Adhesive

CB – Cement Based

FF – Fibrous Felt

IB – Insulation Board

LA – Lagging

LD – Low Density Board

LF – Loose Fill

MF – Mastic/Filler

MI – Millboard

PB – Polymer Bound

SC – Sprayed Coating

VS – Vinyl Sheeting (backing)

VT – Vinyl Tiles

WT – Woven Textile

Type*

Bonded

Bonded

Friable

Friable

Friable

Friable

Friable

Bonded

Friable

Bonded

Friable

Friable

Bonded

Friable

*Bonded forms of ACM in a deteriorated condition may become friable

Test Results

NAD – no asbestos detected

CHR – chrysotile

AMO – amosite

CHR AMO – chrysotile amosite

CHR CRO – chrysotile crocidolite

AMO CRO – amosite crocidolite

CHR AMO CRO – chrysotile amosite crocidolite

Mixed – Contains more than one asbestos type**

** Test required to identify specific asbestos types